

QUESTIONS AND ANSWERS

RFP #2018-003

NEW HAMPSHIRE PUBLIC UTILITIES COMMISSION

REQUEST FOR PROPOSALS

LMI Community Solar Grants

	<b>Questions</b>	<b>Answers</b>
4.	Is it possible to indicate in our response that a structural review is in progress, results will be furnished upon request and that [the building owner] is prepared to handle any necessary upgrades? It is highly unlikely that we will be able to have a structural review completed by the April 13 <sup>th</sup> deadline.	Technical Project Proposal item #8 requires that a structural analysis be completed for roof-mounted PV systems. If the analysis is currently under contract and in-process, but will not be completed prior to RFP response submission, then please confirm that status in the proposal and provide a timeline for completion of the analysis, along with an estimate of potential impacts to the project if structural improvements are necessary and clarification of the party responsible for bearing any associated upgrade costs.