

RPS Emission Verification Summary
RENEWABLE PORTFOLIO STANDARDS

1st 2012 Quarter Summary				
Todays Date 1-May-12				
Source Name	Emission Report Date (electronic)	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu
PT Tamworth	18-Apr-12	0.067	16-Jun-11	0.003
PT Bethlehem	4-Apr-12	0.073	28-Jun-11	0.002
PSNH SR5	30-Apr-12	0.064	1-Jun-11	0.0029
Indeck Energy	12-Apr-12	0.069	30-Jun-11	0.01
Springfield Power	25-Apr-12	0.062	6/17/2011	0.034