




The State of New Hampshire  
DEPARTMENT OF ENVIRONMENTAL SERVICES

Thomas S. Burack, Commissioner  
January 26, 2010

DE 09-008  
DE 08-024  
DE 09-104  
DE 08-051  
DE 08-044



Debra A. Howland, Executive Director and Secretary  
New Hampshire Public Utilities Commission  
21 South Fruit Street, Suite 10  
Concord, NH 03301-2429

**Re: Quarterly Emissions Verification Summary for Certified and Conditionally Certified Renewable Energy Sources**

Dear Ms. Howland:

Based on the attached summary, the New Hampshire Department of Environmental Services (DES) recommends certification of the following wood-fired power plants as renewable energy sources, because the facilities continue to meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

**Pinetree Power, Inc.**  
1241 Whitefield Rd  
Bethlehem, NH 03574

**Pinetree Power-Tamworth, Inc.**  
469 Plains Rd  
Tamworth, NH 03886

**Public Service Company of New Hampshire (PSNH) Schiller Station # 5**  
400 Gosling Rd  
Portsmouth, NH 03801

**Springfield Power, LLC**  
54 Fisher Corner Road  
Springfield, NH 03284

DES recommends continued conditional certification of the following wood-fired power plant as a renewable energy source, because DES anticipates that the facility will eventually meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for TSP and NOx, respectively:

**Indeck**  
151 Smith River Road  
Alexandria, NH 03222

If you have any questions regarding DES's recommendations, please contact me at [joseph.fontaine@des.nh.gov](mailto:joseph.fontaine@des.nh.gov) or (603) 271-6794.

Sincerely

Joseph T. Fontaine  
Trading Programs Manager  
Air Resources Division

cc: Maureen Reno, NH PUC