



**Public Service
of New Hampshire**

PSNH Energy Park
780 North Commercial Street, Manchester, NH 03101

Public Service Company of New Hampshire
P.O. Box 330
Manchester, NH 03105-0330
(603) 669-4000
www.psnh.com

The Northeast Utilities System

June 24, 2011

Debra A. Howland
Executive Director and Secretary
State of New Hampshire
Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429



Re: Interim Change in the Default Energy Service Rate Docket No. DE 10-257
Transmission Cost Adjustment Mechanism Docket No. DE 11-133

Dear Ms. Howland:

After the Default Energy Service Rate hearing closed in this proceeding, Mr. Frederick B. White believes he provided an answer to some questions from Chairman Getz that needs to be clarified. Mr. White stated that the current inventory of residual fuel oil on hand would allow Newington Station to run for six and one half weeks serving peak loads (16 hours per weekday). If Newington is called on to run at full load around the clock, as it has done in the past, the inventory on hand would be sufficient for a run of approximately 21 days.

Enclosed please find seven copies of the response to a record request concerning actual sales growth and forecasted sales growth which was reserved as Exhibit 4 in the Transmission Cost Adjustment Mechanism hearing.

Thank you for the opportunity to clarify the record.

Very truly yours,

Gerald M. Eaton
Senior Counsel

Enclosures
cc: Service List