

**AQUARION WATER COMPANY OF NEW HAMPSHIRE
WATER INFRASTRUCTURE AND CONSERVATION ADJUSTMENT**

CONTACT: Carl McMorran, Operations Manager
cmcmorran@aquarionwater.com
603-926-3319 ext 116

Contents:

Project Summary Estimated capital expenses by major category
All projected figures for 2014-2016 are estimates.

Hydrants	Aquarion has historically replaced 7 hydrants per year, on average.
Services	Aquarion has historically replaced 7 services per year, on average.
Main Replacements	Main replacements are prioritized based on GIS information. As of this date, the distribution system is separated into 1,523 pipe segments. Each segment is rated on each of the categories described below. Most ratings are based on a scale of 0 (low) to 3 (high), except for Scheduled Work Coordination and Staff Priority. The differences are explained below. The ratings for each category are summed to produce an overall rating for each pipe segment as shown in CM-2. The highest rated pipe segments are scheduled for replacement.
Main Break History	3 - Multiple main breaks in the past 3 years
Ratings	2 - Multiple main breaks 1 - One main break 0 - No history of main breaks
Bleeder (Non-revenue water)	3 - Main requires a bleeder to prevent freezing 0 - Main does not require a bleeder to prevent freezing
Pipe Age / Useful Life	3 - Installed in 1914 or sooner
Ratings	2 - Installed between 1915 and 1926 1 - Installed between 1927 and 1940 0 - Installed after 1940
Material Integrity	3 - Cast iron (CI), unlined 3 - Galvanized Steel (GS) 3 - Universal Pipe (UP) 3 - Lead joint (LJ) 2 - Cast iron, cement-lined (CICL) 1 - Asbestos-cement (AC) 0 - Copper (CU) 0 - Ductile iron (DI) 0 - High density polyethylene (HDPE) 0 - Plastic wrapped ductile iron (PWDI) 0 - Poly-vinyl-chloride (PVC) 0 - Unknown (UNK)
Critical System	3 - Primary transmission line w/ no redundancy
Component Ratings	2 - Primary transmission line w/ redundancy 1 - Secondary transmission line 0 - Regular distribution main
Water Quality Issues	3 - Chronic discoloration or taste / odor that requires bleeding or frequent flushing 2 - Frequent discoloration or taste / odor that requires flushing 1 - Occasional discoloration or taste / odor that requires little or no flushing 0 - No history of water quality issues
Hydraulic Capacity	3 - Hydrants do not provide satisfactory fire flow rates 0 - Hydrants provide satisfactory fire flow rates
Scheduled Work	3 - Paving or excavation projects by others scheduled in next two years
Coordination	2 - Paving or excavation projects by others scheduled in next three or four years 1 - Paving or excavation projects by others scheduled in more than four years 0 - No other scheduled projects -1 - Street was paved five years ago -2 - Street was paved four years ago -3 - Street was paved three years ago -4 - Street was paved two years ago -5 - Street was paved one year ago
Staff Concerns / Other Factors	The point system shown above is used to establish an objective priority for main replacements. Staff concerns and other subjective factors are used to determine which projects are implemented immediately. These factors include the professional judgement of Company management and engineering, the operating and maintenance concerns of staff, scheduling constraints (for projects that require a longer lead time for design, permitting, etc.) and capital budget constraints. See the comment field in CM-2 for explanations pertaining to individual projects.
Main Replacement Project Management	Some main replacement projects are split into design and construction phases. Due to the amount of time required for surveys, design, permitting and other design phase factors, these activities are typically scheduled for the year prior to construction. Attempts to squeeze design and construction into a single calendar year have caused scheduling and budgeting problems. The design phase typically cannot be completed early enough in the year to allow for a sufficient construction period with respect to cold weather, road opening bans and year end accounting constraints.
Control Valves	Includes pressure reducing valves and other control valves; none are currently scheduled for replacement, but a breakdown or failure could occur that would require a replacement.
Valves	Aquarion has historically replaced 4 valves per year, on average.
Production Meters	Replacement / capitalized repairs of production meters is performed on an as needed basis when routine calibration show that the meters are not functioning accurately. Sometimes these replacements can be scheduled in advance when included as part of a pumping station upgrade.

**Aquarion Water Company of New Hampshire
Water Conservation and Infrastructure Adjustment Project Summary**

	Estimated Oct 1, 2013 thru Sep 30, 2014	Estimated Oct 1, 2014 thru Sep 30, 2015	Estimated Oct 1, 2015 thru Sep 30, 2016	Project Totals
MAIN REPLACEMENTS				
Well 9 Transmission Main	\$ 67,000	\$ -	\$ -	\$ 67,000
Ocean Boulevard - Dumas Ave to Winnacunnet Road	\$ 663,968	\$ -	\$ -	\$ 663,968
Great Boars Head - Cliff Circle to Ocean Blvd	\$ 207,000	\$ -	\$ -	\$ 207,000
Ross Avenue	\$ 21,000	\$ 246,000	\$ -	\$ 267,000
Gentian / Green / Meadow Pond	\$ 35,000	\$ 412,000	\$ -	\$ 447,000
Ocean Blvd - Boars Head Terrace to Highland Avenue	\$ -	\$ 164,000	\$ 786,000	\$ 950,000
CONTROL VALVES	\$ -	\$ -	\$ -	\$ -
PRODUCTION METERS	\$ 1,600	\$ 2,000	\$ 2,000	\$ 5,600
HYDRANTS	\$ 24,000	\$ 24,000	\$ 24,000	\$ 72,000
SERVICE LINES	\$ 32,000	\$ 32,000	\$ 32,000	\$ 96,000
VALVES	\$ 17,000	\$ 17,000	\$ 17,000	\$ 51,000
Hydrant / Service Line / Valve Threshold	\$ (50,000)	\$ (50,000)	\$ (50,000)	\$ (150,000)
Hydrant / Service Line / Valve Net	\$ 23,000	\$ 23,000	\$ 23,000	\$ 69,000
ANNUAL TOTALS	\$ 1,018,568	\$ 847,000	\$ 811,000	\$ 2,676,568

Aquarion Water Company of New Hampshire
WICA Hydrant Replacements

Account 335

PROPOSED PROJECTS					
	Hydrant Replacements	Town	Number	Average Annual Cost	Completion Date
	Oct 1, 2013 - Sep 30, 2014	To be determined	7	\$ 24,000	Sep 30, 2014
	Oct 1, 2014 - Sep 30, 2015	To be determined	7	\$ 24,000	Sep 30, 2015
	Oct 1, 2015 - Sep 30, 2016	To be determined	7	\$ 24,000	Sep 30, 2016
		TOTAL	21	\$ 72,000	

Comments

Hydrant replacements are not scheduled more than a year in advance because hydrants are not replaced unless identified as malfunctioning during hydrant maintenance activities, at which time they are replaced with a week.

Aquarion Water Company of New Hampshire
WICA Service Line Replacements

Account 333

PROPOSED PROJECTS							
	Service Line Replacements	Town	Number			Average Annual Cost	Completion Date
	Oct 1, 2013 - Sep 30, 2014	To be determined	7			\$ 32,000	Sep 30, 2014
	Oct 1, 2014 - Sep 30, 2015	To be determined	7			\$ 32,000	Sep 30, 2015
	Oct 1, 2015 - Sep 30, 2016	To be determined	7			\$ 32,000	Sep 30, 2016
		TOTAL	21			\$ 96,000	

Comments Service lines are not scheduled for replacement unless they are identified as leaking or defective. When identified as such, they are typically replaced in less than three months.

**Aquarion Water Company of New Hampshire
WICA Main Replacement Projects**

Account 331

Project	Town	Material	Length (feet)	Diameter (inches)	Total Cost/ Estimated Costs	Projected 2014	Projected 2015	Projected 2016	Comments	Prioritization Factors
Well 9 Transmission Main	Hampton	CI	40	6	\$ 67,000	\$ 67,000			From pump discharge to first yard valve	Old cast-iron main New main needed to hold new production meter and other new production equipment
Ocean Boulevard - Dumas Ave to Winnacunnet Road	Hampton	CI	2,100	12	\$ 663,968	\$ 663,968				Old cast-iron pipe History of breaks Critical transmission main Project coordination w/ NH DOT paving
Great Boars Head - Cliff Circle to Ocean Blvd	Hampton	CI	700	8	\$ 207,000	\$ 207,000				Old cast-iron pipe Extremely poor access (narrow alley) that will be very difficult if a main break occurred
Ross Avenue	Hampton	CI	200	6	\$ 267,000	\$ 21,000	\$ 246,000			Old cast-iron pipe Shallow main / non-revenue water Project coordination w/ Town paving
Gentian / Green / Meadow Pond	Hampton	AC	1,600	6	\$ 447,000	\$ 35,000	\$ 412,000			Old asbestos-cement pipe Shallow mains / non-revenue water reduction
Ocean Blvd - Boars Head Terrace to Highland Avenue	Hampton	CI	3,400	8	\$ 950,000		\$ 164,000	\$ 786,000		Old cast-iron pipe Critical transmission main Project coordination w/ NH DOT paving
TOTALS					\$ 2,601,968	\$ 993,968	\$ 822,000	\$ 786,000		

Aquarion Water Company of New Hampshire
WICA Control Valve Replacements

Project	Town	Projected 2014	Projected 2015	Projected 2016	Comments
None		\$ -	\$ -	\$ -	None are currently scheduled for replacement
	TOTALS	\$ -	\$ -	\$ -	

Aquarion Water Company of New Hampshire
WICA Valve Replacements

Account 331

A	B	C	D	E	F
PROPOSED PROJECTS					
	Valve Replacements	Town	Projected Number	Average Annual Cost	Completion Date
	Oct 1, 2013 - Sep 30, 2014	To be determined	3	\$ 17,000	Sep 30, 2014
	Oct 1, 2014 - Sep 30, 2015	To be determined	3	\$ 17,000	Sep 30, 2015
	Oct 1, 2015 - Sep 30, 2016	To be determined	3	\$ 17,000	Sep 30, 2016
		TOTAL	9	\$ 51,000	

Comments Valve replacements are not scheduled more than a year in advance because valves are not replaced unless identified as malfunctioning during valve exercising activities, at which time they are replaced with a month or two.

Aquarion Water Company of New Hampshire
WICA Production Meter Replacements

Project	Town	Projected 2014	Projected 2015	Projected 2016	Comments
Replace Well 9 Flow Meter	Hampton	\$ 1,600			
Future projects			\$ 2,000	\$ 2,000	Reactive capital replacements and repairs.
	TOTALS	\$ 1,600	\$ 2,000	\$ 2,000	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE PRIORITIZATION	TOTAL of 30	Comments
524	Ocean Blvd - Dumas Ave to Kings Hwy PRV	1907	CI	2,078	8	3	0	3	3	3	0	0	3	3	18		18	One of 2 transmission mains to the beach
531	Boar's Head Terr.	1910	CI	371	10	0	0	3	3	0	0	0	0	3	9	6	15	In a narrow, inaccessible alley; relocate before it breaks!
533	Boar's Head Terr.	1910	CI	366	2	0	0	3	3	0	0	0	0	3	9	6	15	In a narrow, inaccessible alley; relocate before it breaks!
547	Ross Ave.	1961	CI	209	6	0	3	0	3	0	0	0	2	3	11	3	14	Too shallow, must be bled in winter, contributes to hihg NRW
1397	Ross Ave.	1961	CI	499	6	0	3	0	3	0	0	0	2	3	11	3	14	Too shallow, must be bled in winter, contributes to hihg NRW
556	Ross Ave.	1954	AC	241	8	0	3	0	1	0	0	0	2	3	9	5	14	Too shallow, must be bled in winter, contributes to hihg NRW
721	Meadow Pond Rd: north of Greene St	1955	CI	272	2	2	3	0	3	0	0	0	0	3	11	2	13	Too shallow, must be bled in winter, contributes to hihg NRW
722	Meadow Pond Rd: Greene St - Greene St	1955	AC	99	6	0	3	0	1	0	0	0	0	3	7	6	13	Too shallow, must be bled in winter, contributes to hihg NRW
723	Meadow Pond Rd: south of Greene St	1955	AC	231	6	0	3	0	1	0	0	0	0	3	7	6	13	Too shallow, must be bled in winter, contributes to hihg NRW
1120	Ocean Blvd - Boars Head Terr to Dumas Ave	1910	CI	920	8	0	0	3	3	3	0	0	0	3	12		12	
1125	Ocean Blvd - Boars Head Terr to Highland Ave	1910	CI	3,392	8	0	0	3	3	3	0	0	0	3	12		12	
528	Sunsurf Ave.	1910	CI	363	2	2	0	3	3	0	0	0	0	3	11		11	
735	Exeter-Hampton Rd.	1962	CICL	1,395	12	0	3	0	2	3	0	0	3	0	11		11	
1057	Willow Ave: Chapel Rd - Ocean Blvd	1971	DI	1,002	8	0	0	0	0	3	0	2	3	3	11		11	
505	Kings Hwy: 11th St - Wilch Island Way	1915	UP	946	8	2	0	2	3	0	0	0	0	3	10		10	
515	Ocean Blvd: 8th St - 9th St	1920	CI	230	2	2	0	2	3	0	0	0	0	3	10		10	
636	Ocean Blvd - Bradford Ave to O St	1920	CI	221	6	2	0	2	3	0	0	0	0	3	10		10	
640	Ocean Blvd - P St to Q St	1920	CI	245	6	2	0	2	3	0	0	0	0	3	10		10	
765	Chapel Rd - Maple Rd PRV to Old Locke Rd	1965	CICL	2,731	8	2	0	0	2	3	0	0	0	3	10		10	
1058	Chapel Rd - Old Locke Rd to Willow Ave	1965	CICL	1,434	8	2	0	0	2	3	0	0	0	3	10		10	
1115	King's Hwy - Kings Hwy PRV to Red Coat Ln	1915	UP	388	8	2	0	2	3	0	0	0	0	3	10		10	
1173	Old Locke Rd	1935	AC	1,117	6	2	0	1	1	0	0	0	3	3	10		10	
1460	Brown Ave - Church St to Highland Ave	1958	CICL	135	8	2	0	0	2	3	0	0	0	3	10		10	
298	North Shore Rd: Acorn Rd - Ocean Blvd	1930	CI	371	8	2	0	1	3	0	0	0	0	3	9		9	
504	Eleventh St	1935	GS	327	2	2	0	1	3	0	0	0	0	3	9		9	
525	Dumas Ave.	1910	CI	839	8	0	0	3	3	0	0	0	0	3	9		9	
526	Cliff Ave (in part)	1910	CI	291	8	0	0	3	3	0	0	0	0	3	9		9	
527	Dumas Ave.	1910	CI	879	4	0	0	3	3	0	0	0	0	3	9		9	
530	Ocean Blvd.	1910	CI	829	8	0	0	3	3	0	0	0	0	3	9		9	
536	Ocean Blvd - Cole St to Fuller Acres	1910	CI	151	8	0	0	3	3	0	0	0	0	3	9		9	
548	Ocean Blvd.	1910	CI	665	8	0	0	3	3	0	0	0	0	3	9		9	
558	Ocean Blvd.	1910	CI	373	8	0	0	3	3	0	0	0	0	3	9		9	
560	Highland Ave.	1910	CI	50	8	0	0	3	3	0	0	0	0	3	9		9	
561	Ocean Blvd - north of Fuller Acres	1910	CI	1,052	8	0	0	3	3	0	0	0	0	3	9		9	
567	Church St - Brown Ave to Highland Ave	1955	CI	150	12	0	0	0	3	3	0	0	0	3	9		9	
577	Ocean Blvd.	1910	CI	173	8	0	0	3	3	0	0	0	0	3	9		9	
581	Ashworth Ave - Nudd Ave to Island Path	1910	CI	270	8	0	0	3	3	0	0	0	0	3	9		9	
582	Ashworth Ave - Nudd Ave to Island Path	1910	CI	116	8	0	0	3	3	0	0	0	0	3	9		9	
583	Island Path	1910	CI	305	6	0	0	3	3	0	0	0	0	3	9		9	
617	Joann Ln.	1959	CI	305	6	0	3	0	3	0	0	0	0	3	9		9	
637	Ocean Blvd.	1920	CI	59	6	1	0	2	3	0	0	0	0	3	9		9	
641	Ocean Blvd.	1920	CI	122	6	1	0	2	3	0	0	0	0	3	9		9	
646	Manchester St.	1959	AC	457	6	2	3	0	1	0	0	0	0	3	9		9	
689	Ocean Blvd.	1969	CICL	780	8	1	0	0	2	3	0	0	0	3	9		9	
767	Atlantic Ave - Ocean Blvd to Sea Rd	1958	CI	1,685	8	0	0	0	3	3	0	0	0	3	9		9	
1062	Appledore Ave: Boulters Cove - Boulters Cove	1970	CICL	1,246	8	2	0	0	2	0	0	0	2	3	9		9	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE PRIORITY	12 of 30	Comments
1119	Ocean Blvd - Dumas Ave to Winnacunnet Rd	1910	CI	2,053	8	0	0	3	3	0	0	0	0	3	9		9	
1124	Great Boar's Head Ave.	1910	CI	692	8	0	0	3	3	0	0	0	0	3	9		9	
1126	Ocean Blvd - Boars Head Terr to Anchor St	1910	CI	497	8	0	0	3	3	0	0	0	0	3	9		9	
1140	Highland Ave.	1910	CI	16	8	0	0	3	3	0	0	0	0	3	9		9	
1233	Highland Ave.	1953	LJ	39	16	0	0	0	3	3	0	0	0	3	9		9	
1332	Ocean Blvd - south of Anchor St	1910	CI	598	8	0	0	3	3	0	0	0	0	3	9		9	
1357	Ashworth Ave - Nudd Ave to Island Path	1910	CI	14	8	0	0	3	3	0	0	0	0	3	9		9	
8	Exeter-Hampton Rd.	1962	CICL	696	12	0	0	0	2	3	0	0	3	0	8		8	
9	Exeter-Hampton Rd.	1962	CICL	407	12	0	0	0	2	3	0	0	3	0	8		8	
313	Ancient Hwy: Ocean Blvd - Shaw St	1925	CI	669	6	0	0	2	3	0	0	0	0	3	8		8	
316	Ancient Hwy: Shaw St - Toppan st	1925	CI	243	6	0	0	2	3	0	0	0	0	3	8		8	
318	Ancient Hwy: James St - Toppan St	1925	CI	258	6	0	0	2	3	0	0	0	0	3	8		8	
322	Ancient Hwy: James St - Ocean Blvd	1925	CI	339	6	0	0	2	3	0	0	0	0	3	8		8	
499	King's Hwy: Gill St - Redman St	1915	UP	288	8	0	0	2	3	0	0	0	0	3	8		8	
500	King's Hwy: 6th St - Redman St	1915	UP	501	8	0	0	2	3	0	0	0	0	3	8		8	
501	King's Hwy: 6th St - 8th St	1915	UP	492	8	0	0	2	3	0	0	0	0	3	8		8	
503	King's Hwy: 8th St - 11th St	1915	UP	717	8	0	0	2	3	0	0	0	0	3	8		8	
506	Kings Hwy: Greene St - High St	1915	UP	617	8	0	0	2	3	0	0	0	0	3	8		8	
507	Ocean Blvd: 16th St - 19th St	1920	CI	721	2	0	0	2	3	0	0	0	0	3	8		8	
508	Ocean Blvd: 15th St - 16th St	1920	CI	244	2	0	0	2	3	0	0	0	0	3	8		8	
510	Ocean Blvd: 12th St - 13th St	1920	CI	229	2	0	0	2	3	0	0	0	0	3	8		8	
512	Ocean Blvd: 11th St - 12th St	1920	CI	249	2	0	0	2	3	0	0	0	0	3	8		8	
513	Ocean Blvd: 9th St - 10th St	1920	CI	247	2	0	0	2	3	0	0	0	0	3	8		8	
516	Ocean Blvd: 7th St - 8th St	1920	CI	243	2	0	0	2	3	0	0	0	0	3	8		8	
518	Ocean Blvd: 1st St - 6th St	1920	CI	1,203	4	0	0	2	3	0	0	0	0	3	8		8	
522	Ocean Blvd.	1920	CI	76	8	0	0	2	3	0	0	0	0	3	8		8	
568	Brown Ave.	1958	CICL	115	8	0	0	0	2	3	0	0	0	3	8		8	
569	Brown Ave.	1958	CICL	688	8	0	0	0	2	3	0	0	0	3	8		8	
576	Ocean Blvd.	1915	CI	368	8	0	0	2	3	0	0	0	0	3	8		8	
580	Ocean Blvd.	1910	CICL	49	8	0	0	3	2	0	0	0	0	3	8		8	
586	Island Path	1954	CICL	39	6	0	3	0	2	0	0	0	0	3	8		8	
601	Ocean Blvd.	1915	CI	234	8	0	0	2	3	0	0	0	0	3	8		8	
602	Ocean Blvd.	1915	CI	246	8	0	0	2	3	0	0	0	0	3	8		8	
604	Ocean Blvd.	1915	CI	144	8	0	0	2	3	0	0	0	0	3	8		8	
605	B St	1966	CI	486	6	2	0	0	3	0	0	0	0	3	8		8	
607	Ocean Blvd.	1915	CI	84	8	0	0	2	3	0	0	0	0	3	8		8	
621	Ocean Blvd.	1915	CI	481	8	0	0	2	3	0	0	0	0	3	8		8	
624	Ocean Blvd.	1915	CI	244	8	0	0	2	3	0	0	0	0	3	8		8	
625	Ocean Blvd.	1915	CI	240	8	0	0	2	3	0	0	0	0	3	8		8	
627	Ocean Blvd.	1915	CI	240	6	0	0	2	3	0	0	0	0	3	8		8	
628	Ocean Blvd.	1915	CI	236	6	0	0	2	3	0	0	0	0	3	8		8	
629	Ocean Blvd.	1915	CI	242	6	0	0	2	3	0	0	0	0	3	8		8	
630	Ocean Blvd.	1915	CI	239	6	0	0	2	3	0	0	0	0	3	8		8	
631	Ocean Blvd.	1915	CI	234	6	0	0	2	3	0	0	0	0	3	8		8	
632	Ocean Blvd.	1915	CI	13	6	0	0	2	3	0	0	0	0	3	8		8	
633	Ocean Blvd.	1920	CI	175	6	0	0	2	3	0	0	0	0	3	8		8	
634	Ocean Blvd.	1920	CI	59	6	0	0	2	3	0	0	0	0	3	8		8	
635	Ocean Blvd.	1920	CI	142	6	0	0	2	3	0	0	0	0	3	8		8	
638	Ocean Blvd.	1920	CI	65	6	0	0	2	3	0	0	0	0	3	8		8	
639	Ocean Blvd.	1920	CI	113	6	0	0	2	3	0	0	0	0	3	8		8	
642	Ocean Blvd.	1920	CI	319	6	0	0	2	3	0	0	0	0	3	8		8	
648	Mooring Dr.	1961	CICL	788	6	3	0	0	2	0	0	0	0	3	8		8	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE 3 of 30	Comments
649	Keefe Ave.	1959	CI	348	6	2	0	0	3	0	0	0	0	3	8	8	
663	Johnson Ave.	1962	CICL	450	6	0	3	0	2	0	0	0	0	3	8	8	
695	Ocean Blvd./Portsmouth Ave.	1967	CICL	453	8	0	0	0	2	3	0	0	0	3	8	8	
719	Kings Hwy: Greene St - Witch Island Way	1915	UP	376	8	0	0	2	3	0	0	0	0	3	8	8	
885	Post Rd.	1977	CICL	747	12	0	0	0	2	3	0	0	0	3	8	8	
929	Exeter Rd.	1957	CICL	1,369	12	0	0	0	2	3	0	0	3	0	8	8	
949	Kenphil Ave.	1961	CICL	256	2.25	0	3	0	2	0	0	0	0	3	8	8	
971	Central Rd.	1937	CI	202	8	0	0	1	3	3	0	0	1	0	8	8	
1016	Exeter Rd.	1957	CICL	166	8	0	0	0	2	3	0	0	3	0	8	8	
1040	Central Rd	1937	CI	436	8	0	0	1	3	3	0	0	1	0	8	8	
1041	Central Rd	1937	CICL	1,235	8	0	0	1	2	3	0	0	2	0	8	8	
1087	Ocean Blvd: 13th St - 14th St	1920	CI	243	2	0	0	2	3	0	0	0	0	3	8	8	
1088	King's Hwy: 16th - Witch Island Way S	1915	UP	269	8	0	0	2	3	0	0	0	0	3	8	8	
1089	Ocean Blvd: 6th St - 7th St	1920	CI	235	2	0	0	2	3	0	0	0	0	3	8	8	
1090	Sixth St	1935	GS	310	2	1	0	1	3	0	0	0	0	3	8	8	
1102	Ocean Blvd: 10th St - 11th St	1920	CI	236	2	0	0	2	3	0	0	0	0	3	8	8	
1106	Kings Hwy: Sixteenth St - Witch Island Way	1915	UP	169	8	0	0	2	3	0	0	0	0	3	8	8	
1118	First St	1920	GS	146	4	0	0	2	3	0	0	0	0	3	8	8	
1225	Ocean Blvd: 14th St - 15 St	1920	CI	239	2	0	0	2	3	0	0	0	0	3	8	8	
1323	King's Highway	1915	UP	347	8	0	0	2	3	0	0	0	0	3	8	8	
1324	King's Hwy: Redcoat Ln - 30 Kings condos	1915	UP	405	8	0	0	2	3	0	0	0	0	3	8	8	
1365	King's Highway	1915	UP	725	8	0	0	2	3	0	0	0	0	3	8	8	
1461	Brown Ave.	1958	CICL	93	8	0	0	0	2	3	0	0	0	3	8	8	
143	High St.	1934	CI	251	8	0	0	1	3	1	0	0	2	0	7	7	
190	Mill Rd.	1940	CI	259	8	0	0	1	3	3	0	0	0	0	7	7	
201	Mill Rd.	1940	CI	102	8	0	0	1	3	3	0	0	0	0	7	7	
210	Mill Rd.	1940	CI	264	8	0	0	1	3	3	0	0	0	0	7	7	
212	Mill Rd.	1940	CI	309	8	0	0	1	3	3	0	0	0	0	7	7	
333	North Shore Rd: Cusack Rd - Quinlan Ln	1930	CI	897	8	0	3	1	3	0	0	0	0	0	7	7	
509	Thirteenth St	1935	GS	293	2	0	0	1	3	0	0	0	0	3	7	7	
511	Twelfth St	1935	GS	301	2	0	0	1	3	0	0	0	0	3	7	7	
514	Ninth St	1935	GS	284	2	0	0	1	3	0	0	0	0	3	7	7	
517	Seventh St	1935	GS	286	2	0	0	1	3	0	0	0	0	3	7	7	
519	Winnicunnet Rd.	1938	CI	473	8	0	0	1	3	0	0	0	0	3	7	7	
523	Ocean Blvd.	1938	CI	73	8	0	0	1	3	0	0	0	0	3	7	7	
535	Fuller Acres	1935	GS	563	2	0	0	1	3	0	0	0	0	3	7	7	
540	McKay Ave.	1935	GS	386	2	0	0	1	3	0	0	0	0	3	7	7	
549	Kentville Ter.	1961	CICL	423	6	2	0	0	2	0	0	0	0	3	7	7	
585	Island Path	1954	AC	883	6	0	3	0	1	0	0	0	0	3	7	7	
609	Bittersweet Ln	1972	CICL	317	6	2	0	0	2	0	0	0	0	3	7	7	
618	Brown Ave.	1950	CI	244	8	1	0	0	3	0	0	0	0	3	7	7	
709	Atlantic Ave.	1968	CICL	479	6	2	0	0	2	0	0	0	0	3	7	7	
750	Well No. 8, 20 and 21	1935	CI	1,283	10	0	0	1	3	3	0	0	0	0	7	7	
755	Sea Rd.	1950	CI	1,091	8	1	0	0	3	0	0	0	0	3	7	7	
821	Mill Rd.	1940	CI	206	8	0	0	1	3	3	0	0	0	0	7	7	
940	Straw Point Rd.	1973	CICL	350	6	2	0	0	2	0	0	0	0	3	7	7	
970	Cable Rd.	1937	CI	373	8	0	0	1	3	3	0	0	0	0	7	7	
972	Cable Rd.	1937	CI	219	8	0	0	1	3	3	0	0	0	0	7	7	
997	Cable Rd	1937	CI	439	8	0	0	1	3	0	0	0	0	3	7	7	
1056	Appledore Ave: Boulters Cove - Ocean Blvd	1970	CICL	419	8	0	0	0	2	0	0	0	2	3	7	7	
1063	Appledore Ave: Boulters Cove - cul de sac	1970	CICL	203	8	0	0	0	2	0	0	0	2	3	7	7	
1084	Mill Rd.	1940	CI	396	8	0	0	1	3	3	0	0	0	0	7	7	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE PRIORITIZATION	Page 4 of 30	Comments
1086	Fourteenth St	1935	GS	237	2	0	0	1	3	0	0	0	0	3	7		7	
1103	Tenth St	1935	GS	283	2	0	0	1	3	0	0	0	0	3	7		7	
1104	Fifteenth St	1935	GS	223	2	0	0	1	3	0	0	0	0	3	7		7	
1137	Charles St.	1935	GS	559	2	0	0	1	3	0	0	0	0	3	7		7	
1158	King's Highway/Winnicunnet Rd.	1938	CI	35	4	0	0	1	3	0	0	0	0	3	7		7	
1185	Central Rd	1958	CICL	1,078	8	2	0	0	2	0	0	0	3	0	7		7	
1211	Well No. 6	1937	CI	62	10	0	0	1	3	3	0	0	0	0	7		7	
1244	Ashworth Ave.	1958	AC	954	12	0	0	0	1	3	0	0	0	3	7		7	
1358	O St.	1973	CI	516	8	1	0	0	3	0	0	0	0	3	7		7	
1411	Split Pipe	1937	CI	359	10	0	0	1	3	3	0	0	0	0	7		7	
1414	Well 7 transmission main	1950	CICL	809	12	2	0	1	1	3	0	0	0	0	7		7	
1227	Rt. 101 Cross Country	1955	CICL	2,800	12	0	0	0	2	3	0	0	0	-1	4	3	7	Crosses inaccessible tidal salt marsh; cable & telephone
1228	Rt. 101 Cross Country	1991	DI	175	12	1	0	0	0	3	0	0	0	0	4	3	7	Crosses inaccessible tidal salt marsh; cable & telephone
77	Exeter-Hampton Rd.	1952	CI	1,084	12	0	0	0	3	0	0	0	3	0	6		6	
89	Exeter-Hampton Rd.	1952	CI	418	8	0	0	0	3	0	0	0	3	0	6		6	
111	Winnicunnet Rd.	1938	CI	545	8	1	0	1	3	0	0	0	1	0	6		6	
112	Winnicunnet Rd.	1938	CI	980	8	0	0	1	3	1	0	0	1	0	6		6	
113	Winnicunnet Rd.	1938	CI	492	8	0	0	1	3	1	0	0	1	0	6		6	
114	Winnicunnet Rd.	1938	CI	738	8	0	0	1	3	1	0	0	1	0	6		6	
116	Exeter-Hampton Rd.	1952	CI	1,275	8	0	0	0	3	0	0	0	3	0	6		6	
135	High St.	1950	CI	377	8	0	0	0	3	1	0	0	2	0	6		6	
137	High St.	1950	CI	396	8	0	0	0	3	1	0	0	2	0	6		6	
139	High St.	1934	CI	73	8	0	0	1	3	0	0	0	2	0	6		6	
242	High St.	1934	CI	333	8	0	0	1	3	0	0	0	2	0	6		6	
243	High St.	1934	CI	355	8	0	0	1	3	0	0	0	2	0	6		6	
249	High St.	1934	CI	331	8	0	0	1	3	0	0	0	2	0	6		6	
250	High St.	1934	CI	387	8	0	0	1	3	0	0	0	2	0	6		6	
325	Cusack Rd @ Ocean Blvd	1950	CI	297	6	0	0	0	3	0	0	0	0	3	6		6	
502	Elighth St	1965	CI	326	6	0	0	0	3	0	0	0	0	3	6		6	
565	Church St - Highland Ave to Williams St	2013	HDPE	638	12	0	0	0	0	3	0	0	0	3	6		6	
566	Glade Path Tank	1955	CI	22	8	0	0	0	3	0	0	0	0	3	6		6	
615	Brown Ave.	1950	CI	23	8	0	0	0	3	0	0	0	0	3	6		6	
616	Brown Ave.	1950	CI	36	8	0	0	0	3	0	0	0	0	3	6		6	
623	G St.	1971	CI	475	8	0	0	0	3	0	0	0	0	3	6		6	
645	I St.	1966	CI	506	6	0	0	0	3	0	0	0	0	3	6		6	
651	J St.	1964	CI	532	6	0	0	0	3	0	0	0	0	3	6		6	
655	K St.	1964	CI	555	6	0	0	0	3	0	0	0	0	3	6		6	
669	Bragg Ave	1960	CI	378	6	0	0	0	3	0	0	0	0	3	6		6	
671	N St.	1971	CI	615	8	0	0	0	3	0	0	0	0	3	6		6	
691	Interconnection with Seabrook	1973	HDPE	727	4	0	0	0	0	3	0	0	0	3	6		6	
692	Interconnection with Seabrook	1973	HDPE	727	4	0	0	0	0	3	0	0	0	3	6		6	
694	Interconnection with Seabrook	1973	HDPE	102	4	0	0	0	0	3	0	0	0	3	6		6	
716	Dover Ave.	1969	CICL	230	6	0	0	0	2	0	1	0	0	3	6		6	
718	Epping Rd.	1961	AC	854	6	2	0	0	1	0	0	0	0	3	6		6	
766	Old Locke Rd: Chapel Rd - AC pipe	1935	CICL	1,127	6	0	0	1	2	0	0	0	3	0	6		6	
771	Causeway Rd	1971	DI	1,101	8	0	0	0	0	0	0	0	3	3	6		6	
797	Locke Rd	1961	AC	805	8	2	0	0	1	0	0	0	0	3	6		6	
908	H St.	1969	CI	483	8	0	0	0	3	0	0	0	0	3	6		6	
932	Atlantic Ave.	1950	CI	2,484	8	0	0	0	3	0	0	0	0	3	6		6	
941	Jenness Ave.	1962	CI	493	6	0	0	0	3	0	0	0	0	3	6		6	
955	Ocean Blvd.	1958	CI	19	8	0	0	0	3	0	0	0	0	3	6		6	
1105	Sixteenth St	1960	CI	246	6	0	0	0	3	0	0	0	0	3	6		6	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE 5 of 30	Comments
1111	Well 6	1957	CI	634	10	0	0	0	3	3	0	0	0	0	6	6	
1112	High St.	1934	CI	452	8	0	0	1	3	0	0	0	2	0	6	6	
1116	King's Highway/Winnicunnet Rd.	1950	CI	31	8	0	0	0	3	0	0	0	0	3	6	6	
1130	Glade Path Tank	1953	LJ	70	16	0	0	0	3	3	0	0	0	0	6	6	
1131	Glade Path Tank	1955	CI	18	8	0	0	0	3	0	0	0	0	3	6	6	
1132	Glade Path Tank	1953	CI	63	12	0	0	0	3	3	0	0	0	0	6	6	
1146	Exeter Rd	1952	CI	19	8	0	0	0	3	0	0	0	3	0	6	6	
1148	Exeter Rd	1952	CI	9	8	0	0	0	3	0	0	0	3	0	6	6	
1191	Central Rd.	1958	CI	877	8	0	0	0	3	0	0	0	3	0	6	6	
1193	Central Rd.	1958	CI	978	8	0	0	0	3	0	0	0	3	0	6	6	
1212	Mill Rd.	2007	DI	903	12	0	0	0	0	3	0	3	0	0	6	6	
1248	Glade Path Tank	1953	LJ	36	16	0	0	0	3	3	0	0	0	0	6	6	
1262	Willow Rd: GV0815 - GV0816	1971	DI	286	8	0	0	0	0	0	0	0	3	3	6	6	
1268	Glade Path Tank	1953	LJ	28	16	0	0	0	3	3	0	0	0	0	6	6	
1269	Glade Path Tank	1953	CI	6	12	0	0	0	3	3	0	0	0	0	6	6	
1270	Glade Path Tank	1953	CI	30	12	0	0	0	3	3	0	0	0	0	6	6	
1284	Mill Rd.	1958	AC	1,337	12	2	0	0	1	3	0	0	0	0	6	6	
1345	Mill Rd.	2007	DI	1,134	12	0	0	0	0	3	0	3	0	0	6	6	
1346	Exeter-Hampton Rd.	1952	CI	83	12	0	0	0	3	0	0	0	3	0	6	6	
1389	Interconnection with Seabrook	1973	HDPE	152	4	0	0	0	0	3	0	0	0	3	6	6	
1390	Interconnection with Seabrook	1973	HDPE	147	4	0	0	0	0	3	0	0	0	3	6	6	
1391	Interconnection with Seabrook	1973	HDPE	606	4	0	0	0	0	3	0	0	0	3	6	6	
1392	Interconnection with Seabrook	1973	HDPE	613	4	0	0	0	0	3	0	0	0	3	6	6	
1415	Mill Rd	2007	DI	253	12	0	0	0	0	3	0	3	0	0	6	6	
7	Exeter-Hampton Rd.	1962	CICL	204	12	0	0	0	2	0	0	0	3	0	5	5	
19	Exeter-Hampton Rd.	1962	CICL	122	12	0	0	0	2	0	0	0	3	0	5	5	
29	Exeter-Hampton Rd.	1962	CICL	307	12	0	0	0	2	0	0	0	3	0	5	5	
30	Exeter-Hampton Rd.	1962	CICL	513	12	0	0	0	2	0	0	0	3	0	5	5	
32	Exeter-Hampton Rd.	1962	CICL	42	12	0	0	0	2	0	0	0	3	0	5	5	
69	Exeter-Hampton Rd.	1962	CICL	462	12	0	0	0	2	0	0	0	3	0	5	5	
102	Lafayette Rd	1965	CICL	239	6	2	0	0	2	1	0	0	0	0	5	5	
106	Park Ave.	1965	CICL	425	6	2	0	0	2	1	0	0	0	0	5	5	
110	Winnicunnet Rd.	1938	CI	492	8	0	0	1	3	0	0	0	1	0	5	5	
117	High St.	1950	CI	20	6	0	0	0	3	0	0	0	2	0	5	5	
120	High St.	1950	CI	232	6	0	0	0	3	0	0	0	2	0	5	5	
122	High St.	1982	CI	10	6	0	0	0	3	0	0	0	2	0	5	5	
123	High St.	1950	CI	86	6	0	0	0	3	0	0	0	2	0	5	5	
125	High St.	1950	CI	506	6	0	0	0	3	0	0	0	2	0	5	5	
127	High St.	1950	CI	56	6	0	0	0	3	0	0	0	2	0	5	5	
129	High St.	1982	CI	17	6	0	0	0	3	0	0	0	2	0	5	5	
130	High St.	1950	CI	587	6	0	0	0	3	0	0	0	2	0	5	5	
132	High St.	1950	CI	318	6	0	0	0	3	0	0	0	2	0	5	5	
133	Mill Rd.	1958	CICL	686	8	0	0	0	2	3	0	0	0	0	5	5	
134	High St.	1950	CI	19	6	0	0	0	3	0	0	0	2	0	5	5	
299	Acorn Rd	1967	CICL	316	6	0	0	0	2	0	0	0	0	3	5	5	
398	Landing Rd.	1958	CICL	787	8	0	0	0	2	1	0	0	2	0	5	5	
421	Hurd Ave.	1958	CI	225	6	2	0	0	3	0	0	0	0	0	5	5	
445	Tide Mill Rd.	1966	CICL	1,768	12	0	0	0	2	3	0	0	0	0	5	5	
496	Gill St: Kings Hwy - Pearl St	1964	CICL	231	6	0	0	0	2	0	0	0	0	3	5	5	
497	Gill St: west of Pearl St	1973	CICL	182	6	0	0	0	2	0	0	0	0	3	5	5	
529	Cliff Ave.	1950	CICL	334	4	0	0	0	2	0	0	0	0	3	5	5	
532	Boar's Head Terr.	1950	CICL	67	10	0	0	0	2	0	0	0	0	3	5	5	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE PRIORITY	Page 6 of 30	Comments
550	Kentville Ter.	1961	CICL	106	6	0	0	0	2	0	0	0	0	3	5		5	
552	Nudd Ave./Highland Ave.	1958	CICL	216	4	0	0	0	2	0	0	0	0	3	5		5	
570	Page Ln.	1964	CICL	199	6	0	0	0	2	0	0	0	0	3	5		5	
571	Brown Ave.	1958	CICL	150	8	0	0	0	2	0	0	0	0	3	5		5	
572	Wall St.	1964	CICL	276	6	0	0	0	2	0	0	0	0	3	5		5	
574	Nudd Ave.	1958	CICL	264	8	0	0	0	2	0	0	0	0	3	5		5	
575	Nudd Ave.	1958	CICL	1,041	4	0	0	0	2	0	0	0	0	3	5		5	
584	Jones Ave.	1967	CICL	441	8	0	0	0	2	0	0	0	0	3	5		5	
603	C St	1972	CICL	495	8	0	0	0	2	0	0	0	0	3	5		5	
608	Battcock Ave.	1956	CICL	386	8	0	0	0	2	0	0	0	0	3	5		5	
610	Battcock Ave.	1956	CICL	267	8	0	0	0	2	0	0	0	0	3	5		5	
613	Diane Ln.	1957	AC	277	6	1	0	0	1	0	0	0	0	3	5		5	
614	Brown Ave.	1971	DI	126	8	2	0	0	0	0	0	0	0	3	5		5	
674	Tuttle Ave.	1962	CICL	564	6	0	0	0	2	0	0	0	0	3	5		5	
676	Fellows Ave.	1960	CICL	503	6	0	0	0	2	0	0	0	0	3	5		5	
681	Whitten Ave.	1972	CICL	520	8	0	0	0	2	0	0	0	0	3	5		5	
682	Dustin Ave.	1972	CICL	148	8	0	0	0	2	0	0	0	0	3	5		5	
683	Harris Ave.	1963	CICL	733	6	0	0	0	2	0	0	0	0	3	5		5	
684	Dustin Ave.	1965	CICL	326	8	0	0	0	2	0	0	0	0	3	5		5	
685	Dover Ave	1969	CICL	92	6	0	0	0	2	0	0	0	0	3	5		5	
686	Ocean Blvd./Ashworth Ave.	1969	CICL	46	8	0	0	0	2	0	0	0	0	3	5		5	
687	Harbor Rd.	1967	CICL	592	8	0	0	0	2	0	0	0	0	3	5		5	
688	Harbour Rd.	1967	CICL	61	8	0	0	0	2	0	0	0	0	3	5		5	
696	Portsmouth Ave.	1967	CICL	178	6	0	0	0	2	0	0	0	0	3	5		5	
698	Thornton St.	1967	CICL	477	6	0	0	0	2	0	0	0	0	3	5		5	
699	Campton St.	1967	CICL	378	6	0	0	0	2	0	0	0	0	3	5		5	
700	Campton St.	1967	CICL	591	6	0	0	0	2	0	0	0	0	3	5		5	
701	Plymouth St.	1967	CICL	527	6	0	0	0	2	0	0	0	0	3	5		5	
702	Plymouth St.	1967	CICL	311	6	0	0	0	2	0	0	0	0	3	5		5	
703	Ocean Dr.	1967	CICL	210	6	0	0	0	2	0	0	0	0	3	5		5	
704	Ocean Dr.	1967	CICL	244	6	0	0	0	2	0	0	0	0	3	5		5	
705	Woodstock St.	1967	CICL	383	6	0	0	0	2	0	0	0	0	3	5		5	
706	Ocean Dr.	1967	CICL	191	6	0	0	0	2	0	0	0	0	3	5		5	
708	Bradford Ave	1968	CICL	338	6	0	0	0	2	0	0	0	0	3	5		5	
710	River Ave.	1961	CICL	182	6	0	0	0	2	0	0	0	0	3	5		5	
712	River Ave.	1961	CICL	246	6	0	0	0	2	0	0	0	0	3	5		5	
715	River Ave.	1961	CICL	235	6	0	0	0	2	0	0	0	0	3	5		5	
717	Dover Ave.	1969	CICL	533	6	0	0	0	2	0	0	0	0	3	5		5	
736	Exeter-Hampton Rd.	1962	CICL	70	12	0	0	0	2	0	0	0	3	0	5		5	
739	Island Path	1966	CICL	33	8	0	3	0	2	0	0	0	0	0	5		5	
740	Island Path	1966	CICL	1,024	8	0	3	0	2	0	0	0	0	0	5		5	
746	Pine Rd.	2007	DI	2,591	12	1	0	0	0	1	0	3	0	0	5		5	
759	Boutlers Cove	1970	CICL	1,046	8	0	0	0	2	0	0	0	0	3	5		5	
790	Birch Rd.	1970	CICL	82	8	0	0	0	2	0	0	0	3	0	5		5	
795	Foss Cir.	1965	CICL	543	8	0	0	0	2	0	0	0	0	3	5		5	
803	Breakers Rd	1971	CICL	512	8	0	0	0	2	0	0	0	0	3	5		5	
807	Powers Ave.	1968	CICL	629	8	0	0	0	2	0	3	0	0	0	5		5	
875	Crenshaw Well No. 10	1963	CICL	121	12	0	0	0	2	3	0	0	0	0	5		5	
879	Birch Rd.	1970	CICL	718	8	0	0	0	2	0	0	0	3	0	5		5	
880	Post Rd.	1977	CICL	1,245	12	0	0	0	2	3	0	0	0	0	5		5	
887	Post Rd.	1977	CICL	452	12	0	0	0	2	3	0	0	0	0	5		5	
917	South Rd.	1988	CICL	1,810	12	0	0	0	2	0	0	0	3	0	5		5	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE PRIORITIZATION	TOTAL	Comments
933	Maple Rd.	1965	CICL	2,006	6	0	0	0	2	0	0	0	0	3	5		5	
935	Straw Point Rd.	1973	CICL	279	6	0	0	0	2	0	0	0	0	3	5		5	
936	Straw Point Rd.	1973	CICL	249	6	0	0	0	2	0	0	0	0	3	5		5	
937	Straw Point Rd.	1966	CICL	451	6	0	0	0	2	0	0	0	0	3	5		5	
938	Straw Point Rd.	1973	CICL	172	6	0	0	0	2	0	0	0	0	3	5		5	
939	Straw Point Rd.	1973	CICL	271	6	0	0	0	2	0	0	0	0	3	5		5	
942	Surf Ln	1971	CICL	248	8	0	0	0	2	0	0	0	0	3	5		5	
943	Surf Ln	1971	CICL	268	6	0	0	0	2	0	0	0	0	3	5		5	
944	Old Beach Rd.	1961	CICL	304	8	0	0	0	2	0	0	0	0	3	5		5	
945	Old Beach Rd.	1961	CICL	454	8	0	0	0	2	0	0	0	0	3	5		5	
946	Old Beach Rd.	1961	CICL	305	8	0	0	0	2	0	0	0	0	3	5		5	
947	Carbee Dr	1961	CICL	288	6	0	0	0	2	0	0	0	0	3	5		5	
951	Old Beach Rd.	1961	CICL	264	8	0	0	0	2	0	0	0	0	3	5		5	
952	Off of Jenness Ave.	1961	CICL	264	2.25	0	0	0	2	0	0	0	0	3	5		5	
992	F St.	1973	CICL	190	6	0	0	0	2	0	0	0	0	3	5		5	
993	F St.	1973	CICL	170	6	0	0	0	2	0	0	0	0	3	5		5	
998	Cable Rd	1961	CICL	583	8	0	0	0	2	0	0	0	0	3	5		5	
1006	Surf Ln	1971	CICL	226	6	0	0	0	2	0	0	0	0	3	5		5	
1017	Exeter Rd.	1957	CICL	13	8	0	0	0	2	0	0	0	3	0	5		5	
1070	South Rd.	1988	CICL	54	12	0	0	0	2	0	0	0	3	0	5		5	
1071	South Rd	1988	CICL	855	12	0	0	0	2	0	0	0	3	0	5		5	
1072	Winnicut Rd.	1963	CICL	1,002	12	0	0	0	2	3	0	0	0	0	5		5	
1083	Well No. 11	1966	CICL	83	12	0	0	0	2	3	0	0	0	0	5		5	
1091	Pearl St: north of Gill St	1971	CICL	218	6	0	0	0	2	0	0	0	0	3	5		5	
1092	Pearl St: south of Gill St	1971	CICL	69	6	0	0	0	2	0	0	0	0	3	5		5	
1133	Chase St.	1961	CICL	159	6	0	0	0	2	0	0	0	0	3	5		5	
1134	Kentville Ter.	1961	CICL	101	6	0	0	0	2	0	0	0	0	3	5		5	
1145	High St	1950	CI	516	6	0	0	0	3	0	0	0	2	0	5		5	
1152	Mill Road Tank	1914	CI	32	10	0	0	2	3	0	0	0	0	0	5		5	
1153	Mill Road Tank	1914	CI	25	10	0	0	2	3	0	0	0	0	0	5		5	
1154	Mill Road Tank	1914	CI	9	10	0	0	2	3	0	0	0	0	0	5		5	
1155	Mill Road Tank	1914	CI	11	10	0	0	2	3	0	0	0	0	0	5		5	
1156	Mill Road Tank	1914	CI	19	6	0	0	2	3	0	0	0	0	0	5		5	
1157	Mill Road Tank	1914	CI	26	6	0	0	2	3	0	0	0	0	0	5		5	
1181	Winnicut Rd.	1963	CICL	1,146	12	0	0	0	2	3	0	0	0	0	5		5	
1182	Winnicut Rd.	1963	CICL	944	12	0	0	0	2	3	0	0	0	0	5		5	
1186	Central Rd	1958	CICL	486	8	0	0	0	2	0	0	0	3	0	5		5	
1187	Central Rd.	1958	CICL	317	8	0	0	0	2	0	0	0	3	0	5		5	
1188	Central Rd.	1958	CICL	127	8	0	0	0	2	0	0	0	3	0	5		5	
1226	Rt. 101 Cross Country	1955	CICL	692	12	1	0	0	2	3	0	0	0	-1	5		5	
1239	Off of Portsmouth Ave.	1967	CICL	70	8	0	0	0	2	0	0	0	0	3	5		5	
1242	Ocean Blvd./Ashworth Ave.	1973	CICL	87	8	0	0	0	2	0	0	0	0	3	5		5	
1261	Willow Ave: Chapel Rd - GV0815	1971	DI	1,474	8	0	0	0	0	0	0	0	2	3	5		5	
1264	Mill Rd.	1958	CICL	659	8	0	0	0	2	3	0	0	0	0	5		5	
1265	Mill Road Tank	1914	CI	30	6	0	0	2	3	0	0	0	0	0	5		5	
1266	Mill Rd.	1958	CICL	657	8	0	0	0	2	3	0	0	0	0	5		5	
1293	Mill Road Tank	1914	CI	18	6	0	0	2	3	0	0	0	0	0	5		5	
1298	South Rd	1988	CICL	257	12	0	0	0	2	0	0	0	3	0	5		5	
1322	30 Kings Hwy	1965	CICL	405	6	0	0	0	2	0	0	0	0	3	5		5	
1336	Central Rd	1958	CICL	407	8	0	0	0	2	0	0	0	3	0	5		5	
1339	Maple Rd.	1965	CICL	145	6	0	0	0	2	0	0	0	0	3	5		5	
1368	Chapel Rd.	1965	CICL	152	8	0	0	0	2	0	0	0	0	3	5		5	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE 8 of 30	Comments
1369	Ocean Blvd.	1958	CICL	30	8	0	0	0	2	0	0	0	0	3	5	5	
1402	Maple Rd	1965	CICL	571	6	0	0	0	2	0	0	0	0	3	5	5	
1403	Maple Rd	1965	CICL	523	6	0	0	0	2	0	0	0	0	3	5	5	
1412	Split Pipe	1963	CICL	597	12	0	0	0	2	3	0	0	0	0	5	5	
1413	Split Pipe	1966	CICL	1,066	12	0	0	0	2	3	0	0	0	0	5	5	
1414	Split Pipe	1950	CICL	809	12	0	0	0	2	3	0	0	0	0	5	5	
1427	Sicard to Mill	1966	CICL	54	8	0	0	0	2	0	0	0	0	0	2	2	
1448	Split Pipe	1966	CICL	1,066	12	0	0	0	2	3	0	0	0	0	5	5	
36	Evergreen Rd.	1965	CICL	732	6	2	0	0	2	0	0	0	0	0	4	4	
37	Heather Ln.	1965	CICL	361	8	2	0	0	2	0	0	0	0	0	4	4	
49	Seavey St.	1966	CICL	272	8	2	0	0	2	0	0	0	0	0	4	4	
97	Lafayette Rd	1950	CI	458	8	0	0	0	3	1	0	0	0	0	4	4	
98	Lafayette Rd	1950	CI	532	8	0	0	0	3	1	0	0	0	0	4	4	
99	Lafayette Rd	1950	CI	422	6	0	0	0	3	1	0	0	0	0	4	4	
118	High St.	1982	CICL	6	6	0	0	0	2	0	0	0	2	0	4	4	
126	Academy Ave.	1960	CI	1,042	6	0	0	0	3	1	0	0	0	0	4	4	
131	George/Emery	1952	AC	1,232	6	0	0	0	1	3	0	0	0	0	4	4	
166	Fairfield Ave.	1950	CICL	382	6	0	0	0	2	0	0	0	2	0	4	4	
167	Ruth Ln.	1950	CICL	260	6	0	0	0	2	0	0	0	2	0	4	4	
168	Ruth Ln.	1950	CICL	113	6	0	0	0	2	0	0	0	2	0	4	4	
169	Fairfield Ave.	1950	CICL	647	2	0	0	0	2	0	0	0	2	0	4	4	
170	Fairfield Ave	1950	CICL	250	6	0	0	0	2	0	0	0	2	0	4	4	
193	Mill Rd.	1940	CI	394	8	0	0	1	3	0	0	0	0	0	4	4	
195	Mill Rd.	1940	CI	335	8	0	0	1	3	0	0	0	0	0	4	4	
197	Mill Rd.	1940	CI	105	8	0	0	1	3	0	0	0	0	0	4	4	
200	Mill Rd	1940	CI	936	8	0	0	1	3	0	0	0	0	0	4	4	
202	Well No. 8, 20 and 21	1935	CI	6	10	0	0	1	3	0	0	0	0	0	4	4	
203	Mill Rd	1958	AC	1,230	12	0	0	0	1	3	0	0	0	0	4	4	
287	Briar Rd: Cranberry Ln - Wild Rose Ln	1969	CICL	311	6	2	0	0	2	0	0	0	0	0	4	4	
300	North Shore Rd: Acorn Rd - Willow Ln	1930	CI	683	6	0	0	1	3	0	0	0	0	0	4	4	
302	North Shore Rd: Seaview Ave - Willow Ln	1930	CI	242	6	0	0	1	3	0	0	0	0	0	4	4	
304	North Shore Rd: Briar Rd - Seaview Ave	1930	CI	396	6	0	0	1	3	0	0	0	0	0	4	4	
305	North Shore Rd: Briar Rd - Robin Ln	1930	CI	486	6	0	0	1	3	0	0	0	0	0	4	4	
307	North Shore Rd: Cusack Rd - Robin Ln	1930	CI	708	6	0	0	1	3	0	0	0	0	0	4	4	
335	High St: GV0620 - Gv0621	1958	AC	1,056	10	2	0	0	1	0	0	0	1	0	4	4	
366	Moulton Rd.	1965	CICL	722	8	0	0	0	2	0	0	0	2	0	4	4	
368	Moulton Rd.	1954	CICL	436	6	0	0	0	2	0	0	0	2	0	4	4	
381	Winnicunnet Rd.	1938	CI	383	8	0	0	1	3	0	0	0	0	0	4	4	
385	Winnacunnet Rd.	1938	CI	185	8	0	0	1	3	0	0	0	0	0	4	4	
387	Winnacunnet Rd.	1938	CI	438	8	0	0	1	3	0	0	0	0	0	4	4	
392	Winnacunnet Rd.	1938	CI	18	8	0	0	1	3	0	0	0	0	0	4	4	
394	Landing Rd: Hilda Dr - Winnacunnet Rd	1971	CICL	390	12	0	0	0	2	0	0	0	2	0	4	4	
395	Winnicunnet Rd.	1938	CI	498	8	0	0	1	3	0	0	0	0	0	4	4	
408	Locke Rd.	1940	CI	1,211	8	0	0	1	3	0	0	0	0	0	4	4	
414	Winnicunnet Rd.	1938	CI	1,861	8	0	0	1	3	0	0	0	0	0	4	4	
441	Landing Rd: Hilda Dr - Tide Mill Rd	1971	CICL	808	12	0	0	0	2	0	0	0	2	0	4	4	
442	Landing Rd: Malek Cir - Tide Mill Rd	1966	CICL	348	12	0	0	0	2	0	0	0	2	0	4	4	
447	Winnicunnet Rd.	1938	CI	653	8	0	0	1	3	0	0	0	0	0	4	4	
449	Winnicunnet Rd.	1938	CI	202	8	0	0	1	3	0	0	0	0	0	4	4	
451	Winnicunnet Rd.	1938	CI	449	8	0	0	1	3	0	0	0	0	0	4	4	
491	Winnicunnet Rd.	1938	CI	290	8	0	0	1	3	0	0	0	0	0	4	4	
492	Winnicunnet Rd.	1938	CI	17	8	0	0	1	3	0	0	0	0	0	4	4	

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE PRIORITY	Page 9 of 30	Comments
495	Winnicunnet Rd.	1955	AC	471	12	0	0	0	1	0	0	0	0	3	4		4	
534	Boar's Head Terr.	1958	AC	413	10	0	0	0	1	0	0	0	0	3	4		4	
553	Nudd Ave. to Ross Ave.	1954	AC	23	12	0	0	0	1	0	0	0	0	3	4		4	
554	Nudd Ave. to Ross Ave.	1954	AC	136	12	0	0	0	1	0	0	0	0	3	4		4	
555	Nudd Ave. to Ross Ave.	1954	AC	14	12	0	0	0	1	0	0	0	0	3	4		4	
557	Nudd Ave. to Ross Ave.	1954	AC	308	12	0	0	0	1	0	0	0	0	3	4		4	
562	Nudd Ave. to Ross Ave.	1954	AC	241	12	0	0	0	1	0	0	0	0	3	4		4	
563	Nudd Ave.	1954	AC	175	12	0	0	0	1	0	0	0	0	3	4		4	
564	D St.	1980	AC	496	12	0	0	0	1	0	0	0	0	3	4		4	
589	Church St.	1955	CICL	638	12	0	0	0	2	3	0	0	0	-1	4		4	
598	Rt. 101 Cross Country	1955	CICL	29	12	0	0	0	2	3	0	0	0	-1	4		4	
599	Rt. 101 Cross Country	1955	CICL	117	12	0	0	0	2	3	0	0	0	-1	4		4	
620	F St.	1952	AC	473	8	0	0	0	1	0	0	0	0	3	4		4	
643	Hobson Ave.	1956	AC	939	6	0	0	0	1	0	0	0	0	3	4		4	
667	Riverview Terr.	1956	AC	511	6	0	0	0	1	0	0	0	0	3	4		4	
680	Q St	1976	DI	320	8	1	0	0	0	0	0	0	0	3	4		4	
720	Greene St. Kings Hwy - Meadow Pond Rd	1955	AC	246	6	0	0	0	1	0	0	0	0	3	4		4	
724	Greene St. Gentian Rd - Meadow Pond Rd	1955	AC	182	6	0	0	0	1	0	0	0	0	3	4		4	
725	Gentian Rd. south of Green St	1957	AC	293	6	0	0	0	1	0	0	0	0	3	4		4	
726	Gentian Rd. north of Green St	1957	AC	261	6	0	0	0	1	0	0	0	0	3	4		4	
737	Landing Rd: GV0183 - GV0184	1990	DI	1,483	8	2	0	0	0	0	0	0	2	0	4		4	
744	Sylvan Rd.	1960	CI	943	8	1	0	0	3	0	0	0	0	0	4		4	
796	Straw Point Rd	1961	AC	39	8	0	0	0	1	0	0	0	0	3	4		4	
814	Glendale Rd.	1962	CICL	795	8	0	0	0	2	0	0	0	2	0	4		4	
815	Alden Ave	1962	CICL	423	8	0	0	0	2	0	0	0	2	0	4		4	
820	Atlantic Ave.	1950	CI	1,494	8	0	0	0	3	1	0	0	0	0	4		4	
948	Atlantic Ave.	1961	AC	281	6	0	0	0	1	0	0	0	0	3	4		4	
950	Atlantic Ave.	1961	AC	137	6	0	0	0	1	0	0	0	0	3	4		4	
963	Jenness Beach Tank & Well No. 5	1937	CI	43	6	0	0	1	3	0	0	0	0	0	4		4	
964	Well No. 5	1937	CI	59	6	0	0	1	3	0	0	0	0	0	4		4	
965	Jenness Beach Tank & Well No. 5	1937	CI	17	6	0	0	1	3	0	0	0	0	0	4		4	
973	Fielding Way	1938	CI	13	8	0	0	1	3	0	0	0	0	0	4		4	
974	Cable Rd	1937	CI	876	8	0	0	1	3	0	0	0	0	0	4		4	
975	Cable Rd	1937	CI	564	8	0	0	1	3	0	0	0	0	0	4		4	
996	Looke Rd	1961	AC	326	8	0	0	0	1	0	0	0	0	3	4		4	
999	Big Rock Rd.	1938	CI	576	8	0	0	1	3	0	0	0	0	0	4		4	
1000	Big Rock Rd.	1938	CI	187	6	0	0	1	3	0	0	0	0	0	4		4	
1001	Big Rock Rd.	1938	CI	244	6	0	0	1	3	0	0	0	0	0	4		4	
1002	Big Rock Rd.	1938	CI	131	6	0	0	1	3	0	0	0	0	0	4		4	
1003	Big Rock Rd.	1938	CI	336	6	0	0	1	3	0	0	0	0	0	4		4	
1004	Perkins Rd.	1938	CI	266	6	0	0	1	3	0	0	0	0	0	4		4	
1005	Perkins Rd.	1938	CI	20	6	0	0	1	3	0	0	0	0	0	4		4	
1025	Woodland Rd: Maple Rd - River Rd	1951	AC	643	6	0	0	0	1	0	0	0	3	0	4		4	
1026	River Rd: south end off Woodland Rd	1956	AC	757	6	0	0	0	1	0	0	0	3	0	4		4	
1042	Central Rd	1958	CICL	382	8	0	0	0	2	0	0	0	2	0	4		4	
1045	Central Rd	1958	CICL	266	8	0	0	0	2	0	0	0	2	0	4		4	
1101	Lafayette Rd	1995	DI	821	12	2	0	0	0	2	0	0	0	0	4		4	
1107	Mill Rd	1940	CI	1,060	8	0	0	1	3	0	0	0	0	0	4		4	
1114	Red Coat Ln	1957	AC	348	6	0	0	0	1	0	0	0	0	3	4		4	
1117	Winnicunnet Rd.	1938	CI	22	8	0	0	1	3	0	0	0	0	0	4		4	
1136	Nudd Ave. to Ross Ave.	1954	AC	152	12	0	0	0	1	0	0	0	0	3	4		4	
1149	New Pipe	1938	CI	49	8	0	0	1	3	0	0	0	0	0	4		4	

Attachment CM-II

ID		Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Page 10 of 30	Comments
1151		Lafayette Rd.	1965	CICL	278	6	1	0	0	2	1	0	0	0	0	4	4	
1159		Rt. 101 Cross Country	1955	CICL	29	12	0	0	0	2	3	0	0	0	-1	4	4	
1160		Rt. 101 Cross Country	1955	CICL	68	12	0	0	0	2	3	0	0	0	-1	4	4	
1189		Willowbrook Dr	1958	GS	483	2	1	0	0	3	0	0	0	0	0	4	4	
1213		Mill Rd	1940	CI	4	8	0	0	1	3	0	0	0	0	0	4	4	
1229		Winnicunnet Rd.	1938	CI	1,186	8	0	0	1	3	0	0	0	0	0	4	4	
1230		Winnicunnet Rd.	1938	CI	1,171	8	0	0	1	3	0	0	0	0	0	4	4	
1231		Winnicunnet Rd.	1938	CI	1,327	8	0	0	1	3	0	0	0	0	0	4	4	
1238		Nudd Ave./Island Path	1954	AC	402	12	0	0	0	1	0	0	0	0	3	4	4	
1245		Ashworth Ave.	1958	AC	131	12	0	0	0	1	0	0	0	0	3	4	4	
1249		Jenness Beach Tank & Well No. 5	1937	CI	4	6	0	0	1	3	0	0	0	0	0	4	4	
1250		Jenness Beach Tank & Well No. 5	1937	CI	9	6	0	0	1	3	0	0	0	0	0	4	4	
1253		Jenness Beach Tank & Well No. 5	1937	CI	25	12	0	0	1	3	0	0	0	0	0	4	4	
1259		Jenness Beach Tank & Well No. 5	1937	CI	23	4	0	0	1	3	0	0	0	0	0	4	4	
1263		Well No. 8	1937	CI	56	6	0	0	1	3	0	0	0	0	0	4	4	
1288		Well No. 6	1937	CI	4	10	0	0	1	3	0	0	0	0	0	4	4	
1290		Jenness Beach Tank & Well No. 5	1937	CI	26	6	0	0	1	3	0	0	0	0	0	4	4	
1291		Well No. 5	1937	CI	8	6	0	0	1	3	0	0	0	0	0	4	4	
1331		Mill Rd	1940	CI	802	8	0	0	1	3	0	0	0	0	0	4	4	
1333		Jenness Beach Tank & Well No. 5	1937	CI	156	6	0	0	1	3	0	0	0	0	0	4	4	
1335		Central Rd	1958	CICL	707	8	0	0	0	2	0	0	0	2	0	4	4	
1341		Mill Rd	1958	AC	538	12	0	0	0	1	3	0	0	0	0	4	4	
1376		Woodland Rd: Atlantic Ave - River Rd	1951	AC	602	6	0	0	0	1	0	0	0	3	0	4	4	
1399		Winnicunnet Rd.	1938	CI	14	8	0	0	1	3	0	0	0	0	0	4	4	
1401		Sea Rd	1958	CI	625	6	1	0	0	3	0	0	0	0	0	4	4	
1421		Old Locke Rd	1935	CICL	610	6	1	0	1	2	0	0	0	0	0	4	4	
1438		Susan Ln	1970	CI	200	6	1	0	0	3	0	0	0	0	0	4	4	
1449		Fairfield Ave.	1950	CICL	120	2	0	0	0	2	0	0	0	2	0	4	4	
1469		High St	1958	AC	168	10	0	0	0	1	0	0	0	0	3	4	4	
1502		High St parallel main	1974	DI	274	4	1	0	0	0	0	0	0	0	0	1	1	
10		Falcone Cir.	1982	DI	226	16	0	0	0	0	3	0	0	0	0	3	3	
11		Exeter Road Elevated Tank	1982	DI	261	16	0	0	0	0	3	0	0	0	0	3	3	
13		Falcone Dr.	1994	DI	403	8	0	0	0	0	3	0	0	0	0	3	3	
14		Falcone Dr.	1994	DI	293	8	0	0	0	0	3	0	0	0	0	3	3	
15		St. Cyr Dr.	1986	DI	525	8	0	0	0	0	3	0	0	0	0	3	3	
16		Falcone Dr.	1994	DI	1,472	8	0	0	0	0	3	0	0	0	0	3	3	
17		St. Cyr Dr.	1990	DI	1,198	8	0	0	0	0	3	0	0	0	0	3	3	
18		Falcone Cir.	1986	DI	1,587	8	0	0	0	0	3	0	0	0	0	3	3	
46		Wingate St	1960	CI	598	8	0	0	0	3	0	0	0	0	0	3	3	
48		Seavey St.	1960	CI	278	8	0	0	0	3	0	0	0	0	0	3	3	
54		Carolan Dr.	1959	AC	593	8	2	0	0	1	0	0	0	0	0	3	3	
73		Exeter-Hampton Rd.	1971	DI	415	12	0	0	0	0	0	0	0	3	0	3	3	
74		Exeter-Hampton Rd.	1971	DI	26	12	0	0	0	0	0	0	0	3	0	3	3	
90		Exeter-Hampton Rd.	1982	DI	616	12	0	0	0	0	0	0	0	3	0	3	3	
91		Exeter-Hampton Rd.	1982	DI	1,282	12	0	0	0	0	0	0	0	3	0	3	3	
92		Exeter-Hampton Rd.	1982	DI	38	12	0	0	0	0	0	0	0	3	0	3	3	
95		High St.	1982	DI	908	12	0	0	0	0	1	0	0	2	0	3	3	
96		Lafayette Rd.	1950	CI	19	6	0	0	0	3	0	0	0	0	0	3	3	
100		Lafayette Rd	1965	CICL	820	6	0	0	0	2	1	0	0	0	0	3	3	
104		Lafayette Rd	1965	CICL	283	6	0	0	0	2	1	0	0	0	0	3	3	
109		Park Ave.	1958	CICL	466	8	0	0	0	2	1	0	0	0	0	3	3	
115		Lafayette Rd.	1950	CI	13	6	0	0	0	3	0	0	0	0	0	3	3	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Page 11 of 30	Comments
124	Towle Ave.	1968	CICL	1,155	8	0	0	0	2	1	0	0	0	0	3	3	
140	Mill Rd.	1958	CICL	1,062	8	0	0	0	2	1	0	0	0	0	3	3	
145	Hobbs Rd.	1965	CICL	1,055	2	0	0	0	2	1	0	0	0	0	3	3	
150	Rice Terr.	1950	CI	211	2	0	0	0	3	0	0	0	0	0	3	3	
160	Anns Ln: Dearborn Ave - Tuck Rd	1950	AC	259	6	0	0	0	1	0	0	0	2	0	3	3	
172	Belmont Cir	1954	AC	560	6	0	0	0	1	0	0	0	2	0	3	3	
182	Lamson Ln	1956	AC	801	6	0	0	0	1	2	0	0	0	0	3	3	
198	Anns Ln: Anns Terr - Dearborn Ave	1950	AC	240	6	0	0	0	1	0	0	0	2	0	3	3	
199	Anns Ln: Anns Terr - Mill Rd	1950	AC	964	6	0	0	0	1	0	0	0	2	0	3	3	
215	Mace Rd	1950	CI	257	6	0	0	0	3	0	0	0	0	0	3	3	
217	Mace Rd.	1950	CI	235	6	0	0	0	3	0	0	0	0	0	3	3	
224	Mace Rd.	1950	CI	351	6	0	0	0	3	0	0	0	0	0	3	3	
226	Mace Rd.	1950	CI	437	6	0	0	0	3	0	0	0	0	0	3	3	
230	Mace Rd.	1950	CI	556	8	0	0	0	3	0	0	0	0	0	3	3	
236	Naves Rd.	1957	CI	503	6	0	0	0	3	0	0	0	0	0	3	3	
239	Naves St.	1957	CI	243	6	0	0	0	3	0	0	0	0	0	3	3	
241	Naves Rd.	1957	CI	95	6	0	0	0	3	0	0	0	0	0	3	3	
252	High St.	1958	AC	63	10	0	0	0	1	0	0	0	2	0	3	3	
255	Little River Rd.	1995	DI	714	12	0	0	0	0	3	0	0	0	0	3	3	
276	Juniper Ln: Huckleberry Ln - Linden Ln	1961	CI	241	8	0	0	0	3	0	0	0	0	0	3	3	
278	Huckleberry Ln: Juniper Ln - Keene Ln crossover	1961	CI	543	8	0	0	0	3	0	0	0	0	0	3	3	
279	Huckleberry Ln: Bay Berry Ln - Keene Ln crossover	1961	CI	205	8	0	0	0	3	0	0	0	0	0	3	3	
280	Huckleberry Ln: Bay Berry Ln - Ocean Blvd	1961	CI	1,464	8	0	0	0	3	0	0	0	0	0	3	3	
281	Linden Ln	1961	CI	744	6	0	0	0	3	0	0	0	0	0	3	3	
282	Ocean Blvd: Huckleberry Ln - Nor East Ln	1915	UP	344	8	0	0	2	3	0	0	0	-5	3	3	3	
283	Ocean Blvd: Nor East Ln - N Hampton Town Line	1915	UP	470	8	0	0	2	3	0	0	0	-5	3	3	3	
284	Nor East Ln	1980	DI	628	6	0	0	0	0	0	0	0	0	3	3	3	
285	Ocean Blvd: Cranberry Ln - Huckleberry Ln	1915	UP	1,047	8	0	0	2	3	0	0	0	-5	3	3	3	
286	Cranberry Ln @ Ocean Blvd	1976	DI	770	8	0	0	0	0	0	0	0	0	3	3	3	
289	Briar Rd: Lancaster St - Wild Rose Ln	1969	CICL	170	6	1	0	0	2	0	0	0	0	0	3	3	
297	Ocean Blvd: Ancient Hwy - Cranberry Ln	1915	UP	248	8	0	0	2	3	0	0	0	-5	3	3	3	
301	Willow Ln	1958	CI	368	6	0	0	0	3	0	0	0	0	0	3	3	
314	Shaw St	1985	DI	161	6	0	0	0	0	0	0	0	0	3	3	3	
315	Beach Plum Way: north of Shaw St	1985	DI	247	6	0	0	0	0	0	0	0	0	3	3	3	
317	Toppan St	1985	DI	220	6	0	0	0	0	0	0	0	0	3	3	3	
319	James St	1985	DI	277	6	0	0	0	0	0	0	0	0	3	3	3	
320	Beach Plum Way: Shaw St - Tappan St	1985	DI	241	6	0	0	0	0	0	0	0	0	3	3	3	
321	Beach Plum Way: James St - Tappan St	1985	DI	246	6	0	0	0	0	0	0	0	0	3	3	3	
323	Ocean Blvd: Ancient Hwy - N Shore Rd	1915	UP	1,151	8	0	0	2	3	0	0	0	-5	3	3	3	
324	Ocean Blvd: Ancient Hwy - Cusack Rd	1915	UP	997	8	0	0	2	3	0	0	0	-5	3	3	3	
328	Mill Pond Ln: GV0619 - Little Fox Rd	1969	CICL	495	8	1	0	0	2	0	0	0	0	0	3	3	
337	Hutchinson Dr: GV1139 - Pine Rd	1960	CI	516	6	0	0	0	3	0	0	0	0	0	3	3	
360	Little River Rd.	2003	DI	702	12	0	0	0	0	3	0	0	0	0	3	3	
367	Moulton Rd.	1954	AC	826	6	0	0	0	1	0	0	0	2	0	3	3	
372	Eastmore	1954	AC	279	6	2	0	0	1	0	0	0	0	0	3	3	
377	Leary Ln	1961	CI	749	6	0	0	0	3	0	0	0	0	0	3	3	
382	Winnacunnet High School	1958	CICL	754	6	0	0	0	2	1	0	0	0	0	3	3	
384	Winnacunnet High School	1958	CICL	668	6	0	0	0	2	1	0	0	0	0	3	3	
400	Edgewood Dr.	1953	CI	571	6	0	0	0	3	0	0	0	0	0	3	3	
401	Laurel Ln.	1953	CI	437	6	0	0	0	3	0	0	0	0	0	3	3	
403	Edgewood Dr.	1953	CI	347	6	0	0	0	3	0	0	0	0	0	3	3	
411	Wentworth Ave.	1964	CI	506	8	0	0	0	3	0	0	0	0	0	3	3	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Page 12 of 30	Comments
412	Colby St.	1964	CI	195	6	0	0	0	3	0	0	0	0	0	3	3	
413	Wentworth Ave.	1964	CI	341	8	0	0	0	3	0	0	0	0	0	3	3	
422	Tafford Rd.	1957	CI	849	6	0	0	0	3	0	0	0	0	0	3	3	
423	Hurd Ave.	1958	CI	97	6	0	0	0	3	0	0	0	0	0	3	3	
428	Elliot St.	1965	CICL	331	8	0	0	0	2	0	0	0	1	0	3	3	
430	Elliot St.	1965	CICL	439	6	0	0	0	2	0	0	0	1	0	3	3	
431	Randall St	1965	CICL	327	6	0	0	0	2	0	0	0	1	0	3	3	
432	Randall St.	1965	CICL	357	6	0	0	0	2	0	0	0	1	0	3	3	
433	Randall St.	1965	CICL	248	6	0	0	0	2	0	0	0	1	0	3	3	
436	Bradstreet Rd.	1963	CICL	416	8	0	0	0	2	0	0	0	1	0	3	3	
438	Bradstreet Rd.	1963	CICL	249	8	0	0	0	2	0	0	0	1	0	3	3	
446	Tide Mill Rd.	1971	DI	1,395	8	0	0	0	0	3	0	0	0	0	3	3	
468	Shirley Terr.	1956	CI	334	6	0	0	0	3	0	0	0	0	0	3	3	
470	Shirley Terr.	1956	CI	349	6	0	0	0	3	0	0	0	0	0	3	3	
498	Redman St	1975	DI	241	6	0	0	0	0	0	0	0	0	3	3	3	
521	Winnicunnet Rd.	1955	CI	17	8	0	0	0	3	0	0	0	0	0	3	3	
537	Cole St.	1978	DI	547	6	0	0	0	0	0	0	0	0	3	3	3	
538	Church St.	2006	DI	141	6	0	0	0	0	0	0	0	0	3	3	3	
539	Church St.	2006	DI	25	6	0	0	0	0	0	0	0	0	3	3	3	
541	Church St.	2006	DI	163	6	0	0	0	0	0	0	0	0	3	3	3	
542	Francis St.	1982	DI	220	6	0	0	0	0	0	0	0	0	3	3	3	
543	Francis St.	1982	DI	92	6	0	0	0	0	0	0	0	0	3	3	3	
544	Lyon St.	1982	DI	304	6	0	0	0	0	0	0	0	0	3	3	3	
545	William St	1982	DI	192	6	0	0	0	0	0	0	0	0	3	3	3	
546	Church St.	2006	DI	281	6	0	0	0	0	0	0	0	0	3	3	3	
551	Highland Ave.	2007	DI	221	16	0	0	0	0	0	0	0	0	3	3	3	
559	Highland Ave.	2007	DI	461	16	0	0	0	0	0	0	0	0	3	3	3	
573	Wall St.	1981	CU	148	1	0	0	0	0	0	0	0	0	3	3	3	
578	Ashworth Ave.	2007	DI	52	6	0	0	0	0	0	0	0	0	3	3	3	
579	Ocean Blvd.	2007	DI	198	6	0	0	0	0	0	0	0	0	3	3	3	
588	Island Path	1993	PVC	2,153	8	0	3	0	0	0	0	0	0	0	3	3	
600	A St	1986	DI	407	8	0	0	0	0	0	0	0	0	3	3	3	
606	Ashworth Ave.	2007	DI	233	16	0	0	0	0	0	0	0	0	3	3	3	
611	Brown Ave.	1971	DI	151	8	0	0	0	0	0	0	0	0	3	3	3	
612	Brown Ave.	1971	DI	158	8	0	0	0	0	0	0	0	0	3	3	3	
619	Brown Ave.	2004	DI	843	8	0	0	0	0	0	0	0	0	3	3	3	
622	Ashworth Ave.	2007	DI	252	16	0	0	0	0	0	0	0	0	3	3	3	
626	Ashworth Ave.	2007	DI	196	16	0	0	0	0	0	0	0	0	3	3	3	
644	Ashworth Ave.	2007	DI	39	16	0	0	0	0	0	0	0	0	3	3	3	
647	Ashworth Ave.	2007	DI	113	16	0	0	0	0	0	0	0	0	3	3	3	
650	Ashworth Ave.	2007	DI	123	16	0	0	0	0	0	0	0	0	3	3	3	
652	Ashworth Ave.	2007	DI	64	16	0	0	0	0	0	0	0	0	3	3	3	
654	Ashworth Ave.	2007	PVC	167	12	0	0	0	0	0	0	0	0	3	3	3	
656	Ashworth Ave.	2007	PVC	95	12	0	0	0	0	0	0	0	0	3	3	3	
660	Ashworth Ave.	2007	PVC	151	12	0	0	0	0	0	0	0	0	3	3	3	
661	L St.	1972	CI	585	8	0	0	0	3	0	0	0	0	0	3	3	
662	Ashworth Ave.	2007	PVC	57	12	0	0	0	0	0	0	0	0	3	3	3	
664	Ashworth Ave.	2007	PVC	176	12	0	0	0	0	0	0	0	0	3	3	3	
666	Ashworth Ave.	2007	PVC	22	12	0	0	0	0	0	0	0	0	3	3	3	
668	Ashworth Ave.	2007	PVC	186	12	0	0	0	0	0	0	0	0	3	3	3	
670	Ashworth Ave.	2007	PVC	36	12	0	0	0	0	0	0	0	0	3	3	3	
672	Ashworth Ave.	2007	PVC	93	12	0	0	0	0	0	0	0	0	3	3	3	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PIPE PRIORITY	Page 13 of 30	Comments
673	Ashworth Ave.	2007	PVC	58	12	0	0	0	0	0	0	0	0	3	3		3	
675	Ashworth Ave.	2007	PVC	187	12	0	0	0	0	0	0	0	0	3	3		3	
677	Ashworth Ave	2007	PVC	207	12	0	0	0	0	0	0	0	0	3	3		3	
678	Ashworth Ave	2007	PVC	54	12	0	0	0	0	0	0	0	0	3	3		3	
679	P St	1975	DI	426	8	0	0	0	0	0	0	0	0	3	3		3	
693	Interconnection with Seabrook	1973	HDPE	101	4	0	0	0	0	0	0	0	0	3	3		3	
697	Portsmouth Ave.	1971	DI	78	6	0	0	0	0	0	0	0	0	3	3		3	
707	Haverhill Ave.	1977	DI	260	6	0	0	0	0	0	0	0	0	3	3		3	
711	Boston Ave	1975	DI	443	6	0	0	0	0	0	0	0	0	3	3		3	
713	Concord Ave.	1984	DI	296	6	0	0	0	0	0	0	0	0	3	3		3	
714	Concord Ave.	1976	DI	457	6	0	0	0	0	0	0	0	0	3	3		3	
738	Island Path	1993	PVC	14	8	0	3	0	0	0	0	0	0	0	3		3	
743	Meadowfox Rd	1960	CI	731	8	0	0	0	3	0	0	0	0	0	3		3	
749	Mill Rd.	1953	AC	1,843	8	2	0	0	1	0	0	0	0	0	3		3	
753	Ship Rock Road	1986	DI	1,962	8	0	0	0	0	0	0	0	3	0	3		3	
757	Ocean Blvd.	1915	UP	1,730	8	0	0	2	3	0	0	0	-5	3	3		3	
758	Ocean Blvd.	1915	UP	209	8	0	0	2	3	0	0	0	-5	3	3		3	
760	River Road: opposite Maple Rd	1970	DI	282	8	0	0	0	0	0	0	0	3	0	3		3	
761	Woodland Rd: Cotton Farm Ln - Maple Rd	1971	DI	907	8	0	0	0	0	0	0	0	3	0	3		3	
764	Ship Rock Road	1986	DI	1,961	8	0	0	0	0	0	0	0	3	0	3		3	
769	Ocean Blvd.	1958	CICL	543	8	0	0	0	2	3	0	0	-5	3	3		3	
817	Atlantic Ave.	1950	CI	1,265	8	0	0	0	3	0	0	0	0	0	3		3	
818	Atlantic Ave.	1950	CI	832	8	0	0	0	3	0	0	0	0	0	3		3	
826	Post Rd.	1950	CI	62	12	0	0	0	3	0	0	0	0	0	3		3	
828	Lafayette Rd.	1950	CI	204	12	0	0	0	3	0	0	0	0	0	3		3	
846	Lafayette Rd	1950	CI	44	12	0	0	0	3	0	0	0	0	0	3		3	
866	North Rd.	1980	DI	2,019	12	0	0	0	0	0	0	0	3	0	3		3	
869	North Rd.	1980	DI	852	12	0	0	0	0	0	0	0	3	0	3		3	
870	North Rd.	1980	DI	974	12	0	0	0	0	0	0	0	3	0	3		3	
871	North Rd	1980	DI	1,015	12	0	0	0	0	0	0	0	3	0	3		3	
872	Birch Rd.	1986	DI	728	12	0	0	0	0	0	0	0	3	0	3		3	
889	Well No. 12 & 13A	1978	DI	534	16	0	0	0	0	3	0	0	0	0	3		3	
890	Rock Well No. 13A	1982	DI	478	8	0	0	0	0	3	0	0	0	0	3		3	
893	Well No. 12 & 13A	1978	DI	536	8	0	0	0	0	3	0	0	0	0	3		3	
895	Well No. 12 & 13A	1995	DI	549	12	0	0	0	0	3	0	0	0	0	3		3	
899	Well No. 17, 18 & 19	1998	DI	1,109	12	0	0	0	0	3	0	0	0	0	3		3	
900	Well No. 19	1998	DI	190	8	0	0	0	0	3	0	0	0	0	3		3	
903	Well No. 18	1998	DI	497	6	0	0	0	0	3	0	0	0	0	3		3	
905	Well No. 19	1998	DI	169	8	0	0	0	0	3	0	0	0	0	3		3	
927	Well No. 14	1989	DI	538	12	0	0	0	0	3	0	0	0	0	3		3	
928	Well No. 14	1989	DI	867	12	0	0	0	0	3	0	0	0	0	3		3	
931	Atlantic Ave.	2012	PWDI	1,028	16	0	0	0	0	0	0	3	0	0	3		3	
934	Wildwood Ln.	1989	DI	460	6	0	0	0	0	0	0	0	0	3	3		3	
953	Cable Rd.	1991	DI	375	6	0	0	0	0	0	0	0	0	3	3		3	
980	Myrica Ave.	1964	CI	322	6	0	0	0	3	0	0	0	0	0	3		3	
981	Myrica Ave.	1965	CI	209	6	0	0	0	3	0	0	0	0	0	3		3	
994	Drake Ln.	1988	DI	79	8	0	0	0	0	0	0	0	0	3	3		3	
1007	Surf Ln	1992	DI	240	6	0	0	0	0	0	0	0	0	3	3		3	
1008	Off of Surf Ln.	1992	DI	280	6	0	0	0	0	0	0	0	0	3	3		3	
1010	Grandview Terr.	1957	AC	577	6	2	0	0	1	0	0	0	0	0	3		3	
1019	Atlantic Ave: GV1116 - GV1164	2011	DI	1,434	12	0	0	0	0	0	0	3	0	0	3		3	
1051	Sea Rd	1958	CI	1,307	6	0	0	0	3	0	0	0	0	0	3		3	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Page 14 of 30	Comments
1059	Church Rd.	2000	DI	324	8	0	0	0	0	0	0	0	0	3	3	3	
1060	Central St	1991	DI	196	8	0	0	0	0	0	0	0	0	3	3	3	
1061	Woodland Rd: Cotton Farm Ln - dead end	1971	DI	119	8	0	0	0	0	0	0	0	3	0	3	3	
1081	Lafayette Rd.	1950	CI	203	12	0	0	0	3	0	0	0	0	0	3	3	
1096	Ridgeview Ter	1959	CI	661	6	0	0	0	3	0	0	0	0	0	3	3	
1098	Naves St	1957	CI	237	6	0	0	0	3	0	0	0	0	0	3	3	
1128	Church St.	2006	DI	146	6	0	0	0	0	0	0	0	0	3	3	3	
1129	Cutter Ave.	1978	DI	470	6	0	0	0	0	0	0	0	0	3	3	3	
1135	Highland Ave.	2007	DI	160	16	0	0	0	0	0	0	0	0	3	3	3	
1138	Highland Ave.	2007	DI	189	16	0	0	0	0	0	0	0	0	3	3	3	
1139	Highland Ave.	2007	DI	19	16	0	0	0	0	0	0	0	0	3	3	3	
1141	Highland Ave.	2007	DI	9	16	0	0	0	0	0	0	0	0	3	3	3	
1162	Lafayette Rd	1950	CI	771	12	0	0	0	3	0	0	0	0	0	3	3	
1163	Lafayette Rd	1950	CI	369	12	0	0	0	3	0	0	0	0	0	3	3	
1164	Lafayette Rd.	1950	CI	305	12	0	0	0	3	0	0	0	0	0	3	3	
1166	Meadowfox Rd.	1960	CI	53	8	0	0	0	3	0	0	0	0	0	3	3	
1176	Winnicut Rd.	1995	DI	940	8	0	0	0	0	3	0	0	0	0	3	3	
1177	Winnicut Rd.	1995	DI	472	8	0	0	0	0	3	0	0	0	0	3	3	
1179	Well No. 8, 20 and 21	2003	DI	1,295	8	0	0	0	0	3	0	0	0	0	3	3	
1180	Well No. 16	1995	DI	332	8	0	0	0	0	3	0	0	0	0	3	3	
1192	Central Rd.	1958	CI	34	8	0	0	0	3	0	0	0	0	0	3	3	
1194	Central Rd.	1958	CI	21	8	0	0	0	3	0	0	0	0	0	3	3	
1199	Lafayette Rd	1950	CI	487	12	0	0	0	3	0	0	0	0	0	3	3	
1200	Lafayette Rd.	1950	CI	554	12	0	0	0	3	0	0	0	0	0	3	3	
1204	Central St	1991	DI	233	8	0	0	0	0	0	0	0	0	3	3	3	
1205	Ocean Blvd.	1971	DI	128	8	0	0	0	0	0	0	0	0	3	3	3	
1208	Well No. 20	2003	DI	346	4	0	0	0	0	3	0	0	0	0	3	3	
1210	Well No. 20 and 21	2003	DI	148	4	0	0	0	0	3	0	0	0	0	3	3	
1214	Runnymede Dr.	1990	DI	755	8	0	0	0	0	0	0	0	0	3	3	3	
1215	Runnymede Dr.	1990	DI	1,156	8	0	0	0	0	0	0	0	0	3	3	3	
1216	Runnymede Dr.	1990	DI	766	8	0	0	0	0	0	0	0	0	3	3	3	
1224	Winnacunnet High School	1958	CICL	275	6	0	0	0	2	1	0	0	0	0	3	3	
1232	Highland Ave.	2007	DI	299	16	0	0	0	0	0	0	0	0	3	3	3	
1234	Ashworth Ave.	2007	DI	272	16	0	0	0	0	0	0	0	0	3	3	3	
1235	Ashworth Ave.	2007	DI	224	16	0	0	0	0	0	0	0	0	3	3	3	
1236	Ashworth Ave.	2007	DI	295	16	0	0	0	0	0	0	0	0	3	3	3	
1237	Ashworth Ave.	2007	DI	192	16	0	0	0	0	0	0	0	0	3	3	3	
1243	Ashworth Ave.	2007	PVC	426	12	0	0	0	0	0	0	0	0	3	3	3	
1246	Ashworth Ave.	2007	DI	135	16	0	0	0	0	0	0	0	0	3	3	3	
1247	Ashworth Ave.	2007	DI	42	16	0	0	0	0	0	0	0	0	3	3	3	
1282	Well No. 11	1966	CI	37	12	0	0	0	3	0	0	0	0	0	3	3	
1295	Ashworth Ave	1975	DI	7	8	0	0	0	0	0	0	0	0	3	3	3	
1296	Exeter-Hampton Rd.	1982	DI	431	12	0	0	0	0	0	0	0	3	0	3	3	
1297	Ocean Blvd.	1915	UP	867	8	0	0	2	3	0	0	0	-5	3	3	3	
1327	Lafayette Rd	1950	CI	424	12	0	0	0	3	0	0	0	0	0	3	3	
1328	Lafayette Rd	1950	CI	467	12	0	0	0	3	0	0	0	0	0	3	3	
1343	Sea Rd	1958	CI	402	6	0	0	0	3	0	0	0	0	0	3	3	
1348	Off of Lafayette Rd.	NA	UNK	58	8	0	0	0	0	0	0	0	0	0	0	0	
1349	Off of Lafayette Rd.	NA	UNK	37	6	0	0	0	0	0	0	0	0	0	0	0	
1350	Off of Lafayette Rd.	NA	UNK	82	6	0	0	0	0	0	0	0	0	0	0	0	
1351	Off of Lafayette Rd.	NA	UNK	122	4	0	0	0	0	0	0	0	0	0	0	0	
1352	Off of Lafayette Rd.	NA	UNK	22	4	0	0	0	0	0	0	0	0	0	0	0	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Pipe Priority	Page 15 of 30	Comments
1353	Off of Lafayette Rd.	NA	UNK	29	4	0	0	0	0	0	0	0	0	0	0	0		
1354	Off of Lafayette Rd.	NA	UNK	63	4	0	0	0	0	0	0	0	0	0	0	0		
1355	Off of Lafayette Rd.	NA	UNK	37	6	0	0	0	0	0	0	0	0	0	0	0		
1356	Ashworth Ave.	2007	DI	254	16	0	0	0	0	0	0	0	0	3	3		3	
1359	Lafayette Rd.	1950	CI	1,196	12	0	0	0	3	0	0	0	0	0	3		3	
1361	Anns Ln: Lafayette Rd - Tuck Rd	1950	AC	300	6	0	0	0	1	0	0	0	2	0	3		3	
1374	North Rd.	1980	DI	997	12	0	0	0	0	0	0	0	3	0	3		3	
1375	North Rd.	1980	DI	101	12	0	0	0	0	0	0	0	3	0	3		3	
1377	North Rd.	1980	DI	237	12	0	0	0	0	0	0	0	3	0	3		3	
1378	North Rd.	1980	DI	121	12	0	0	0	0	0	0	0	3	0	3		3	
1381	Well No. 17, 18 & 19	1998	DI	334	12	0	0	0	0	3	0	0	0	0	3		3	
1409	Lafayette Rd.	1950	CI	451	12	0	0	0	3	0	0	0	0	0	3		3	
1417	Ashworth Ave	2007	PVC	65	12	0	0	0	0	0	0	0	0	3	3		3	
1419	New Pipe	0	DI	9	6	0	0	3	0	0	0	0	0	0	3		3	
1420	Morningside Dr	1954	AC	250	6	2	0	0	1	0	0	0	0	0	3		3	
1422	Old Locke Rd: Causeway Rd - North Hampton line	1935	CICL	322	6	0	0	1	2	0	0	0	0	0	3		3	
1436	Atlantic Ave: GV0724 to GV0725	2010	CI	20	8	0	0	0	3	0	0	0	0	0	3		3	
1437	Atlantic Ave: GV1166 - GV1167	2011	PWDI	229	16	0	0	0	0	0	0	3	0	0	3		3	
1462	Highland Ave.	2007	DI	299	16	0	0	0	0	0	0	0	0	3	3		3	
1463	Pine Rd: High St - Victor Rd	1954	CI	265	6	0	0	0	3	0	0	0	0	0	3		3	
1464	Victor Rd: Birch Rd - Pine Rd	1954	CI	241	6	0	0	0	3	0	0	0	0	0	3		3	
1465	Birch Rd: GV1092 - Victor Rd	1960	CI	494	6	0	0	0	3	0	0	0	0	0	3		3	
1466	Birch Rd: GV1092 - end	1960	CI	180	6	0	0	0	3	0	0	0	0	0	3		3	
1467	Hutchinson Dr: GV1139 - Oak Rd	1960	CI	400	6	0	0	0	3	0	0	0	0	0	3		3	
1468	Oak Rd: High St - Hutchinson Dr	1960	CI	189	6	0	0	0	3	0	0	0	0	0	3		3	
1472	High St: GV0618 - Mill Pond Ln	1958	AC	284	10	1	0	0	1	0	0	0	1	0	3		3	
1486	Bayberry Ln	1961	CI	232	6	0	0	0	3	0	0	0	0	0	3		3	
1501	High St crossover	1970	DI	57	4	0	0	0	0	0	0	0	0	0	0		0	
1511	Atlantic Ave.	2012	PWDI	753	16	0	0	0	0	0	0	3	0	0	3		3	
1513	Atlantic Ave - GV1104 to GV1105	1950	CI	174	8	0	0	0	3	0	0	0	0	0	3		3	
1516	Victor Rd: Birch Rd - Pine Rd	1954	CI	246	6	0	0	0	3	0	0	0	0	0	3		3	
1518	Ocean Blvd.	2012	DI	21	8	0	0	0	0	0	0	0	0	3	3		3	
1522	Ashworth Ave.	2007	DI	114	16	0	0	0	0	0	0	0	0	3	3		3	
20	Langdale Dr.	1971	CICL	1,730	8	0	0	0	2	0	0	0	0	0	2		2	
21	Langdale Dr.	1975	CICL	643	8	0	0	0	2	0	0	0	0	0	2		2	
22	Langdale Dr.	1973	CICL	326	8	0	0	0	2	0	0	0	0	0	2		2	
23	Pine Knoll	1975	CICL	478	8	0	0	0	2	0	0	0	0	0	2		2	
24	Sweetbriar Ln.	1973	CICL	701	8	0	0	0	2	0	0	0	0	0	2		2	
25	Langdale Dr.	1973	CICL	416	8	0	0	0	2	0	0	0	0	0	2		2	
26	Sweetbriar Ln.	1973	CICL	136	8	0	0	0	2	0	0	0	0	0	2		2	
27	Sweetbriar Ln.	1973	CICL	706	8	0	0	0	2	0	0	0	0	0	2		2	
28	Oakdale Ave.	1968	CICL	323	8	0	0	0	2	0	0	0	0	0	2		2	
33	Longwood Dr.	1963	CICL	356	8	0	0	0	2	0	0	0	0	0	2		2	
34	Burgundy Dr.	1965	CICL	453	6	0	0	0	2	0	0	0	0	0	2		2	
35	Burgundy Dr./Heather Ln.	1981	CICL	1,117	8	0	0	0	2	0	0	0	0	0	2		2	
38	Longwood Dr.	1963	CICL	676	8	0	0	0	2	0	0	0	0	0	2		2	
39	Longwood Dr.	1963	CICL	337	8	0	0	0	2	0	0	0	0	0	2		2	
45	Carolan Ave.	1962	CICL	980	8	0	0	0	2	0	0	0	0	0	2		2	
47	Carolan Ave.	1960	CICL	891	8	0	0	0	2	0	0	0	0	0	2		2	
50	Colonial Cir.	1966	CICL	800	8	0	0	0	2	0	0	0	0	0	2		2	
51	Seavey St.	1966	CICL	593	8	0	0	0	2	0	0	0	0	0	2		2	
52	Longwood Dr.	1960	CICL	150	8	0	0	0	2	0	0	0	0	0	2		2	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Pipe Priority	Page 16 of 30	Comments
53	Carolan Dr.	1959	CICL	188	8	0	0	0	2	0	0	0	0	0	2		2	
55	Thayer Rd.	1961	CICL	884	6	0	0	0	2	0	0	0	0	0	2		2	
61	Merrill Rd.	1985	DI	1,103	12	2	0	0	0	0	0	0	0	0	2		2	
93	High St	1982	DI	533	12	0	0	0	0	0	0	0	2	0	2		2	
94	Lafayette Rd.	1960	CICL	902	8	0	0	0	2	0	0	0	0	0	2		2	
105	Lafayette Rd.	1965	CICL	696	12	0	0	0	2	0	0	0	0	0	2		2	
107	Park Ave.	1958	AC	406	8	0	0	0	1	1	0	0	0	0	2		2	
108	Park Ave.	1958	AC	1,013	8	0	0	0	1	1	0	0	0	0	2		2	
119	Dearborn Ave.	1967	CICL	23	6	0	0	0	2	0	0	0	0	0	2		2	
121	High St.	1982	DI	255	12	0	0	0	0	0	0	0	2	0	2		2	
128	High St.	1982	DI	648	12	0	0	0	0	0	0	0	2	0	2		2	
136	Marston Way	1975	AC	343	6	0	0	0	1	1	0	0	0	0	2		2	
138	High St.	1982	DI	855	12	0	0	0	0	0	0	0	2	0	2		2	
144	Thomsen Rd.	1956	AC	1,429	6	0	0	0	1	1	0	0	0	0	2		2	
146	Hobbs Rd.	1956	AC	606	6	0	0	0	1	1	0	0	0	0	2		2	
147	Rice Terr.	1967	CICL	256	6	0	0	0	2	0	0	0	0	0	2		2	
148	Newman St.	1967	CICL	215	6	0	0	0	2	0	0	0	0	0	2		2	
149	Rice Terr.	1967	CICL	194	6	0	0	0	2	0	0	0	0	0	2		2	
151	Lafayette Rd.	1960	CICL	568	8	0	0	0	2	0	0	0	0	0	2		2	
152	Scott Rd.	1960	CICL	436	8	0	0	0	2	0	0	0	0	0	2		2	
153	Scott Rd.	1960	CICL	215	6	0	0	0	2	0	0	0	0	0	2		2	
154	Lafayette Rd.	1960	CICL	276	8	0	0	0	2	0	0	0	0	0	2		2	
155	Kershaw Ave.	1955	CICL	564	6	0	0	0	2	0	0	0	0	0	2		2	
157	Moore Ave.	1967	CICL	152	6	0	0	0	2	0	0	0	0	0	2		2	
158	Moore Ave.	1967	CICL	160	6	0	0	0	2	0	0	0	0	0	2		2	
159	Dearborn Ave.	1967	CICL	443	6	0	0	0	2	0	0	0	0	0	2		2	
161	Lafayette Rd.	1960	CICL	433	8	0	0	0	2	0	0	0	0	0	2		2	
162	Tuck Rd.	1967	CICL	414	6	0	0	0	2	0	0	0	0	0	2		2	
165	Lafayette Rd.	1995	DI	601	12	0	0	0	0	2	0	0	0	0	2		2	
171	Lafayette Rd.	1995	DI	357	12	0	0	0	0	2	0	0	0	0	2		2	
173	Lafayette Rd.	1995	DI	564	12	0	0	0	0	2	0	0	0	0	2		2	
179	Lafayette Rd.	1985	DI	458	12	0	0	0	0	2	0	0	0	0	2		2	
180	Lafayette Rd.	1995	DI	463	8	0	0	0	0	2	0	0	0	0	2		2	
183	Reddington Landing/Lamson Ln.	1995	DI	179	8	0	0	0	0	2	0	0	0	0	2		2	
186	Reddington Landing	1995	DI	744	8	0	0	0	0	2	0	0	0	0	2		2	
194	Mill Rd.	1958	CICL	12	8	0	0	0	2	0	0	0	0	0	2		2	
209	Mace Rd.	1958	CICL	15	8	0	0	0	2	0	0	0	0	0	2		2	
218	Milbern Ave	1962	CICL	1,476	8	0	0	0	2	0	0	0	0	0	2		2	
221	Barbour Rd.	1990	CICL	244	12	0	0	0	2	0	0	0	0	0	2		2	
232	Norton Rd.	1950	CICL	594	2	0	0	0	2	0	0	0	0	0	2		2	
244	Tobey St.	1955	AC	709	6	1	0	0	1	0	0	0	0	0	2		2	
253	Barbour Rd.	1990	CICL	740	12	0	0	0	2	0	0	0	0	0	2		2	
290	Lancaster St	1974	CICL	124	6	0	0	0	2	0	0	0	0	0	2		2	
291	Briar Rd: Lancaster St - Moccasin Ln	1969	CICL	173	6	0	0	0	2	0	0	0	0	0	2		2	
292	Briar Rd: Moccasin Ln - N Shore Rd	1969	CICL	636	8	0	0	0	2	0	0	0	0	0	2		2	
293	Moccasin Ln.	1967	CICL	397	8	0	0	0	2	0	0	0	0	0	2		2	
294	Huckleberry Ln - Keene Ln crossover	1977	CICL	253	8	0	0	0	2	0	0	0	0	0	2		2	
295	Keene Ln: Wild Rose Ln - Huckleberry Ln crossover	1967	CICL	249	8	0	0	0	2	0	0	0	0	0	2		2	
327	High St: GV0617 - GV0618	1958	AC	872	10	0	0	0	1	0	0	0	1	0	2		2	
329	Mill Pond Ln: north of Little Fox Rd	1969	CICL	290	6	0	0	0	2	0	0	0	0	0	2		2	
330	Little Fox Rd	1969	CICL	216	6	0	0	0	2	0	0	0	0	0	2		2	
331	Glen Rd: south of Little Fox Rd	1969	CICL	246	6	0	0	0	2	0	0	0	0	0	2		2	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Pipe Priority	Page 17 of 30	Comments
332	Glen Rd. north of Little Fox Rd	1969	CICL	299	6	0	0	0	2	0	0	0	0	0	2		2	
334	Quinlan Ln	1950	CICL	521	6	0	0	0	2	0	0	0	0	0	2		2	
336	High St. Oak Rd - Pine Rd	1958	AC	173	10	0	0	0	1	0	0	0	1	0	2		2	
339	High St. GV0585 - Dunvegan Woods	1958	AC	1,124	10	0	0	0	1	0	0	0	1	0	2		2	
353	High St. Alexander Ave - Dunvegan Woods	1958	AC	730	10	0	0	0	1	0	0	0	1	0	2		2	
357	High St. Alexander Ave - Hedman Ave	1958	AC	253	10	0	0	0	1	0	0	0	1	0	2		2	
358	High St. Hedman Ave - Taylor St	1958	AC	604	10	0	0	0	1	0	0	0	1	0	2		2	
359	High St. Elliot St - Taylor St	1958	AC	389	10	0	0	0	1	0	0	0	1	0	2		2	
362	Taylor St.	1965	CICL	375	8	0	0	0	2	0	0	0	0	0	2		2	
363	Ward Ln.	1965	CICL	260	8	0	0	0	2	0	0	0	0	0	2		2	
364	Taylor St.	1965	CICL	642	8	0	0	0	2	0	0	0	0	0	2		2	
383	Park Ave.	1958	AC	475	8	0	0	0	1	1	0	0	0	0	2		2	
388	Leavitt Rd.	1972	CICL	297	8	0	0	0	2	0	0	0	0	0	2		2	
389	Leavitt Rd.	1972	CICL	34	8	0	0	0	2	0	0	0	0	0	2		2	
391	Landing Rd.	1983	DI	73	12	0	0	0	0	0	0	0	2	0	2		2	
393	Winnicunnet Rd.	1971	CICL	56	12	0	0	0	2	0	0	0	0	0	2		2	
409	Locke Rd.	1940	AC	23	12	0	0	1	1	0	0	0	0	0	2		2	
420	Sanborn Rd.	1960	CICL	267	8	0	0	0	2	0	0	0	0	0	2		2	
425	Sanborn Rd.	1960	CICL	1,475	8	0	0	0	2	0	0	0	0	0	2		2	
427	Jenness Rd.	1963	CICL	588	8	0	0	0	2	0	0	0	0	0	2		2	
443	Landing Rd: GV0183 - Malek Cir	1975	DI	176	12	0	0	0	0	0	0	0	2	0	2		2	
494	Winnicunnet Rd.	1955	CICL	16	8	0	0	0	2	0	0	0	0	0	2		2	
587	Battcock Ave.	1956	CICL	16	8	0	0	0	2	0	0	0	0	0	2		2	
591	Glade Path	1972	CICL	19	6	0	0	0	2	0	0	0	0	0	2		2	
592	Francine St.	1972	CICL	227	6	0	0	0	2	0	0	0	0	0	2		2	
593	Glade Path	1972	CICL	164	6	0	0	0	2	0	0	0	0	0	2		2	
594	Francis St.	1972	CICL	196	6	0	0	0	2	0	0	0	0	0	2		2	
595	Glade Path	1972	CICL	157	6	0	0	0	2	0	0	0	0	0	2		2	
596	Patricia St.	1972	CICL	202	6	0	0	0	2	0	0	0	0	0	2		2	
597	Glade Path	1972	CICL	42	6	0	0	0	2	0	0	0	0	0	2		2	
690	Ocean Blvd./Ashworth Ave.	1973	CICL	25	8	0	0	0	2	0	0	0	0	0	2		2	
742	Stevens Rd.	1967	CICL	664	8	0	0	0	2	0	0	0	0	0	2		2	
745	South Rd.	1955	CICL	1,186	8	0	0	0	2	0	0	0	0	0	2		2	
772	Old Locke Rd: GV0823 - Central Rd	1965	CICL	733	6	0	0	0	2	0	0	0	0	0	2		2	
778	McLaughlin Dr	1968	CICL	701	8	0	0	0	2	0	0	0	0	0	2		2	
779	Foster Ln.	1968	CICL	489	8	0	0	0	2	0	0	0	0	0	2		2	
781	Pine St.	1969	CICL	1,001	8	0	0	0	2	0	0	0	0	0	2		2	
784	Lafayette Ter.	1983	DI	1,398	8	0	0	0	0	0	0	0	2	0	2		2	
788	Walnut Ave.	1962	CICL	1,009	8	0	0	0	2	0	0	0	0	0	2		2	
789	Juniper Rd.	1964	CICL	608	8	0	0	0	2	0	0	0	0	0	2		2	
792	Glendale Rd.	1979	DI	410	8	0	0	0	0	0	0	0	2	0	2		2	
793	Kimberly/Hampshire	1967	CICL	2,055	8	0	0	0	2	0	0	0	0	0	2		2	
801	Brown Ct	1962	CICL	122	8	0	0	0	2	0	0	0	0	0	2		2	
816	Atlantic Ave.	1950	AC	2,216	8	0	0	0	1	1	0	0	0	0	2		2	
819	Atlantic Ave.	1950	AC	481	8	0	0	0	1	1	0	0	0	0	2		2	
827	Lafayette Rd	1995	DI	601	8	0	0	0	0	2	0	0	0	0	2		2	
876	Woodridge Rd: Juniper Rd - Juniper Rd	1965	CICL	862	8	0	0	0	2	0	0	0	0	0	2		2	
877	Juniper Rd.	1964	CICL	576	6	0	0	0	2	0	0	0	0	0	2		2	
878	Woodridge Rd: Birch Rd - Juniper Rd	1965	CICL	337	8	0	0	0	2	0	0	0	0	0	2		2	
881	Post Rd.	1977	CICL	73	12	0	0	0	2	0	0	0	0	0	2		2	
882	Post Rd	1977	CICL	29	12	0	0	0	2	0	0	0	0	0	2		2	
883	Post Rd	1977	CICL	39	12	0	0	0	2	0	0	0	0	0	2		2	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Pipe Condition	Page 18 of 30	Comments
884	Post Rd.	1977	CICL	133	12	0	0	0	2	0	0	0	0	0	2		2	
886	Post Rd.	1977	CICL	340	12	0	0	0	2	0	0	0	0	0	2		2	
888	Winnicut Rd.	1968	CICL	1,479	8	0	0	0	2	0	0	0	0	0	2		2	
896	Winnicut Rd.	1968	CICL	591	8	0	0	0	2	0	0	0	0	0	2		2	
912	Post Rd.	1964	CICL	1,318	12	0	0	0	2	0	0	0	0	0	2		2	
913	Post Rd.	1958	CICL	1,244	12	0	0	0	2	0	0	0	0	0	2		2	
918	Post Rd.	1955	CICL	181	8	0	0	0	2	0	0	0	0	0	2		2	
919	Post Rd.	1955	CICL	2,010	8	0	0	0	2	0	0	0	0	0	2		2	
920	Post Rd.	1955	CICL	1,203	8	0	0	0	2	0	0	0	0	0	2		2	
921	Post Rd.	1955	CICL	532	8	0	0	0	2	0	0	0	0	0	2		2	
923	Hillside Rd.	1967	CICL	823	6	0	0	0	2	0	0	0	0	0	2		2	
924	Stevens Rd.	1967	CICL	955	6	0	0	0	2	0	0	0	0	0	2		2	
959	Perkins Rd.	1961	CICL	1,235	6	0	0	0	2	0	0	0	0	0	2		2	
969	Central Rd.	1937	CU	331	1	0	0	1	0	0	0	0	1	0	2		2	
976	Oak Ave.	1972	CICL	607	8	0	0	0	2	0	0	0	0	0	2		2	
988	Browns Ct.	1962	CICL	164	8	0	0	0	2	0	0	0	0	0	2		2	
989	Browns Ct.	1962	CICL	63	8	0	0	0	2	0	0	0	0	0	2		2	
990	Off of Myrica Ave.	1965	CICL	119	6	0	0	0	2	0	0	0	0	0	2		2	
991	Off of Myrica Ave.	1965	CICL	137	6	0	0	0	2	0	0	0	0	0	2		2	
1009	Grandview Terr.	1957	CICL	481	6	0	0	0	2	0	0	0	0	0	2		2	
1018	Atlantic Ave.	1960	CICL	187	8	0	0	0	2	0	0	0	0	0	2		2	
1039	Perkins Rd.	1961	CICL	129	6	0	0	0	2	0	0	0	0	0	2		2	
1043	Maple Ave.	1970	DI	267	8	2	0	0	0	0	0	0	0	0	2		2	
1046	McLaughlin Dr	1968	CICL	586	8	0	0	0	2	0	0	0	0	0	2		2	
1067	Juniper Rd.	1964	CICL	207	8	0	0	0	2	0	0	0	0	0	2		2	
1082	Lafayette Rd	1995	DI	525	8	0	0	0	0	2	0	0	0	0	2		2	
1095	Barbour Rd.	1990	CICL	1,475	12	0	0	0	2	0	0	0	0	0	2		2	
1113	High St. Elliot St - Little River Rd	1958	AC	167	10	0	0	0	1	0	0	0	1	0	2		2	
1123	Hemlock St.	1973	CICL	502	6	0	0	0	2	0	0	0	0	0	2		2	
1143	Mill Rd.	1958	CICL	12	8	0	0	0	2	0	0	0	0	0	2		2	
1144	Mill Rd.	1958	CICL	7	8	0	0	0	2	0	0	0	0	0	2		2	
1150	Langdale Dr.	1973	CICL	47	8	0	0	0	2	0	0	0	0	0	2		2	
1167	Dustin Ave.	1966	CICL	238	8	0	0	0	2	0	0	0	0	0	2		2	
1168	South Rd	1958	CICL	1,932	6	0	0	0	2	0	0	0	0	0	2		2	
1178	Cedar Rd.	1958	AC	1,114	6	1	0	0	1	0	0	0	0	0	2		2	
1195	South Rd	1958	CICL	396	6	0	0	0	2	0	0	0	0	0	2		2	
1196	South Rd.	1958	CICL	581	6	0	0	0	2	0	0	0	0	0	2		2	
1197	South Rd	1958	CICL	1,465	8	0	0	0	2	0	0	0	0	0	2		2	
1198	South Rd	1958	CICL	458	8	0	0	0	2	0	0	0	0	0	2		2	
1206	Reddington Landing	1995	DI	516	8	0	0	0	0	2	0	0	0	0	2		2	
1207	Lafayette Rd/Reddington Landing	1995	DI	215	8	0	0	0	0	2	0	0	0	0	2		2	
1240	Ocean Blvd.	1969	CICL	6	8	0	0	0	2	0	0	0	0	0	2		2	
1241	Ocean Blvd./Ashworth Ave.	1973	CICL	43	8	0	0	0	2	0	0	0	0	0	2		2	
1267	Mill Rd.	1958	CICL	11	8	0	0	0	2	0	0	0	0	0	2		2	
1273	Crenshaw Well No. 10	1963	CICL	24	12	0	0	0	2	0	0	0	0	0	2		2	
1285	Mill Road Tank	1958	CICL	19	6	0	0	0	2	0	0	0	0	0	2		2	
1289	Well No. 7	1950	CICL	42	12	0	0	0	2	0	0	0	0	0	2		2	
1329	Post Rd.	1964	CICL	1,237	12	0	0	0	2	0	0	0	0	0	2		2	
1334	South Rd	1958	CICL	587	8	0	0	0	2	0	0	0	0	0	2		2	
1337	South Rd	1958	CICL	399	8	0	0	0	2	0	0	0	0	0	2		2	
1338	Fairway Dr.	1973	CICL	18	6	0	0	0	2	0	0	0	0	0	2		2	
1340	Post Rd.	1955	CICL	91	8	0	0	0	2	0	0	0	0	0	2		2	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Page 19 of 30	Comments
1347	Lafayette Rd	1995	DI	642	12	0	0	0	0	2	0	0	0	0	2	2	
1370	Maple Rd.	1965	CICL	193	8	0	0	0	2	0	0	0	0	0	2	2	
1371	Maple Rd.	1965	CICL	343	8	0	0	0	2	0	0	0	0	0	2	2	
1404	Dearborn Ave	1967	CICL	2,044	6	0	0	0	2	0	0	0	0	0	2	2	
1405	Perkins Rd	1961	CICL	602	6	0	0	0	2	0	0	0	0	0	2	2	
1423	Causeway Rd: GV0823 - Old Lookie Rd	1965	CICL	35	6	0	0	0	2	0	0	0	0	0	2	2	
1452	Landing Rd: GV0184 - blowoff at end	2011	DI	333	8	0	0	0	0	0	0	0	2	0	2	2	
1471	High St: GV0617 - Kings Hwy	1958	AC	351	10	0	0	0	1	0	0	0	1	0	2	2	
1473	High St: GV0620 - Mill Pond Ln	1958	AC	60	10	0	0	0	1	0	0	0	1	0	2	2	
1474	High St: GV0621 - Oak Rd	1958	AC	234	10	0	0	0	1	0	0	0	1	0	2	2	
1475	High St: GV0585 - Pine Rd	1958	AC	311	10	0	0	0	1	0	0	0	1	0	2	2	
1484	Mill Pond Ln: GV0619 - High St	1969	CICL	87	8	0	0	0	2	0	0	0	0	0	2	2	
1485	Keene Ln: Moccasin Ln - Huckleberry Ln crossover	1967	CICL	330	8	0	0	0	2	0	0	0	0	0	2	2	
56	Carolan Dr.	1959	AC	140	8	0	0	0	1	0	0	0	0	0	1	1	
57	Elm Dr.	1959	AC	610	8	0	0	0	1	0	0	0	0	0	1	1	
58	Carolan Dr.	1959	AC	239	8	0	0	0	1	0	0	0	0	0	1	1	
59	Bourn Ave	1956	AC	1,027	8	0	0	0	1	0	0	0	0	0	1	1	
60	Josephine Dr.	1956	AC	524	8	0	0	0	1	0	0	0	0	0	1	1	
61	Josephine Dr.	1956	AC	96	8	0	0	0	1	0	0	0	0	0	1	1	
62	Josephine Dr.	1956	AC	501	6	0	0	0	1	0	0	0	0	0	1	1	
63	Godfrey Ave.	1956	AC	982	6	0	0	0	1	0	0	0	0	0	1	1	
65	Wigwam Cir	1956	AC	338	6	0	0	0	1	0	0	0	0	0	1	1	
66	Josephine Dr: Wigwam Cir./Exeter-Hampton Rd.	1956	AC	127	8	0	0	0	1	0	0	0	0	0	1	1	
67	Josephine Dr: Wigwam Cir./Exeter-Hampton Rd.	1956	AC	17	8	0	0	0	1	0	0	0	0	0	1	1	
68	Josephine Dr: Wigwam Cir./Exeter-Hampton Rd.	1956	AC	43	8	0	0	0	1	0	0	0	0	0	1	1	
75	Carolan Dr.	1959	AC	247	8	0	0	0	1	0	0	0	0	0	1	1	
103	Drakeside Rd.	1990	DI	3,262	12	0	0	0	0	1	0	0	0	0	1	1	
142	Windmill Ln.	1982	DI	1,507	12	0	0	0	0	1	0	0	0	0	1	1	
156	Hackett Ln.	1961	AC	179	8	0	0	0	1	0	0	0	0	0	1	1	
164	Tuck Rd.	1967	AC	365	6	0	0	0	1	0	0	0	0	0	1	1	
181	Lafayette Rd.	1995	AC	25	6	0	0	0	1	0	0	0	0	0	1	1	
191	Palmer St	1956	AC	316	6	0	0	0	1	0	0	0	0	0	1	1	
192	Sicard St	1956	AC	324	6	0	0	0	1	0	0	0	0	0	1	1	
204	Mill Rd.	1958	AC	371	12	0	0	0	1	0	0	0	0	0	1	1	
205	Mill Rd.	1958	AC	27	12	0	0	0	1	0	0	0	0	0	1	1	
206	Mill Rd.	1958	AC	446	12	0	0	0	1	0	0	0	0	0	1	1	
207	Mill Rd	1958	AC	898	12	0	0	0	1	0	0	0	0	0	1	1	
208	Mill Rd	1958	AC	984	12	0	0	0	1	0	0	0	0	0	1	1	
211	Philbrook Ter	1955	AC	608	6	0	0	0	1	0	0	0	0	0	1	1	
213	Homestead Cir	1956	AC	713	6	0	0	0	1	0	0	0	0	0	1	1	
214	Mill Rd.	1958	AC	48	12	0	0	0	1	0	0	0	0	0	1	1	
216	Blake Ln	1952	AC	779	6	0	0	0	1	0	0	0	0	0	1	1	
219	Mill Rd.	1958	AC	77	12	0	0	0	1	0	0	0	0	0	1	1	
227	Ridgeview Ter	1956	AC	242	6	0	0	0	1	0	0	0	0	0	1	1	
233	Mace Rd.	1958	AC	142	8	0	0	0	1	0	0	0	0	0	1	1	
234	Mace Rd.	1958	AC	195	8	0	0	0	1	0	0	0	0	0	1	1	
235	Mace Rd.	1958	AC	57	8	0	0	0	1	0	0	0	0	0	1	1	
237	Curtis St.	1958	AC	231	6	0	0	0	1	0	0	0	0	0	1	1	
238	Beatrice Ln	1958	AC	239	6	0	0	0	1	0	0	0	0	0	1	1	
240	Yeaton St.	1958	AC	232	6	0	0	0	1	0	0	0	0	0	1	1	
245	Gray Ave.	1955	AC	618	6	0	0	0	1	0	0	0	0	0	1	1	
246	Tobey St.	1955	AC	241	6	0	0	0	1	0	0	0	0	0	1	1	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PIPE PRIORITY	Page 20 of 30	Comments
247	Mace Rd.	1958	AC	372	8	0	0	0	1	0	0	0	0	0	1		1	
248	Mace Rd.	1958	AC	879	8	0	0	0	1	0	0	0	0	0	1		1	
303	Seaview Ave	1985	DI	1,310	8	1	0	0	0	0	0	0	0	0	1		1	
369	Morningside Dr.	1954	AC	301	6	0	0	0	1	0	0	0	0	0	1		1	
370	Holly Ln.	1954	AC	420	8	0	0	0	1	0	0	0	0	0	1		1	
371	Holly Ln.	1954	AC	433	6	0	0	0	1	0	0	0	0	0	1		1	
373	Tucker Ln.	1954	AC	436	6	0	0	0	1	0	0	0	0	0	1		1	
374	Tucker Ln.	1954	AC	401	6	0	0	0	1	0	0	0	0	0	1		1	
375	Morningside Dr.	1954	AC	322	6	0	0	0	1	0	0	0	0	0	1		1	
378	Leavitt Rd.	1952	AC	1,297	6	0	0	0	1	0	0	0	0	0	1		1	
380	Winnicunnet Rd.	1983	DI	1,414	12	0	0	0	0	0	0	0	1	0	1		1	
397	Leavitt Rd.	1954	AC	1,455	6	0	0	0	1	0	0	0	0	0	1		1	
404	Locke Rd.	1953	AC	256	6	0	0	0	1	0	0	0	0	0	1		1	
405	Locke Rd.	1953	AC	373	6	0	0	0	1	0	0	0	0	0	1		1	
406	Locke Rd.	1953	AC	716	6	0	0	0	1	0	0	0	0	0	1		1	
407	Locke Rd.	1953	AC	415	6	0	0	0	1	0	0	0	0	0	1		1	
410	Winnicunnet Rd.	1955	AC	1,012	12	0	0	0	1	0	0	0	0	0	1		1	
415	Winnicunnet Rd.	1955	AC	203	12	0	0	0	1	0	0	0	0	0	1		1	
417	Carlsen Rd.	1956	AC	366	6	0	0	0	1	0	0	0	0	0	1		1	
418	Carlsen Rd.	1956	AC	895	6	0	0	0	1	0	0	0	0	0	1		1	
419	Carlsen Rd.	1956	AC	180	6	0	0	0	1	0	0	0	0	0	1		1	
424	Winnicunnet Rd.	1955	AC	673	12	0	0	0	1	0	0	0	0	0	1		1	
426	Bradstreet Rd.	1970	DI	517	6	0	0	0	0	0	0	0	1	0	1		1	
429	Elliot St.	1965	DI	343	8	0	0	0	0	0	0	0	1	0	1		1	
437	Janvin St.	1978	DI	681	8	0	0	0	0	0	0	0	1	0	1		1	
448	Richard	1956	AC	1,009	6	0	0	0	1	0	0	0	0	0	1		1	
450	Elaine	1956	AC	1,096	6	0	0	0	1	0	0	0	0	0	1		1	
453	Winnicunnet Rd.	1955	AC	988	12	0	0	0	1	0	0	0	0	0	1		1	
455	New Pipe	1955	AC	2,200	12	0	0	0	1	0	0	0	0	0	1		1	
471	Bonair Ave.	1955	AC	310	6	0	0	0	1	0	0	0	0	0	1		1	
474	Off of Walnut Ave.	1960	AC	54	6	0	0	0	1	0	0	0	0	0	1		1	
493	Winnicunnet Rd.	1955	AC	1,038	12	0	0	0	1	0	0	0	0	0	1		1	
520	Winnicunnet Rd.	1955	AC	108	12	0	0	0	1	0	0	0	0	0	1		1	
590	Glade Path	1972	CICL	1,466	8	0	0	0	2	0	0	0	0	-1	1		1	
665	M St.	1952	AC	607	8	0	0	0	1	0	0	0	0	0	1		1	
754	Mill Rd.	1953	AC	1,162	8	0	0	0	1	0	0	0	0	0	1		1	
770	Ocean Blvd: GV0818 - Rye line	1958	CI	1,034	8	0	0	0	3	0	0	0	-5	3	1		1	
786	New Rd.	1958	AC	1,409	8	0	0	0	1	0	0	0	0	0	1		1	
847	Atlantic Ave.	1956	AC	2,900	8	0	0	0	1	0	0	0	0	0	1		1	
848	Atlantic Ave.	1950	AC	39	8	0	0	0	1	0	0	0	0	0	1		1	
849	Atlantic Ave.	1950	AC	852	8	0	0	0	1	0	0	0	0	0	1		1	
852	Hobbs Rd.	1953	AC	1,185	8	0	0	0	1	0	0	0	0	0	1		1	
853	Birch Rd./Elm Rd.	1957	AC	2,081	8	0	0	0	1	0	0	0	0	0	1		1	
922	Post Rd.	1957	AC	270	8	0	0	0	1	0	0	0	0	0	1		1	
925	Post Rd.	1957	AC	301	8	0	0	0	1	0	0	0	0	0	1		1	
926	Post Rd.	1957	AC	293	8	0	0	0	1	0	0	0	0	0	1		1	
930	Post Rd.	1957	AC	2,277	8	0	0	0	1	0	0	0	0	0	1		1	
956	Ocean Blvd.	1958	CI	407	8	0	0	0	3	0	0	0	-5	3	1		1	
957	Ocean Blvd.	1958	CI	89	8	0	0	0	3	0	0	0	-5	3	1		1	
958	Richard Rd.	1952	AC	1,149	6	0	0	0	1	0	0	0	0	0	1		1	
966	Hunterville Ave.	1958	AC	655	4	0	0	0	1	0	0	0	0	0	1		1	
967	Hunterville Ave.	1958	AC	611	6	0	0	0	1	0	0	0	0	0	1		1	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Page 21 of 30	Comments
978	Gray Ct.	1958	AC	691	6	0	0	0	1	0	0	0	0	0	1	1	
982	Ocean Blvd.	1958	CI	186	8	0	0	0	3	0	0	0	-5	3	1	1	
983	Ocean Blvd.	1958	CI	299	8	0	0	0	3	0	0	0	-5	3	1	1	
984	Ocean Blvd.	1958	CI	330	8	0	0	0	3	0	0	0	-5	3	1	1	
985	Ocean Blvd.	1958	CI	153	8	0	0	0	3	0	0	0	-5	3	1	1	
986	Ocean Blvd.	1958	CI	228	8	0	0	0	3	0	0	0	-5	3	1	1	
987	Ocean Blvd.	1958	CI	1,681	8	0	0	0	3	0	0	0	-5	3	1	1	
1011	Post Rd.	1957	AC	425	8	0	0	0	1	0	0	0	0	0	1	1	
1012	Post Rd.	1957	AC	395	8	0	0	0	1	0	0	0	0	0	1	1	
1013	Post Rd.	1957	AC	775	8	0	0	0	1	0	0	0	0	0	1	1	
1014	Hobbs Rd.	1953	AC	1,792	8	0	0	0	1	0	0	0	0	0	1	1	
1015	Centennial Hall	1953	AC	659	8	0	0	0	1	0	0	0	0	0	1	1	
1044	Maple Ave.	1988	DI	221	8	1	0	0	0	0	0	0	0	0	1	1	
1047	Ocean Blvd.	1958	CI	302	8	0	0	0	3	0	0	0	-5	3	1	1	
1048	Ocean Blvd.	1958	CI	537	8	0	0	0	3	0	0	0	-5	3	1	1	
1050	Ocean Blvd.	1958	CI	469	8	0	0	0	3	0	0	0	-5	3	1	1	
1068	Post Rd.	1957	AC	379	8	0	0	0	1	0	0	0	0	0	1	1	
1099	Tower Dr.	1956	AC	542	6	0	0	0	1	0	0	0	0	0	1	1	
1108	Homestead Cir.	1956	AC	164	6	0	0	0	1	0	0	0	0	0	1	1	
1109	Homestead Cir.	1956	AC	781	6	0	0	0	1	0	0	0	0	0	1	1	
1122	Walnut Ave	1960	AC	651	6	0	0	0	1	0	0	0	0	0	1	1	
1190	Lawrence Ln.	1958	AC	469	6	0	0	0	1	0	0	0	0	0	1	1	
1283	Mill Rd.	1958	AC	1,198	12	0	0	0	1	0	0	0	0	0	1	1	
1292	New Rd.	1958	AC	523	8	0	0	0	1	0	0	0	0	0	1	1	
1299	Winnicunnet Rd.	1983	DI	531	12	0	0	0	0	0	0	0	1	0	1	1	
1320	Atlantic Ave.	1950	AC	69	8	0	0	0	1	0	0	0	0	0	1	1	
1330	Mill Rd	1958	AC	806	12	0	0	0	1	0	0	0	0	0	1	1	
1342	Mill Rd.	1950	AC	990	8	0	0	0	1	0	0	0	0	0	1	1	
1367	Post Rd.	1957	AC	530	8	0	0	0	1	0	0	0	0	0	1	1	
1453	Randall St. GV0456 - GV0457	1965	CICL	34	6	0	0	0	2	0	0	0	1	0	3	3	
1455	Eliot St. GV1161 - GV1162	1965	CICL	10	6	0	0	0	2	0	0	0	1	0	3	3	
1456	Randall St. GV1163 - Eliot St	1965	CICL	5	6	0	0	0	2	0	0	0	1	0	3	3	
1497	Ocean Blvd.	1958	CI	1,903	8	0	0	0	3	0	0	0	-5	3	1	1	
1498	Ocean Blvd. GV0817 - GV0818	1958	CI	165	8	0	0	0	3	0	0	0	-5	3	1	1	
1499	Ocean Blvd. GV0816 - GV0817	1958	CI	566	8	0	0	0	3	0	0	0	-5	3	1	1	
1519	Ocean Blvd.	1958	CI	852	8	0	0	0	3	0	0	0	-5	3	1	1	
1	Fieldstone Cir.	1983	DI	745	8	0	0	0	0	0	0	0	0	0	0	0	
2	Fieldstone Cir.	1990	DI	958	8	0	0	0	0	0	0	0	0	0	0	0	
3	Fieldstone Cir.	1990	DI	556	8	0	0	0	0	0	0	0	0	0	0	0	
4	Stowcroft Dr.	1983	DI	140	8	0	0	0	0	0	0	0	0	0	0	0	
5	Westridge Rd.	1995	DI	1,859	8	0	0	0	0	0	0	0	0	0	0	0	
6	Stowcroft Dr.	1983	DI	1,650	8	0	0	0	0	0	0	0	0	0	0	0	
12	Exeter Road Elevated Tank	1982	DI	119	16	0	0	0	0	0	0	0	0	0	0	0	
31	Dupuis Cir.	1981	DI	228	8	0	0	0	0	0	0	0	0	0	0	0	
40	Hayden Dr.	1981	DI	558	8	0	0	0	0	0	0	0	0	0	0	0	
41	Hayden Dr.	1981	DI	870	8	0	0	0	0	0	0	0	0	0	0	0	
42	Hayden Dr.	1981	DI	284	8	0	0	0	0	0	0	0	0	0	0	0	
43	Coffin Dr.	1981	DI	512	8	0	0	0	0	0	0	0	0	0	0	0	
44	Hayden Dr.	1981	DI	1,176	8	0	0	0	0	0	0	0	0	0	0	0	
64	Josephine Dr.	1988	DI	617	8	0	0	0	0	0	0	0	0	0	0	0	
70	Driftwood Rd.	1985	DI	583	8	0	0	0	0	0	0	0	0	0	0	0	
71	Cedarview Ln./Forest Dr.	1985	DI	1,384	8	0	0	0	0	0	0	0	0	0	0	0	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Pipe Condition	Page 22 of 30	Comments
72	Maplewood Dr.	1985	DI	756	8	0	0	0	0	0	0	0	0	0	0	0		
76	Forest Dr.	1987	DI	448	8	0	0	0	0	0	0	0	0	0	0	0		
78	Towle Farm Rd.	1985	DI	981	12	0	0	0	0	0	0	0	0	0	0	0		
79	Merrill Rd.	1985	DI	241	12	0	0	0	0	0	0	0	0	0	0	0		
80	Merrill Rd.	1985	DI	312	8	0	0	0	0	0	0	0	0	0	0	0		
82	Towle Farm Rd.	1985	DI	362	12	0	0	0	0	0	0	0	0	0	0	0		
83	Hampton Towne Estates	1985	DI	214	8	0	0	0	0	0	0	0	0	0	0	0		
84	Hampton Towne Estates	1985	DI	326	8	0	0	0	0	0	0	0	0	0	0	0		
85	Hampton Towne Estates	1985	DI	578	8	0	0	0	0	0	0	0	0	0	0	0		
86	Hampton Towne Estates	1985	DI	90	8	0	0	0	0	0	0	0	0	0	0	0		
87	Towle Farm Rd.	1985	DI	26	12	0	0	0	0	0	0	0	0	0	0	0		
88	Riverwalk	1985	DI	748	8	0	0	0	0	0	0	0	0	0	0	0		
101	Stickney Ter	1978	DI	345	8	0	0	0	0	0	0	0	0	0	0	0		
141	Windmill Ln.	1982	DI	22	12	0	0	0	0	0	0	0	0	0	0	0		
163	Cogger St.	1971	DI	545	6	0	0	0	0	0	0	0	0	0	0	0		
174	Off of Lafayette Rd.	1995	DI	56	8	0	0	0	0	0	0	0	0	0	0	0		
175	Lafayette Rd.	1995	DI	23	8	0	0	0	0	0	0	0	0	0	0	0		
184	Reddington Landing/Lamson Ln.	1995	DI	56	8	0	0	0	0	0	0	0	0	0	0	0		
185	Reddington Landing/Lamson Ln.	1995	DI	74	8	0	0	0	0	0	0	0	0	0	0	0		
187	Reddington Landing	1995	DI	94	8	0	0	0	0	0	0	0	0	0	0	0		
188	Off of Reddington Landing	1995	DI	155	4	0	0	0	0	0	0	0	0	0	0	0		
189	Reddington Landing	1995	DI	520	8	0	0	0	0	0	0	0	0	0	0	0		
196	Holman Ln.	1984	DI	447	8	0	0	0	0	0	0	0	0	0	0	0		
220	Barbour Rd.	1990	DI	461	12	0	0	0	0	0	0	0	0	0	0	0		
222	Vanderpool Dr.	1988	DI	1,485	8	0	0	0	0	0	0	0	0	0	0	0		
223	Barbour Rd.	1990	DI	1,098	12	0	0	0	0	0	0	0	0	0	0	0		
225	Noel St	1979	DI	802	8	0	0	0	0	0	0	0	0	0	0	0		
228	Little River Rd.	1990	DI	231	8	0	0	0	0	0	0	0	0	0	0	0		
229	Norton Rd.	1990	DI	571	8	0	0	0	0	0	0	0	0	0	0	0		
231	Norton Rd.	1990	DI	473	8	0	0	0	0	0	0	0	0	0	0	0		
251	Little River Rd.	2003	DI	83	12	0	0	0	0	0	0	0	0	0	0	0		
254	Bear Path	1994	DI	1,673	8	0	0	0	0	0	0	0	0	0	0	0		
256	Woodland Rd: Hunter Dr - Little River Rd	1995	DI	806	12	0	0	0	0	0	0	0	0	0	0	0		
257	Hunter Dr.	1988	DI	1,573	8	0	0	0	0	0	0	0	0	0	0	0		
258	Woodland Rd: Hunter Dr - North Shore Rd	1995	DI	908	12	0	0	0	0	0	0	0	0	0	0	0		
259	North Shore Rd east of Woodland Rd	1995	DI	90	8	0	0	0	0	0	0	0	0	0	0	0		
260	Woodland Rd: Katie Ln - North Shore Rd	1995	DI	1,435	12	0	0	0	0	0	0	0	0	0	0	0		
261	Woodland Rd: Katie Ln - Mohawk St	1995	DI	294	12	0	0	0	0	0	0	0	0	0	0	0		
262	Katie Ln.	2001	DI	1,153	8	0	0	0	0	0	0	0	0	0	0	0		
263	Woodland Rd: Mohawk St - Pawnees St	1995	DI	259	12	0	0	0	0	0	0	0	0	0	0	0		
264	Mohawk St	1994	DI	240	6	0	0	0	0	0	0	0	0	0	0	0		
265	Woodland Rd: Great Gate Dr - Pawnees St	1995	DI	1,199	12	0	0	0	0	0	0	0	0	0	0	0		
266	Woodland Rd: Great Gate Dr - Munsey Dr	1990	DI	399	12	0	0	0	0	0	0	0	0	0	0	0		
267	Munsey Dr	1990	DI	3,447	8	0	0	0	0	0	0	0	0	0	0	0		
268	Woodland Rd: Munsey Dr - town line	1990	DI	636	12	0	0	0	0	0	0	0	0	0	0	0		
269	Great Gate Dr: Downer Dr - Woodland Rd	1992	DI	719	8	0	0	0	0	0	0	0	0	0	0	0		
270	Downer Dr	1993	DI	788	8	0	0	0	0	0	0	0	0	0	0	0		
271	Great Gate Dr: Downer Dr - Juniper Ln	1992	DI	485	8	0	0	0	0	0	0	0	0	0	0	0		
272	Juniper Ln: Great Gate Dr - Nersesian Way	1993	DI	1,160	8	0	0	0	0	0	0	0	0	0	0	0		
273	Great Gate Dr: east of Juniper Ln	1992	DI	832	8	0	0	0	0	0	0	0	0	0	0	0		
274	Nersesian Way	1993	DI	551	8	0	0	0	0	0	0	0	0	0	0	0		
275	Juniper Ln: Linden Ln - Nersesian Way	1990	DI	493	8	0	0	0	0	0	0	0	0	0	0	0		

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Page 23 of 30	Comments
277	Huckleberry Ln: west of Juniper Ln	1988	DI	251	8	0	0	0	0	0	0	0	0	0	0	0	
288	Wild Rose Ln	1977	DI	776	8	0	0	0	0	0	0	0	0	0	0	0	
296	Keene Ln east of Wild Rose Ln.	1977	DI	633	8	0	0	0	0	0	0	0	0	0	0	0	
306	Robin Ln	1977	DI	577	8	0	0	0	0	0	0	0	0	0	0	0	
308	Cusack Rd.	1988	DI	541	8	0	0	0	0	0	0	0	0	0	0	0	
309	Cusack Rd.	1988	DI	259	8	0	0	0	0	0	0	0	0	0	0	0	
310	Off of Cusack Rd.	1988	DI	187	6	0	0	0	0	0	0	0	0	0	0	0	
311	Cusack Rd.	1988	DI	53	4	0	0	0	0	0	0	0	0	0	0	0	
312	Cusack Rd.	1988	DI	225	4	0	0	0	0	0	0	0	0	0	0	0	
338	Dunvegan Woods	1985	DI	212	8	0	0	0	0	0	0	0	0	0	0	0	
340	Dunvegan Woods	1985	DI	613	8	0	0	0	0	0	0	0	0	0	0	0	
341	Dunvegan Woods	1985	DI	210	4	0	0	0	0	0	0	0	0	0	0	0	
342	Dunvegan Woods	1985	DI	94	4	0	0	0	0	0	0	0	0	0	0	0	
343	Dunvegan Woods	1985	DI	558	4	0	0	0	0	0	0	0	0	0	0	0	
344	Dunvegan Woods	1985	DI	75	4	0	0	0	0	0	0	0	0	0	0	0	
345	Dunvegan Woods	1985	DI	874	4	0	0	0	0	0	0	0	0	0	0	0	
346	Dunvegan Woods	1985	DI	62	4	0	0	0	0	0	0	0	0	0	0	0	
347	Dunvegan Woods	1985	DI	293	8	0	0	0	0	0	0	0	0	0	0	0	
348	Dunvegan Woods	1985	DI	100	8	0	0	0	0	0	0	0	0	0	0	0	
349	Dunvegan Woods	1985	DI	224	8	0	0	0	0	0	0	0	0	0	0	0	
350	Dunvegan Woods	1985	DI	515	6	0	0	0	0	0	0	0	0	0	0	0	
351	Dunvegan Woods	1985	DI	109	4	0	0	0	0	0	0	0	0	0	0	0	
352	Dunvegan Woods	1985	DI	372	4	0	0	0	0	0	0	0	0	0	0	0	
354	Alexander Ave: High St - GV0252	1981	DI	893	8	0	0	0	0	0	0	0	0	0	0	0	
355	Fielding Ln.	1991	DI	899	8	0	0	0	0	0	0	0	0	0	0	0	
356	Alexander Ave: Fielding Ln - GV0069	1981	DI	1,408	8	0	0	0	0	0	0	0	0	0	0	0	
361	Little River Rd.	2003	DI	839	12	0	0	0	0	0	0	0	0	0	0	0	
365	Wheaton Lane Terr.	1986	DI	482	8	0	0	0	0	0	0	0	0	0	0	0	
376	Lamprey Terr.	1971	DI	186	6	0	0	0	0	0	0	0	0	0	0	0	
379	Windmill Ln.	1982	DI	36	12	0	0	0	0	0	0	0	0	0	0	0	
386	Jeffrey Dr.	1982	DI	452	8	0	0	0	0	0	0	0	0	0	0	0	
390	Winnicunnet Rd.	1983	DI	61	8	0	0	0	0	0	0	0	0	0	0	0	
396	Winnicunnet Rd.	1983	DI	998	12	0	0	0	0	0	0	0	0	0	0	0	
399	Edgewood Dr.	1984	DI	1,494	8	0	0	0	0	0	0	0	0	0	0	0	
402	Laurel Ln.	1984	DI	407	8	0	0	0	0	0	0	0	0	0	0	0	
416	Penniman Ln.	1986	DI	1,152	8	0	0	0	0	0	0	0	0	0	0	0	
434	Hedman Ave.	1965	DI	388	8	0	0	0	0	0	0	0	0	0	0	0	
435	Hedman Ave.	1965	DI	224	8	0	0	0	0	0	0	0	0	0	0	0	
439	Hedman Ave.	1978	DI	752	8	0	0	0	0	0	0	0	0	0	0	0	
440	Hilda Dr.	1985	DI	722	8	0	0	0	0	0	0	0	0	0	0	0	
444	Malek Cir.	1990	DI	223	6	0	0	0	0	0	0	0	0	0	0	0	
452	Ring's Ter.	1985	DI	951	8	0	0	0	0	0	0	0	0	0	0	0	
454	Presidential Cir.	1980	DI	191	8	0	0	0	0	0	0	0	0	0	0	0	
456	Presidential Cir.	1980	DI	1,241	8	0	0	0	0	0	0	0	0	0	0	0	
457	Esker St.	1980	DI	298	8	0	0	0	0	0	0	0	0	0	0	0	
458	Presidential Cir	1980	DI	866	8	0	0	0	0	0	0	0	0	0	0	0	
459	Esker St.	1980	DI	305	8	0	0	0	0	0	0	0	0	0	0	0	
460	Laurence Cir.	1981	DI	342	6	0	0	0	0	0	0	0	0	0	0	0	
461	Esker Rd.	1981	DI	1,103	8	0	0	0	0	0	0	0	0	0	0	0	
462	Esker Rd.	1978	DI	617	8	0	0	0	0	0	0	0	0	0	0	0	
463	Esker Rd.	1981	DI	551	8	0	0	0	0	0	0	0	0	0	0	0	
464	Vrylenas Way	1999	DI	651	8	0	0	0	0	0	0	0	0	0	0	0	

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Page 24 of 30	Comments
465	Icehouse Way	1985	DI	954	4	0	0	0	0	0	0	0	0	0	0	0	
466	Reubens Driftway	1985	DI	295	4	0	0	0	0	0	0	0	0	0	0	0	
467	Bonair Ave.	1970	DI	449	8	0	0	0	0	0	0	0	0	0	0	0	
469	Bonair Ave.	1970	DI	114	8	0	0	0	0	0	0	0	0	0	0	0	
472	Acadia Ave: Bonair Ave - Emerald Ave	1970	DI	327	8	0	0	0	0	0	0	0	0	0	0	0	
473	Acadia Ave: Emerald Ave - Walnut Ave	1970	DI	226	8	0	0	0	0	0	0	0	0	0	0	0	
475	Walnut Ave.	1970	DI	157	6	0	0	0	0	0	0	0	0	0	0	0	
476	Walnut Ave.	1970	DI	236	6	0	0	0	0	0	0	0	0	0	0	0	
477	Emerald Ave.	1984	DI	226	6	0	0	0	0	0	0	0	0	0	0	0	
478	Emerald Ave.	1984	DI	179	6	0	0	0	0	0	0	0	0	0	0	0	
479	Emerald Ave.	1984	DI	188	6	0	0	0	0	0	0	0	0	0	0	0	
480	Emerald Ave.	1984	DI	190	6	0	0	0	0	0	0	0	0	0	0	0	
481	Emerald Ave.	1984	DI	76	6	0	0	0	0	0	0	0	0	0	0	0	
482	Crest St.	1984	DI	266	6	0	0	0	0	0	0	0	0	0	0	0	
483	Overlook Rd.	1984	DI	174	6	0	0	0	0	0	0	0	0	0	0	0	
484	Seaview Ave.	1984	DI	294	6	0	0	0	0	0	0	0	0	0	0	0	
485	Spruce St.	1984	DI	298	6	0	0	0	0	0	0	0	0	0	0	0	
486	Thorwald St.	1984	DI	99	8	0	0	0	0	0	0	0	0	0	0	0	
487	Thorwald St.	1984	DI	190	8	0	0	0	0	0	0	0	0	0	0	0	
488	Thorwald St.	1984	DI	375	8	0	0	0	0	0	0	0	0	0	0	0	
489	Acadia Ave: Bonair Ave - Winnicunnet Rd	1970	DI	242	8	0	0	0	0	0	0	0	0	0	0	0	
490	Thorwald St.	1984	DI	493	8	0	0	0	0	0	0	0	0	0	0	0	
653	Auburn Ave.	2013	PWDI	215	6	0	0	0	0	0	0	0	0	0	0	0	
657	Perkins Ave.	2013	PWDI	522	6	0	0	0	0	0	0	0	0	0	0	0	
658	Auburn Ave.	2013	PWDI	190	6	0	0	0	0	0	0	0	0	0	0	0	
659	Auburn Ave. Ext.	2013	PWDI	244	4	0	0	0	0	0	0	0	0	0	0	0	
727	Langdale Dr./Liberty Lane	1985	DI	570	8	0	0	0	0	0	0	0	0	0	0	0	
728	Liberty Lane/Towle Farm Rd.	1985	DI	766	8	0	0	0	0	0	0	0	0	0	0	0	
729	Liberty Lane	1985	DI	417	8	0	0	0	0	0	0	0	0	0	0	0	
730	Towle Farm Rd.	1985	DI	67	12	0	0	0	0	0	0	0	0	0	0	0	
731	Towle Farm Rd.	1985	DI	383	12	0	0	0	0	0	0	0	0	0	0	0	
732	Towle Farm Rd.	1985	DI	48	12	0	0	0	0	0	0	0	0	0	0	0	
733	Towle Farm Rd.	1985	DI	143	12	0	0	0	0	0	0	0	0	0	0	0	
734	Off of Exeter-Hampton Rd.	1984	DI	1,431	12	0	0	0	0	0	0	0	0	0	0	0	
741	Garrett Dr	1988	DI	1,243	8	0	0	0	0	0	0	0	0	0	0	0	
747	Spruce Meadow Dr.	1980	DI	263	8	0	0	0	0	0	0	0	0	0	0	0	
748	Spruce Meadow Dr.	1980	DI	540	8	0	0	0	0	0	0	0	0	0	0	0	
751	Rockrimmon Rd.	1990	DI	648	8	0	0	0	0	0	0	0	0	0	0	0	
752	Rockrimmon Rd	1990	DI	2,425	8	0	0	0	0	0	0	0	0	0	0	0	
762	Cotton Farm Ln: Woodland Rd to cul-de-sac	1971	DI	1,785	8	0	0	0	0	0	0	0	0	0	0	0	
763	Cotton Farm Ln: cul-de-sac	1971	DI	1,282	8	0	0	0	0	0	0	0	0	0	0	0	
768	Ocean Blvd.	1958	CICL	20	8	0	0	0	2	0	0	0	-5	3	0	0	
773	Central Rd.	1991	DI	674	8	0	0	0	0	0	0	0	0	0	0	0	
775	Felding Way	1983	DI	389	8	0	0	0	0	0	0	0	0	0	0	0	
776	Spring Rd	1983	DI	833	8	0	0	0	0	0	0	0	0	0	0	0	
777	Love Ln	2000	DI	879	8	0	0	0	0	0	0	0	0	0	0	0	
780	Maple Ave.	1970	DI	310	8	0	0	0	0	0	0	0	0	0	0	0	
782	Buckskin Ln.	1991	DI	1,620	8	0	0	0	0	0	0	0	0	0	0	0	
783	Post Rd.	1988	DI	104	8	0	0	0	0	0	0	0	0	0	0	0	
785	Off of Lafayette Rd.	1990	DI	212	8	0	0	0	0	0	0	0	0	0	0	0	
787	Shepherds Ln.	1996	DI	772	8	0	0	0	0	0	0	0	0	0	0	0	
791	Shel AI Mobile Estates	1985	DI	976	8	0	0	0	0	0	0	0	0	0	0	0	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE 25 of 30	Comments
794	Park Cir	1986	DI	816	8	0	0	0	0	0	0	0	0	0	0	0	
802	South Rd	1978	DI	1,894	8	0	0	0	0	0	0	0	0	0	0	0	
804	Baker Ave.	1986	DI	272	8	0	0	0	0	0	0	0	0	0	0	0	
805	Baker Ave.	1992	DI	202	8	0	0	0	0	0	0	0	0	0	0	0	
806	Baker Ave.	1986	DI	481	8	0	0	0	0	0	0	0	0	0	0	0	
808	Bradley Ln.	1985	DI	1,145	8	0	0	0	0	0	0	0	0	0	0	0	
809	Pond Path	1985	DI	563	8	0	0	0	0	0	0	0	0	0	0	0	
810	Pond Path	1985	DI	1,273	8	0	0	0	0	0	0	0	0	0	0	0	
811	Spruce Meadow Dr.	1980	DI	1,210	8	0	0	0	0	0	0	0	0	0	0	0	
812	Osco & Shaw's Plaza	1998	DI	303	8	0	0	0	0	0	0	0	0	0	0	0	
813	Osco & Shaw's Plaza	1998	DI	211	8	0	0	0	0	0	0	0	0	0	0	0	
822	Park in the Pines	1995	DI	170	8	0	0	0	0	0	0	0	0	0	0	0	
823	Park in the Pines	1995	DI	92	8	0	0	0	0	0	0	0	0	0	0	0	
824	Park in the Pines	1995	DI	24	8	0	0	0	0	0	0	0	0	0	0	0	
825	Park in the Pines	1995	DI	106	8	0	0	0	0	0	0	0	0	0	0	0	
829	Cedar Rd	1981	DI	747	12	0	0	0	0	0	0	0	0	0	0	0	
830	Cedar Rd.	1981	DI	53	12	0	0	0	0	0	0	0	0	0	0	0	
831	Osco & Shaw's Plaza	1998	DI	19	8	0	0	0	0	0	0	0	0	0	0	0	
832	Osco & Shaw's Plaza	1998	DI	20	4	0	0	0	0	0	0	0	0	0	0	0	
833	Osco & Shaw's Plaza	1998	DI	387	8	0	0	0	0	0	0	0	0	0	0	0	
834	Osco & Shaw's Plaza	1998	DI	29	8	0	0	0	0	0	0	0	0	0	0	0	
835	Osco & Shaw's Plaza	1998	DI	22	4	0	0	0	0	0	0	0	0	0	0	0	
836	Osco & Shaw's Plaza	1998	DI	16	8	0	0	0	0	0	0	0	0	0	0	0	
837	Osco & Shaw's Plaza	1998	DI	54	4	0	0	0	0	0	0	0	0	0	0	0	
838	Osco & Shaw's Plaza	1998	DI	26	8	0	0	0	0	0	0	0	0	0	0	0	
839	Osco & Shaw's Plaza	1998	DI	728	8	0	0	0	0	0	0	0	0	0	0	0	
840	Osco & Shaw's Plaza	1998	DI	36	8	0	0	0	0	0	0	0	0	0	0	0	
841	Osco & Shaw's Plaza	1998	DI	489	8	0	0	0	0	0	0	0	0	0	0	0	
842	Osco & Shaw's Plaza	1998	DI	17	8	0	0	0	0	0	0	0	0	0	0	0	
843	Osco & Shaw's Plaza	1998	DI	547	8	0	0	0	0	0	0	0	0	0	0	0	
844	Osco & Shaw's Plaza	1998	DI	103	8	0	0	0	0	0	0	0	0	0	0	0	
845	Osco & Shaw's Plaza	1998	DI	309	8	0	0	0	0	0	0	0	0	0	0	0	
850	Lafayette Rd	1985	DI	1,422	12	0	0	0	0	0	0	0	0	0	0	0	
851	Lafayette Rd	1985	DI	865	12	0	0	0	0	0	0	0	0	0	0	0	
854	Hobbs Rd.	1985	DI	35	12	0	0	0	0	0	0	0	0	0	0	0	
855	Elm Rd./Lafayette Rd.	1985	DI	20	12	0	0	0	0	0	0	0	0	0	0	0	
856	Lafayette Rd	1985	DI	1,077	12	0	0	0	0	0	0	0	0	0	0	0	
857	Lafayette Rd	1985	DI	868	12	0	0	0	0	0	0	0	0	0	0	0	
858	Boutlier Ln.	1998	DI	1,136	8	0	0	0	0	0	0	0	0	0	0	0	
859	Boutlier Ln.	1998	DI	258	12	0	0	0	0	0	0	0	0	0	0	0	
860	Boutlier Ln.	1998	DI	1,342	12	0	0	0	0	0	0	0	0	0	0	0	
861	South Rd.	1980	DI	94	12	0	0	0	0	0	0	0	0	0	0	0	
862	North Rd.	1980	DI	250	12	0	0	0	0	0	0	0	0	0	0	0	
863	Lafayette Rd./North Rd.	1985	DI	19	12	0	0	0	0	0	0	0	0	0	0	0	
864	North Rd.	1980	DI	2,756	12	0	0	0	0	0	0	0	0	0	0	0	
865	Lafayette Rd	1985	DI	907	12	0	0	0	0	0	0	0	0	0	0	0	
867	Cherry Rd.	1999	DI	77	8	0	0	0	0	0	0	0	0	0	0	0	
868	Highlander Dr	1987	DI	1,628	12	0	0	0	0	0	0	0	0	0	0	0	
873	Evergreen Dr.	2001	DI	25	8	0	0	0	0	0	0	0	0	0	0	0	
874	Evergreen Dr.	2001	DI	2,621	8	0	0	0	0	0	0	0	0	0	0	0	
891	Coakley Well No. 12	1978	DI	33	8	0	0	0	0	0	0	0	0	0	0	0	
892	Well No. 12 & 13A	1978	DI	62	8	0	0	0	0	0	0	0	0	0	0	0	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	Page 26 of 30	Comments
894	Well No. 12 & 13A	1978	DI	30	8	0	0	0	0	0	0	0	0	0	0	0	
897	Winnicut Rd.	1978	DI	6	12	0	0	0	0	0	0	0	0	0	0	0	
898	Winnicut Rd.	1991	DI	19	12	0	0	0	0	0	0	0	0	0	0	0	
901	Well No. 17	1998	DI	40	4	0	0	0	0	0	0	0	0	0	0	0	
902	Well No. 17	1998	DI	37	4	0	0	0	0	0	0	0	0	0	0	0	
904	Well No. 18	1998	DI	96	6	0	0	0	0	0	0	0	0	0	0	0	
906	Well No. 17, 18 & 19	1998	DI	33	8	0	0	0	0	0	0	0	0	0	0	0	
907	Well No. 17, 18 & 19	1998	DI	17	8	0	0	0	0	0	0	0	0	0	0	0	
909	Winnicut Rd.	1971	DI	654	8	0	0	0	0	0	0	0	0	0	0	0	
910	Winnicut Rd.	1995	DI	14	12	0	0	0	0	0	0	0	0	0	0	0	
911	Winnicut Rd.	1995	DI	917	12	0	0	0	0	0	0	0	0	0	0	0	
914	Deer Run Rd.	1988	DI	257	12	0	0	0	0	0	0	0	0	0	0	0	
915	Red Fox Rd.	1988	DI	652	8	0	0	0	0	0	0	0	0	0	0	0	
916	Deer Run Rd.	1988	DI	1,173	8	0	0	0	0	0	0	0	0	0	0	0	
954	Old Beach Rd.	1961	CICL	602	8	0	0	0	2	0	0	0	-5	3	0	0	
960	Perkins Rd	1975	DI	793	8	0	0	0	0	0	0	0	0	0	0	0	
961	Perkins Rd	1975	DI	756	8	0	0	0	0	0	0	0	0	0	0	0	
962	Jenness Beach Tank	1966	DI	34	12	0	0	0	0	0	0	0	0	0	0	0	
968	Douglas Cir.	1958	CU	112	2	0	0	0	0	0	0	0	0	0	0	0	
977	Alder Ave	1980	PVC	368	1	0	0	0	0	0	0	0	0	0	0	0	
979	Gray Ct.	1991	DI	432	6	0	0	0	0	0	0	0	0	0	0	0	
1020	Woodland Rd: Atlantic Ave - Ship Rock Rd	1985	DI	798	12	0	0	0	0	0	0	0	0	0	0	0	
1021	Woodland Rd: Runnymede Dr - Ship Rock Rd N	1985	DI	440	12	0	0	0	0	0	0	0	0	0	0	0	
1022	Woodland Rd: Runnymede Dr - Ship Rock Rd S	1985	DI	283	12	0	0	0	0	0	0	0	0	0	0	0	
1023	Woodland Rd: Rockrimmon Rd - Ship Rock Rd	1985	DI	1,751	12	0	0	0	0	0	0	0	0	0	0	0	
1024	Woodland Rd: Rockrimmon Rd - Hampton line	1990	DI	243	12	0	0	0	0	0	0	0	0	0	0	0	
1027	Lafayette Rd	1985	DI	1,921	12	0	0	0	0	0	0	0	0	0	0	0	
1028	Lafayette Rd	1990	DI	724	12	0	0	0	0	0	0	0	0	0	0	0	
1029	Lafayette Rd	1990	DI	769	12	0	0	0	0	0	0	0	0	0	0	0	
1030	Lafayette Rd	1990	DI	570	12	0	0	0	0	0	0	0	0	0	0	0	
1031	Lafayette Rd	1990	DI	180	12	0	0	0	0	0	0	0	0	0	0	0	
1032	Park in the Pines	1995	DI	59	8	0	0	0	0	0	0	0	0	0	0	0	
1033	Park in the Pines	1995	DI	426	8	0	0	0	0	0	0	0	0	0	0	0	
1034	Park in the Pines	1995	DI	386	8	0	0	0	0	0	0	0	0	0	0	0	
1035	Park in the Pines	1995	DI	469	8	0	0	0	0	0	0	0	0	0	0	0	
1036	Fielding Way	1983	DI	313	8	0	0	0	0	0	0	0	0	0	0	0	
1037	Fielding Way	1983	DI	993	8	0	0	0	0	0	0	0	0	0	0	0	
1038	Pine St	1971	DI	16	8	0	0	0	0	0	0	0	0	0	0	0	
1052	Pond Path	1985	DI	608	8	0	0	0	0	0	0	0	0	0	0	0	
1053	Pond Path	1985	DI	889	8	0	0	0	0	0	0	0	0	0	0	0	
1054	Bradley Ln.	1985	DI	799	8	0	0	0	0	0	0	0	0	0	0	0	
1055	Bradley Ln.	1985	DI	1,402	8	0	0	0	0	0	0	0	0	0	0	0	
1064	Lafayette Rd.	1990	DI	117	12	0	0	0	0	0	0	0	0	0	0	0	
1065	Lafayette Rd	1985	DI	291	12	0	0	0	0	0	0	0	0	0	0	0	
1066	Lafayette Rd	1985	DI	978	12	0	0	0	0	0	0	0	0	0	0	0	
1069	Garrett Dr	1988	DI	1,203	8	0	0	0	0	0	0	0	0	0	0	0	
1073	Red Fox Rd.	1988	DI	695	8	0	0	0	0	0	0	0	0	0	0	0	
1074	Red Fox Rd.	1988	DI	372	8	0	0	0	0	0	0	0	0	0	0	0	
1075	Well No. 12 & 13A	1978	DI	5	16	0	0	0	0	0	0	0	0	0	0	0	
1076	Buckskin Ln.	1991	DI	4	12	0	0	0	0	0	0	0	0	0	0	0	
1077	Winnicut Rd.	1991	DI	7	12	0	0	0	0	0	0	0	0	0	0	0	
1078	Buckskin Ln.	1991	DI	920	8	0	0	0	0	0	0	0	0	0	0	0	

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PIPE PRIORITY	Page 27 of 30	Comments
1079	Buckskin Ln.	1991	DI	1,035	8	0	0	0	0	0	0	0	0	0	0	0		
1080	Oso & Shaw's Plaza	1998	DI	496	8	0	0	0	0	0	0	0	0	0	0	0		
1085	Spruce Meadow Dr.	1980	DI	310	8	0	0	0	0	0	0	0	0	0	0	0		
1093	Rockrimmon Rd.	1990	DI	642	8	0	0	0	0	0	0	0	0	0	0	0		
1094	Barbour Rd.	1990	DI	518	12	0	0	0	0	0	0	0	0	0	0	0		
1097	Little River Rd	1990	DI	254	8	0	0	0	0	0	0	0	0	0	0	0		
1100	Lafayette Rd	1995	DI	31	12	0	0	0	0	0	0	0	0	0	0	0		
1110	Anns Terr	1980	DI	568	6	0	0	0	0	0	0	0	0	0	0	0		
1121	Off of Walnut Ave.	1984	DI	201	6	0	0	0	0	0	0	0	0	0	0	0		
1127	Church St.	2006	DI	124	6	0	0	0	0	0	0	0	0	0	0	0		
1142	Swain Ct	1986	DI	201	6	0	0	0	0	0	0	0	0	0	0	0		
1147	Lafayette Rd.	1982	DI	9	12	0	0	0	0	0	0	0	0	0	0	0		
1161	Pine St	1971	DI	976	8	0	0	0	0	0	0	0	0	0	0	0		
1165	Oso & Shaw's Plaza	1998	DI	97	8	0	0	0	0	0	0	0	0	0	0	0		
1169	Fairway Dr	2009	HDPE	972	8	0	0	0	0	0	0	0	0	0	0	0		
1171	Red Mill Ln.	1955	CU	197	0.75	0	0	0	0	0	0	0	0	0	0	0		
1172	Red Mill Ln	1955	CU	454	1	0	0	0	0	0	0	0	0	0	0	0		
1174	Willow Rd./Ocean Blvd.	1961	CICL	525	6	0	0	0	2	0	0	0	-5	3	0	0		
1175	Ocean Blvd.	1958	CICL	319	6	0	0	0	2	0	0	0	-5	3	0	0		
1183	Rock Well No. 13A	1982	DI	34	8	0	0	0	0	0	0	0	0	0	0	0		
1184	Winnicut Rd.	1995	DI	1,773	12	0	0	0	0	0	0	0	0	0	0	0		
1201	Oso & Shaw's Plaza	1998	DI	153	8	0	0	0	0	0	0	0	0	0	0	0		
1202	Oso & Shaw's Plaza	1998	DI	73	8	0	0	0	0	0	0	0	0	0	0	0		
1203	Oso & Shaw's Plaza	1998	DI	80	8	0	0	0	0	0	0	0	0	0	0	0		
1209	Well No. 21	2003	DI	122	4	0	0	0	0	0	0	0	0	0	0	0		
1217	Liberty Lane	1985	DI	1,219	8	0	0	0	0	0	0	0	0	0	0	0		
1218	Liberty Lane	1985	DI	221	8	0	0	0	0	0	0	0	0	0	0	0		
1219	Raymond Ter.	1990	DI	811	8	0	0	0	0	0	0	0	0	0	0	0		
1220	Raymond Ter.	1995	DI	86	8	0	0	0	0	0	0	0	0	0	0	0		
1221	Little River Rd.	1990	DI	383	8	0	0	0	0	0	0	0	0	0	0	0		
1222	Little River Rd.	2003	DI	215	8	0	0	0	0	0	0	0	0	0	0	0		
1223	Little River Rd.	2003	DI	629	8	0	0	0	0	0	0	0	0	0	0	0		
1251	Jenness Beach Tank & Well No. 5	1966	DI	40	12	0	0	0	0	0	0	0	0	0	0	0		
1252	Jenness Beach Tank & Well No. 5	1966	DI	12	12	0	0	0	0	0	0	0	0	0	0	0		
1254	Jenness Beach Tank & Well No. 5	1966	DI	13	12	0	0	0	0	0	0	0	0	0	0	0		
1255	Jenness Beach Tank & Well No. 5	1966	DI	25	6	0	0	0	0	0	0	0	0	0	0	0		
1256	Jenness Beach Tank & Well No. 5	1966	DI	36	12	0	0	0	0	0	0	0	0	0	0	0		
1257	Jenness Beach Tank & Well No. 5	1966	DI	128	12	0	0	0	0	0	0	0	0	0	0	0		
1258	Jenness Beach Tank & Well No. 5	1966	DI	10	12	0	0	0	0	0	0	0	0	0	0	0		
1271	Pond Path	1985	DI	256	8	0	0	0	0	0	0	0	0	0	0	0		
1272	Winnicut Rd.	1971	DI	202	8	0	0	0	0	0	0	0	0	0	0	0		
1274	Well No. 17	1998	DI	25	4	0	0	0	0	0	0	0	0	0	0	0		
1275	Well No. 19	1998	DI	25	8	0	0	0	0	0	0	0	0	0	0	0		
1276	Well No. 18	1998	DI	16	6	0	0	0	0	0	0	0	0	0	0	0		
1277	Well No. 16	1995	DI	42	8	0	0	0	0	0	0	0	0	0	0	0		
1278	Coakley Well No. 12	1978	DI	14	8	0	0	0	0	0	0	0	0	0	0	0		
1279	Rock Well No. 13A	1982	DI	18	8	0	0	0	0	0	0	0	0	0	0	0		
1280	Jenness Beach Tank & Well No. 5	1966	DI	17	12	0	0	0	0	0	0	0	0	0	0	0		
1281	Well No. 21	2003	DI	28	4	0	0	0	0	0	0	0	0	0	0	0		
1286	Well No. 14	1989	DI	68	12	0	0	0	0	0	0	0	0	0	0	0		
1287	Well No. 20	2003	DI	6	4	0	0	0	0	0	0	0	0	0	0	0		
1294	Lafayette Rd.	1990	DI	823	12	0	0	0	0	0	0	0	0	0	0	0		

Docket No. DW 13-___

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PIPE PRIORITY	Page 28 of 30	Comments
1300	Winnicunnet Rd.	1983	DI	53	12	0	0	0	0	0	0	0	0	0	0	0		
1301	Park in the Pines	1995	DI	14	8	0	0	0	0	0	0	0	0	0	0	0		
1302	Park in the Pines	1995	DI	399	6	0	0	0	0	0	0	0	0	0	0	0		
1303	Park in the Pines	1995	DI	398	6	0	0	0	0	0	0	0	0	0	0	0		
1304	Park in the Pines	1995	DI	156	8	0	0	0	0	0	0	0	0	0	0	0		
1305	Park in the Pines	1995	DI	395	6	0	0	0	0	0	0	0	0	0	0	0		
1306	Park in the Pines	1995	DI	397	6	0	0	0	0	0	0	0	0	0	0	0		
1307	Park in the Pines	1995	DI	734	8	0	0	0	0	0	0	0	0	0	0	0		
1308	Park in the Pines	1995	DI	14	8	0	0	0	0	0	0	0	0	0	0	0		
1309	Park in the Pines	1995	DI	78	8	0	0	0	0	0	0	0	0	0	0	0		
1310	Park in the Pines	1995	DI	209	8	0	0	0	0	0	0	0	0	0	0	0		
1311	Park in the Pines	1995	DI	160	8	0	0	0	0	0	0	0	0	0	0	0		
1312	Park in the Pines	1995	DI	108	8	0	0	0	0	0	0	0	0	0	0	0		
1313	Park in the Pines	1995	DI	335	8	0	0	0	0	0	0	0	0	0	0	0		
1314	Park in the Pines	1995	DI	673	8	0	0	0	0	0	0	0	0	0	0	0		
1315	Park in the Pines	1995	DI	92	8	0	0	0	0	0	0	0	0	0	0	0		
1316	Park in the Pines	1995	DI	220	8	0	0	0	0	0	0	0	0	0	0	0		
1317	Park in the Pines	1995	DI	157	8	0	0	0	0	0	0	0	0	0	0	0		
1318	Towle Farm Rd.	1985	DI	221	12	0	0	0	0	0	0	0	0	0	0	0		
1319	Lafayette Crossing Mall	2002	UNK	431	8	0	0	0	0	0	0	0	0	0	0	0		
1321	Lafayette Crossing Mall	2002	UNK	107	8	0	0	0	0	0	0	0	0	0	0	0		
1325	Lafayette Rd	1990	DI	351	12	0	0	0	0	0	0	0	0	0	0	0		
1326	Lafayette Rd	1990	DI	393	12	0	0	0	0	0	0	0	0	0	0	0		
1344	Sea Rd.	1971	DI	360	8	0	0	0	0	0	0	0	0	0	0	0		
1362	Osco & Shaw's Plaza	1998	DI	583	8	0	0	0	0	0	0	0	0	0	0	0		
1363	Park in the Pines	1995	DI	1,602	8	0	0	0	0	0	0	0	0	0	0	0		
1364	Park in the Pines	1995	DI	776	6	0	0	0	0	0	0	0	0	0	0	0		
1366	Drakeside Rd.	1990	DI	3,206	12	0	0	0	0	0	0	0	0	0	0	0		
1372	Lafayette Rd.	1985	DI	467	12	0	0	0	0	0	0	0	0	0	0	0		
1373	Lafayette Rd.	1985	DI	105	12	0	0	0	0	0	0	0	0	0	0	0		
1379	Deer Run Rd.	1988	DI	123	12	0	0	0	0	0	0	0	0	0	0	0		
1380	Deer Run Rd.	1988	DI	1,566	12	0	0	0	0	0	0	0	0	0	0	0		
1382	Well No. 17, 18 & 19	1998	DI	117	12	0	0	0	0	0	0	0	0	0	0	0		
1383	Stowecroft Dr.	1983	DI	173	8	0	0	0	0	0	0	0	0	0	0	0		
1384	Stowecroft Dr.	1983	DI	174	8	0	0	0	0	0	0	0	0	0	0	0		
1385	Liberty Lane	1985	DI	871	8	0	0	0	0	0	0	0	0	0	0	0		
1386	Liberty Lane	1985	DI	163	8	0	0	0	0	0	0	0	0	0	0	0		
1387	Drakeside Rd.	1990	DI	201	12	0	0	0	0	0	0	0	0	0	0	0		
1388	Drakeside Rd.	1990	DI	135	12	0	0	0	0	0	0	0	0	0	0	0		
1393	Red Mill Ln.	1955	CU	126	0.75	0	0	0	0	0	0	0	0	0	0	0		
1394	Red Mill Ln.	1955	CU	140	0.75	0	0	0	0	0	0	0	0	0	0	0		
1395	Red Mill Ln.	1955	CU	99	1	0	0	0	0	0	0	0	0	0	0	0		
1396	Red Mill Ln.	1955	CU	229	1	0	0	0	0	0	0	0	0	0	0	0		
1398	Drakes Landing	1985	DI	1,042	8	0	0	0	0	0	0	0	0	0	0	0		
1400	Pine Rd	2007	DI	84	12	0	0	0	0	0	0	0	0	0	0	0		
1407	Hampton Towne Estates	1985	DI	477	8	0	0	0	0	0	0	0	0	0	0	0		
1408	Off of Exeter-Hampton Rd.	1984	DI	1,971	12	0	0	0	0	0	0	0	0	0	0	0		
1410	Off Lafayette Rd south of Cedar	2008	DI	562	6	0	0	0	0	0	0	0	0	0	0	0		
1416	Holman Ln	1984	DI	213	8	0	0	0	0	0	0	0	0	0	0	0		
1424	Winnicut River Crossing- GV0947 - GV0983	2000	DI	1,402	12	0	0	0	0	0	0	0	0	0	0	0		
1429	Lamprey Terr	1996	DI	515	6	0	0	0	0	0	0	0	0	0	0	0		
1431	Atlantic Ave- GV0724 - GV1118	2010	DI	1,046	12	0	0	0	0	0	0	0	0	0	0	0		

Docket No. DW 13-

Attachment CM-II

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	PAGE 29 of 30	Comments
1432	Atlantic Ave: GV1116 to GV1117	2010	DI	535	12	0	0	0	0	0	0	0	0	0	0	0	
1433	Atlantic Ave: GV1116 - GV1117	2010	DI	509	12	0	0	0	0	0	0	0	0	0	0	0	
1434	Atlantic Ave	2010	DI	45	8	0	0	0	0	0	0	0	0	0	0	0	
1435	Atlantic Ave	2010	DI	5	8	0	0	0	0	0	0	0	0	0	0	0	
1439	Playhouse Cir	2000	DI	465	8	0	0	0	0	0	0	0	0	0	0	0	
1440	Playhouse Cir	2000	DI	1,790	8	0	0	0	0	0	0	0	0	0	0	0	
1441	Holly Ln	2010	DI	230	6	0	0	0	0	0	0	0	0	0	0	0	
1442	Janet Ln	1999	DI	580	8	0	0	0	0	0	0	0	0	0	0	0	
1443	Partridge House	1999	Unknown	400	0	0	0	0	0	0	0	0	0	0	0	0	
1444	Service to Hampton WWTP	1964	UNK	1,100	4	0	0	0	0	0	0	0	0	0	0	0	
1446	Baron Rd	2007	DI	592	8	0	0	0	0	0	0	0	0	0	0	0	
1447	Wayside Farm Ln	2002	DI	875	8	0	0	0	0	0	0	0	0	0	0	0	
1450	Lafayette Rd	1990	DI	320	12	0	0	0	0	0	0	0	0	0	0	0	
1451	Lafayette Rd	1990	DI	100	12	0	0	0	0	0	0	0	0	0	0	0	
1454	Jenness Rd: GV0455 - Randall St	1963	CICL	30	8	0	0	0	2	0	0	0	0	0	2	2	
1457	Atlantic Ave: GV1164 - Woodland Rd main	2011	DI	41	12	0	0	0	0	0	0	0	0	0	0	0	
1458	Atlantic Ave: GV1165 - Woodland Rd main	2011	DI	270	16	0	0	0	0	0	0	0	0	0	0	0	
1459	Atlantic Ave: GV1165 - GV1166	2011	DI	120	16	0	0	0	0	0	0	0	0	0	0	0	
1476	Witch Island Way	2011	DI	702	6	0	0	0	0	0	0	0	0	0	0	0	
1477	Summer Ct	2010	DI	114	8	0	0	0	0	0	0	0	0	0	0	0	
1478	Goldenrod Way	2010	DI	279	8	0	0	0	0	0	0	0	0	0	0	0	
1479	Greystone Way: Lafayette Rd - Aspen Way	2010	DI	324	8	0	0	0	0	0	0	0	0	0	0	0	
1480	Greystone Way: Aspen Way - Summer Ct	2010	DI	325	8	0	0	0	0	0	0	0	0	0	0	0	
1481	Greystone Way: Aspen Wy - Goldenrod Wy	2010	DI	325	8	0	0	0	0	0	0	0	0	0	0	0	
1482	Aspen Way: Goldenrod Wy - private hydrant	2010	DI	297	8	0	0	0	0	0	0	0	0	0	0	0	
1483	Aspen Way: Greystone Way - private hydrant	2010	DI	478	8	0	0	0	0	0	0	0	0	0	0	0	
1487	Pawnees St	1994	DI	281	6	0	0	0	0	0	0	0	0	0	0	0	
1488	Decolah St	1994	DI	248	6	0	0	0	0	0	0	0	0	0	0	0	
1489	Alexander Ave: Fielding Ln - GV0252	1981	DI	531	8	0	0	0	0	0	0	0	0	0	0	0	
1490	Alexander Ave: GV0069 - Presidential Cir	1981	DI	175	8	0	0	0	0	0	0	0	0	0	0	0	
1491	Winterberry Ln: GV0949 - Walnut Ave	2000	DI	1,174	12	0	0	0	0	0	0	0	0	0	0	0	
1492	Winterberry Ln: GV0948 - GV0949	2000	DI	1,263	12	0	0	0	0	0	0	0	0	0	0	0	
1493	Winterberry Ln: GV0947 - GV0948	2000	DI	1,012	12	0	0	0	0	0	0	0	0	0	0	0	
1494	Winnicut River Crossing: GV0982 - GV0983	2000	DI	124	12	0	0	0	0	0	0	0	0	0	0	0	
1495	Winnicut River Crossing: Winnicut Rd - GV0982	2000	DI	1,073	12	0	0	0	0	0	0	0	0	0	0	0	
1500	Dalton Ln	2009	DI	471	6	0	0	0	0	0	0	0	0	0	0	0	
1503	Drakeside Rd 056	2011	DI	149	6	0	0	0	0	0	0	0	0	0	0	0	
1504	Aspen Way: Greystone Way - private hydrant	2010	DI	225	8	0	0	0	0	0	0	0	0	0	0	0	
1505	Grist Mill Condos	2011	DI	415	8	0	0	0	0	0	0	0	0	0	0	0	
1506	Off Ocean Blvd @ 375	2011	DI	26	4	0	0	0	0	0	0	0	0	0	0	0	
1507	Off Ocean Blvd @375	2011	DI	130	4	0	0	0	0	0	0	0	0	0	0	0	
1508	Off Ocean Blvd @375	2011	DI	101	4	0	0	0	0	0	0	0	0	0	0	0	
1509	Smith Ave	1955	CU	181	1	0	0	0	0	0	0	0	0	0	0	0	
1510	Atlantic Ave.	2012	PWDI	5	16	0	0	0	0	0	0	0	0	0	0	0	
1512	Maple Road	2012	PWDI	30	8	0	0	0	0	0	0	0	0	0	0	0	
1514	Mill Rd @ Pine Rd (crossing)	2007	DI	37	12	0	0	0	0	0	0	0	0	0	0	0	
1517	Oak Road	1960	CU	59	1	0	0	0	0	0	0	0	0	0	0	0	
1520	Auburn Ave (crossing Ashworth)	2005	PVC	31	8	0	0	0	0	0	0	0	0	0	0	0	
1521	Perkins Ave (crossing Ashworth)	2005	PVC	34	8	0	0	0	0	0	0	0	0	0	0	0	
326	Ocean Blvd: High St - Cusack Rd	1958	AC	487	10	0	0	0	1	0	0	0	-5	3	-1	-1	
995	Ocean Blvd.	1961	AC	96	8	0	0	0	1	0	0	0	-5	3	-1	-1	
1406	Ocean Blvd	1961	AC	50	8	0	0	0	1	0	0	0	-5	3	-1	-1	

ID	Main	Year Installed	Material	Length (ft)	Diameter (in)	MAIN BREAK	Bleeder?	PIPE AGE /	MATERIAL INTEGRITY	CRITICAL / SYSTEM	WATER QUALITY	HYDRAULIC CAPACITY	SCHEDULED WORK	OTHER FACTOR	RAW SCORE	STATUS PRIORITY	Page 30 of 30	Comments
178	Watsons Ln.	1950	CI	803	6	0	0	0	3	0	0	0	-5	0	-2		-2	
756	Sea Rd./Ocean Blvd.	1971	DI	145	8	0	0	0	0	0	0	0	-5	3	-2		-2	
774	Ocean Blvd.	1971	DI	434	8	0	0	0	0	0	0	0	-5	3	-2		-2	
798	Church Rd./Ocean Blvd.	2000	DI	875	8	0	0	0	0	0	0	0	-5	3	-2		-2	
799	Church Rd.	2000	DI	1,269	8	0	0	0	0	0	0	0	-5	3	-2		-2	
1260	Ocean Blvd	1971	DI	305	8	0	0	0	0	0	0	0	-5	3	-2		-2	
177	Watsons Ln.	1985	DI	798	12	0	0	0	0	2	0	0	-5	0	-3		-3	
800	South Rd	1958	CICL	1,246	8	0	0	0	2	0	0	0	-5	0	-3		-3	
1049	South Rd	1958	CICL	1,070	8	0	0	0	2	0	0	0	-5	0	-3		-3	
1170	Fairway Dr.	1973	CICL	996	8	0	0	0	2	0	0	0	-5	0	-3		-3	
1418	Watsons Ln	1985	DI	187	12	0	0	0	0	2	0	0	-5	0	-3		-3	
176	Watsons Ln.	1985	DI	104	12	0	0	0	0	0	0	0	-5	0	-5		-5	