

KNOLLWOOD ENERGY

Knollwood Energy of MA LLC
P.O. Box 30
Chester, New Jersey 07930

#PUC 13JAN16AM11:14

January 8, 2016

Debra A. Howland
Executive Director
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

Dear Ms Howland,

Enclosed please find applications for 10 systems to be part of the Knollwood Energy of MA LLC (NH-II-13-089) Class II Photovoltaic aggregation for New Hampshire Renewable Energy Certificates (RECs) generated from customer-sited sources, pursuant to New Hampshire Code of Administrative Rules Puc 2506.

Also enclosed are the Simplified Process Interconnection Application and Service Agreement, and the Certificate of Completion.

Electronic versions have been entered into the new online application system under batch number KN0415.

Paul Barker	Bill Haig
Darren Blood	John Hanson
Mike Blichmann	Peter and Elaine Klose
Rod Gagnon	Charlie Lovett
Zachary Gardner	Robert McDonald

Please feel free to contact me with any questions or further instructions.
Thank you for your consideration,

Linda Modica
New England REC Operations Manager
Knollwood Energy of MA LLC
973.879.7826
linda@knollwoodenergy.com

Who is submitting this request?

Aggregator

Aggregator Batch Number

KN0415

Aggregator name

Knollwood Energy

Aggregator Email

linda@knollwoodenergy.com

Other Aggregator name

Other aggregator email address

Facility Owner Name

Charles Lovett

Owner Prefix

Mr.

Facility Owner email

potslove@verizon.net

Owner Phone

603-823-5634

Facility Address

771 Wells Rd

Facility Town/City

Franconia

Facility State

NH

Facility Zip

03580

Is the facility address the same as the owner's mailing address

- Yes
- No

Mailing Address

1517 Profile Rd

Mailing Town/City

Franconia

Mailing State

NH

Mailing Zip

03580

Primary Contact (who should we call with questions)

Linda Modica

Contact Phone

Other Email Address

Facility Information

Class

II

Utility

PSNH

Other Utility Name

Date of Utility Signoff

07/27/2015

To obtain a GIS ID contact:

James Webb

408 517 2174

jwebb@apx.com

GIS ID (include "NON")

NON57206

Facility Operator Name, if applicable

Panel Quantity

40

Panel Make

LG

Panel Model

X NeON

Panel Rated Output

300

System capacity based on panels

12.0000

Inverter Quantity

2

Inverter Make

Sunnyboy

Additional Inverter Make

Rated Output - Primary Inverter

5000

Rated Output - Additional Inverter

System capacity based on inverters

10.00

System capacity in mW as stated on the interconnection agreement

10.0

Revenue Grade Meter Make

Focus

Meter Model

Other

Other Meter Model

7466943613139

Was this facility installed directly by the customer (no electrician involved)?

- Yes
 No

Electrician Name

Choice B

Other Electrician Name

13139M

Sign-off Electrician's License Number

Installation Company

ReVision Energy

Other Installation Company Name

Other Inst. Company Address

Other Inst. Company City

Other Inst. Company State

Other Inst. Company Zip

Independent Monitor Name

Paul Button

Monitor Company Name

Energy Audits Unlimited

Monitor Company Name

Monitor Company Name

Monitor Company Name

Other Monitor Company Name

Is the installer also the equipment vendor?

- Yes
 No

Equipment Vendor

Please attach your completed interconnection agreement including Exhibit B.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Please attach additional document here

https://fs30.formsite.com/jan1947/files/f-5-168-5834583_JITG1igN_Lovett_COC.pdf

Please attach additional document here

https://fs30.formsite.com/jan1947/files/f-5-173-5834583_Vg3PxnLb_Lovett_NHOS.pdf

Aggregator statement of accuracy

Sign your name using a mouse or, if you are using a touch-screen device, a stylus or other pointer.



Print Name

Linda Modica

Date Signed

01/07/2016

RECEIVED

AUG 07 2014

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA

SESD

Simplified Process Interconnection Application and Service Agreement

PSNH Application Project ID#: N3098

Contact Information:

Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate):

Customer or Company Name (print): Susan Retz & Charlie Lovett ✓

Contact Person, if Company: _____

Mailing Address: 1517 Profile Road

City: Franconia State: NH Zip Code: 03580

Telephone (Daytime): 603-823-5634 (Evening): _____

Facsimile Number: _____ E-Mail Address: saretz@verizon.net

Alternative Contact Information (e.g., System installation contractor or coordinating company, if appropriate):

Name: ReVision Energy, LLC contact Sara Bogue

Mailing Address: 7 Commercial Drive

City: Exeter State: NH Zip Code: 03833

Telephone (Daytime): 603-679-1777 (Evening): _____

Facsimile Number: _____ E-Mail Address: sbogue@revisionenergy.com

Electrical Contractor Contact Information (if appropriate):

Name: Same as Alternative Contract

Mailing Address: _____

City: _____ State: _____ Zip Code: _____

Telephone (Daytime): _____ (Evening): _____

Facsimile Number: _____ E-Mail Address: _____

Facility Site Information:

Facility (Site) Address: 771 Wells Rd ✓

City: Franconia State: NH Zip Code: 03580

Electric _____

Service Company: PSNH Account Number: 5656958404 ✓ Meter Number: G77011996 ✓

Account and Meter Number: Please consult an actual PSNH electric bill and enter the correct Account Number and Meter Number on this application. If the facility is to be installed in a new location, please provide the PSNH Work Request number.

PSNH Work Request # _____

Non-Default Service Customers Only:

Competitive Electric _____

Energy Supply Company: _____ Account Number: _____

(Customer's with a Competitive Energy Supply Company should verify the Terms & Conditions of their contract with their Energy Supply Company.)

**PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA**

Simplified Process Interconnection Application and Service Agreement

Facility Machine Information:

Generator/ Inverter Manufacturer: SMA ✓ Model Name & Number: Sunny Boy 5000TL-US ✓ Quantity: 2 ✓
 Nameplate Rating: 5 (kW) _____ (kVA) 240 (AC Volts) Phase: Single Three

Nameplate Rating: *The AC Nameplate rating of the individual inverter.*

System Design Capacity: 10 (kW) _____ (kVA) Battery Backup: Yes No

System Design Capacity: *The system total of the inverter AC ratings. If there are multiple inverters installed in the system, this is the sum of the AC nameplate ratings of all inverters.*

Net Metering: If Renewably Fueled, will the account be Net Metered? Yes No

✓ Prime Mover: Photovoltaic Reciprocating Engine Fuel Cell Turbine Other _____

✓ Energy Source: Solar Wind Hydro Diesel Natural Gas Fuel Oil Other _____

Inverter-based Generating Facilities:

UL 1741 / IEEE 1547.1 Compliant (Refer To Part Puc 906 Compliance Path For Inverter Units, Part Puc 906.01 Inverter Requirements)

✓ Yes No

The standard UL 1741.1 dated May, 2007 or later, "Inverters, Converters, and Controllers for Use With Independent Power Systems," addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers choose to submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL 1741.1. This term "Listed" is then marked on the equipment and supporting documentation. *Please include, any documentation provided by the inverter manufacturer describing the inverter's UL 1741/IEEE 1547.1 listing.*

External Manual Disconnect Switch:

An External Manual Disconnect Switch shall be installed in accordance with 'Part Puc 905 Technical Requirements For Interconnections For Facilities, Puc 905.01 Requirements For Disconnect Switches and 905.02 Disconnect Switch.'

✓ Yes No

Location of External Manual Disconnect Switch: DISCONNECT SHALL BE LOCATED ADJACENT TO OR IN CLOSE PROXIMITY TO PSNH METER.

Project Estimated Install Date: August 2014 Project Estimated In-Service Date: September 2014

Interconnecting Customer Signature:

I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the **Terms and Conditions for Simplified Process Interconnections** attached hereto:

Customer Signature: [Signature] Title: Homeowner Date: 8/14/14

Please include a one-line and/or three-line diagram of proposed installation. Diagram must indicate the generator connection point in relation to the customer service panel and the PSNH meter socket. Applications without such a diagram may be returned.

For PSNH Use Only

Approval to Install Facility:

Installation of the Facility is approved contingent upon the Terms and Conditions For Simplified Process Interconnections of this Agreement, and agreement to any system modifications, if required.

Are system modifications required? Yes No To be Determined

Company Signature: [Signature] Title: SR. ENGINEER Date: 8-7-14

From: PSNHSESD@eversource.com
 Subject: #N3098 Lovett PV (Franconia) - Authorization to Interconnect
 Date: July 27, 2015 at 11:11 AM
 To: saretz@verizon.net
 Cc: michael.motta@eversource.com, richard.labrecque@eversource.com, sbogue@revisionenergy.com

Dear Mr. Lovett:

We have processed the Exhibit B - Certificate of Completion for project # N3098 Lovett PV (Franconia) located at 711 Wells Road, Franconia, NH.

The Certificate of Completion has been reviewed and processed and a new net meter has been installed. Enrollment into the Net Metering program is complete and you may interconnect your project to the Eversource electrical distribution system in accordance with the *New Hampshire Code of Administrative Rules Chapter Puc 900 Net Metering For Customer-Owned Renewable Energy Generation Resources of 1000 Kilowatts or Less*, and the *Terms and Conditions for Simplified Process Interconnections*. Attached for your records is a copy of the "Certificate of Completion" and the "Simplified Process Interconnection Application and Service Agreement."

Please contact Michael.Motta@eversource.com or by calling (603) 634-2920 should you have any questions or require additional information.

Sincerely,

Michael D. Motta
 Senior Engineer, Eversource Distributed Generation

This e-mail, including any files or attachments transmitted with it, is confidential and/or proprietary and is intended for a specific purpose and for use only by the individual or entity to whom it is addressed. Any disclosure, copying or distribution of this e-mail or the taking of any action based on its contents, other than for its intended purpose, is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete it from your system. Any views or opinions expressed in this e-mail are not necessarily those of Northeast Utilities, its subsidiaries and affiliates dba Eversource Energy (Eversource). E-mail transmission cannot be guaranteed to be error-free or secure or free from viruses, and Eversource disclaims all liability for any resulting damage, errors, or omissions.

PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE
 INTERCONNECTION STANDARDS FOR INVERTERS
 SIZED UP TO 100 KVA (Continued)



Exhibit B - Certificate of Completion for Simplified Process Interconnections

Installation Information: Check if owner-installed

Customer or Company Name (print): Charlie Lovett & Susan Retz

Contact Person, if Company: _____

Mailing Address: 1517 Profile Road

City: Franconia State: NH Zip Code: 03580

Telephone (Daytime): 603-823-5634 (Evening): _____

Facsimile Number: _____ E-Mail Address: saretz@verizon.net

Address of Facility (if different from above): 711 Wells Rd

City: Franconia State: NH Zip Code: 03580

Generation Vendor: ReVision Energy, LLC Contact Person: Sara Bogue

I hereby certify that the system hardware is in compliance with Puc 900

Vendor Signature: Sara Bogue Date: 8/1/15

Electrical Contractor's Name (if appropriate): ReVision Energy

Mailing Address: 7 Commercial Drive

City: Exeter State: NH Zip Code: 03833

Telephone (Daytime): 603-679-1777 (Evening): _____

Facsimile Number: _____ E-Mail Address: sbogue@revisionenergy.com

License number: 13139M

Date of approval to install Facility granted by the Company: 8/8/14 Installation Date:

Application ID number: N3098

Inspection:

The system has been installed and inspected in compliance with the local Building Electrical Code of

FRANKLINIA, NH AND STATE BUILDING CODE
(City/County)

Signed (Local Electrical Wiring Inspector, or attach signed electrical inspection): [Signature]

Name (printed): WILLY B. CHASE

Date: 7/7/2015

Customer Certification:

I hereby certify that, to the best of my knowledge, all the information contained in this Interconnection Notice is true and correct. This system has been installed and shall be operated in compliance with applicable electrical standards. Also, the initial start up test required by Puc 905.04 has been successfully completed.

Customer Signature: [Signature] Date: 7/8/15



New Hampshire PUC REC Certification Application Owner Statements

The information provided on this application for New Hampshire Renewable Energy Certificate eligibility is accurate to the best of my knowledge and I authorize Knollwood Energy to act on my behalf in filing said application.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor, or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Christopher P. Murphy

Printed Name of signature owner

Christopher P. Murphy

Christopher P. Murphy (Oct 22, 2015)

Signature of system owner