



REC 16-175

Knollwood Energy of MA LLC
P.O. Box 30
Chester, New Jersey 07930

HPUC 22 JAN 16 PM 12:06

January 15, 2016

Debra A. Howland
Executive Director
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

Dear Ms Howland,

Enclosed please find applications for 12 systems to be part of the Knollwood Energy of MA LLC (NH-II-13-089) Class II Photovoltaic aggregation for New Hampshire Renewable Energy Certificates (RECs) generated from customer-sited sources, pursuant to New Hampshire Code of Administrative Rules Puc 2506.

Also enclosed are the Simplified Process Interconnection Application and Service Agreement, and the Certificate of Completion.

Electronic versions have been entered into the new online application system under batch number KN16008.

Michael Melasecca	Sheila Piwowarczyk
Ed Mical	Brad Presby
David Munro	Doug Silver
Christopher Murphy	John Stone
David Phillips	Robert Twombly
Stephen Phillips	Shaine Young

Please feel free to contact me with any questions or further instructions.
Thank you for your consideration,

Linda Modica
New England REC Operations Manager
Knollwood Energy of MA LLC
973.879.7826
linda@knollwoodenergy.com

NH Public Utilities Commission

REC Aggregator Portal

New Users [CLICK HERE](#) to setup your account for this form. Creating an account enables you to partially complete the form and return later to finish it or to make changes after the form is submitted. Be sure to create your account **BEFORE** entering information into the form, or the information will be lost.

Existing Users [CLICK HERE](#)

Basic Information

Who is submitting this request?

Aggregator Batch Number

Aggregator name

Aggregator Email

Other Aggregator name

Other aggregator email address

Facility Owner Name

Facility Owner email

Owner Phone

Facility Address

Facility Town/City

Canterbury

Facility State

NH

Facility Zip

03224

Is the facility address the same as the owner's mailing address

- Yes
 No

Mailing Address

Mailing Town/City

Mailing State

Mailing Zip

Primary Contact (who should we call with questions)

Linda Modica

Contact Phone

Other Email Address

Facility Information

Class

II

Utility

Eversource

Other Utility Name

To obtain a GIS ID contact:

James Webb

408 517 2174

jwebb@apx.com

GIS ID (include "NON")

NON59104

Date of Initial Operation

07/06/2015

Facility Operator Name, if applicable

Panel Quantity

26

Panel Make

Solarworld

Panel Model

Sunmodule 275

Panel Rated Output

275

System capacity based on panels

0.0715

Inverter Quantity

26

Inverter Make

Enphase Energy

Add'l Inverter Quantity

NA

Additional Inverter Make

None

Add'l Inverter Model

Rated Output - Primary Inverter

Rated Output - Additional Inverter

System capacity based on single inverter make

System capacity based on two inverter types

System capacity in mW as stated on the interconnection agreement

Revenue Grade Meter Make

Was this facility installed directly by the customer (no electrician involved)?

- Yes
- No

Electrician Name & Number

Other Electrician Name & Number

Installation Company

Other Installation Company Name

Other Inst. Company Address

Other Inst. Company City

Other Inst. Company State

Other Inst. Company Zip

Independent Monitor Name & Company

Other Monitor Name and Company

Is the installer also the equipment supplier?

- Yes
 No

Equipment Vendor

Please attach your completed interconnection agreement including Exhibit B.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Please attach additional document here

https://fs30.formsite.com/jan1947/files/f-5-168-5894115_KZQOawGS_Melasecca_NHOS.pdf

Please attach additional document here

Aggregator statement of accuracy

Sign your name using a mouse or, if you are using a touch-screen device, a stylus or other pointer.

A rectangular box containing a handwritten signature in black ink. The signature is a cursive-style name, possibly "Linda Modica", written across the width of the box.

Print Name

Linda Modica

Date Signed

01/15/2016

RECEIVED

MAY 18 2015

EVERSOURCE
INTERCONNECTION STANDARDS FOR INVERTERS
SIZED UP TO 100 KVA

SESD

Simplified Process Interconnection Application and Service Agreement

Eversource Application Project ID#: N3468

Contact Information:

Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)

Customer or Company Name (print): SARAH McLASCECCA

Contact Person, if Company: _____

Mailing Address: 434 Shaker Road

City: Eastonbury State: NH Zip Code: 03224

Telephone (Daytime): 603-783-4201 (Evening): _____

Facsimile Number: _____ E-Mail Address: cdloweaver@gmail.com

Alternative Contact Information (e.g., System installation contractor or coordinating company, if appropriate):

Name: Sundial Solar

Mailing Address: 96 Hilliard Rd

City: Chester, NH State: NH Zip Code: 03258

Telephone (Daytime): _____ (Evening): _____

Facsimile Number: www.sundialsolarnh.com

603-961-0045

Electrical Contractor Contact Information (if appropriate):

Name: Potter Electric

Mailing Address: _____

City: Rich Potter State: _____ Zip Code: _____

Telephone (Daytime): 101 Bedn Hill Rd (Evening): _____

Facsimile Number: Belmont, NH 03220

Rpotterelectric@yahoo.com

Master Elect. #11696

Facility Site Information:

Facility (Site) Address: _____

City: _____ State: NH Zip Code: _____

Electric

Service Company: Eversource Account Number: 5686692502 Meter Number: 567755415

Account and Meter Number: Please consult an actual Eversource electric bill and enter the correct Account Number and Meter Number on this application. If the facility is to be installed in a new location, please provide the Eversource Work Request number.

Eversource Work Request # _____

Non-Default' Service Customers Only:

Competitive Electric

Energy Supply Company: _____ Account Number: _____

(Customer's with a Competitive Energy Supply Company should verify the Terms & Conditions of their contract with their Energy Supply Company.)

EVERSOURCE
 INTERCONNECTION STANDARDS FOR INVERTERS
 SIZED UP TO 100 KVA
 Simplified Process Interconnection Application and Service Agreement

Facility Machine Information:

Generator: Solar World Model Name & #: SUN MODULE SW 275
 Inverter Manufacturer: ENPHASE Number: M 250 Quantity: 26
 Nameplate Rating: 6,500 (kW) _____ (kVA) _____ (AC Volts) Phase: Single Three
 Nameplate Rating: The AC Nameplate rating of the individual inverter.
 System Design Capacity: 6,500 (kW) _____ (kVA) Battery Backup: Yes No
 System Design Capacity: The system total of the inverter AC ratings. If there are multiple inverters installed in the system, this is the sum of the AC nameplate ratings of all inverters.
 Net Metering: If Renewably Fueled, will the account be Net Metered? Yes No
 Prime Mover: Photovoltaic Reciprocating Engine Fuel Cell Turbine Other _____
 Energy Source: Solar Wind Hydro Diesel Natural Gas Fuel Oil Other _____

Inverter-based Generating Facilities:

UL 1741 / IEEE 1547.1 Compliant (Refer To Part Puc 906 Compliance Path For Inverter Units, Part Puc 906.01 Inverter Requirements)
 Yes No
 The standard UL 1741.1 dated May, 2007 or later, "Inverters, Converters, and Controllers for Use With Independent Power Systems," addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers choose to submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL 1741.1. This term "Listed" is then marked on the equipment and supporting documentation. *Please include, any documentation provided by the inverter manufacturer describing the inverter's UL 1741/IEEE 1547.1 listing.*

External Manual Disconnect Switch:

An External Manual Disconnect Switch shall be installed in accordance with 'Part Puc 905 Technical Requirements For Interconnections For Facilities, Puc 905.01 Requirements For Disconnect Switches and 905.02 Disconnect Switch.'
 Yes No
 Location of External Manual Disconnect Switch: Next to the meter

Project Estimated Install Date: End of May Project Estimated In-Service Date: Mid June

Interconnecting Customer Signature:

I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the Terms and Conditions for Simplified Process Interconnections attached hereto:

Customer Signature: [Signature] Title: Owner Date: 6/28/15

Please include a one-line and/or three-line diagram of proposed installation. Diagram must indicate the generator connection point in relation to the customer service panel and the Eversource meter socket. Applications without such a diagram may be returned.

For Eversource Use Only


Approval to Install Facility:

Installation of the Facility is approved contingent upon the Terms and Conditions For Simplified Process Interconnections of this Agreement, and agreement to any system modifications, if required.

Are system modifications required? Yes No To be Determined

Company Signature: [Signature] Title: Associate Engineer Date: 6/18/15

Interconnection Standards For Inverters Sized Up To 100 kVA
Exhibit B - Certificate of Completion for Simplified Process Interconnections



Installation Information:

Check if owner-installed

Customer or Company Name (print): Sun Dial Solar

Contact Person, if Company: Fuat Ari

Mailing Address: 96 Hilliard Rd

City: Chichester State: PA Zip Code: 03258

Telephone (Daytime): 603 961 0045 (Evening): _____

Facsimile Number: _____ E-Mail Address: Fuat.ari@sundialsolar.com

Facility Information: →

EverSource Meter # _____

Address of Facility (if different from above): 434 Shaker Rd

City: Cantabury State: N.H. Zip Code: 03204

Electrical Contractor Contact Information:

Electrical Contractor's Name (if appropriate): Roussow Power and Light

Mailing Address: 15 Bayley Rd

City: Chichester State: N.H. Zip Code: 03258

Telephone (Daytime): 603 491 8244 (Evening): _____

Facsimile Number: _____ E-Mail Address: Roussow.powerand.light@comcast.net

License number: 10750M

Date of approval to install Facility granted by the Company: _____

EverSource Application ID number: AN 3468

Inspection:

The system has been installed and inspected in compliance with the local Building/Electrical Code of:

City: Cantabury County: Merrimack

Signed (Local Electrical Writing Inspector, or attach signed electrical inspection):

Signature: [Signature]

Name (printed): Lisa Snyder, Cantabury Building Inspector Date: 7/6/15

Customer Certification:

I hereby certify that, to the best of my knowledge, all information contained in this Exhibit B - Certification of Completion is true and correct. This system has been installed and shall be operated in compliance with applicable standards. Also, the initial start-up test required by Pub. 915.04 has been successfully completed.

Please remember to provide digital photos of the installation, including the AC disconnect switch (if required), the existing EverSource meter, the inverters, and the point of electrical interconnection.

Customer Signature: _____

As a condition of interconnection you are required to send/fax a copy of this form to:

EverSource
Distributed Generation
780 North Commercial Street
P. O. Box 330, Manchester, NH 03105-0330



Sarah Melasecca <celloweaver@gmail.com>

#N3468 Melasecca PV (Canterbury) - Authorization to Interconnect

1 message

PSNHSESD@eversource.com <PSNHSESD@eversource.com>

Mon, Jul 13, 2015 at 3:36 PM

To: celloweaver@gmail.com

Cc: michael.motta@eversource.com, richard.labrecque@eversource.com, fuat@sundialsolarnh.com

Dear Ms. Melasecca:

We have processed the Exhibit B - Certificate of Completion for project # N3468 Melasecca PV (Canterbury) located at 434 Shaker Road, Canterbury, NH.

The Certificate of Completion has been reviewed and processed and a new net meter has been installed. Enrollment into the Net Metering program is complete and you may interconnect your project to the Eversource electrical distribution system in accordance with the *New Hampshire Code of Administrative Rules Chapter Puc 900 Net Metering For Customer-Owned Renewable Energy Generation Resources of 1000 Kilowatts or Less*, and the *Terms and Conditions for Simplified Process Interconnections*. Attached for your records is a copy of the "Certificate of Completion" and the "Simplified Process Interconnection Application and Service Agreement."

Please contact at Michael.Motta@eversource.com or by calling (603) 634-2920 should you have any questions or require additional information.

Sincerely,

Michael D. Motta
Senior Engineer, Eversource Distributed Generation

This e-mail, including any files or attachments transmitted with it, is confidential and/or proprietary and is intended for a specific purpose and for use only by the individual or entity to whom it is addressed. Any disclosure, copying or distribution of this e-mail or the taking of any action based on its contents, other than for its intended purpose, is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete it from your system. Any views or opinions expressed in this e-mail are not necessarily those of Northeast Utilities, its subsidiaries and affiliates dba Eversource Energy (Eversource). E-mail transmission cannot be guaranteed to be error-free or secure or free from viruses, and Eversource disclaims all liability for any resulting damage, errors, or omissions.

2 attachments

 N3468 Melasecca PV - Certificate of Completion.pdf
85K

 N3468 Melasecca PV - Processed Application.pdf
198K

New Hampshire PUC REC Certification Application Owner Statements

The information provided on this application for New Hampshire Renewable Energy Certificate eligibility is accurate to the best of my knowledge and I authorize Knollwood Energy to act on my behalf in filing said application.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor, or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Sarah B.E. Melasecca

Printed Name of signature owner

Sarah Melasecca

Sarah Melasecca (Oct 1, 2015)

Signature of system owner