



LCC 10 101

Knollwood Energy of MA LLC  
P.O. Box 30  
Chester, New Jersey 07930

NHPUC 22JAN16PM12:06

January 15, 2016

Debra A. Howland  
Executive Director  
New Hampshire Public Utilities Commission  
21 South Fruit Street, Suite 10  
Concord, NH 03301-2429

Dear Ms Howland,

Enclosed please find applications for 12 systems to be part of the Knollwood Energy of MA LLC (NH-II-13-089) Class II Photovoltaic aggregation for New Hampshire Renewable Energy Certificates (RECs) generated from customer-sited sources, pursuant to New Hampshire Code of Administrative Rules Puc 2506.

Also enclosed are the Simplified Process Interconnection Application and Service Agreement, and the Certificate of Completion.

Electronic versions have been entered into the new online application system under batch number KN16008.

Michael Melasecca	Sheila Piwowarczyk
Ed Mical	Brad Presby
David Munro	Doug Silver
Christopher Murphy	John Stone
David Phillips	Robert Twombly
Stephen Phillips	Shaine Young

Please feel free to contact me with any questions or further instructions.  
Thank you for your consideration,

Linda Modica  
New England REC Operations Manager  
**Knollwood Energy of MA LLC**  
973.879.7826  
[linda@knollwoodenergy.com](mailto:linda@knollwoodenergy.com)

## NH Public Utilities Commission

REC Aggregator Portal

---

New Users [CLICK HERE](#) to setup your account for this form. Creating an account enables you to partially complete the form and return later to finish it or to make changes after the form is submitted. Be sure to create your account **BEFORE** entering information into the form, or the information will be lost.

Existing Users [CLICK HERE](#)

Basic Information

---

Who is submitting this request?

Aggregator Batch Number

Aggregator name

Aggregator Email

Other Aggregator name

Other aggregator email address

Facility Owner Name

Facility Owner email

Owner Phone

Facility Address

Facility Town/City

Deerfield

Facility State

NH

Facility Zip

03037

Is the facility address the same as the owner's mailing address

- Yes
- No

Mailing Address

Mailing Town/City

Mailing State

Mailing Zip

Primary Contact (who should we call with questions)

Linda Modica

Contact Phone

Other Email Address

Facility Information

---

Class

II

Utility

Eversource

Other Utility Name

To obtain a GIS ID contact:

James Webb

408 517 2174

jwebb@apx.com

GIS ID (include "NON")

NON61642

Date of Initial Operation

12/17/2015

Facility Operator Name, if applicable

Panel Quantity

39

Panel Make

SunEdison

Panel Model

F270

Panel Rated Output

270

System capacity based on panels

0.1053

Inverter Quantity

39

Inverter Make

Enphase Energy

Add'l Inverter Quantity

NA

Additional Inverter Make

None

Add'l Inverter Model

Rated Output - Primary Inverter

Rated Output - Additional Inverter

System capacity based on single inverter make

System capacity based on two inverter types

System capacity in mW as stated on the interconnection agreement

Revenue Grade Meter Make

Was this facility installed directly by the customer (no electrician involved)?

- Yes
- No

Electrician Name & Number

Other Electrician Name & Number

Installation Company

Other Installation Company Name

Other Inst. Company Address

Other Inst. Company City

Other Inst. Company State

Other Inst. Company Zip

Independent Monitor Name & Company

Paul Button - Energy Audits Unlimited

Other Monitor Name and Company

Is the installer also the equipment supplier?

- Yes  
 No

Equipment Vendor

Please attach your completed interconnection agreement including Exhibit B.

[https://fs30.formsite.com/jan1947/files/f-5-99-5895710\\_mUtsDYmt\\_N4397\\_Piwowarczyk\\_PV\\_-\\_Proces](https://fs30.formsite.com/jan1947/files/f-5-99-5895710_mUtsDYmt_N4397_Piwowarczyk_PV_-_Proces)

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor or a designated representative.

A revenue quality meter is used to measure the electricity generated.

The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

A copy of the facility's interconnection agreement is attached.

Please attach additional document here

[https://fs30.formsite.com/jan1947/files/f-5-168-5895710\\_JBKamcbd\\_N4397\\_Piwowarczyk\\_PV\\_-\\_Certif](https://fs30.formsite.com/jan1947/files/f-5-168-5895710_JBKamcbd_N4397_Piwowarczyk_PV_-_Certif)

Please attach additional document here

[https://fs30.formsite.com/jan1947/files/f-5-173-5895710\\_1milqnjR\\_piowowarczyk\\_NHOS.pdf](https://fs30.formsite.com/jan1947/files/f-5-173-5895710_1milqnjR_piowowarczyk_NHOS.pdf)

Aggregator statement of accuracy

Sign your name using a mouse or, if you are using a touch-screen device, a stylus or other pointer.




Print Name

Linda Modica

Date Signed

01/15/2016



EVERSOURCE  
INTERCONNECTION STANDARDS FOR INVERTERS  
SIZED UP TO 100 KVA

Simplified Process Interconnection Application and Service Agreement

Eversource Application Project ID#:   N4397  

**Contact Information:**

Legal Name and Address of Interconnecting Customer (or, Company name, if appropriate)

Customer or Company Name (print):   Sheila Piwowarczyk  

Contact Person, if Company: \_\_\_\_\_

Mailing Address:   10 Colton Rd  

City:   Deerfield   State:   New Hampshire   Zip Code:   03037  

Telephone (Daytime):   (603) 463-7756   (Evening): \_\_\_\_\_

Facsimile Number: \_\_\_\_\_ E-Mail Address:   tequilalowrider@aol.com  

**Alternative Contact Information** (e.g., System installation contractor or coordinating company, if appropriate):

Name:   Granite State Solar  

Mailing Address:   197 North Main St  

City:   Boscawen   State:   New Hampshire   Zip Code:   03303  

Telephone (Daytime):   (603) 369-4318   (Evening): \_\_\_\_\_

Facsimile Number: \_\_\_\_\_ E-Mail Address:   justin@granitestatesolar.com  

**Electrical Contractor Contact Information** (if appropriate):

Name: \_\_\_\_\_

Mailing Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip Code: \_\_\_\_\_

Telephone (Daytime): \_\_\_\_\_ (Evening): \_\_\_\_\_

Facsimile Number: \_\_\_\_\_ E-Mail Address: \_\_\_\_\_

**Facility Site Information:**

Facility (Site) Address:   10 Cotton Rd  

City:   Deerfield   State:   NH   Zip Code:   03037  

Electric

Service Company:   Eversource   Account Number:   56419551015   Meter Number:   W63240346  

Account and Meter Number: Please consult an actual Eversource electric bill and enter the correct Account Number and Meter Number on this application. If the facility is to be installed in a new location, please provide the Eversource Work Request number.

Eversource Work Request # \_\_\_\_\_

**Non-Default Service Customers Only:**

Competitive Electric

Energy Supply Company: \_\_\_\_\_ Account Number: \_\_\_\_\_

*(Customer's with a Competitive Energy Supply Company should verify the Terms & Conditions of their contract with their Energy Supply Company.)*

EVERSOURCE  
INTERCONNECTION STANDARDS FOR INVERTERS  
SIZED UP TO 100 KVA

Simplified Process Interconnection Application and Service Agreement

**Facility Machine Information:**

Generator/ Model Name &  
Inverter Manufacturer: Enphase Number: m215 Quantity: 39  
Nameplate Rating: .225 (kW) \_\_\_\_\_ (kVA) \_\_\_\_\_ (AC Volts) Phase: Single  Three

Nameplate Rating: *The AC Nameplate rating of the individual inverter.*

System Design Capacity: 8.77 (kW) \_\_\_\_\_ (kVA) Battery Backup: Yes  No

System Design Capacity: *The system total of the inverter AC ratings. If there are multiple inverters installed in the system, this is the sum of the AC nameplate ratings of all inverters.*

Net Metering: If Renewably Fueled, will the account be Net Metered? Yes  No

Prime Mover: Photovoltaic  Reciprocating Engine  Fuel Cell  Turbine  Other \_\_\_\_\_

Energy Source: Solar  Wind  Hydro  Diesel  Natural Gas  Fuel Oil  Other \_\_\_\_\_

**Inverter-based Generating Facilities:**

UL 1741 / IEEE 1547.1 Compliant (Refer To Part Puc 906 Compliance Path For Inverter Units, Part Puc 906.01 Inverter Requirements)  
Yes  No

The standard UL 1741.1 dated May, 2007 or later, "Inverters, Converters, and Controllers for Use With Independent Power Systems," addresses the electrical interconnection design of various forms of generating equipment. Many manufacturers choose to submit their equipment to a Nationally Recognized Testing Laboratory (NRTL) that verifies compliance with UL 1741.1. This term "Listed" is then marked on the equipment and supporting documentation. *Please include, any documentation provided by the inverter manufacturer describing the inverter's UL 1741/IEEE 1547.1 listing.*

**External Manual Disconnect Switch:**

An External Manual Disconnect Switch shall be installed in accordance with 'Part Puc 905 Technical Requirements For Interconnections For Facilities, Puc 905.01 Requirements For Disconnect Switches and 905.02 Disconnect Switch.'

Yes  No

Location of External Manual Disconnect Switch: Next to the meter

Project Estimated Install Date: October Project Estimated In-Service Date: October

**Interconnecting Customer Signature:**

I hereby certify that, to the best of my knowledge, all of the information provided in this application is true and I agree to the **Terms and Conditions for Simplified Process Interconnections** attached hereto:

DocuSigned by: [Signature] Date: 9/15/2015  
Customer Signature: \_\_\_\_\_ Title: Homeowner Date: \_\_\_\_\_

**Please include a one-line and/or three-line diagram of proposed installation. Diagram must indicate the generator connection point in relation to the customer service panel and the Eversource meter socket. Applications without such a diagram may be returned.**


**For Eversource Use Only**

**Approval to Install Facility:**

Installation of the Facility is approved contingent upon the Terms and Conditions For Simplified Process Interconnections of this Agreement, and agreement to any system modifications, if required.

Are system modifications required? Yes  No  To be Determined

Company Signature: [Signature] Title: Associate Engineer Date: 10/26/15



Eversource  
Interconnection Standards For Inverters Sized Up To 100 kVA  
Exhibit B - Certificate of Completion for Simplified Process Interconnections

**Installation Information:**  Check if owner-installed  
Customer or Company Name (print): Sheila Piwowarczyk  
Contact Person, if Company: \_\_\_\_\_  
Mailing Address: 10 Cotton Rd  
City: Deerfield State: New Hampshire Zip Code: 03037  
Telephone (Daytime): (603) 463-7756 (Evening): \_\_\_\_\_  
Facsimile Number: \_\_\_\_\_ E-Mail Address: tequilalowrider@aol.com

**Facility Information:** → Eversource Meter # W63240346  
Address of Facility (if different from above): \_\_\_\_\_  
City: \_\_\_\_\_ State: \_\_\_\_\_ Zip Code: \_\_\_\_\_

**Electrical Contractor Contact Information:**  
Electrical Contractor's Name (if appropriate): Granite State Solar  
Mailing Address: 197 North Main St  
City: Boscawen State: New Hampshire Zip Code: 03303  
Telephone (Daytime): (603) 369-4318 (Evening): \_\_\_\_\_  
Facsimile Number: \_\_\_\_\_ E-Mail Address: justin@granitestatesolar.com  
License number: 0366 C

Date of approval to install Facility granted by the Company: 10/23/15  
Eversource Application ID number: #N 4397

**Inspection:**  
The system has been installed and inspected in compliance with the local Building/Electrical Code of:  
City: Deerfield N.H. County: Rockingham  
Signed (Local Electrical Wiring Inspector, or attach signed electrical inspection):  
Signature: Richard H. Pelletier  
Name (printed): Rick Pelletier Date: 12/17/15

**Customer Certification:**  
I hereby certify that, to the best of my knowledge, all information contained in this Exhibit B - Certification of Completion is true and correct. This system has been installed and shall be operated in compliance with applicable standards. Also, the initial start-up test required by Puc. 905.04 has been successfully completed.  
Please remember to provide digital photos of the installation, including the AC disconnect switch (if required), the existing Eversource meter, the inverters, and the point of electrical interconnection.  
Customer Signature: [Signature]

As a condition of interconnection you are required to send/fax a copy of this form to:

Eversource  
Distributed Generation  
780 North Commercial Street  
P. O. Box 330, Manchester, NH 03105-0330  
Fax No.: (603) 634-2924

## New Hampshire PUC REC Certification Application Owner Statements

The information provided on this application for New Hampshire Renewable Energy Certificate eligibility is accurate to the best of my knowledge and I authorize Knollwood Energy to act on my behalf in filing said application.

The project described in this application will meet the metering requirements of PUC 2506 including:

Electricity generation in megawatt hours shall be reported to the GIS quarterly with a statement that the submission is accurate by the owner of the source, the independent monitor, or a designated representative.

A revenue quality meter is used to measure the electricity generated.


The facility owner has certified to the independent monitor that the meter operates according to manufacturing standards.

The meter shall be maintained according to the manufacturer's recommendations.

The project is installed and operating in conformance with applicable building codes.

SHEILA PIWOWARCZYK

Printed Name of signature owner

  
Signature of system owner