

AFFIDAVIT OF MARK DRISCOLL

Mark Driscoll, being duly sworn, deposes and says:

- (1) I am the plant manager and duly authorized representative of Pinetree Power, Inc. ("PPI") (MS337) for the purpose of certifying Class III RPS certificates in New Hampshire.
- (2) Attached to this affidavit are accurate copies of emissions data for Pinetree Power, Inc. facility for the months of April, May & June 2013.
- (3) The attached emissions data demonstrate that Pinetree Power, Inc's. Average NOx emission rate during the second quarter of 2013 was equal to or less than the 0.075 lbs/MMbtu threshold level required for Class III certificates.
- (4) Further, the affiant sayeth naught.

Date: 7/17/13

Mark Driscoll
Mark Driscoll

STATE OF NEW HAMPSHIRE
COUNTY OF GRAFTON, SS.

Personally appeared the person signing the above affidavit, and swore that it is true to the best of his knowledge and belief.

Date: July 17, 2013

Pamela S Landry
Notary Public



GSI Emission Chart 2013

BETHLEHEM

MSS 337

CT00218-07

2013	Operation Hours	Generation Gross MWh	Generation Net MWh	CO Tons	CO lbs.	CO lb/MWh	NOX Tons	NOX lbs.	NOX lb/MMbtu	NOX lbs/hr	Heat Input	SOX lb/MWh	SOX Tons	SOX lbs.	Particulate lb/MWh	Particulate Tons	Particulate lbs.	Mercury lb/MWh
January	744	12723.84	11480	40.36	80720	7.031	8.68	17360	0.072	23.32	323.889	0.0164	0.0640	127.95	0.0234	0.2790	558.00	0.000066
February	669.8	11465.28	10369	38.06	76120	7.341	8.0	16000	0.072	23.90	331.944	0.0164	0.0576	115.19	0.0234	0.2512	502.35	0.000065
March	743	12,695.04	11415	41.88	83760	7.338	8.93	17860	0.072	24.01	333.472	0.0164	0.0639	127.78	0.0234	0.2786	557.25	0.000066
April	649.17	11048.00	10087	31.51	63020	6.248	7.06	14120	0.071	21.75	306.338	0.0165	0.0558	111.64	0.0235	0.2434	486.88	0.000065
May	740.62	12579.78	11455	34.36	68720	5.999	8.28	16560	0.071	22.36	314.930	0.0165	0.0637	127.37	0.0235	0.2777	555.47	0.000065
June	717.6	12142.08	11039	36.41	72820	6.597	8.29	16580	0.072	23.11	320.972	0.0165	0.0617	123.41	0.0236	0.2691	538.20	0.000066
July				0	#DIV/0!		0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00	#DIV/0!
August				0	#DIV/0!		0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00	#DIV/0!
September				0	#DIV/0!		0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00	#DIV/0!
October				0	#DIV/0!		0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00	#DIV/0!
November				0	#DIV/0!		0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00	#DIV/0!
December				0	#DIV/0!		0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00	#DIV/0!
Total	4264.19	72654.02	65845	222.58	445160	6.761	49.24	98480	0.072	23.08	#DIV/0!	#DIV/0!	0.3667	733.36	#DIV/0!	1.5991	3198.14	0.000066

PM tested in 2012 .40 lb/hr
 SO2 Tested 2009 .28 lb/hr

