

## RPS Emission Verification Summary

4th Quarter 2013 Summary		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu	
PT Tamworth	0.068	22-May-13	0.007	
PT Bethlehem	0.069	17-May-13	0.003	
		3-year test frequency approved by DES		
PT Fitchburg	0.072	27-Jun-13	0.0162	
PSNH SR5	0.068	1-Jun-11	0.0029	
		3-year test frequency approved by DES		
Indeck Energy	0.073	24-May-13	0.003	
Springfield Power	0.061	16-May-13	0.02	
Berlin				
Ryegate		18-Jun-13	0.0012	
Sullivan County Complex	annual tune-up & CE test	1-time test		
EMD Millipore	annual tune-up & CE test	1-time test		
AVH	annual tune-up & CE test	1-time test		