

AFFIDAVIT OF MARK DRISCOLL

Mark Driscoll, being duly sworn, deposes and says:

- (1) I am the plant manager and duly authorized representative of Pinetree Power, Inc. ("PPI") (MS337) for the purpose of certifying Class III RPS certificates in New Hampshire.
- (2) Attached to this affidavit are accurate copies of emissions data for Pinetree Power, Inc. facility for the months of April, May and June 2014.
- (3) The attached emissions data demonstrate that Pinetree Power, Inc.'s. Average NOx emission rate during the second quarter of 2014 was equal to or less than the 0.075 lbs/MMbtu threshold level required for Class III certificates.
- (4) Further, the affiant sayeth naught.

Date: 7/16/14

Mark Driscoll
Mark Driscoll

STATE OF NEW HAMPSHIRE
COUNTY OF GRAFTON, SS.

Personally appeared the person signing the above affidavit, and swore that it is true to the best of his knowledge and belief.

Date: 7/16, 2014

Pamela S Landry
Notary Public



Pinetree Power - Monthly Data Summary - March2014

Averages: 382.62 114.06 0.36 47.944 23.56 0.074 159.740 68372 4.72 0.90 18.12 8.94 0.97 424.46
 Totals: 81985.75 16961.80

DATE	CO PPM	CO LB/HR	CO LB/MMBTU	NOx PPM	NOx LB/HR	NOx LB/MMBTU	Steam K#/HR	Stack KSCFM	O2	OPACITY	NH3 LB/HR	UREA GAL/HR	Ratio NH3/Nox	CATALYST BED TEMP
3/1/2014	394.19	119.65	0.37	47.436	23.75	0.073	160.692	69714	4.73	1.12	18.17	8.96	0.90	421.40
3/2/2014	385.70	115.05	0.36	47.945	23.64	0.073	160.586	68565	4.69	0.79	18.16	8.95	0.98	423.54
3/3/2014	373.47	112.73	0.35	47.795	23.78	0.074	160.443	69205	4.78	1.33	18.44	9.09	0.90	418.83
3/4/2014	379.12	113.28	0.36	47.618	23.43	0.074	160.465	68382	4.85	1.20	18.68	9.21	0.89	421.20
3/5/2014	352.26	104.66	0.33	46.706	22.99	0.072	160.071	68433	4.79	1.20	18.34	9.05	0.99	419.21
3/6/2014	368.28	109.71	0.35	47.426	23.29	0.073	160.583	68200	4.81	1.30	18.39	9.07	0.89	421.52
3/7/2014	372.56	113.11	0.36	62.637	31.68	0.101	160.858	69801	4.94	1.41	15.83	7.81	0.75	370.12
3/8/2014	351.87	103.70	0.33	48.655	23.69	0.075	160.155	67665	4.73	0.95	18.08	8.92	1.01	429.36
3/9/2014	385.83	115.98	0.36	47.637	23.66	0.073	160.040	69115	4.74	1.09	18.13	8.95	1.02	426.51
3/10/2014	361.50	106.39	0.34	50.171	24.39	0.077	160.329	67456	4.71	1.01	18.16	8.95	1.99	428.93
3/11/2014	378.07	112.18	0.36	48.091	23.49	0.073	159.653	67968	4.62	0.91	18.25	9.01	0.78	426.73
3/12/2014	388.70	114.63	0.36	47.035	22.91	0.071	160.184	67744	4.62	1.15	18.01	8.89	2.22	428.89
3/13/2014	410.62	123.50	0.38	47.149	23.37	0.072	159.952	68993	4.67	1.51	17.97	8.86	1.00	422.20
3/14/2014	388.63	116.68	0.36	47.990	23.76	0.073	160.537	68858	4.61	1.31	18.11	8.92	0.94	428.78
3/15/2014	373.84	111.74	0.34	47.747	23.45	0.072	160.182	68301	4.47	0.87	17.68	8.72	0.82	427.72
3/16/2014	385.18	115.58	0.36	47.513	23.45	0.073	160.394	68663	4.69	0.82	17.77	8.75	0.68	428.91
3/17/2014	388.20	118.85	0.36	46.560	23.41	0.071	160.451	70046	4.71	1.38	17.93	8.86	0.92	424.12
3/18/2014	378.27	113.36	0.35	47.089	23.13	0.072	159.900	68323	4.68	1.03	17.91	8.83	0.97	426.86
3/19/2014	363.70	98.97	0.34	47.421	20.82	0.072	160.673	62793	4.62	1.51	18.29	9.02	1.65	427.17
3/20/2014	385.13	113.69	0.35	49.203	23.98	0.074	160.479	67802	4.49	0.29	18.24	9.02	0.16	431.33
3/21/2014	371.77	111.60	0.35	48.788	24.09	0.075	160.148	68689	4.70	0.24	18.73	9.25	1.92	427.72
3/22/2014	391.53	116.42	0.36	48.625	23.79	0.074	160.104	68002	4.68	0.55	18.64	9.22	1.16	430.80
3/23/2014	392.75	117.88	0.37	48.040	23.89	0.074	159.433	69194	4.81	0.37	18.45	9.10	0.93	428.07
3/24/2014	380.90	113.87	0.36	47.391	23.29	0.072	159.046	68312	4.69	0.79	18.42	9.09	0.95	426.58
3/25/2014	385.61	114.49	0.35	48.112	23.68	0.072	160.430	68331	4.52	0.66	18.45	9.10	1.54	425.12
3/26/2014	441.62	129.69	0.41	45.819	22.07	0.070	159.120	66954	4.67	0.53	18.65	9.20	1.04	424.54
3/27/2014	384.97	116.72	0.37	47.653	23.86	0.074	159.616	69638	4.85	0.63	18.44	9.11	-0.63	425.26
3/28/2014	377.19	111.76	0.35	46.321	22.65	0.070	160.832	68020	4.49	0.43	18.18	8.98	1.23	433.10
3/29/2014	368.37	110.92	0.34	45.778	22.83	0.070	160.215	69406	4.60	0.14	17.81	8.80	-0.44	431.73
3/30/2014	413.30	122.65	0.40	45.475	22.38	0.072	154.913	68439	5.06	0.39	17.81	8.79	0.71	429.19
3/31/2014	387.99	116.30	0.38	44.430	21.89	0.071	151.462	68531	5.24	0.85	17.75	8.75	1.07	422.94

Pinetree Power - Monthly Data Summary - April2014

Averages:	331.19	97.64	0.32	47.876	23.25	0.073	155.877	66998	4.76	0.15	18.04	8.90	1.04	424.76
Totals:		65615.09			15644.96									

DATE	CO PPM	CO LB/HR	CO LB/MMBTU	NOx PPM	NOx LB/HR	NOx LB/MMBTU	Steam K#/HR	Stack KSCFM	O2	OPACITY	NH3 LB/HR	UREA GAL/HR	Ratio NH3/Nox	CATALYST BED TEMP
4/1/2014	336.03	97.60	0.32	46.891	22.34	0.073	155.787	66150	4.83	0.31	18.77	9.25	1.44	426.83
4/2/2014	368.10	104.68	0.39	47.870	23.09	0.076	141.890	64128	6.10	0.15	16.66	8.22	0.43	420.06
4/3/2014														
4/4/2014	405.03	116.96	0.84	58.110	25.61	0.110	75.400	48226	11.67	1.22	8.21	4.04	0.77	227.94
4/5/2014	307.20	86.51	0.28	48.183	22.56	0.072	156.613	64872	4.42	0.12	18.64	9.20	1.53	421.98
4/6/2014	313.35	89.41	0.29	48.160	22.71	0.073	158.008	65353	4.59	0.02	18.94	9.35	0.82	425.90
4/7/2014	310.70	90.79	0.29	46.732	22.49	0.071	158.259	66886	4.65	0.39	18.68	9.21	1.14	427.81
4/8/2014	333.32	95.98	0.30	47.767	22.85	0.071	158.665	66430	4.31	0.17	18.40	9.08	0.15	431.34
4/9/2014	349.91	103.99	0.32	46.843	23.01	0.071	159.121	68324	4.54	0.09	18.46	9.11	0.56	431.10
4/10/2014	330.69	97.64	0.30	47.082	22.92	0.071	159.421	67659	4.45	0.32	18.25	9.01	1.08	436.58
4/11/2014	318.51	94.94	0.29	47.058	23.20	0.070	159.394	68576	4.42	-0.05	18.33	9.05	2.29	433.43
4/12/2014	330.42	99.82	0.30	48.520	24.17	0.073	158.927	69285	4.54	0.09	18.24	9.00	3.72	432.50
4/13/2014	330.74	99.25	0.31	47.303	23.44	0.072	159.368	68892	4.60	0.18	18.32	9.03	0.99	432.22
4/14/2014	318.09	93.60	0.29	46.103	22.35	0.068	159.991	67491	4.25	0.11	17.99	8.88	0.49	437.75
4/15/2014	313.75	94.43	0.28	47.914	23.87	0.070	159.842	69361	4.23	0.28	17.98	8.87	0.59	432.14
4/16/2014	322.36	96.49	0.30	47.257	23.45	0.072	159.357	68985	4.60	0.17	18.63	9.18	1.14	433.21
4/17/2014	326.53	99.41	0.30	46.449	23.29	0.070	159.783	69806	4.61	0.32	18.53	9.14	1.70	433.62
4/18/2014	326.12	97.41	0.30	47.828	23.52	0.072	159.968	68320	4.46	0.22	18.33	9.06	0.96	436.58
4/19/2014	339.38	102.49	0.31	47.176	23.56	0.071	160.105	69535	4.47	0.25	18.46	9.11	0.85	433.21
4/20/2014	326.38	98.00	0.30	47.008	23.16	0.071	159.788	68505	4.58	0.14	18.65	9.20	1.32	434.22
4/21/2014	325.33	97.76	0.29	46.897	23.25	0.070	160.049	68983	4.34	-0.02	18.14	8.95	1.38	434.19
4/22/2014	326.98	95.38	0.29	48.126	23.02	0.070	160.125	66434	4.15	-0.02	18.17	8.97	0.12	434.91
4/23/2014	326.09	96.45	0.29	47.075	23.05	0.069	160.054	68124	4.20	-0.02	18.09	8.92	0.70	430.64
4/24/2014	336.78	98.52	0.30	47.793	23.10	0.071	160.280	67178	4.31	0.07	18.31	9.03	1.17	433.19
4/25/2014	339.75	100.71	0.31	47.700	23.31	0.071	159.635	67927	4.36	0.08	18.33	9.05	1.60	432.14
4/26/2014	338.25	98.40	0.31	48.733	23.40	0.073	159.672	66722	4.33	0.09	18.56	9.17	0.20	435.10
4/27/2014	337.04	100.04	0.31	48.173	23.62	0.072	159.964	68171	4.36	0.19	18.71	9.23	0.22	432.20
4/28/2014	335.33	97.51	0.31	48.772	23.49	0.073	160.424	66821	4.42	0.07	18.75	9.26	2.24	435.22
4/29/2014	330.68	98.81	0.31	46.984	23.17	0.072	160.474	68526	4.70	-0.20	18.74	9.24	0.51	430.39
4/30/2014	301.55	88.59	0.28	47.900	23.22	0.073	160.061	67269	4.62	-0.31	19.00	9.38	0.20	431.62

Pinetree Power - Monthly Data Summary - May2014

Averages:	328.09	94.60	0.32	47.118	22.50	0.073	155.859	63911	4.81	-0.08	18.33	9.04	0.75	422.02
Totals:		56857.72			13494.57									

DATE	CO PPM	CO LB/HR	CO LB/MMBTU	NOx PPM	NOx LB/HR	NOx LB/MMBTU	Steam K#/HR	Stack KSCFM	O2	OPACITY	NH3 LB/HR	UREA GAL/HR	Ratio NH3/NOx	CATALYST BED TEMP
5/1/2014	311.51	90.42	0.28	47.589	22.81	0.070	160.112	66594	4.23	0.02	18.56	9.16	0.88	430.70
5/2/2014	313.41	89.96	0.28	48.109	22.78	0.072	159.990	65768	4.36	-0.04	19.14	9.44	-0.49	430.77
5/3/2014	304.43	88.33	0.28	48.267	23.30	0.072	159.577	67002	4.37	0.04	19.15	9.45	0.55	430.40
5/4/2014	317.26	90.99	0.29	48.480	23.03	0.072	159.949	65973	4.40	0.02	19.23	9.48	0.94	431.04
5/5/2014	331.98	95.48	0.34	49.465	23.68	0.076	158.986	66353	4.56	0.01	18.55	9.15	0.73	425.19
5/6/2014	314.70	89.82	0.29	49.196	23.28	0.074	159.301	65539	4.37	0.05	19.20	9.47	2.36	427.85
5/7/2014	304.77	88.31	0.28	47.805	22.83	0.073	159.672	66351	4.63	0.13	19.19	9.47	0.03	423.85
5/8/2014	311.41	87.66	0.29	47.586	22.22	0.072	159.875	64730	4.52	-0.02	18.90	9.33	-0.87	424.21
5/9/2014	317.35	90.12	0.29	48.368	22.81	0.072	159.326	65368	4.43	-0.01	18.65	9.22	1.45	423.95
5/10/2014	339.80	94.35	0.30	49.328	22.63	0.072	159.055	63521	4.14	-0.28	18.44	9.10	1.18	426.85
5/11/2014	345.69	98.09	0.31	48.114	22.68	0.072	159.274	65369	4.42	-0.29	18.96	9.36	0.76	423.90
5/12/2014	321.78	89.37	0.29	47.879	22.11	0.072	159.878	64024	4.47	-0.26	18.98	9.36	0.85	425.99
5/13/2014	334.82	95.62	0.31	46.331	21.83	0.070	159.639	65352	4.57	-0.16	18.88	9.30	0.74	423.90
5/14/2014	319.36	90.45	0.29	46.651	21.75	0.071	159.804	64587	4.59	-0.12	18.64	9.20	1.43	426.60
5/15/2014	337.76	95.37	0.31	46.512	21.93	0.070	160.133	65435	4.55	0.03	18.84	9.29	0.66	424.42
5/16/2014	339.58	96.34	0.31	48.547	22.68	0.073	160.551	64750	4.45	-0.03	18.85	9.31	1.01	428.03
5/17/2014	365.22	104.27	0.33	48.283	22.83	0.072	159.956	65620	4.47	-0.22	18.88	9.32	0.82	423.11
5/18/2014	319.80	90.90	0.30	47.672	22.38	0.073	159.056	65127	4.67	-0.03	19.04	9.39	1.63	425.13
5/19/2014	327.42	93.28	0.31	48.136	22.66	0.074	159.208	65189	4.72	0.11	18.97	9.36	0.52	420.82
5/20/2014	335.90	93.49	0.31	48.480	22.41	0.074	159.078	64018	4.60	-0.03	18.98	9.37	0.42	425.38
5/21/2014	332.37	94.34	0.30	48.121	22.69	0.072	159.694	65383	4.43	-0.13	18.62	9.19	0.65	426.11
5/22/2014	360.94	101.53	0.33	46.357	21.46	0.070	160.230	64319	4.45	-0.14	18.84	9.30	0.40	430.45
5/23/2014	310.87	125.82	0.71	26.040	21.56	0.096	65.084	32248	13.44	0.17	6.88	3.40	0.61	318.27
5/24/2014	358.76	100.96	0.33	47.950	22.24	0.072	158.244	64218	4.46	-0.22	18.22	8.98	1.06	426.60
5/25/2014	327.09	93.31	0.30	47.660	22.39	0.072	157.749	65221	4.44	-0.28	18.14	8.94	0.71	423.08
5/26/2014	326.34	90.93	0.30	48.140	22.10	0.071	158.913	63619	4.35	-0.37	17.86	8.81	0.52	425.95

GSI Emission Chart 2014

BETHLEHEM

MSS 337

CT00218-07

2014	Operation Hours	Generation Gross MWh	Generation Net MWh	MMBTU	CO Tons	CO lbs.	CO lb/MWh	NOX Tons	NOX lbs.	NOX lb/MMbtu	NOX lbs/hr	Heat Input	SOX lb/MWh	SOX Tons	SOX lbs.	Particulate lb/MWh	Particulate Tons	Particulate lbs.
January	741.22	12360.96	11167	188498.6	42.99	85980	7.899	8.31	16620	0.069	22.41	324.783	0.0168	0.0637	207.54	0.0240	0.1482	296.49
February	672	11410.46	10335	188577.8	36.34	72680	7.032	7.6	15204.2	0.073	23.51	322.055	0.0165	0.0578	188.16	0.0236	0.1344	268.80
March	743	12,582.72	11356	213812.3	42.98	85960	7.570	8.05	16100	0.074	23.56	318.378	0.0165	0.0639	208.04	0.0236	0.1466	297.20
April	682	11467.00	10440	182025.2	32.81	65620	6.285	7.82	15640	0.073	22.04	301.918	0.0167	0.0586	190.96	0.0236	0.1364	272.80
May	730.56	12265.9	11205	235474.3	33.7	67400	6.015	8.12	16240	0.071	22.25	313.380	0.0167	0.0628	204.56	0.0238	0.1461	292.22
June	720	12098	11004	223023.3	30.32	60640	5.511	7.98	15960	0.072	22.17	307.917	0.0167	0.0619	201.60	0.0238	0.1440	288.00
July					0		#DIV/0!	0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
August					0		#DIV/0!	0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
September					0		#DIV/0!	0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
October					0		#DIV/0!	0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
November					0		#DIV/0!	0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
December					0		#DIV/0!	0				#DIV/0!	#DIV/0!	0.0000	0.00	#DIV/0!	0.0000	0.00
Total	4288.78	72185.04	65507		219.14	438280	6.691	47.882	95764.2	0.072	22.66	#DIV/0!	#DIV/0!	0.3688	1200.86	#DIV/0!	0.8578	1715.51