

## RPS Emission Verification Summary

3rd Quarter 2014 Summary		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu	
PT Tamworth	0.068	May-14	0.004	
PT Bethlehem	0.072	May-14 3-year test frequency approved by DES	0.002	
PT Fitchburg	0.065	19-Jun-14	0.013	
PSNH SR5	0.0685	May-14 3-year test frequency approved by DES	0.0057	
Indeck Energy	0.074	May-14	0.004	
Springfield Power	0.065	May-14	0.02	
Berlin	0.057	10-Jun-14	0.0034	
Ryegate		18-Jun-13	0.0012	
<b>Thermal Sources</b>	<b>99% CE</b>	<b>maximum allowed</b>	<b>0.1 lb/mmbtu</b>	
Sullivan County Complex	annual tune-up & CE test	1-time test		
Conway Memorial	annual tune-up & CE test	1-time test		
Littleton Regional Healthcare	99.99% CE	17-Mar-14	boiler #1	0.056
	annual tune-up & CE test	1-time test	18-Mar-14 boiler #2	0.032
EMD Millipore	annual tune-up & CE test	1-time test		
AVH	99.99% CE	4-Jun-14	0.067	
	annual tune-up & CE test	1-time test		