

## 3rd 2009 Quarter Summary

Date 11/2/2009

Source Name	Emission Report Date (electronic)	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average
PT Tamworth	16-Oct-09	0.069	21-May-09	0.002
PT Bethlehem	9-Oct-09	0.072	20-May-09	0.004
PSNH SR5	26-Sep-09 (hard copy)	0.064	14-Nov-08	0.001
Indeck Energy conditional approved	Compliance testing Completed 10/20/09-Awaiting laboratory results and final test report.			
Springfield Power conditional approved	17-Oct-09	0.064	9/3/2009	0.02

h:testing and monitoring/RPS Verification Summary