




The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

DE 09-008
DE 08-024
DE 09-104
DE 08-051
DE 08-044



Thomas S. Burack, Commissioner
April 27, 2010

Debra A. Howland, Executive Director and Secretary
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

Re: Quarterly Emissions Verification Summary for Certified Renewable Energy Sources

Dear Ms. Howland:

Based on the attached summary, the New Hampshire Department of Environmental Services (DES) recommends certification of the following wood-fired power plants as renewable energy sources, because the facilities continue to meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

Pinetree Power, Inc.
1241 Whitefield Rd
Bethlehem, NH 03574

Pinetree Power-Tamworth, Inc.
469 Plains Rd
Tamworth, NH 03886

Public Service Company of New Hampshire (PSNH) Schiller Station # 5
400 Gosling Rd
Portsmouth, NH 03801

Springfield Power, LLC
54 Fisher Corner Road
Springfield, NH 03284

Indeck
151 Smith River Road
Alexandria, NH 03222



If you have any questions regarding DES's recommendations, please contact me at joseph.fontaine@des.nh.gov or (603) 271-6794.

Sincerely

Joseph T. Fontaine
Trading Programs Manager
Air Resources Division

cc: Maureen Reno, NH PUC

RPS Emission Verification Summary
RENEWABLE PORTFOLIO STANDARDS

1st 2010 Quarter Summary

Today's Date 21-Apr-10

Source Name	Emission Report Date (electronic)	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu
PT Tamworth	16-Apr-10	0.068	21-May-09	0.002
PT Bethlehem	15-Apr-10	0.070	20-May-09	0.004
PSNH SR5	27-Apr-10	0.067	13-May-09	0.001
Indeck Energy	21-Apr-10	0.064	19-Oct-09	0.009
Springfield Power	15-Apr-10	0.059	3-Sep-09	0.022

h:\testing and monitoring\RPS Verification-2010