

Babcock & Wilcox Power Generation Group NetDAHS©
Average Values Report
Version 59.0
Generated: 4/15/2011 07:16

Company: PSNH Schiller - Unit 5
Plant: 400 Gosling Road
City/St: Portsmouth, NH 03801
Source: Unit5

Period Start: 1/1/2011 00:00
Period End: 3/31/2011 23:59
Validation Type: 42/60 min
Averaging Period: 24 hr
Type: Block Avg

Period Start	Average nox ppm	Average nox_er_m #mmBtu	Average nox_mr_m #/hr	Average co2 %CO2	Maximum co2_mr_m tn/hr	Average stk_fl_cw kwscfh	Average mwe_1h
01/01/2011 00:00	42.8	0.066	43.9	14.23	71.3	11087	46.7
01/02/2011 00:00	37.0	0.058	37.5	13.95	69.3	10855	45.4
01/03/2011 00:00	42.2	0.066	43.3	13.93	70.0	11067	45.6
01/04/2011 00:00	40.3	0.063	41.9	13.87	70.4	11228	46.6
01/05/2011 00:00	41.6	0.066	43.2	13.82	69.3	11198	46.5
01/06/2011 00:00	40.1	0.063	41.8	13.82	69.6	11240	46.6
01/07/2011 00:00	41.7	0.066	43.2	13.75	68.8	11175	46.1
01/08/2011 00:00	41.3	0.066	43.0	13.68	69.1	11209	46.3
01/09/2011 00:00	41.2	0.066	42.4	13.71	68.6	11143	45.8
01/10/2011 00:00	43.2	0.067	44.7	14.04	70.3	11158	46.5
01/11/2011 00:00	42.0	0.065	42.7	14.15	69.7	11030	46.0
01/12/2011 00:00	41.4	0.066	42.3	13.60	67.8	11134	45.7
01/13/2011 00:00	38.7	0.060	39.3	14.02	69.6	11061	46.2
01/14/2011 00:00	41.3	0.064	42.0	14.20	70.1	11143	46.0
01/15/2011 00:00	38.8	0.060	39.4	14.12	69.4	11068	46.0
01/16/2011 00:00	37.4	0.059	37.9	13.95	68.5	11053	45.8
01/17/2011 00:00	39.9	0.061	40.9	14.19	70.4	11188	46.2
01/18/2011 00:00	42.7	0.067	43.7	13.96	70.5	11113	46.0
01/19/2011 00:00	40.3	0.064	41.0	13.68	67.4	11088	45.1
01/20/2011 00:00	41.1	0.065	41.5	13.88	68.4	11070	44.9
01/21/2011 00:00	41.2	0.066	41.2	13.64	66.5	10978	44.1
01/22/2011 00:00	42.2	0.066	42.4	13.88	68.8	11003	44.8
01/23/2011 00:00	41.8	0.065	41.8	13.96	69.1	10901	44.5
01/24/2011 00:00	39.2	0.061	39.8	14.17	71.7	11030	45.8
01/25/2011 00:00	39.4	0.063	38.4	13.61	70.5	10505	42.3
01/26/2011 00:00	36.0	0.056	33.6	13.99	67.4	10128	39.2
01/27/2011 00:00	35.5	0.058	35.4	13.72	67.7	11110	44.6
01/28/2011 00:00	37.9	0.063	36.5	13.65	67.6	10707	43.2
01/29/2011 00:00	40.4	0.064	40.3	13.79	66.8	11057	44.6
01/30/2011 00:00	37.4	0.059	37.2	13.96	67.3	10988	45.1
01/31/2011 00:00	39.2	0.060	39.0	14.19	68.3	10999	45.2

DISTRIBUTED
DOCKET

Babcock & Wilcox Power Generation Group NetDAHS®

Average Values Report

Version 59.0

Generated: 4/15/2011 07:16

Company: PSNH Schiller - Unit 5
 Plant: 400 Gosling Road
 City/St: Portsmouth, NH 03801
 Source: Unit5

Period Start: 1/1/2011 00:00
 Period End: 3/31/2011 23:59
 Validation Type: 42/60 min
 Averaging Period: 24 hr
 Type: Block Avg

Period Start	Average nox ppm	Average nox_er_m #mmBtu	Average nox_mr_m #/hr	Average co2 %CO2	Maximum co2_mr_m tn/hr	Average stk_fl_cw kwscfh	Average mwe_1h
02/01/2011 00:00	41.1	0.063	40.8	14.24	69.0	10933	45.4
02/02/2011 00:00	41.6	0.065	41.7	13.89	68.2	11027	45.5
02/03/2011 00:00	41.8	0.073	40.8	13.49	68.3	10633	42.8
02/04/2011 00:00	39.5	0.062	39.1	13.92	68.6	10917	44.7
02/05/2011 00:00	39.4	0.063	38.6	13.72	66.3	10794	43.8
02/06/2011 00:00	34.4	0.058	33.2	13.32	63.5	10608	42.2
02/07/2011 00:00	39.3	0.063	38.3	13.61	63.9	10715	42.9
02/08/2011 00:00	38.3	0.062	36.9	13.45	63.9	10651	42.6
02/09/2011 00:00	34.9	0.056	33.7	13.72	65.2	10586	42.9
02/10/2011 00:00	39.6	0.063	39.0	13.67	65.6	10733	44.5
02/11/2011 00:00	39.8	0.065	39.5	13.39	66.8	10718	42.9
02/12/2011 00:00	40.4	0.067	40.6	13.24	66.9	10944	43.7
02/13/2011 00:00	38.6	0.063	37.8	13.34	65.0	10765	42.1
02/14/2011 00:00	38.3	0.063	37.0	13.19	63.2	10475	42.2
02/15/2011 00:00	38.9	0.063	40.2	13.45	72.1	11064	45.5
02/16/2011 00:00	38.7	0.061	39.8	13.92	68.9	11169	46.6
02/17/2011 00:00	40.1	0.064	40.8	13.76	68.1	11087	46.1
02/18/2011 00:00	40.8	0.066	41.6	13.43	67.0	11097	45.7
02/19/2011 00:00	40.5	0.066	41.4	13.42	67.0	11155	45.9
02/20/2011 00:00	38.2	0.061	38.8	13.69	67.3	11080	46.0
02/21/2011 00:00	38.7	0.063	39.7	13.49	66.7	11125	46.0
02/22/2011 00:00	42.2	0.068	42.7	13.65	67.4	11119	44.9
02/23/2011 00:00	38.5	0.065	39.7	13.07	67.3	11092	43.6
02/24/2011 00:00	40.2	0.066	40.3	13.37	66.6	10971	44.1
02/25/2011 00:00	40.7	0.067	40.8	13.22	65.1	11073	44.7
02/26/2011 00:00	40.7	0.066	40.8	13.47	65.6	11057	44.9
02/27/2011 00:00	41.1	0.066	41.4	13.51	65.8	11120	45.1
02/28/2011 00:00	N/A	N/A	N/A	N/A	N/A	N/A	43.1

Babcock & Wilcox Power Generation Group NetDAHS®
Average Values Report
Version 59.0
Generated: 4/15/2011 07:17

Company: PSNH Schiller - Unit 5
Plant: 400 Gosling Road
City/St: Portsmouth, NH 03801
Source: Unit5

Period Start: 1/1/2011 00:00
Period End: 3/31/2011 23:59
Validation Type: 42/60 min
Averaging Period: 24 hr
Type: Block Avg

Period Start	Average nox ppm	Average nox_er_m #mmBtu	Average nox_mr_m #/hr	Average co2 %CO2	Maximum co2_mr_m tn/hr	Average stk_fl_cw kwscfh	Average mwe_1h
03/01/2011 00:00	N/A	N/A	N/A	N/A	N/A	N/A	N/A
03/02/2011 00:00	N/A	N/A	N/A	N/A	N/A	N/A	N/A
03/03/2011 00:00	37.3	0.096	33.5	9.99	70.6	8500	24.0
03/04/2011 00:00	40.1	0.066	40.9	13.29	68.3	10802	44.2
03/05/2011 00:00	37.7	0.063	38.0	13.07	63.6	10870	44.4
03/06/2011 00:00	32.9	0.079	30.2	9.86	64.6	8908	30.3
03/07/2011 00:00	38.4	0.065	38.4	12.83	63.2	10806	44.5
03/08/2011 00:00	35.7	0.060	37.2	12.98	67.2	11098	45.9
03/09/2011 00:00	35.0	0.058	36.5	13.20	66.7	11041	45.9
03/10/2011 00:00	35.7	0.060	36.9	12.95	66.3	11017	44.1
03/11/2011 00:00	39.3	0.064	39.2	13.33	64.8	10859	43.8
03/12/2011 00:00	38.2	0.062	39.0	13.42	66.7	11008	45.3
03/13/2011 00:00	40.7	0.067	42.4	13.35	67.1	11212	45.3
03/14/2011 00:00	41.5	0.067	42.1	13.62	66.9	10930	45.1
03/15/2011 00:00	N/A	N/A	N/A	N/A	N/A	11117	44.2
03/16/2011 00:00	N/A	N/A	N/A	N/A	N/A	11071	45.2
03/17/2011 00:00	N/A	N/A	N/A	N/A	N/A	10990	43.7
03/18/2011 00:00	41.8	0.068	41.4	13.51	66.0	10865	43.8
03/19/2011 00:00	42.8	0.068	43.2	13.84	67.7	11189	44.0
03/20/2011 00:00	42.7	0.067	43.3	13.86	68.7	11157	43.9
03/21/2011 00:00	42.1	0.068	42.4	13.54	67.5	11067	43.2
03/22/2011 00:00	40.0	0.069	40.1	12.72	64.7	10900	40.2
03/23/2011 00:00	41.8	0.071	41.8	12.86	64.7	10914	40.5
03/24/2011 00:00	38.1	0.063	38.8	13.18	66.0	11164	42.6
03/25/2011 00:00	40.8	0.066	41.9	13.39	66.8	11245	43.5
03/26/2011 00:00	36.7	0.059	37.4	13.54	66.6	11244	43.3
03/27/2011 00:00	35.4	0.057	35.7	13.59	66.5	11042	43.3
03/28/2011 00:00	35.9	0.058	35.6	13.51	65.6	10824	42.2
03/29/2011 00:00	38.6	0.062	39.0	13.50	66.4	11060	42.6
03/30/2011 00:00	38.1	0.062	37.8	13.53	67.0	10938	41.4
03/31/2011 00:00	40.4	0.067	40.4	13.28	65.5	11054	40.7
Final Average*	39.5	0.064	39.8	13.53	67.4	10935	44.0
Maximum*	43.2	0.096	44.7	14.24	72.1	11245	46.7
Minimum*	32.9	0.056	30.2	9.86	63.2	8500	24.0

*Does not include Invalid Averaging Periods ("N/A")