

## RPS Emission Verification Summary

2nd Quarter 2014 Summary		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu	
PT Tamworth	0.068	20-May-14	0.004	
PT Bethlehem	0.073	22-May-14 3-year test frequency approved by DES	0.002	
PT Fitchburg	0.062	19-Jun-14	0.013	
PSNH SR5	0.0703	14-May 3-year test frequency approved by DES	0.0057	
Indeck Energy	0.0734	28-May-14	0.004	
Springfield Power	0.061	27-May-14	0.02	
Berlin				
Ryegate		18-Jun-13	0.0012	
<b>Thermal Sources</b>	99% CE	maximum allowed	0.1 lb/mmbtu	
Sullivan County Complex	annual tune-up & CE test	1-time test		
Littleton Regional Healthcare	99.99% CE annual tune-up & CE test	17-Mar-14	boiler #1	0.056
		18-Mar-14	boiler #2	0.032
EMD Millipore	annual tune-up & CE test	1-time test		
AVH	99.99% CE annual tune-up & CE test	4-Jun-14 1-time test	0.067	