The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

Thomas S. Burack, Commissioner

April 25, 2011

Debra A. Howland, Executive Director and Secretary
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

Re: Quarterly Emissions Verification Summary for Certified Renewable Energy Sources (Dockets DE 08-024, DE 08-044, DE 08-051, DE 09-008 and DE 09-104)

Dear Ms. Howland:

Based on the attached summary, the New Hampshire Department of Environmental Services (DES) recommends certification of the following wood-fired power plants as renewable energy sources, because the facilities meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NOx), respectively:

Pinetree Power, Inc.
1241 Whitefield Rd
Bethlehem, NH 03574

Pinetree Power-Tamworth, Inc.
469 Plains Rd
Tamworth, NH 03886

Public Service Company of New Hampshire (PSNH) Schiller Station # 5
400 Gosling Rd
Portsmouth, NH 03801

RECEIVED
APR 25 2011
NH PUBLIC UTILITIES COMMISSION

Please note that the following plant did not meet the 0.075 lb/MMBtu NOx emission rate for the past quarter as required by statute (RSA 362-F) and is not eligible for first quarter 2011:

Indeck
151 Smith River Road
Alexandria, NH 03222

Please note that the following plant did not test for TSP within the past year as required by statute (RSA 362-F) and is no longer eligible:

Springfield Power, LLC
54 Fisher Corner Road
Springfield, NH 03284

If you have any questions regarding DES's recommendations, please contact me at joseph.fontaine@des.nh.gov or (603) 271-6794.

Sincerely,

Joseph T. Fontaine
Trading Programs Manager
Air Resources Division

cc: Maureen Reno, NH PUC