

2nd 2013 Quarter Summary

Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu
PT Tamworth	0.068	22-May-13	0.007
PT Bethlehem	0.07	17-May-13 3-year test frequency approved by DES	0.003
PSNH SR5	0.065	1-Jun-11 3-year test frequency approved by DES	0.0029
Indeck Energy	0.069	24-May-13	0.003
Springfield Power	0.06	16-May-13	0.02
Berlin			