



The State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES



Thomas S. Burack, Commissioner

August 9, 2013

NHPUC 12AUG'13PM2:40

Debra A. Howland, Executive Director and Secretary
New Hampshire Public Utilities Commission
21 South Fruit Street, Suite 10
Concord, NH 03301-2429

**Re: 2nd Quarter Emissions Verification Summary for Certified Renewable Energy Sources
(Dockets DE 08-024, DE 08-044, DE 08-051, DE 09-008, DE 09-104, and DE 12-091)**

Dear Ms. Howland:

Based on the attached summary, the New Hampshire Department of Environmental Services (DES) recommends certification of the following wood-fired power plants as renewable energy sources, because the facilities meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for particulate (TSP) and nitrogen oxides (NO_x), respectively:

Pinetree Power, Inc.
1241 Whitefield Rd
Bethlehem, NH 03574
GIS Unit ID #: MSS337

Pinetree Power-Tamworth, Inc.
469 Plains Rd
Tamworth, NH 03886
GIS Unit ID #: MSS592

Public Service Company of New Hampshire (PSNH) Schiller Station # 5
400 Gosling Rd
Portsmouth, NH 03801
GIS Unit ID #: MSS557

Indeck
151 Smith River Road
Alexandria, NH 03222
GIS Unit ID #: MSS14211


Please note that the following plant tested for TSP as required by statute (RSA 362-F) on May 16, 2013 and DES recommends recertification for the third quarter, but it continues to be ineligible for the second quarter:

Springfield Power, LLC
54 Fisher Corner Road
Springfield, NH 03284
GIS Unit ID #: MSS436

Please note that the following plant applied for conditional approval to generate RECs, but has not yet begun operation:

Berlin Station, LLC
One Community Street
Berlin, NH 03570
GIS Unit ID #:

If you have any questions regarding DES's recommendations, please contact me at joseph.fontaine@des.nh.gov or (603) 271-6794.

Sincerely,

Joseph T. Fontaine
Trading Programs Manager
Air Resources Division

cc: Barbara Bernstein, NH PUC