

Public Service Company of New Hampshire P. O. Box 330 Manchester, NH 03105-0330 (603) 634-3355 (603) 634-2438

bersara@psnh.com

A Northeast Utilities Company

Robert A. Bersak

Assistant Secretary and



September 8, 2010

Ms. Debra A. Howland Executive Director and Secretary New Hampshire Public Utilities Commission 21 Fruit Street, Suite 10 Concord, New Hampshire 03301

> Re: Docket No. DE 10-206

> > Public Service Company of New Hampshire Petition for License to Construct and Maintain Electric Lines Over and Across the Warner River in the Town of Warner, New Hampshire

Dear Secretary Howland:

On August 5, 2010, Public Service Company of New Hampshire ("PSNH") submitted a Petition for License to Construct and Maintain Electric Lines Over and Across the Warner River in the Town of Warner, New Hampshire, with attached exhibits, which has been docketed by the Commission as Docket No. DE 10-206. PSNH wishes to clarify or correct three items contained in that Petition.

- 1. At the end of Paragraph 6 of the Petition, please add the following sentence: The existing conductor and neutral wires were constructed and sagged using NESC heavy loading conditions at a maximum tension of 1.395 lbs.
- 2. Paragraph 9.I of the Petition should be corrected as follows: The minimum clearance was incorrectly stated to be 16.88 inches (1.4 feet). The correct clearance is 23.01 inches (1.9 feet).
- 3. Exhibit 3 should be clarified as follows: The 82 inch clearance identified on the left side of the drawing is a reference to the vertical clearance between the outer phases and the attachment point of the neutral.

PSNH appreciates the opportunity to provide these clarifications/corrections to the Commission. Should there be any technical questions concerning this filing, they may be directed to PSNH Engineer David M. Still, at 634-2078.

Sincerely,

Robert A. Bersak

Assistant Secretary and Assistant General Counsel

cc: Office of Consumer Advocate