


E-29/141 - T-302X/172

Rt 10

PROPOSED NHOS FIBER OPTIC CROSSING

E-29/140 - T-302X/171

E-29/139 - T-302X/170



**NHOS**  
 New Hampshire Optical Systems  
 New Hampshire Optical Systems, Inc.  
 99 Pine Hill Rd.  
 Nashua, NH 03063  
 (603-821-6467)

Project #TID-80-PRI-1  
 Drawing #AC-GIL-RIV-1

Date: 03/12/12  
 Revision # 1

Proposed  
 Ashuelot River Crossing  
 Gilsun, NH

Location:  
 Gilsun Rd - Rt 10, Gilsun, NH  
 Nearest cross street-Centennial Rd.

Sheet 1 of 2



LOCUS MAP (Not to Scale)



Spanmaster® Release 3.1 Sag / Tension Computations

Waveguide  
River and Rail Crossings

Selected Cables	X-SECT AREA (sq.in)	EFF MODULUS (psi)	NOMINAL DIAM (in)	EFF.EXP. COEFF. (1/F)	CABLE WEIGHT (lb/ft)	E* LOAD BEARING CAPACITY (lbs)	MAX. RATED LOAD (lbs)
1/4"6.6mEHS	0.0352	2.60E+07	0.250	5.60E-06	0.1210	914940	6650
ORF-O-288-LN Bundle	0.5782	2.70E+05	0.858	1.13E-05	0.1960	155982	651


NESC RESULTS

Loading Condition	Temp (F)	Ice Load (lb/ft)	Ice Thick (in)	Wind Constant (lb/ft)	Horz Wind Load (lb/ft)	Resultant Load (lb/ft)	Sag (ft)	Tension (lb)	% Len Chg From Input Conditions	Sag @ Point 117.5 ft	Horz Sag Comp (ft)	Vert Sag Comp (ft)	Vector Angle Deg
Rule 251 - Heavy	0.0	1.000	.50	.3	4.0	1.793	5.35	2307	0.11	5.36	2.52	4.72	28.1
232A1	120.0	0.000	.00	.0	0.0	0.317	2.81	779	0.01	2.81	0.00	2.81	0.0

Span Length = 235.00 ft  
 Span Sag = 2.35 ft (28.2 in)  
 Span Tension = 931 lb  
 Max Load = 6,650 lb  
 Usable load (60%) = 3,990 lb  
 Catenary Length = 235.063 ft  
 Stress Free Length @  
 Installed Temperature = 234.824 ft

Temp (F)	Midspan Sag (ft)	Tension (lb)	% Length Change	Clearance
-40.0	1.60	1,361	-0.01	N/A
-30.0	1.66	1,318	-0.01	N/A
-20.0	1.71	1,275	-0.01	N/A
-10.0	1.77	1,233	-0.01	N/A
.0	1.83	1,192	-0.01	N/A
10.0	1.90	1,151	-0.01	N/A
20.0	1.96	1,112	-0.01	N/A
30.0	2.04	1,073	-0.01	N/A
40.0	2.11	1,036	-0.01	N/A
50.0	2.19	999	0.00	N/A
60.0	2.27	964	0.00	N/A
70.0	2.35	930	0.00	N/A
80.0	2.44	897	0.00	N/A
90.0	2.53	865	0.00	N/A
100.0	2.62	835	0.01	N/A
110.0	2.71	806	0.01	N/A
120.0	2.81	779	0.01	N/A
130.0	2.91	752	0.01	N/A
140.0	3.01	727	0.02	N/A


Unloaded Strand  
 Sag = 1.12 ft (13.5 in) 0.48 %  
 Tension = 743 lb



E-29/140 - T-302X/171  
 (Existing joint owned utility pole (PSNH/Fairpoint) in existing Right-of-Way)

E-29/139 - T-302X/170  
 (Existing joint owned utility pole (PSNH/Fairpoint) in existing Right-of-Way)

Not to Scale



E-29/140 - T-302X/171

Construction Notes:

NHOS proposes to install a 1/4 inch metal supporting strand between the existing utility poles shown above that will traverse the river. The strand will be installed at the proposed height (see above). The supporting strand will be secured to each pole using double dead end attachments to prevent any sag in the wire and maintain proper clearances. NHOS will lash a one inch diameter fiber optic cable (PVC jacket) to the strand using a dual lash method to provide security of the fiber over the right of way. The fiber will be tagged with twenty four hour contact information at each pole clamp. NHOS will employ the proper safety personnel during the crossing installation. The proposed install will meet all proper clearances from other Utilities. (see above). Additional pole guys will be added per NESC Rule 264 and as directed by pole owners.



E-29/139 - T-302X/170

Notes:

- The heights of structures shown hereon are based on field measurements taken with a Nikon 362 total station during a site survey on 09/22/11.
- The horizontal distance between the nearest bridge edge and the existing overhead wires is approximately 5'-6".
- Because of the close horizontal proximity to the existing bridge structure, the simplified drawing is submitted with vertical distances measured to the structure. This process simplifies the preparation and review of the crossing without jeopardizing its intent to protect the safe usage of the waterway.
- The smallest vertical distance from the top of existing bridge deck to the lowest existing overhead wire is approximately 16".
- The vertical distance between the top of water and bridge deck is approximately 22".
- Vertical distances are representative of attachment heights after utility make ready moves are completed.
- Per the NESC handbook under Rule 235C2b(1)(a) and Table 238-1, clearance between power and fiber optic cable can be decreased to 30" at the pole and 12" mid-span when there is only a supply neutral (No Triplex). There is no triplex on these poles. The neutral is properly bonded to the PSNH's electrical down guy on pole E-29/140 - T-302X/171.



New Hampshire Optical Systems, Inc.  
 99 Pine Hill Rd.  
 Nashua, NH 03063  
 (603-821-6467)

Project #TID-80-PRI-1  
 Drawing #AC-GIL-RIV-1

Date: 03/12/12  
 Revision # 1

Proposed  
 Ashuelot River Crossing  
 Gilsum, NH

Location:  
 Gilsum Rd - Rt 10, Gilsum, NH  
 Nearest cross street-Centennial Rd.