

4th 2012 Quarter Summary

Todays Date **1-Feb-13**

Source Name	Emission Report Date	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu
PT Tamworth	30-Jan-13	0.064	13-Jun-12	0.003
PT Bethlehem	23-Jan-13	0.073	12-Jun-12	0.001
PSNH SR5	29-Jan-13	0.067	1-Jun-11 3-year test frequency approved by DES	0.0029
Indeck Energy	8-Jan-13	0.069	19-Jun-12	0.007
Springfield Power			6/20/2012	0.028 0.03

h:testing and monitoring/RPS Verification-2012