


CHAIRMAN  
Martin P. Honigberg

COMMISSIONERS  
Robert R. Scott

EXECUTIVE DIRECTOR  
Debra A. Howland

STATE OF NEW HAMPSHIRE



TDD Access: Relay NH  
1-800-735-2964

Tel. (603) 271-2431

FAX No. 271-3878

Website:  
www.puc.nh.gov

PUBLIC UTILITIES COMMISSION

21 S. Fruit St., Suite 10  
Concord, N.H. 03301-2429

February 6, 2015

James Webb  
Registry Administrator  
APX Environmental Markets  
224 Airport Parkway, Suite 600  
San Jose, CA 95110

Re: **Quarterly Emissions Verification Summary for Certified Renewable Energy Sources**

DE 08-024	Pinetree - Bethlehem	DE 09-104	Springfield Power
DE 08-044	Schiller Station #5	DE 12-091	Berlin Station
DE 08-051	Pinetree Power - Tamworth	DE 13-265	Pinetree - Fitchburg
DE 09-008	Indeck	DE 14-007	Ryegate Power Station
DE 14-182	Littleton Regional Healthcare	DE 14-296	Androscoggin Valley Hospital

Dear Mr. Webb:

Pursuant to RSA 362-F:11, III, Renewable Portfolio Standard eligibility determinations of generation facilities that use biomass fuels are conditional. Within ten days of receiving the quarterly notice from the New Hampshire Department of Environmental Services (DES) that a facility has met DES emissions standards, the Commission must designate the facility as eligible to produce Renewable Energy Certificates.

Based on the DES recommendation received February 3, 2015, the Commission hereby certifies the following wood-fired power plants as renewable energy sources for the fourth quarter of 2014, as the facilities meet average emission rates of 0.02 lb/MMBtu and 0.075 lb/MMBtu, for total suspended particulate matter (TSP) and nitrogen oxides (NOx), respectively:


Facility Name	Class	Address	NH Facility Code #	GIS Unit ID #
Pinetree Power, Inc.	III	1241 Whitefield Rd., Bethlehem, NH 03574	NH-III-08-004	MSS337
Pinetree Power-Tamworth, Inc.	III	469 Plains Rd., Tamworth, NH 03886	NH-III-08-005	MSS592
PSNH Schiller Station # 5	I	400 Gosling Rd., Portsmouth, NH 03801	NH-I-08-006	MSS557
Indeck	I	151 Smith River Rd., Alexandria, NH 03222	NH-I-10-033	MSS14211
Springfield Power, LLC	I/III	54 Fisher Corner Rd., Springfield, NH 03284	NH-I-10-030	MSS436
			NH-III-10-029	
Pinetree Power-Fitchburg, Inc.	III	4 Rowtier Dr., Westminster, MA 01473	NH-III-13-133	MSS538
Berlin Station, LLC	I	One Community St., Berlin, NH 03570	NH-I-12-019	MSS 16653
Ryegate Power Station	III	247 Weesner Drive, E. Ryegate, VT 05042	NH-III-14-006	MSS 2433

In addition, DES recommends certification of the following wood-fired boilers as thermal renewable energy sources. These facilities meet average emission rates of 0.10 lb/MMbtu for TSP and best management practices (BMP) for NOx.

Facility Name	Class	Address	NH Facility Code #	GIS Unit ID #
Littleton Regional Healthcare	I-T	600 St. Johnsbury Road, Littleton, NH 03561	NH-IT-14-094	NON 41354
Androscoggin Valley Hospital	I-T	59 Page Hill Road, Berlin NH 03570	NH-IT-14-144	NON 43842

If you have any questions regarding the DES recommendations, please contact Joe Fontaine at <mailto:joseph.fontaine@des.nh.gov> or 603-271-6794. Other questions should be directed to Barbara Bernstein at <mailto:barbara.bernstein@puc.nh.gov> or 603-271-6011.

Sincerely,



Debra A. Howland  
Executive Director

cc: Joe Fontaine, NHDES