

3rd Quarter 2015 Summary		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu	
PT Tamworth 300019	0.066	May-15	0.005	
PT Bethlehem 900026	0.07	Jun-15 3-year test frequency approved by DES	0.002	
PT Fitchburg	0.066	May-15	0.008	
PSNH SR5 1500012	0.0695	May-14 3-year test frequency approved by DES	0.0057	
Indeck Energy 900029	0.0747	May-15	0.002	
Springfield Power 1900031		Jun-15	0.037 ineligible	
Berlin 790137	0.057	26-Jun-15	0.0014	
Bridgewater Power 900021	0.066		n/a under Alternative Plan	
Ryegate	0.068	Nov-14	0.0007	
Thermal Sources	99% CE	maximum allowed	0.1 lb/mmbtu	
Sullivan County Complex	annual tune-up & CE test	1-time test	pending	
Conway Memorial recommended for 4th Quarter	99.999% 99.993% annual tune-up & CE test	1-time test	9-Sep-15 10-Sep-15 boiler #1 boiler #2	0.081 0.095 quarterly reporting of <90% capacity required
Grafton County Complex	annual tune-up & CE test	1-time test	pending	
State Office Park East	annual tune-up & CE test	1-time test	pending	
City of Claremont	annual tune-up & CE test	1-time test	pending	
Holderness School	annual tune-up & CE test	1-time test	pending	
EMD Millipore	99.95% CE annual tune-up & CE test	1-time test	13-Mar-15	0.009
Littleton Regional Healthcare	99.99% CE annual tune-up & CE test	1-time test	17-Mar-14 18-Mar-14	boiler #1 boiler #2 0.056 0.032
Warwick Mills	99.89% CE annual tune-up & CE test	1-time test	30-Sep-14 1-Oct-14	0.018
AVH	99.99% CE annual tune-up & CE test	1-time test	4-Jun-14	0.067