

| 2nd Quarter 2016 Summary      |  | 0.075 lb/mmbtu                                  | maximum allowed                               | 0.02 lb/mmbtu   |
|-------------------------------|--|---|---|---|
| Source Name                   | NOx #/MMBTU Quarter Average                    | TSP Test Date                                   | TSP Emission Average #/mmbtu                  |   |
| PT Tamworth<br>300019         | 0.086  | May-15  | 0.005   |   |
| PT Bethlehem<br>900026        | 0.070  | Jun-16<br>3-year test frequency approved by DES | 0.001   |   |
| PT Fitchburg                  | 0.066  | Jun-16  | 0.004   |   |
| PSNH SR5<br>1500012           | 0.069  | May-14<br>3-year test frequency approved by DES | 0.0057  |   |
| Indeck Energy<br>900029       | 0.073  | May-15  | 0.002   |   |
| Springfield Power<br>1900031  |  | Jun-15  | 0.037<br>ineligible                           |   |
| Berlin<br>790137              | 0.060  | 26-Jun-15                                       | 0.0014  |   |
| Bridgewater Power<br>900021   | 0.065  |   | n/a under Alternative Plan                    |   |
| Ryegate                       | 0.073  | Jun-16  | 0.0002  |   |
| <b>Thermal Sources</b>        | <b>99% CE</b>                                  | <b>maximum allowed</b>                          | <b>0.1 lb/mmbtu</b>                           |   |
| Sullivan County Complex       | annual tune-up & CE test                       | 1-time test                                     | pending                                       |   |
| Conway Memorial               | 99.999%<br>99.993%<br>annual tune-up & CE test | 1-time test                                     | 9-Sep-15 boiler #1<br>10-Sep-15 boiler #2     | 0.081<br>0.095  |
| Grafton County Complex        | annual tune-up & CE test                       | 1-time test                                     | quarterly reporting of <90% capacity required |   |
| State Office Park East        | annual tune-up & CE test                       | 1-time test                                     | pending                                       |   |
| City of Claremont             | annual tune-up & CE test                       | 1-time test                                     | pending                                       |   |
| Holderness School             | 99.998%<br>annual tune-up & CE test            | 1-time test                                     | 15-Dec-15                                     | 0.0075<br>quarterly reporting of <90% capacity required |
| EMD Millipore                 | 99.95% CE<br>annual tune-up & CE test          | 1-time test                                     | 13-Mar-15                                     | 0.009   |
| Littleton Regional Healthcare | 99.99% CE<br>annual tune-up & CE test          | 1-time test                                     | 17-Mar-14<br>18-Mar-14                        | boiler #1 0.056<br>boiler #2 0.032                      |
| Warwick Mills                 | 99.89% CE<br>annual tune-up & CE test          | 1-time test                                     | 30-Sep-14<br>1-Oct-14                         | 0.018   |
| AVH                           | 99.99% CE<br>annual tune-up & CE test          | 1-time test                                     | 4-Jun-14                                      | 0.067   |