

3rd Quarter 2016 Summary		0.075 lb/mmbtu	maximum allowed	0.02 lb/mmbtu
Source Name	NOx #/MMBTU Quarter Average	TSP Test Date	TSP Emission Average #/mmbtu	
PT Tamworth 300019	0.071	Jul-16	0.001	
PT Bethlehem 900026	0.069	Jun-16 3-year test frequency approved by DES	0.001	
PT Fitchburg	0.066	Jun-16	0.004	
PSNH SR5 1500012	0.070	May-14 3-year test frequency approved by DES	0.0057	
Indeck Energy 900029	0.074	Jun-16	0.002	
Springfield Power 1900031		Jun-16	0.094 ineligible	
Berlin 790137	0.056	16-Jun-16	0.0065	
Bridgewater Power 900021	0.069		n/a under Alternative Plan	
Ryegate	0.071	Jun-16	0.0002	
<b>Thermal Sources</b>	<b>99% CE</b>	<b>maximum allowed</b>	<b>0.1 lb/mmbtu</b>	
Sullivan County Complex	annual tune-up & CE test	1-time test	pending	
Conway Memorial	99.999% 99.993% annual tune-up & CE test	1-time test	9-Sep-15 10-Sep-15	boiler #1 0.081 boiler #2 0.095 quarterly reporting of <90% capacity required
Grafton County Complex	annual tune-up & CE test	1-time test	pending	
State Office Park East	annual tune-up & CE test	1-time test	pending	
City of Claremont	annual tune-up & CE test	1-time test	pending	
Holderness School	99.998% annual tune-up & CE test	1-time test	15-Dec-15	0.0075 quarterly reporting of <90% capacity required
EMD Millipore	99.95% CE annual tune-up & CE test	1-time test	13-Mar-15	0.009
Littleton Regional Healthcare	99.99% CE annual tune-up & CE test	1-time test	17-Mar-14 18-Mar-14	boiler #1 0.056 boiler #2 0.032
Warwick Mills	99.89% CE annual tune-up & CE test	1-time test	30-Sep-14 1-Oct-14	0.018
AVH	99.99% CE annual tune-up & CE test	1-time test	4-Jun-14	0.067