School Administrative Unit #76 Lyme School District

MHPLIC 15JUL'16AM11:09

PO Box 117

Lyme, New Hampshire 03768

Phone: 603-795-4431 Fax: 603-795-9407

July 13, 2016

Barbara A. Howland Executive Director New Hampshire Public Utilities Commission 21 South Fruit Street, Suite 10 Concord, NH 03301-2429

Dear Ms. Howland:

I write in response to your letter of June 16 regarding REC 16-543 and the application from the Lyme Elementary School for a Class I Thermal renewable energy certificate. The letter asked for further information regarding four items, and my responses are indicated in the following:

- 1. The GIS number for the Lyme Elementary School is NON85753.
- 2. The initial date of operation for the facility was the opening day of school for the 2014-15 year, August 20, 2014.
- 3. The equipment seller was Froling Energy of Peterborough, NH.
- 4. The completed table is attached.

I thank you for your attention and I will look forward to your further reply.

Sincerely,

Michael Harris

Michael Harris Superintendent

REC 16-543 Lyme Elementary School Class I Thermal REC Eligibility Application Request for Additional Information

Please also send an electronic copy via e-mail to executive.director@puc.nh.gov, and copy me at <u>barbara.bernstein@puc.nh.gov</u>. Should you have any questions, please do not hesitate to contact me. My direct line is 603-271-6011. I look forward to continuing to work with you to complete review of this docket.

Sincerely,

Enstain tubarat

Barbara Bernstein Sustainable Energy Division

Cc: Michael Harris, Superintendent, Lyme School District Jim Van Valkenburgh, Froling Energy

Please complete the following table to assist in the review of the application for REC eligibility.									
Table 1: Description of the Equipment & Meters [Puc 2505.02 (d)(3)-(5),(10)-(14), 2506.04 (b)-(f), (m), & 2506.05]									
C = Provided in compliance with Puc 2500 NC = Compliance with Puc 2500 not demonstrated N/A = Not Applicable									
*if applicable	PUC 2500 Rule	Attachment #	Page #	Mass Flow Meter	Steam or Supply Water Temperature Sensor	Steam Pressure Sensor	Condensate or Return Water Temperature Sensor	Condensate Pressure Sensor	Thermal Energy Monitoring System
Product Name	2505.02(d)(3)	3-1	11-13	- C 1	$- c^{-}$	nla	-c	nla	C
Product Manufacturer*	2505.02(d)(3)	3-1	11-13	- C -	Č –	nla	- c -	nla	C.
Model #*	2505.02(d)(3)	3-1	11-13	(C -	nla	C	nla	Ċ
Total System Accuracy 99%	2506.04(e),(f)	3-1	13	C	C	nía	C.	nía	C
Placement of sensor*	2506.02(d)(3)	3-1	15	C	(nla	C	nla	C-
Temperature operating range*	2506.02(d)(3)	3-1	13	C	Č	nla	C	nla	Ċ
Flow operating range*	2506.02(d)(3)	3-1	13.15	C	nla	nja	nla	nla	nla
Pressure operating range*	2506.02(d)(3)	3-1	13	C	inla	nla	nla	nla	nla
Manufacturer's meter calibration recommendations	2506.02(d)(4)	3-1	TITI	C	nla	nla	nla	nla	C
Manufacturer's guaranteed accuracy	2506.05(d)(10)	3-1	11,13	С	Ċ	na	Ċ	nla	C
Useful thermal energy methodology & calculation	2506.04(m)	3-1	15	0	C	nla	С	nla	C
Meter accuracy discount factors*	2505.02(d)(13)	3-1	15	C	C	ng	C	na	C
Discount factor for operating energy & thermal losses*	2505,02(d)(14)	3-1	15	C	, Ç	ri/a	С	nla	C
Thermal energy data read hourly	2506.04(c)	NIA	NIA	Ν	IIA	nla	Λ (1 Λ	nla	G
Thermal energy totaled every 24 hours	2506.04(c)	NIA	NA	$\left \right\rangle$	IA	nla	NIA	nla	C
Thermal energy totaled monthly	2506.04(c)	NA	NA		TT	nía		4/4	C
Thermal energy totaled quarterly	2506.04(c)	NIA	NIA	/ M	11 1	nía	1 VII I	NIG	C
Manufacturer's specifications for heat meters followed	2506,04(d)	3-1	15	C	C	nla	C	nla	C
Rated thermal heating capacity	2×39	Btu/hr	o	0.	7 <u> </u>		calcula /3,412.142	tion 2 = 205,	15 KW