

DW 19-131 Omni Complaint
 Omni Properties: Exterior Shutoffs & Interior Plumbing
 West of Rte 302
 (Photos taken Sep 10, 2020)

	Photo of Exterior Shutoff	Distance From Exterior Shutoff to Building	Photo(s) of Interior Plumbing
Served from 16-inch Main West of Rte 302:			
Base Lodge	#1	12'	#2, #3
Alpine Club Kitchen & Bathroom	Not found	-	#4
Served from 12-inch Main West of Rte 302:			
First Aid Building	#5	7'	#6
Ski Area Maintenance Building	Not found	-	#7
Served from 8-inch Mains West of Rte 302:			
Rosebrook Rec Center (Note 1)	#8	(Note 2)	#9
Fabyans Restaurant	#10	1'	#11

(1) Building unoccupied, meter pulled.

(2) Blue paint marking indicates shutoff less than 15' from building.



Photo #1

Exterior Shutoff

Base Lodge



Photo #2

Interior Plumbing (Fire)

Base Lodge



Photo #3

Interior Plumbing (Domestic)

Base Lodge



Photo #4

Interior Plumbing (Fire & Domestic)

Alpine Club

0



Photo #5

Exterior Shutoff

First Aid Building



Photo #6

Interior Plumbing (Domestic)

First Aid Building



Photo #7

Interior Plumbing (Domestic)

Ski Area Maintenance Building



Photo #8

Exterior Shutoff

Rosebrook Rec Center



Photo #9

Interior Plumbing (Fire & Domestic)

Rosebrook Rec Center



Photo #10

Exterior Shutoff

Fabyans Restaurant



Photo #11

Interior Plumbing (Domestic)

Fabyans Restaurant