



780 N. Commercial Street
P.O. Box 330
Manchester, NH 03105-0330

Erik Newman
Senior Counsel

603-634-2459
Erik.newman@eversource.com

August 18, 2020

Ms. Debra A. Howland
Executive Director and Secretary
New Hampshire Public Utilities Commission
21 S. Fruit Street, Suite 10
Concord, New Hampshire 03301

**Re: SUPPLEMENT TO DOCKET 20-033
PETITION OF PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE D/B/A
EVERSOURCE ENERGY FOR LICENSE TO CONSTRUCT AND MAINTAIN
ELECTRIC LINES OVER AND ACROSS STATE OWNED LAND IN RAYMOND,
NEW HAMPSHIRE**

Dear Director Howland:

Enclosed for filing with the Commission in Docket 20-033, please find Public Service Company of New Hampshire d/b/a Eversource Energy's supplemental replacement petition encompassing the following revisions discussed with the PUC's Safety Division:

- Expanded project scope to include replacement of existing shield wire with communications wire between Deerfield substation and Scobie Pond Substation as depicted in replacement Exhibit 2 and in Paragraph 2 of the enclosed replacement petition;
- Replacement Exhibit 2 drawing depicting Structures 242 & 243 on Eversource's 345kV 373 Line changed as follows: (i) Temperature rating for the conductor was changed from 212 deg F to 285 deg F; (ii) Clearance distance from max sag to state land changed from 45' to 36.8'; (iii) NESC Table clearance standard changed from "roads, streets and other areas subject to truck traffic (24.7')" to "track rails of railroads (32.7'");
- Petition Paragraph 7 reference to the 2017 NESC changed to 2012 NESC;

Pursuant to the Commission's notice of March 17, 2020, this filing is only being provided by email.

Thank you for your assistance. Please let me know if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Erik Newman".

Erik Newman
Senior Counsel

cc via e-mail w/Encl.: Service List