

780 N. Commercial Street P.O. Box 330 Manchester, NH 03105-0330

Erik Newman Senior Counsel

603-634-2459 Erik.newman@eversource.com

August 6, 2020

Ms. Debra A. Howland Executive Director and Secretary New Hampshire Public Utilities Commission 21 S. Fruit Street, Suite 10 Concord, New Hampshire 03301

## Re: SUPPLEMENT TO DOCKET 20-103 PETITION OF PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE D/B/A EVERSOURCE ENERGY FOR LICENSE TO CONSTRUCT AND MAINTAIN ELECTRIC LINES OVER AND ACROSS STATE OWNED LAND IN MERRIMACK, NEW HAMPSHIRE

Dear Director Howland:

Enclosed for filing with the Commission in Docket 20-103, please find Public Service Company of New Hampshire d/b/a Eversource Energy's supplement encompassing a replacement Exhibit 2 drawing depicting Structures 95, 96 & 97 on Eversource's 345kV 3195 Line. The specific changes to Exhibit 2 are as follows: (i) Sag conditions for the OPGW were corrected from -20 deg with ½" of ice to 32 deg with ½" of ice; (ii) Reference to NESC Rule 250B was removed as being unnecessary; and (iii) Plan View Legend was corrected – "3195 Line 115kV" was corrected to "3195 Line 345KV".

In addition, Paragraph 7 of the Petition should reference the 2012 NESC, not 2017 NESC.

Pursuant to the Commission's notice of March 17, 2020, this filing is only being provided by email.

Thank you for your assistance. Please let me know if you have any questions.

Sincerely,

Erik Newman Senior Counsel

cc via e-mail w/Encl.: Service List