



780 N. Commercial Street
P.O. Box 330
Manchester, NH 03105-0330

Erik Newman
Senior Counsel

603-634-2459
Erik.newman@eversource.com

August 12, 2020

Ms. Debra A. Howland
Executive Director and Secretary
New Hampshire Public Utilities Commission
21 S. Fruit Street, Suite 10
Concord, New Hampshire 03301

**Re: SUPPLEMENT TO DOCKET 20-103
PETITION OF PUBLIC SERVICE COMPANY OF NEW HAMPSHIRE D/B/A
EVERSOURCE ENERGY FOR LICENSE TO CONSTRUCT AND MAINTAIN
ELECTRIC LINES OVER AND ACROSS STATE OWNED LAND IN
MERRIMACK, NEW HAMPSHIRE**

Dear Director Howland:

Enclosed for filing with the Commission in Docket 20-103, please find Public Service Company of New Hampshire d/b/a Eversource Energy's supplemental petition encompassing the following revisions discussed with the PUC's Safety Division:

- Replacement Exhibit 2 drawing depicting Structures 95, 96 & 97 on Eversource's 345kV 3195 Line changed as follows: (i) Sag conditions for the OPGW were corrected from -20 deg with 1/2" of ice to 32 deg with 1/2" of ice; (ii) Reference to NESC Rule 250B was removed as being unnecessary; (iii) The Structure 97 longitude and latitude has changed from -71.49562763, 42.82941310 to -71.49562508, 42.82942321; (iv) Plan View Legend was corrected – "3195 Line 115kV" was corrected to "3195 Line 345KV"; and (v) distance between Strs. 95 to 97 changed from 1301.08 to 1306.08;
- Petition Paragraph 5 distance for the Structure Span between Strs. 95 to 97 changed from 1301.08 to 1306.08
- Petition Paragraph 7 reference to the 2017 NESC changed to 2012 NESC;

Pursuant to the Commission's notice of March 17, 2020, this filing is only being provided by email.

Thank you for your assistance. Please let me know if you have any questions.

Sincerely,

Erik Newman
Senior Counsel

cc via e-mail w/Encl.: Service List