

REDACTED

Liberty Utilities (Granite State Electric) Corp. d/b/a Liberty

DE 21-004  
2021 Least Cost Integrated Resource Plan  
December 12, 2022, Supplemental LCIRP Report

Department of Energy Data Requests - Set 10 (Revised)

Date Request Received: 1/25/23  
Request No. DOE 10-1

Date of Response: 2/3/23  
Respondent: Heather Tebbetts

---

**REQUEST:**

The Plan at Appendix 1, Table 4, Bates 131 shows about .35MW summer peak load growth in the Eastern Service Area (which includes Salem NH) each year from 2021-2037, based on an econometric model, starting with projected summer peak load in 2021 of 97.9616 MW. Data Response DOE 9-1, Attachment 1 (the latest update of the Excel sheet showing the customer by customer actual and projected load for Tuscan Village) shows 7.6 MW added in recent years, 3.0 MW in progress, and 12.0 MW not developed but projected to come online (presumably in the next few years – as indicated in the “Current Status” column on the Summary Tab). Further, Responses DOE 9-6 and DOE 9-7 show a 19 MW increase in forecasted peak load at the Rockingham Substation from 2023 to 2024. Liberty confirmed in a recent technical session that this load is separate from Tuscan Village customers.

In DE 19-064, Docket Tab 86, Liberty’s Salem Area Study at Bates 40 (referenced in the DE 21-004 Department of Energy Testimony of Dudley, Willoughby, and DeVirgilio at Bates 20, footnote 12), Liberty indicated that it planned to (and Liberty has since confirmed that it subsequently did) undertake capital additions in Salem that would result in an increase in total capacity of 177.7 MVA and firm capacity of 142.3 MVA.

- a. Please clarify whether the 177.7MVA total capacity and 142.3 firm capacity additions in Salem are incremental (that is - in addition to what was installed in Salem prior to undertaking the capacity improvements) or are these total capacity amounts after the improvements described on Bates 40 of the Salem Study (Plan Six) are installed. (See also Salem Area Study at Bates 133 “ Appendix G – Comparison of Plans – Cost vs. Added Capacity).
- b. Please provide an updated load forecast for the Eastern PSA that includes the specific customers added and projected in Tuscan Village, and the large customer referred to in Responses DOE 9-6 and DOE 9-7, as described above. For example, start with Plan Appendix B, Bates 131, Table 4 of the Plan and make specific adjustments to the loads projected, year-by-year, to account for the loads added in 2021 and 2022 and projected in years after 2022 at Tuscan Village (DOE 9-1, Attachment 1) and the projected new load referenced in DOE 9-6 and DOE 9-7.

Docket No. DE 21-004 Request No. DOE 10-1 (Redacted)

- c. Please provide a narrative that explains the apparent mismatch between the econometric-based load forecast (Appendix B at Bates 131), the specifically identified customer growth in Tuscan Village (Response DOE 9-1, Attachment 1), and the recent capacity improvements made in Salem (see Salem Area Study at Bates 40) that will be used to serve the projected load. If no mismatch exists, please explain why not.
- d. Does Liberty believe the capacity improvements undertaken in Salem are the appropriate size and scope for the load projected, as supplemented and updated in “b”. above? Please explain why or why not.
- e. Please provide the Salem Area Study referenced above, or similar Liberty document that fully details and describes the capacity additions recently undertaken in Salem.
- f. Please provide any other analysis Liberty believes will help to demonstrate that its LCIRP, as supplemented, demonstrates that Liberty’s distribution system in the Salem area is appropriately sized and scoped for the load projected in the LCIRP, as supplemented and updated in part “b”. above.
- g. Please update Figure 4.7, Bates 057 of the Plan to reflect the above updated load/capacity forecasts. This can be done with a footnote that references Appendix B (as updated) and associated impact on the 5-year forecasted spending.

**RESPONSE:**

- a. The 177.7 MVA of Total Summer Normal Capacity is the net amount of capacity after Baron Ave and Salem Depot substations are retired. In reviewing this question, the Company found that the summer emergency capacity is 51.1 MVA with the retirement of Baron Ave and Salem Depot substations. This revision is provided in Attachment DOE 10-1.a.xlsx, which is a breakdown of Appendix G on page 133 of Attachment DOE 10-1.e.2.
- b. Please see Attachment DOE 10-1.b.xlsx. The Company updated Tables 2, 3, 4, and 6 as those tables in the LCIRP include changes to the forecast in total and the Eastern PSA.
- c. When the LCIRP was produced, it was thought that the additional load in the Salem area, which includes the Tuscan Village development, was included by the consultant in the forecast. After further discussion with the DOE, its consultant, and internal sources, it looks to be that this spot load was not included in the forecast by the consultant.  
  
In addition to the forecasted spot load added to the forecast in Attachment DOE 10-1.b.xlsx for the Tuscan Village development, the Company is working with a large manufacturer looking to open a facility in Salem in 2024. The decision to build the Rockingham substation is the single reason the Company can serve this customer. Service to them is only feasible at the 23.8 kV level, which requires Liberty to offload all load from the Olde Trolley substation to the Rockingham substation and then build a line extension specifically to serve the manufacturer. The additional spot load from the manufacturer is 20 MW.
- d. Yes. The updated forecast shows additional spot loads in the Salem area of over 42 MW which the previous facilities could not have served.

Docket No. DE 21-004 Request No. DOE 10-1 (Redacted)

- e. Please see Attachment DOE 10-1.e.1 for the original Salem Area Study completed in 2017 and Attachment DOE 10-1.e.2 for the updated Salem Area Study completed in 2020.
- f. Liberty does not have any other analyses to provide.
- g. The five-year capital plan on Bates 057 shows a snapshot of the planned capital investments between 2022 and 2026. All things being equal, the only change that would be made due to the Salem Area upgrades is the additional [REDACTED] to serve the incoming manufacturer, of which [REDACTED] will be borne by the customer. The upgrades to the Salem area were included in budgets between 2020 and 2022.

The information marked above is individual customer data ... that can identify, singly or in combination, that specific customer,” RSA 363:37, I, and is thus protected from disclosure by RSA 363:38 and RSA 91-A:5, IV. Therefore, pursuant to Puc 203.08(d), the Company has a good faith basis to seek confidential treatment of this information and will submit a motion seeking confidential treatment prior to the final hearing in this docket.

Liberty Utilities  
Salem Area Study

---

# Liberty Utilities Salem Area Study Salem, New Hampshire

REV	DATE	Reason:	Prepared	Reviewed by:
2	03/17/2016	Draft Revision of Salem, NH Area Study with comments and updates	Michael Wall	Kathy Castro
3	11/19/2016	Draft Revision of Salem, NH Area Study updated with 2016 loading and new planning criteria	Joel Rivera	Chris Brouillard
4	1/11/2017	Chose new underground facilities along ROW as preferred Plan. Updated UG estimates. Implemented Chris' comments. Added 5 <sup>th</sup> Alternate Plan	Joel Rivera	Chris Brouillard



200 Ledgewood Place, Suite 300  
Rockland, MA, 02370



Liberty Utilities  
 Salem Area Study

---

Table of Contents

<b>1</b>	<b>ABSTRACT</b> .....	<b>7</b>
<b>2</b>	<b>EXECUTIVE SUMMARY</b> .....	<b>7</b>
2.1	EXPLANATION.....	8
2.2	RECOMMENDED PLAN.....	9
2.3	REASONS FOR RECOMMENDATION.....	11
2.4	RECOMMENDED ONE-LINES .....	11
2.5	RECOMMENDATION ESTIMATES .....	11
<b>3</b>	<b>INTRODUCTION</b> .....	<b>13</b>
3.1	GEOGRAPHIC SCOPE .....	13
3.2	ELECTRICAL SCOPE.....	14
3.3	ASSET CONDITIONS.....	17
3.4	PRESENT LOADING AND LOAD GROWTH .....	18
3.5	MODELING AND CRITERIA DOCUMENTATION .....	22
3.6	PRESENT CONCERNS OF EXISTING DISTRIBUTION SYSTEM.....	23
3.7	PREDICTED PROBLEMS OF EXISTING DISTRIBUTION SYSTEM .....	26
<b>4</b>	<b>RECOMMENDED PLAN</b> .....	<b>31</b>
4.1	PLAN DESCRIPTION.....	31
<b>5</b>	<b>PLAN SUMMARY</b> .....	<b>33</b>
5.1.1	<i>Recommended Plan Phase One Estimate:</i> .....	35
5.1.2	<i>Recommended Plan Phase Two Estimate:</i> .....	38
5.1.3	<i>Recommended Plan Phase Two Delays - Estimate Salem Depot Upgrade:</i> .....	42
5.1.4	<i>Recommended Plan Phase Three Estimate:</i> .....	43
5.1.5	<i>Summary Recommended Plan Phase Estimates:</i> .....	45
5.2	RECOMMENDED PLAN ONE-LINES .....	46
5.2.1	<i>Recommended Plan Phase One One Lines:</i> .....	46
5.2.2	<i>Recommended Plan Phase Two One-Lines:</i> .....	53
5.2.3	<i>Recommended Plan Phase Three One-Lines:</i> .....	66
<b>6</b>	<b>RECOMMENDED PLAN PROBLEMS RESOLVED</b> .....	<b>72</b>
6.1	RECOMMENDED PLAN PROBLEMS RESOLVED PHASE ONE .....	77
6.2	RECOMMENDED PLAN PROBLEMS RESOLVED PHASE TWO.....	77
6.3	RECOMMENDED PLAN PROBLEMS RESOLVED PHASE THREE.....	78
<b>7</b>	<b>ALTERNATE PLANS</b> .....	<b>79</b>
7.1	ALTERNATE PLAN ONE DESCRIPTION .....	80
7.1.1	<i>Alternate Plan One Phase One Estimates</i> .....	81
7.1.2	<i>Alternate Plan One Problems Resolved</i> .....	84
7.2	ALTERNATE PLAN TWO DESCRIPTION .....	84
7.2.1	<i>Alternate Plan Two Phase One Estimates</i> .....	86
7.2.2	<i>Alternate Plan Two Problems Resolved</i> .....	89
7.3	ALTERNATE PLAN THREE DESCRIPTION .....	89
7.3.1	<i>Alternate Plan Three Phase One Estimates</i> .....	91
7.3.2	<i>Alternate Plan Three Phase Two Estimates</i> .....	94
7.3.3	<i>Alternate Plan Three Phase Three Estimates</i> .....	98
7.3.4	<i>Alternate Plan Three Problems Resolved</i> .....	100
7.4	ALTERNATE PLAN FOUR DESCRIPTION .....	101

---

Liberty Utilities  
Salem Area Study

---

7.4.1	<i>Alternate Plan Four Phase One Estimates</i>	102
7.4.2	<i>Alternate Plan Four Phase Two Estimates</i>	105
7.4.3	<i>Alternate Plan Four Phase Three Estimates</i>	108
7.4.4	<i>Alternate Plan Four Problems Resolved</i>	111
7.5	<b>ALTERNATE PLAN FIVE DESCRIPTION</b>	111
7.5.1	<i>Alternate Plan Five Phase One Estimates</i>	113
7.5.2	<i>Alternate Plan Five Phase Two Estimate:</i>	116
7.5.3	<i>Alternate Plan Five Phase Two Delays - Estimate Salem Depot Upgrade:</i>	120
7.5.4	<i>Alternate Plan Five Phase Three Estimate:</i>	121
7.5.5	<i>Alternate Plan Five Problems Resolved</i>	124
<b>8</b>	<b>PLAN COST COMPARISON</b>	<b>125</b>
<b>9</b>	<b>CONCLUSION</b>	<b>126</b>
	<b>APPENDIX A ELIMINATED PLANS</b>	<b>130</b>
	<b>APPENDIX B ALTERNATE PLAN ONE-LINES</b>	<b>138</b>
	<b>APPENDIX C DISTRIBUTION ESTIMATES</b>	<b>186</b>
	<b>APPENDIX D RECOMMENDED PLAN PROJECT SCHEDULES</b>	<b>187</b>
	<b>APPENDIX D ASSET CONDITION REPORTS</b>	<b>188</b>

**Liberty Utilities**  
**Salem Area Study**

---

**Table of Figures**

FIGURE 1 SALEM, NH GEOGRAPHICAL MAP .....	14
FIGURE 2 SALEM AREA 23 kV SUPPLY SYSTEM ONE-LINE.....	15
FIGURE 3 SALEM AREA 13.2kV SUPPLY SYSTEM ONE-LINE.....	16
FIGURE 4 LIBERTY UTILITIES DISTRIBUTION PLANNING CRITERIA .....	20
FIGURE 5 RECOMMENDED PLAN PHASE ONE GOLDEN ROCK STATION PROPOSED LAYOUT .....	46
FIGURE 6 RECOMMENDED PLAN PHASE ONE GOLDEN ROCK STATION ARRANGEMENT .....	47
FIGURE 7 RECOMMENDED PLAN PHASE ONE GOLDEN ROCK 13.2 kV STATION ONE-LINE.....	48
FIGURE 8 RECOMMENDED PLAN PHASE ONE GOLDEN ROCK 13.2 kV DISTRIBUTION CIRCUIT TIE MAP .....	49
FIGURE 9 RECOMMENDED PLAN PHASE ONE GOLDEN ROCK 13.2 kV 19L2 DISTRIBUTION CIRCUIT.....	50
FIGURE 10 RECOMMENDED PLAN PHASE ONE GOLDEN ROCK 13.2 kV 19L4 DISTRIBUTION CIRCUIT.....	51
FIGURE 11 RECOMMENDED PLAN PHASE ONE GOLDEN ROCK 13.2 kV 19L6 DISTRIBUTION CIRCUIT.....	52
FIGURE 12 RECOMMENDED PLAN PHASE TWO ROCKINGHAM STATION PROPOSED LAYOUT.....	53
FIGURE 13 RECOMMENDED PLAN PHASE TWO ROCKINGHAM STATION ONE-LINE .....	54
FIGURE 14 RECOMMENDED PLAN PHASE TWO ROCKINGHAM 13.2 kV DISTRIBUTION CIRCUIT TIE MAP.....	55
FIGURE 15 RECOMMENDED PLAN PHASE TWO ROCKINGHAM 13.2 kV UNDERGROUND CABLE GETAWAYS.....	56
FIGURE 16 RECOMMENDED PLAN PHASE TWO ROCKINGHAM 13.2 kV 21L1 DISTRIBUTION CIRCUIT.....	57
FIGURE 17 RECOMMENDED PLAN PHASE TWO ROCKINGHAM 13.2 kV 21L2 DISTRIBUTION CIRCUIT.....	58
FIGURE 18 RECOMMENDED PLAN PHASE TWO ROCKINGHAM 13.2 kV 21L3 DISTRIBUTION CIRCUIT.....	59
FIGURE 19 RECOMMENDED PLAN PHASE TWO ROCKINGHAM 13.2 kV 21L4 DISTRIBUTION CIRCUIT.....	60
FIGURE 20 RECOMMENDED PLAN PHASE TWO ROCKINGHAM 13.2 kV 21L5 DISTRIBUTION CIRCUIT.....	61
FIGURE 21 RECOMMENDED PLAN PHASE TWO ROCKINGHAM 13.2 kV 21L6 DISTRIBUTION CIRCUIT.....	62
FIGURE 22 RECOMMENDED PLAN PHASE TWO ROCKINGHAM 13.2 kV 21L5 AND 21L6 DISTRIBUTION CIRCUITS .....	63
FIGURE 23 RECOMMENDED PLAN PHASE TWO GOLDEN ROCK 13.2 kV 19L8 DISTRIBUTION CIRCUIT .....	64
FIGURE 24 RECOMMENDED PLAN PHASE TWO PROPOSED RIGHT-OF-WAY UNDERGROUND CONDUIT SYSTEM .....	65
FIGURE 25 RECOMMENDED PLAN PHASE THREE PROPOSED GOLDEN ROCK STATION PROPOSED LAYOUT.....	66
FIGURE 26 RECOMMENDED PLAN PHASE THREE PROPOSED GOLDEN ROCK STATION ONE-LINE .....	67
FIGURE 27 RECOMMENDED PLAN PHASE THREE GOLDEN ROCK 13.2 kV DISTRIBUTION CIRCUIT TIE MAP.....	68
FIGURE 28 RECOMMENDED PLAN PHASE THREE PROPOSED GOLDEN ROCK 13.2 kV 19L1 DISTRIBUTION CIRCUIT.....	69
FIGURE 29 RECOMMENDED PLAN PHASE THREE PROPOSED GOLDEN ROCK 13.2 kV 19L3 DISTRIBUTION CIRCUIT.....	70
FIGURE 30 RECOMMENDED PLAN PHASE THREE PROPOSED GOLDEN ROCK 13.2 kV 19L5 DISTRIBUTION CIRCUIT.....	71
FIGURE 31 ALTERNATE PLAN ONE GOLDEN ROCK STATION ONE-LINE PHASE ONE.....	138
FIGURE 32 ALTERNATE PLAN ONE SPICKET RIVER STATION UPGRADE ONE-LINE PHASE ONE .....	139
FIGURE 33 ALTERNATE PLAN ONE 23 kV ONE-LINE PHASE ONE .....	140
FIGURE 34 ALTERNATE PLAN TWO NEW GOLDEN ROCK 115/13.2 kV STATION PHASE ONE .....	141
FIGURE 35 ALTERNATE PLAN TWO UPGRADES TO SPICKET RIVER STATION PHASE ONE.....	142
FIGURE 36 ALTERNATE PLAN TWO 23 kV ONE-LINE PHASE ONE.....	143
FIGURE 37 ALTERNATE PLAN THREE NEW GOLDEN ROCK 115/13.2 kV STATION PHASE ONE.....	144
FIGURE 38 ALTERNATE PLAN THREE NEW GOLDEN ROCK 13.2kV DISTRIBUTION CIRCUIT TIE MAP PHASE ONE .....	145
FIGURE 39 ALTERNATE PLAN THREE NEW GOLDEN ROCK 13.2kV DISTRIBUTION CIRCUIT 19L8 PHASE ONE.....	146
FIGURE 40 ALTERNATE PLAN THREE NEW GOLDEN ROCK 23kV LINE RELOCATION SOUTH BROADWAY PHASE TWO .....	147
FIGURE 41 ALTERNATE PLAN THREE NEW ROCKINGHAM 13.2kV DISTRIBUTION CIRCUIT TIE MAP PHASE TWO.....	148
FIGURE 42 ALTERNATE PLAN THREE NEW GOLDEN ROCK 13.2kV DISTRIBUTION CIRCUIT 19L1 PHASE THREE .....	149
FIGURE 43 ALTERNATE PLAN THREE NEW GOLDEN ROCK 13.2kV DISTRIBUTION CIRCUIT 19L3 PHASE THREE .....	150
FIGURE 44 ALTERNATE PLAN THREE NEW GOLDEN ROCK 13.2kV DISTRIBUTION CIRCUIT 19L5 PHASE THREE .....	151
FIGURE 45 ALTERNATE PLAN THREE NEW GOLDEN ROCK 13.2kV DISTRIBUTION CIRCUIT TIE MAP PHASE THREE .....	152
FIGURE 46 ALTERNATE PLAN FOUR NEW GOLDEN ROCK 13.2kV STATION ARRANGEMENT PHASE ONE .....	153
FIGURE 47 ALTERNATE PLAN FOUR NEW GOLDEN ROCK 13.2kV DISTRIBUTION CIRCUIT TIE MAP PHASE ONE.....	154
FIGURE 48 ALTERNATE PLAN FOUR NEW ROCKINGHAM 13.2kV STATION ARRANGEMENT PHASE TWO .....	155
FIGURE 49 ALTERNATE PLAN FOUR NEW ROCKINGHAM 13.2kV DISTRIBUTION CIRCUIT TIE MAP PHASE TWO.....	156
FIGURE 50 ALTERNATE PLAN FOUR NEW ROCKINGHAM 13.2kV STATION ARRANGEMENT PHASE THREE .....	157

---

**Liberty Utilities**  
**Salem Area Study**

---

FIGURE 51 ALTERNATE PLAN FOUR NEW ROCKINGHAM 13.2KV DISTRIBUTION CIRCUIT TIE MAP PHASE THREE .....	158
FIGURE 52 ALTERNATE PLAN FIVE PHASE ONE GOLDEN ROCK STATION PROPOSED LAYOUT .....	159
FIGURE 53 ALTERNATE PLAN FIVE PHASE ONE GOLDEN ROCK STATION ARRANGEMENT .....	160
FIGURE 54 ALTERNATE PLAN FIVE PHASE ONE GOLDEN ROCK 13.2 kV STATION ONE-LINE .....	161
FIGURE 55 ALTERNATE PLAN FIVE PHASE ONE GOLDEN ROCK 13.2 kV DISTRIBUTION CIRCUIT TIE MAP .....	162
FIGURE 56 ALTERNATE PLAN FIVE PHASE ONE GOLDEN ROCK 13.2 kV 19L2 DISTRIBUTION CIRCUIT .....	163
FIGURE 57 ALTERNATE PLAN FIVE PHASE ONE GOLDEN ROCK 13.2 kV 19L4 DISTRIBUTION CIRCUIT .....	164
FIGURE 58 ALTERNATE PLAN FIVE PHASE ONE GOLDEN ROCK 13.2 kV 19L6 DISTRIBUTION CIRCUIT .....	165
FIGURE 59 ALTERNATE PLAN FIVE PHASE ONE GOLDEN ROCK UNDERGROUND CIVIL CONSTRUCTION .....	166
FIGURE 60 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM STATION PROPOSED LAYOUT .....	167
FIGURE 61 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM STATION ONE-LINE .....	168
FIGURE 62 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM 13.2 kV DISTRIBUTION CIRCUIT TIE MAP .....	169
FIGURE 63 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM 13.2 kV UNDERGROUND CABLE GETAWAYS.....	170
FIGURE 64 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM 13.2 kV 21L1 DISTRIBUTION CIRCUIT.....	171
FIGURE 65 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM 13.2 kV 21L2 DISTRIBUTION CIRCUIT.....	172
FIGURE 66 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM 13.2 kV 21L3 DISTRIBUTION CIRCUIT.....	173
FIGURE 67 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM 13.2 kV 21L4 DISTRIBUTION CIRCUIT.....	174
FIGURE 68 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM 13.2 kV 21L5 DISTRIBUTION CIRCUIT.....	175
FIGURE 69 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM 13.2 kV 21L6 DISTRIBUTION CIRCUIT.....	176
FIGURE 70 ALTERNATE PLAN FIVE PHASE TWO ROCKINGHAM 13.2 kV 21L5 AND 21L6 DISTRIBUTION CIRCUITS .....	177
FIGURE 71 ALTERNATE PLAN FIVE PHASE TWO GOLDEN ROCK 13.2 kV 19L4 DISTRIBUTION CIRCUIT.....	178
FIGURE 72 ALTERNATE PLAN FIVE PHASE TWO PROPOSED SOUTH BROADWAY UNDERGROUND CONDUIT SYSTEM .....	179
FIGURE 73 ALTERNATE PLAN FIVE PHASE THREE PROPOSED GOLDEN ROCK STATION PROPOSED LAYOUT .....	180
FIGURE 74 ALTERNATE PLAN FIVE PHASE THREE PROPOSED GOLDEN ROCK STATION ONE-LINE .....	181
FIGURE 75 ALTERNATE PLAN FIVE PHASE THREE GOLDEN ROCK 13.2 kV DISTRIBUTION CIRCUIT TIE MAP.....	182
FIGURE 76 ALTERNATE PLAN FIVE PHASE THREE PROPOSED GOLDEN ROCK 13.2 kV 19L1 DISTRIBUTION CIRCUIT.....	183
FIGURE 77 ALTERNATE PLAN FIVE PHASE THREE PROPOSED GOLDEN ROCK 13.2 kV 19L3 DISTRIBUTION CIRCUIT.....	184
FIGURE 78 ALTERNATE PLAN FIVE PHASE THREE PROPOSED GOLDEN ROCK 13.2 kV 19L5 DISTRIBUTION CIRCUIT.....	185

**Tables**

TABLE 1 SALEM AREA 2016 PEAK LOAD.....	18
TABLE 2 SALEM AREA SPOT LOADS .....	19
TABLE 3 SUMMER TOWNSHIP NORMAL LOAD GROWTH - SALEM, NH.....	19
TABLE 4 PRESENT CONCERNS CONDUCTOR THERMAL OVERLOADS IN EXCESS OF 100% .....	23
TABLE 5 SPICKET RIVER LOAD AT RISK.....	24
TABLE 6 EXISTING DISTRIBUTION CIRCUIT CONTINGENCY WITH LOAD AT RISK .....	25
TABLE 7 EXISTING CONCERN DISTRIBUTION CIRCUIT PEAK LOAD IN EXCESS OF 75% .....	25
TABLE 8 EXISTING CONCERN SUB-TRANSMISSION CIRCUIT PEAK LOAD IN EXCESS OF 90% .....	25
TABLE 9 EXISTING CONCERN TRANSFORMER LOADING IN EXCESS OF 90% - DURING CONTINGENCY.....	26
TABLE 10 EXISTING CONCERN 23 kV SUPPLY LINE IN EXCESS OF 90% - DURING CONTINGENCY .....	26
TABLE 11 PREDICTED CONCERN DISTRIBUTION CIRCUITS WITH NORMAL LOADING IN EXCESS OF 75% SUMMER NORMAL RATING.....	27
TABLE 12 PREDICTED CONCERN DISTRIBUTION CIRCUITS CONTINGENCIES WITH LOAD AT RISK VIOLATIONS .....	28
TABLE 13 PREDICTED CONCERN TRANSFORMERS WITH NORMAL LOADING IN EXCESS OF 75% SUMMER NORMAL .....	28
TABLE 14 PREDICTED CONCERN TRANSFORMER LOADING IN EXCESS OF 90% SUMMER EMERGENCY – DURING CONTINGENCY.....	29
TABLE 15 PREDICTED CONCERN 23kV SUPPLY LINE LOADING IN EXCESS OF 90% SUMMER EMERGENCY – DURING CONTINGENCY.....	30
TABLE 16 RECOMMENDED PLAN PHASE ONE ESTIMATE .....	35
TABLE 17 RECOMMENDED PLAN PHASE TWO ESTIMATE.....	38
TABLE 18 RECOMMENDED PLAN PHASE TWO SALEM DEPOT UPGRADE ESTIMATE .....	42
TABLE 19 RECOMMENDED PLAN PHASE THREE ESTIMATE .....	43
TABLE 20 SUMMARY OF RECOMMENDED PLAN ESTIMATES .....	45
TABLE 21 FORECASTED DISTRIBUTION CIRCUIT LOADING WITH RECOMMENDED PROJECTS .....	73

---

## Liberty Utilities Salem Area Study

---

TABLE 22 FORECASTED DISTRIBUTION CIRCUIT LOADING WITH AND WITHOUT RECOMMENDED PROJECTS PHASE ONE.....	74
TABLE 23 FORECASTED DISTRIBUTION CIRCUIT LOADING WITH AND WITHOUT RECOMMENDED PROJECTS PHASE TWO.....	74
TABLE 24 FORECASTED DISTRIBUTION CIRCUIT LOADING WITH AND WITHOUT RECOMMENDED PROJECTS PHASE THREE.....	75
TABLE 25 FORECASTED DISTRIBUTION TRANSFORMER LOADING WITH RECOMMENDED PROJECTS.....	75
TABLE 26 FORECASTED SUB-TRANSMISSION CIRCUIT LOADING WITH RECOMMENDED PROJECTS.....	76
TABLE 27 CONDUCTOR THERMAL OVERLOAD UPDATED % OF NORMAL RATING.....	77
TABLE 28 ALTERNATE PLAN ONE PHASE ONE ESTIMATE.....	81
TABLE 29 ALTERNATE PLAN TWO PHASE ONE ESTIMATE.....	86
TABLE 30 ALTERNATE PLAN THREE PHASE ONE ESTIMATE.....	91
TABLE 31 ALTERNATE PLAN THREE PHASE TWO ESTIMATE.....	94
TABLE 32 ALTERNATE PLAN THREE PHASE THREE ESTIMATE.....	98
TABLE 33 ALTERNATE PLAN FOUR PHASE ONE ESTIMATE.....	102
TABLE 34 ALTERNATE PLAN FOUR PHASE TWO ESTIMATE.....	105
TABLE 35 ALTERNATE PLAN FOUR PHASE THREE ESTIMATE.....	108
TABLE 36 ALTERNATE PLAN FIVE PHASE ONE ESTIMATE.....	113
TABLE 37 ALTERNATE PLAN FIVE PHASE TWO ESTIMATE.....	116
TABLE 38 ALTERNATE PLAN FIVE PHASE TWO SALEM DEPOT UPGRADE ESTIMATE.....	120
TABLE 39 ALTERNATE PLAN FIVE PHASE THREE ESTIMATE.....	121
TABLE 40 PLAN COMPARISON.....	125
TABLE 41 INVESTMENT GRADE OVERHEAD DISTRIBUTION ESTIMATES.....	186
TABLE 42 INVESTMENT GRADE UNDERGROUND DISTRIBUTION ESTIMATES.....	186
TABLE 43 INVESTMENT GRADE SUBSTATION DISTRIBUTION ESTIMATES.....	187
TABLE 44 PHASE 1 - GOLDEN ROCK #19 PROJECT SCHEDULE.....	188
TABLE 45 PHASE 2 – ROCKINGHAM #21 PROJECT SCHEDULE.....	188
TABLE 46 PHASE 3 – GOLDEN ROCK#19 PROJECT SCHEDULE.....	188

Liberty Utilities  
Salem Area Study

---

## 1 Abstract

Adequate distribution capacity is key to overall system reliability and proper functioning of system facilities. The town of Salem, NH will experience more than expected load growth in the upcoming years. This is due to commercial redevelopment. This area consists of expansive residential developments, numerous retail plazas, office parks and Industrial/Commercial Parks. The loading of the system has changed over the years to where various components are at or have exceeded certain planning and operating criteria. In addition, sub-transmission facilities in the area are approaching its design limits. The upcoming developments in the area result in an increase of components exceeding planning and operating criteria.

This Area Study is being carried out to study five (5) possible options for the development of the power distribution system in the Salem, NH area. It determines the best engineering solution to mitigate overloads, address contingencies, and to upgrade/replace vintage assets in the system. The recommended plan accomplishes all system capacity and asset replacement requirements. The plan will be achieved in three (3) phases. The first phase recommends the installation of a 115/13.2 kV - 33/44/55 MVA transformer and four 13.2kV feeders at the Golden Rock Substation and the retirement of Baron Avenue Substation. The second phase installs a new double-ended 115/13.2kV substation Rockingham #21 and eight 13.2kV feeders in the Rockingham Park Track and retires the Salem Depot Substation. The third phase replaces the existing 115/23kV transformer at Golden Rock with a 115/13.2kV – 33/44/55 MVA transformer and four 13.2kV feeders and converts the Olde Trolley Substation to a switching/regulator station, and retires the 23kV sub-transmission system in the area. This recommendation is based on the engineering analysis to find the most economical alternative to provide for projected load growth, contingency mitigation, and to assess condition issues of the existing equipment.

## 2 Executive Summary

Control Point Technologies with the assistance of Liberty Utilities has completed the Salem, NH distribution planning study. The Liberty Utilities Distribution Planning Criteria was used to determine any Electric Supply System upgrades required to meet existing and future capacity requirements. The study focused on the distribution requirements needed to supply the proposed business park development in the range of 14MW – 17MW located at the former Rockingham Park Track. The study also focused on the retirement of Baron Ave Substation, Salem Depot Substation and Olde Trolley substation due to issues with asset condition. The retirement of these substations will set the stage for the retirement of the Salem Area 23kV sub-transmission system.

The Distribution System under study included:

## Liberty Utilities Salem Area Study

---

- One (1) 115kV/23kV substation Golden Rock No.19.
- Four (4) 23kV sub-transmission (supply) circuits, 2352, 2393, 2353 and 2376.
- Four (4) 23kV/13.2kV substations, Baron Ave No.10, Olde Trolley No.18, Salem Depot No. 9 and Spicket River No 13.
- Thirteen (13), 13.2kV distribution circuits, 10L1, 10L2, 10L4, 18L1, 18L2, 18L3, 18L4, 9L1, 9L2, 9L3, 13L1, 13L2 and 13L3.

### 2.1 Explanation

The study, focused on current and future capacity needs of the supply lines, substations and distribution system supplying the area along with the asset conditions of the existing electrical infrastructure. Evaluations identified a number of existing and predicted system Distribution Circuit, Supply Line, and Transformer capacity concerns that did not meet the requirements of the Liberty Distribution Planning Criteria.

Existing Criteria violations, based on 2016 peak loading, were identified for both the Normal Loading and the Contingency Loading cases. These are detailed under Section 3.6 and include the following:

1. Conductor Thermal overloads in excess of 100% Summer Normal ratings on the, 18L4 circuit.
2. During Contingency (N-1) cases, the Salem Depot 9L2 Circuit violates the 16 MWH rule with 3.7 MVA of Load at risk.
3. During Contingency (N-1) cases the Spicket River Loss of 23kV Supply violates the 36 MWH rule with 8.9 MVA load at risk.
4. The 13L2 Circuit, which is limited to 515 Amps by 336 AI OH, exceeds 75% of its Summer Normal rating.
5. The 9L2 Circuit's transformer which is limited to 322 Amps exceeds 75% of its Summer Normal rating.
6. The Spicket River 2376 Supply Line, which is limited by 336 AI OH, exceeds 90% of its summer Normal rating.

In addition to the existing distribution evaluation the study also focused on the distribution requirements needed to supply the proposed business park development in the range of 14 MW - 17 MW located at the former Rockingham Park Track.

Liberty Utilities  
Salem Area Study

---

Existing loading concerns and planning criteria violations amplify with the addition of the proposed business park and other known spot loads in the area. Existing transformer, distribution circuit and supply line capacity in the Salem area will be exceeded, presenting many challenges to the existing 23kV/13.2kV distribution system. These predicted criteria violations were identified by year for both the Normal Loading and the Contingency Loading cases under Section 3.8.

## 2.2 Recommended Plan

A total of twelve (12) plans were evaluated to address the existing and future system needs of the area. Six (6) of these plans were eliminated because of transmission costs and construction challenges due to site locations; refer to Appendix A for a list of all Eliminated Plans. Five (5) Alternate plans were developed and weighed against the Recommended Plan. The Five (5) Alternate Plans are detailed in Section 7 and the Recommend Plan is detailed in Section 4.

The study took into consideration existing distribution asset concerns while determining possible recommendations. These asset concerns are detailed in Section 3.3.

The recommended plan for consideration accomplishes all system capacity and asset replacement requirements. The plan will be achieved in three (3) phases. It addresses the existing concerns and the future concerns in the most complete way while moving the system from the legacy 23 kV supplied system to a more reliable and sustainable 115 kV supplied system. It also provides the capacity needed to supply the proposed business park development in the former Rockingham Park Track.

### **Phase One (New 115/13.2 kV Transformer at Golden Rock Station with Baron Ave Station Elimination & Spicket River Mitigation)**

Phase One of the recommended plan consists of a second 115 kV transmission line into Golden Rock Station supplying a new 115kV/13.2 kV substation transformer with three (3) new 13.2 kV circuit positions. The 13.2 kV circuits would be constructed to provide contingency support to Spicket River Station and to eliminate the Baron Ave Station. It would also be used to mitigate forecasted capacity issues after initial Rockingham expansions in the range of 3MW – 5MW take place. The future circuit #4 will be installed during Phase 2 after the new underground conduit system along the right-of-way (ROW) is installed.

This phase would also include the replacement of existing conductor in excess of 100% of Summer Normal ratings, on the 18L4 circuit. The conductor upgrade would be accomplished using 477 Al spacer cable to the first protective device, then 477 Al open wire or 477 tree wire depending upon field conditions.



Liberty Utilities  
Salem Area Study

---

Phase One of the Recommended Plan also consists of the removal of the existing 23kV bus tie breakers and the relocation of the 23kV OH tie line between the 2393 and 2376 circuits outside of the Golden Rock substation to make way for new 13.2kV equipment. The 2352 circuit will also be removed from Golden Rock to Baron Ave.

The total cost of the Phase One project is estimated at \$5,584,000.

**Phase Two (New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination and Criteria Mitigation)**

Phase Two of the recommended plan consists of an extension of the 115 kV transmission system from Golden Rock Station to a proposed new double ended 115kV/13.2kV station in the Rockingham Park Track area. Acquisition of land within the Rockingham Park will be required to install the new substation.

Each new 115 kV/ 13.2 kV supply transformer, T1 and T2, would have four (4) circuits, eight (8) total, with secondary breakers and a bus tie breaker. An automatic bus transfer system would be utilized to improve reliability and simplify maintenance.

Three (3) of the T1 supply transformer circuits would be used to supply a reconfigured 13.2 kV distribution system, which will bring the system into compliance with Liberty's Distribution Planning Criteria. The configuration would be targeted to improve reliability and better balance loading on all circuits.

Three (3) of the T2 supply transformer circuits would be used eliminate the Salem Depot Station and provide backup support to the Olde Trolley substation.

The fourth circuit on both the T1 and T2 supply transformers would serve the proposed business park load.

The two (2) 23kv supply circuits 2352 and 2393 will be relocated from OH to UG along the ROW to make way for the two (2) new 115kV transmission supply lines supplying the new Rockingham Substation. This new underground system along the ROW will also be used for future distribution feeders out of Golden Rock Substation (Phase 3) and for the fourth feeder out of Golden Rock T2.

The total cost of the Phase Two project is estimated at \$20,648,000.

**Phase Three (Install Second 115/13.2 KV Transformer at Golden Rock Station with Olde Trolley Elimination)**

Phase three of the recommended plan consists of a second 115kV/13.2kV substation transformer at Golden Rock with four (4) new 13.2kV feeder positions.

---

## Liberty Utilities Salem Area Study

---

The existing 115kV/23kV Golden Rock transformer is to be removed and the substation is to be converted into a 13.2kV with a breaker and a half scheme. The existing 23kV lines will be converted to 13.2kV distribution circuits. The 13.2 kV circuits would be constructed to provide contingency support to Rockingham Station and Spicket River Station. Phase Three of the Recommended Plan will convert the Olde Trolley Station into a regulating/switching station and will eliminate the 23kV supply system in the Salem area.

The total cost of the Phase Three project is estimated at \$4,684,000.

### 2.3 Reasons for Recommendation

The recommended plan addresses existing and predicted normal and contingency operational, capacity, and asset challenges associated with the existing 23kV/13.2kV based distribution system. In addition, the plan addresses, capacity loading concerns developed with the addition of the proposed business park at the former Rockingham Park Track and other known spot loads in the area.

Additionally, Spicket River Station is presently supplied by one 23kV circuit fed from the Transmission Service Provider, National Grid. With the loss of this supply, the existing 13.2 kV circuit ties do not have sufficient capacity to pick up the entire station load on peak. The load at risk resulting from this contingency scenario violates the Liberty Distribution Planning Criteria. The added capacity and 13.2 kV circuits would be constructed from Golden Rock to provide contingency support to Spicket River Station and bring the station into compliance with Liberty's Distribution Planning Criteria.

The opportunity to move the system from a 23kV/13.2kV to a more robust 115kV/13.2kV substation transformer based system is presented. The 115kV/13.2kV transformers will allow larger capacity transformers to be utilized in supplying system demand. By utilizing the additional capacity available from the larger capacity transformers; Liberty Utilities can develop a multi-phased plan to eliminate existing 23 kV facilities, including Baron Ave, Salem Depot station and Olde Trolley, with their legacy maintenance and operational concerns. Also, the recommended plan will decrease the reliance on the 23 kV supply line system and its continued dependence on the Transmission Service Provider to allocate 23 kV capacity for Liberty Utilities.

### 2.4 Recommended One-lines

Refer to section 5.2 Recommended Plan One-lines, for Station and Distribution Systems.

### 2.5 Recommendation Estimates

Liberty Utilities  
 Salem Area Study

The following tables provide estimated costs, by phase, for the Recommended Plan.

<b>Recommended Plan Phase One Estimate</b>	
<b>Required Construction</b>	<b>Cost - \$k</b>
Baron Ave Station Elimination & Spicket River Mitigation Distribution Circuit Estimate	<b>\$2,400</b>
Baron Ave Station Elimination & Spicket River Mitigation Sub-Transmission Circuit Estimate	<b>\$184</b>
New 115/13.2 kV Transformer at Golden Rock Station Estimate	<b>\$3,000</b>
<b>Phase One Project Total</b>	<b>\$5,584</b>

<b>Recommended Plan Phase Two Estimate</b>	
<b>Required Construction</b>	<b>Cost - \$k</b>
Salem Depot Station Elimination Distribution Circuit Estimate and Design Criteria Compliance	<b>\$6,343</b>
Salem Depot Station Elimination Sub-transmission Circuit Estimate and 23kV Relocation.	<b>\$8,504</b>
New 115/13.2 KV Transformer, T1, at New Rockingham Station Estimate	<b>\$2,800</b>
New 115/13.2 KV Transformer, T2, at New Rockingham Station Estimate	<b>\$3,000</b>
<b>Phase Two Project Total</b>	<b>\$20,648</b>

<b>Recommended Plan Phase Three Estimate</b>	
<b>Required Construction</b>	<b>Cost - \$k</b>
Olde Trolley Elimination Distribution Circuit Estimate	<b>\$150</b>
Olde Trolley Elimination Sub-transmission Circuit Estimate and 23kV Supply Retirement	<b>\$34</b>
New 115/13.2 kV Transformer at Golden Rock Station Estimate	<b>\$4,500</b>
<b>Phase Three Project Total</b>	<b>\$4,684</b>

Liberty Utilities  
 Salem Area Study

---

If the implementation of a new Rockingham Station is significantly delayed, Salem Depot Station upgrades should be pursued due to issues with asset condition.

In addition, if the implementation of a new Rockingham Station is significantly delayed, the temporary installation of a 23/13.2kV 9.375 MVA transformer within the Rockingham Park should be pursued. One transformer from the retired Baron Avenue substation could be reserved for this application. Although this transformer and sub-transmission supply system would not have the full capacity to supply all of the forecasted expansions in the park, it could buy enough time to supply some new developments in the Park as the new Rockingham Station is being implemented.

<b>Recommended Plan Phase Two Delay Estimate</b>	
<b>Required Construction</b>	<b>Cost - \$k</b>
<b>Salem Depot Station Upgrades Station Estimate</b>	<b>\$1,550</b>
<b>Phase Two Project Total (Delay)</b>	<b>\$1,550</b>


### 3 Introduction

The Salem, NH area distribution Study was completed to determine any Electric Supply System upgrades required to meet existing and future capacity operational and asset requirements. The study also focused on the distribution requirements needed to supply the proposed business park development in the range of 14MW – 17MW located at the former Rockingham Park Track.

#### 3.1 Geographic Scope

This study was performed on the Liberty Utilities Distribution System supplying Salem, New Hampshire. The system is confined to the City of Salem, NH with small excursions into Windham and Derry, NH and Methuen, MA.

Liberty Utilities  
Salem Area Study



**Figure 1 Salem, NH Geographical Map**

### 3.2 Electrical Scope

The Distribution System under study includes the 2352, 2353, 2376, and 2393, 23 kV supply circuits; refer to *Figure 2, Salem Area 23 kV Supply System One-Line*. These circuits supply four (4) 23kV/13.2kV substations: Baron Ave No.10, Olde Trolley No.18, Salem Depot No. 9 and Spicket River No 13 and one 23kV customer station “Jockey Club”.

Liberty Utilities  
Salem Area Study




Figure 2 Salem Area 23 kV Supply System One-line

The substations supply thirteen (13) 13.2kV circuits, refer to Figure 3, Salem Area 13.2kV Supply System One-line:

1. Baron Ave: 10L1, 10L2, 10L4
2. Olde Trolley: 18L1, 18L2, 18L3, 18L4
3. Salem Depot: 9L1, 9L2, 9L3
4. Spicket River: 13L1, 13L2, 13L3



Liberty Utilities  
Salem Area Study




Figure 3 Salem Area 13.2kV Supply System One-line

Liberty Utilities  
Salem Area Study

---

### 3.3 Asset Conditions

Existing distribution asset concerns were taken into consideration during this study. The evaluation included the following:

1. Site visits to all Salem area Stations.
2. Review of condition assessment reports provided to Liberty Utilities by National Grid and most recently by United Power Group, INC. See Appendix D for a list of Condition Assessment Reports.

The following is a list of concerns that were documented as part of the Asset Condition evaluation:

1. Barron Ave No. 10 Substation was initially constructed in the early 1960s. It is supplied by the 2393 supply line, which originates from Golden Rock Station, and the National Grid 2353 supply line, which originates from the Methuen No 5 Station. Liberty Utilities has experienced multiple issues with asset concerns at this substation. The 10L1 recloser is 30 years old with an outdated control system (Form 3), the McGraw Edison type VSA has a high failure rate. The 10L4 recloser is 30 years old, this model Kyle recloser is no longer supported with spare parts and the control system has a high failure rate. The regulator contacts are at end of its useful life and the height to live parts inside the substation is below minimum height clearance requirements for a modern substation. It is not considered practical or economic to rebuild the substation in its present location, based upon a benchmark cost of approximately \$1 million per feeder position, plus site and supply side construction. Further, capacity is limited to what the Salem 23kV system can provide.

Additionally, per the 2014 United Power Group, Inc. Asset Condition Report:

- a. The 10L1 – Transformer bushings are showing signs of deterioration; the transformer is over 50 years old.
  - b. The 10L2 – 20 Amp Control Circuit Breaker needs replacement.
  - c. The 10L4 – Transformer bushings are showing signs of deterioration and are leaking oil around the bottom valve.
2. Salem Depot No. 9 Substation was initially constructed in the 1950's. It is supplied by the 2393 supply line and the 2352 supply line, which originate from Golden Rock Station. The existing 9L1 and 9L2 Breaker Positions and bus are constructed on Wood Pole Structures with limited clearance. This causes reliability and maintenance concerns at the station. It is not considered practical or economic to rebuild the substation in its present



Liberty Utilities  
 Salem Area Study

location, based upon a benchmark cost of approximately \$1 million per feeder position, plus site and supply side construction. Further, capacity is limited to what the Salem 23kV system can provide.

Additionally, per the 2014 United Power Group, Inc. Asset Condition Report:

- a. The 9L3 Transformer 9T3's H3 bushing is showing signs of deterioration.
3. Per the National Grid Asset Condition Report (08/26/2006);
- a. The Olde Trolley 18L2 A and C phase regulator tanks are severely rusted. The regulators will require replacement with 10 years.

3.4 Present Loading and Load Growth

The study was conducted using load data beginning with the recorded 2016 peak load; refer to Table 1 Salem 2016 Peak Load.

<i>Station</i>	<i>Circuit</i>	<i>2016 Peak Load (Amps)</i>
<i>BARRON AVENUE 10</i>	10L1	197
<i>BARRON AVENUE 10</i>	10L2	312
<i>BARRON AVENUE 10</i>	10L4	229
<i>OLDE TROLLEY 18</i>	18L1	280
<i>OLDE TROLLEY 18</i>	18L2	366
<i>OLDE TROLLEY 18</i>	18L3	321
<i>OLDE TROLLEY 18</i>	18L4	328
<i>SALEM DEPOT 9</i>	9L1	135
<i>SALEM DEPOT 9</i>	9L2	284
<i>SALEM DEPOT 9</i>	9L3	346
<i>SPICKET RIVER 13</i>	13L1	304
<i>SPICKET RIVER 13</i>	13L2	424
<i>SPICKET RIVER 13</i>	13L3	362
<i>Golden Rock</i>	2352	816
<i>Golden Rock</i>	2393	946

**Table 1 Salem Area 2016 Peak Load**

Anticipated large customer spot loads were also added to the evaluation, refer to Table 2 Spot Loads. The Distribution System was modelled and analyzed using

Liberty Utilities  
 Salem Area Study

---

the CYME application to perform the load flow analysis.

<i>Year</i>	<i>Distribution Circuit</i>	<i>Location</i>	<i>Load (Amps)</i>
2017	9L1	Rockingham Park North	104
2017	9L3	Rockingham Park North	32
2018	18L2	Rockingham Park South	13
2018	9L3	Windham Economic Development I	66
2018	9L3	Windham Economic Development II	66
2018	18L3	Rockingham Park South	186
2019	18L2	Rockingham Park South	88
2019	18L3	Rockingham Park South	110
2019	9L1	Rockingham Park South	50
2019	9L2	Rockingham Park South	35

**Table 2 Salem Area Spot Loads**

The load was escalated through 2031 using the Summer Township Normal – Salem NH load growth data provided by Liberty Utilities; refer to Table 3 Summer Township Normal Load Growth - Salem, NH.

*Summer Township Normal - Salem NH*

<i>PSA</i>	<i>Town</i>	<i>Year</i>	<i>MW</i>	<i>% Increase</i>
<i>Eastern Geco</i>	Salem, NH	2016	71.96	
<i>Eastern Geco</i>	Salem, NH	2017	72.46	0.69%
<i>Eastern Geco</i>	Salem, NH	2018	73.04	0.80%
<i>Eastern Geco</i>	Salem, NH	2019	73.58	0.75%
<i>Eastern Geco</i>	Salem, NH	2020	73.95	0.50%
<i>Eastern Geco</i>	Salem, NH	2021	74.23	0.38%
<i>Eastern Geco</i>	Salem, NH	2022	74.54	0.43%
<i>Eastern Geco</i>	Salem, NH	2023	74.91	0.49%
<i>Eastern Geco</i>	Salem, NH	2024	75.25	0.46%
<i>Eastern Geco</i>	Salem, NH	2025	75.57	0.43%
<i>Eastern Geco</i>	Salem, NH	2026	75.90	0.44%
<i>Eastern Geco</i>	Salem, NH	2027	76.24	0.45%
<i>Eastern Geco</i>	Salem, NH	2028	76.60	0.47%
<i>Eastern Geco</i>	Salem, NH	2029	76.97	0.49%
<i>Eastern Geco</i>	Salem, NH	2030	77.36	0.50%
<i>Eastern Geco</i>	Salem, NH	2031	77.76	0.50%

**Table 3 Summer Township Normal Load Growth - Salem, NH**

Liberty Utilities  
Salem Area Study

---

Distribution Planning Criteria

Liberty Utilities' existing Distribution Planning Criteria was utilized to evaluate system capacity and reliability compliance.

The goal of these planning criteria is to provide adequate capacity for safe, reliable and economic service to customers with minimal impact on the environment. To achieve that goal, the distribution system is planned, measured, and operated with the objective of providing electric service to customers under system intact conditions (i.e., "normal") and first contingency conditions ("N-1").

For normal loading conditions, the planning criteria are based on feeders and transformers to remain within 75% of normal ratings at all times and supply lines to remain within 90% of normal ratings at all times.

For N-1 contingency situations, the planning criteria is based on interrupted load returning to service via system reconfiguration through switching, installation of temporary equipment, such as mobile transformers or generators, and/or by repair of a failed device.

The following criteria summarized below shall guide planning on the distribution system:

Condition	Sub-Transmission	Substation Transformer	Distribution Circuit
<b>Normal</b>	<ul style="list-style-type: none"> <li>Loading to remain within 90% of normal rating.</li> <li>Voltage at customer meter to remain within acceptable range.</li> <li>Circuit phasing is to remain balanced.</li> </ul>	<ul style="list-style-type: none"> <li>Loading to remain within 75% of normal rating.</li> <li>Voltage at customer meter to remain within acceptable range.</li> <li>Circuit phasing is to remain balanced.</li> </ul>	<ul style="list-style-type: none"> <li>Loading to remain within 75% of normal rating.</li> <li>Voltage at customer meter to remain within acceptable range.</li> <li>Circuit phasing is to remain balanced.</li> <li>Each feeder should have at least three feeder ties to adjacent feeders.</li> </ul>
<b>N-1 Contingency, which results in facilities operating above their Long Term Emergency (LTE) rating but below their Short Term Emergency (STE) rating.</b>	<ul style="list-style-type: none"> <li>Load must be transferred to other supply lines in the area to within their LTE rating.</li> <li>Repairs expected to be made within 24hrs.</li> <li>Evaluate alternatives if more than 36 MWhr of load at risk results following post-contingency switching.</li> </ul>	<ul style="list-style-type: none"> <li>Load must be transferred to nearby transformers to within their LTE rating.</li> <li>Repairs or installation of Mobile Transformer expected to take place within 24 hours.</li> <li>Evaluate alternatives if more than 60 MWhr of load at risk results following post-contingency switching.</li> </ul>	<ul style="list-style-type: none"> <li>Load must be transferred to nearby feeders to within their LTE rating.</li> <li>Repairs expected to be made within 24hrs.</li> <li>Evaluate alternatives if more than 16 MWhr of load at risk results following post-contingency switching.</li> </ul>
<b>N-1 Contingency, which results in facilities operating above their Short Term Emergency (STE) rating</b>	<ul style="list-style-type: none"> <li>As Needed – Typically 15min for OH conductors and 1-24 hours for UG cables</li> </ul>	<ul style="list-style-type: none"> <li>Loads must be reduced within 15 minutes to operate within their LTE rating</li> </ul>	<ul style="list-style-type: none"> <li>As Needed – Typically 15min for OH conductors and 1-24 hours for UG cables</li> </ul>

**Figure 4 Liberty Utilities Distribution Planning Criteria**

Liberty Utilities  
Salem Area Study

---

According to Liberty's Planning Criteria regarding loss of a supply line:

*For first contingency emergency conditions on a supply circuit, the worst of which is the loss of the circuit's getaway cable or circuit breaker. After transfers, all resultant components must be below the emergency ratings as defined by the appropriate loading guides. For the loss of a supply line, the following criterion applies:*

- *The initial load increase at the remaining sub-transmission supply lines within the area must not exceed the summer or winter LTE rating.*
- *Every effort must be made to return the failed sub-transmission line to service within 24 hours.*
- *Feeder ties and cascading of load within the area can be utilized to the emergency limits of feeders to offload a sub-transmission line.*
- *For a typical LU owned sub-transmission supply line consisting of either 13.8 kV or 23 kV, the quantity of load at risk of being out of service following post contingency switching should be limited to 1.5 MW. If more than 36MWh of load is at risk at peak load periods for a single fault, alternatives to eliminate or significantly reduce this risk shall be evaluated and prioritized considering the load at risk, reliability impacts and the cost to mitigate.*

According to Liberty's Planning Criteria regarding loss of a distribution feeder:

*For first contingency emergency conditions on a distribution circuit, the worst of which is the loss of the circuit's getaway cable or circuit breaker. For the loss of a distribution feeder, the following criterion applies:*

- *Feeders shall tie to neighboring feeders as much as practical as the flexibility to reconfigure feeders has a positive reliability impact for a wide range of possible contingencies. In general, and whenever practical, each feeder should have three feeder ties to neighboring feeders.*
- *Distribution feeders should be limited to 2,500 customers and sectionalized such that the number of customers does not exceed 500 or 2,000kVA of load between disconnecting devices.*
- *After transfers, all resultant components must be below the emergency ratings as defined by the appropriate loading guides. All adjoining tie feeders can be loaded to their maximum LTE rating.*
- *Feeder ties and cascading of load within the area can be utilized to the emergency limits of feeders to offload adjoining feeders.*
- *If more than 16 MWh of load is at risk at peak load periods for a single feeder fault, alternatives to eliminate or significantly reduce this risk shall be evaluated and prioritized considering the load at risk, reliability impacts, and the cost to mitigate.*
- *For a typical Liberty owned 10 MW feeder, approximately 8 MW would need to be restored via switching within one hour. The remaining 2 MW would be*

Liberty Utilities  
Salem Area Study

---

*restored after repairs within 4 hours. Where longer repair times are needed such as for a cable getaway fault, the load out of service should be reduced to 1 MW.*

According to Liberty's Planning Criteria regarding loss of a distribution transformer:

*First contingency operation is the condition under which a single element (feeder circuit or distribution substation transformer) is out of service. For first contingency emergency conditions involving the loss of one distribution substation transformer in an existing two-bank or more configuration, the following system design criteria applies:*

- In cases where a first contingency situation causes the LTE rating of the remaining transformer to be exceeded, all load above the LTE rating of the remaining transformers must be transferred to neighboring facilities or shed 15 minutes without exceeding the LTE rating of the substation transformers or distribution circuits receiving the load.*
- In cases where a first contingency situation will cause the STE rating of a remaining transformer to be exceeded, load must be immediately reduced (dropped/shed) to a level within the STE. All load between the LTE and STE ratings, and any load that was initially shed to get the remaining transformer below its STE rating, must be transferred to peripheral facilities without exceeding the LTE rating of the substation transformers or the distribution circuits receiving the load.*
- Repairs or the installation of mobile equipment are expected to require at least a 24 hour implementation.*
- For a typical Liberty owned substation consisting of 9.375 MVA transformers, the quantity of load at risk of being out of service following post contingency switching should be limited to 2.5 MW. If more than 60MWhrs of load is at risk at peak load periods for a transformer or substation bus fault, alternatives to eliminate or significantly reduce this risk shall be evaluated and prioritized considering the load at risk, reliability impacts and the cost to mitigate.*

### 3.5 Modeling and Criteria Documentation

CYME models were created for the Salem area distribution system. Transformers, supply lines, and distribution circuits were evaluated and modeled for each year thru 2031. The peak load and the available tie capacity for each component of the system was determined. N-1 contingencies were developed and the system consequences reviewed.

Distribution System Ratings were used in order to identify any station, supply line, and distribution circuit system capacity and reliability deficiencies, as applicable to Liberty Utilities Planning Criteria.

The condition of the existing assets was also reviewed during the study. Based on the results of these evaluations a series of short term and long term recommendations were developed.

Liberty Utilities  
 Salem Area Study

3.6 Present Concerns of Existing Distribution System

There were a number of existing system Circuit, Supply Line, and Transformer capacity concerns identified that did not meet the requirements of the Liberty Distribution Planning Criteria. These concerns were identified in the CYME Models by year for both the peak Normal and Contingency Loading configurations.

The CYME analysis of the Peak Loading configuration of the 13.2 kV circuits identified a number of conductor locations with loading in excess of 100% of the normal thermal limit.

1. These are listed in below Table 4, Present Concerns Conductor Thermal Overloads in Excess of 100%.

<i>Year</i>	<i>Feeder</i>	<i>Street &amp; Pole #</i>	<i>Conductor Type</i>	<i>Length Feet</i>	<i>% Overloaded</i>	<i>Targeted Mitigation</i>
2014	18L3	S Policy P55 to Fairmont P7	3P_4/0_AL	830	102	Phase 1

**Table 4 Present Concerns Conductor Thermal Overloads in excess of 100%**

The major present contingency issue found involves Spicket River No 13 substation. The Spicket River No.13 Station is currently supplied at 23 kV by the 2376 circuit from the National Grid Ward Hill Substation in Methuen, MA. The 2376 circuit ties with the 2353 circuit, which also originates from Ward Hill, via a pole mounted recloser loop scheme. The tie is located in the Spicket River Massachusetts Right of Way. Downstream of the 2376/2353 tie, the 2376 continues for 4.3 miles in National Grid territory crossing into New Hampshire and continuing 0.9 miles to the Spicket River No. 13 Substation. Approximately 5.2 miles of the 2376 is exposed to outages without any backup, with 4.3 miles in National Grid maintenance territory and 0.9 miles in Liberty Utilities territory.

The loss of the 23 kV source for an outage on the 5.2 mile section would require the Spicket River circuits to be backed up by existing distribution circuit ties. Based on 2016 actual load reads, the total Spicket River load is 24.9 MVA.

2. Table 5, Spicket River Load at Risk, represents the available capacity on the 13.2 kV tie circuits as well as Load at Risk by circuit.

<i>Distribution Circuit</i>	<i>Ties</i>	<i>Available Capacity</i>	<i>Load At Risk (Amps)</i>	<i>Load At Risk (MVA)</i>	<i>Targeted Mitigation</i>
13L1	13L2, 13L3	0 Amps	304	6.950	Phase 1,2

Liberty Utilities  
 Salem Area Study

13L2	9L1, 9L3	397 Amps	27	0.617	Phase 1,2
13L3	10L2, 9L1, 18L2	415 Amps	0	0	Phase 1,2

**Table 5 Spicket River Load at Risk**

Loss of the 23 kV sub-transmission supply circuit to the Spicket River No.13 Station would result in approximately 7.6 MVA of load at risk, after restorative switching occurs.

Liberty Utilities is dependent on National Grid to expedite repairs should an outage related problem occur anywhere along the 4.2 miles of National Grid owned 2376 sub-transmission line downstream of the 2376/2353 tie. This could cause Liberty Utilities to have up to 116 MWHrs of load at risk, for an assumed repair time of 12 hours, which violates Liberty’s planning criteria

The National Grid planning criteria is not appropriate for a system the size of Liberty Utilities. According to the National Grid criteria, National Grid is required to return the failed sub transmission line to service within 12 hours and is allowed 240 MWHrs of load at risk. A more conservative approach should be taken in this case since the 23 kV supply line feeding Spicket River Station is a sole source circuit without any contingency sub-transmission backup within Liberty Utilities operating territory. This will eliminate reliance on National Grid and allow Liberty Utilities to significantly reduce load at risk.

In addition to the aforementioned supply line criteria violation; the 9L2 distribution circuit fed from Salem Depot Station has an existing loading issue that violates the 16 MWH rule with 3.7 MVA at risk in 2016.

- Referring to Table 6, Existing Identified load at risk after loss of a distribution Feeder Contingency (N-1). It also notes when a supply line’s contingency loading exceeds 16MWH which is a violation of the Liberty Utilities Planning criteria. It is assumed that a distribution feeder outage will require one hour of switch time and four hours of repair time.

<b>Year</b>	<b>Distribution Circuit</b>	<b>Distribution Circuit Load MVA</b>	<b>Load at Risk MVA</b>	<b>Total MWHR Outage</b>	<b>Comments</b>	<b>Targeted Mitigation</b>
2016	9L2	6.5	3.7	17.0	Violates 16 MWHR Criteria	Phase 2
2016	18L1	6.4	0.5	6.5		Phase 2,3

Liberty Utilities  
 Salem Area Study

2016	18L3	7.3	0.6	7.3	Phase 2,3
2016	18L4	7.5	1.1	9.2	Phase 2,3
2016	9L3	7.9	1.0	9.0	Phase 2
2016	13L1	7.0	2.6	13.8	Phase 1,2
2016	13L2	9.7	0.9	10.2	Phase 1,2

**Table 6 Existing Distribution Circuit Contingency with Load at Risk**

The study also identified several capacity concerns that did not meet the requirements of the Liberty Distribution Planning Criteria for both the peak Normal and Contingency Loading configurations.

The following tables identify the distribution system components which exceed 75% of their Summer Normal and exceed load at risk during contingency conditions:

The 13L2 Circuit, which is limited to 515 Amps by 336 Al OH, exceeds 75% of its Summer Normal rating in 2016. The 9L2 Circuit's transformer which is limited to 322 Amps exceeds 75% of its Summer Normal rating in 2016. The 9L2 Transformer is the limiting factor on this circuit. The Liberty Distribution Planning criteria limits loading on distribution circuits to below 75% of their summer normal rating.

- Refer to Table 7, Existing Concern Distribution Circuit Peak Load in excess of 75%:

Year	Distribution Circuit	SN Rating	% Load	Amps Load	Targeted Mitigation
2016	9L2	322	88	284	Phase 2
2016	13L2	515	82	424	Phase 1,2

**Table 7 Existing Concern Distribution Circuit Peak Load in excess of 75%**

- Table 8, Existing Concern Sub-Transmission Circuit Peak Load in excess of 90%. The Liberty Distribution Planning criteria limits loading on sub-transmission circuits to below 90% of their summer normal rating. Supply Line 2376 is approximately 5.2 miles in length, with 4.3 miles in National Grid maintenance territory and 0.9 miles in Liberty Utilities territory.

Year	Supply Line	Line Segment	SN Rating	% Load	MVA Load	Targeted Mitigation
2016	2376	Meth Tap to Spicket Tap	25.3	98	24.9	Phase 1,2

**Table 8 Existing Concern Sub-Transmission Circuit Peak Load in excess of 90%**



Liberty Utilities  
 Salem Area Study

6. Table 9, Existing Concern Transformer Contingency in excess of 90%, identifies system transformer contingencies where the transformer loading exceeds 90% of Summer Emergency rating. The contingency assumes one station transformer out of service (N-1). The Liberty Distribution Planning criteria limits contingency loading on transformers to 2.5MW of load at risk.

<b>Year</b>	<b>Transformer</b>	<b>SE Rating</b>	<b>% Load</b>	<b>MVA Load</b>	<b>Targeted Mitigation</b>
2016	Salem Depot L2	9.20	95	8.7	Phase 2

**Table 9 Existing Concern Transformer Loading in excess of 90% - during Contingency**

1. Table 10, Existing Concern 23 kV Supply Line Contingency in excess of 90%, identifies 23 kV supply line contingencies where the individual line segment's loading exceeds 90% of Summer Emergency rating. It also notes when a supply line's contingency loading reaches 100% of the Summer Emergency rating. The contingency assumes one supply line out of service (N-1). The Liberty Distribution Planning criteria limits contingency loading on supply lines to 1.5 MW of load at risk. Supply Line 2376 is approximately 5.2 miles in length, with 4.3 miles in National Grid maintenance territory and 0.9 miles in Liberty Utilities territory.

<b>Year</b>	<b>Supply Line</b>	<b>Line Segment</b>	<b>SE Rating</b>	<b>% Load</b>	<b>MVA Load</b>	<b>Targeted Mitigation</b>
2016	2393	Baron Ave Tap to Olde Trolley Tap	58.2	101	58.7	Phase 1,2
2016	2376	Meth Tap to Spicket Tap	25.3	98	24.9	Phase 1,2

**Table 10 Existing Concern 23 kV Supply Line in excess of 90% - during Contingency**

### 3.7 Predicted Problems of Existing Distribution System

There are a number of forecasted system Distribution Circuit, Supply Line, and Transformer capacity concerns identified that are not expected to meet the requirements of the Liberty Distribution Planning Criteria and Strategy given the forecasted growth and proposed customer expansions in the area. These customer expansions are expected to take place from 2017 through 2019.

These concerns were identified by year for both the Normal Loading and the

Liberty Utilities  
 Salem Area Study

contingency Loading cases and are further detailed below.

1. Table 11, Predicted Concern Distribution Circuits with Normal Loading in excess of 75% Summer Normal Rating, identifies the 13.2 kV Distribution Circuits exceeding 75% of their Summer Normal Rating in the years 2017 through 2019. It also notes when a distribution circuit loading reaches 100% of the Summer Normal rating. Liberty's Distribution Planning criteria limits distribution circuit loading to 75% of its summer normal rating.

<b>Year</b>	<b>Distribution Circuit</b>	<b>Limiting Element</b>	<b>SN Rating</b>	<b>% Load</b>	<b>Amps Load</b>	<b>Targeted Mitigation</b>
2017	9L1	7 MVA Transformer	322	75	240	Phase 2
2019	9L1	7 MVA Transformer	322	91	294	Phase 2
2017	9L2	7 MVA Transformer	322	89	286	Phase 2
2019	9L2	7 MVA Transformer	322	101	325	Phase 2
2017	9L3	9.4 MVA Transformer	507	75	380	Phase 2
2018	9L3	9.4 MVA Transformer	507	102	515	Phase 2
2018	18L2	1000 AL UG Cable	503	76	384	Phase 2, 3
2019	18L2	1000 AL UG Cable	503	94	475	Phase 2,3
2019	18L3	336.4 AL OH Line	515	83	425	Phase 2,3
2017	13L2	336.4 AL OH Line	515	83	427	Phase 1,2
2030	13L3	Regulator	522	75	389	Phase 1,2

**Table 11 Predicted Concern Distribution Circuits with Normal Loading in excess of 75% Summer Normal Rating**

2. Table 12 Predicted Concern Distribution Circuits Contingencies with Load at Risk Violations, identifies 13.2kV circuits where the contingency outage restoration MWHRs exceeds the 16 MWHR criteria and the year in which this occurs.

<b>Year</b>	<b>Distribution Circuits</b>	<b>Distribution Circuits Load MVA</b>	<b>MVA Load at Risk</b>	<b>Total MWHR Outage</b>	<b>Targeted Mitigation</b>
-------------	------------------------------	---------------------------------------	-------------------------	--------------------------	----------------------------

Liberty Utilities  
 Salem Area Study

2017	9L2	6.5	4.4	19.1	Phase 2
2018	9L2	6.6	6.7	26.8	Phase 2
2019	9L2	7.4	7.6	30.4	Phase 2
2019	18L1	6.6	4.3	19.0	Phase 2,3
2019	18L3	9.7	6.1	27.3	Phase 2,3
2018	9L3	11.8	6.1	28.6	Phase 2
2019	9L3	11.9	9.3	39.2	Phase 2
2018	13L2	9.8	4.3	21.5	Phase 1,2
2019	13L2	9.9	5.1	24.0	Phase 1,2
2019	9L1	6.7	3.7	17.1	Phase 2
2021	13L1	7.2	3,3	16.1	Phase 1,2
2028	18L2	11.1	2.5	16.3	Phase 2,3

**Table 12 Predicted Concern Distribution Circuits Contingencies with Load at Risk Violations**

3. Table 13 Predicted Concern Transformers with Normal Loading in excess of 75% Summer Normal, identifies system transformers where the normal loading exceeds 75% of the Summer Normal rating and the year in which this occurs. It also notes when a distribution transformer loading reaches 100% of the Summer Normal rating. Liberty’s Distribution Planning criteria limits transformer loading to 75% of its summer normal rating.

<b>Year</b>	<b>Transformer</b>	<b>SN Rating</b>	<b>% Load</b>	<b>MVA Load</b>	<b>Targeted Mitigation</b>
2017	Salem L1	12.5	75	5.5	Phase 2
2019	Salem L1	12.5	91	6.7	Phase 2
2017	Salem L2	7.36	89	6.6	Phase 2
2019	Salem L2	7.36	101	7.4	Phase 2
2017	Salem L3	11.6	75	8.7	Phase 2
2018	Salem L3	11.6	102	11.8	Phase 2
2019	Olde Trolley L2	12.4	88	10.9	Phase 2,3
2019	Olde Trolley L3	12.5	78	9.7	Phase 2,3
2029	Spicket River L2	13.9	75	10.4	Phase 1,2

**Table 13 Predicted Concern Transformers with Normal Loading in excess of 75% Summer Normal**

4. Table 14 Predicted Concern Transformer Contingencies with loading in excess of 90% Summer Emergency, identifies system transformer contingencies where the transformer loading exceeds 90% of Summer Emergency rating and the year it occurs. It also notes when a transformer’s

Liberty Utilities  
 Salem Area Study

loading reaches 100% of the Summer Emergency rating. The contingency assumes one station transformer out of service (N-1). Liberty’s Distribution Planning criteria limits contingency load at risk on transformers to within 2.5 MW.

<b>Year</b>	<b>Transformer</b>	<b>SE Rating</b>	<b>% Load</b>	<b>MVA Load</b>	<b>Targeted Mitigation</b>
2017	Salem L1	10.1	103	10.4	Phase 2
2017	Salem L2	9.2	113	10.4	Phase 2
2018	Salem L1	10.1	118	11.9	Phase 2
2018	Salem L2	9.2	130	11.9	Phase 2
2018	Salem L3	11.6	103	11.9	Phase 2
2019	Salem L1	10.1	129	13.0	Phase 2
2019	Salem L2	9.2	141	13.0	Phase 2
2019	Salem L3	11.6	112	13.0	Phase 2
2022	Spicket L1	14.4	90	12.9	Phase 1,2
2022	Spicket L2	14.4	90	12.9	Phase 1,2
2022	Spicket L3	14.4	90	12.9	Phase 1,2
2020	Olde T L1	12.9	90	11.6	Phase 2,3
2020	Olde T L2	12.9	90	11.6	Phase 2,3
2021	Olde T L3	13.0	90	11.7	Phase 2,3
2021	Olde T L4	13.0	90	11.7	Phase 2,3

**Table 14 Predicted Concern Transformer Loading in excess of 90% Summer Emergency – during Contingency**

Liberty Utilities  
 Salem Area Study

5. Table 15 Predicted Concern 23kV Supply Line Contingencies with Loading in excess of 90% Summer Emergency, identifies 23kV supply line contingencies where the individual line segment's loading exceeds 90% of Summer Emergency rating and the year it occurred. It also notes when a supply line segment's loading reaches 100% of the Summer Emergency rating. Liberty's Distribution Planning criteria limits contingency load at risk on supply lines to 2.5 MW.

<b>Year</b>	<b>Supply Line</b>	<b>Line Segment</b>	<b>SE Rating</b>	<b>% Load</b>	<b>MVA Load</b>	<b>Load at Risk</b>	<b>Targeted Mitigation</b>
2017	2393	Baron Tap to Olde Trolley Tap	58.2	99	57.5	0	Phase 1,2
2018	2393	Baron Tap to Olde Trolley Tap	58.2	113	65.6	7.4	Phase 1,2
2018	2393	Golden Rock to Baron Tap	67.4	97	65.6	0	Phase 1,2
2019	2393	Baron Tap to Olde Trolley Tap	58.2	125	72.5	14.3	Phase 1,2
2019	2393	Golden Rock to Baron Tap	67.4	108	72.5	5.1	Phase 1,2
2019	2393	Olde Trolley Tap to Salem Depot	27.1	96	26.0	0	Phase 1,2
2019	2352	Olde Trolley Tap to Salem Depot	27.1	96	26.0	0	Phase 1,2
2019	2352	GR to Baron Ave Tap	67.4	90	60.6	0	Phase 1,2
2028	2352	Olde Trolley Tap to Salem Depot	27.1	100	27.1	0.1	Phase 1,2
2028	2393	Olde Trolley Tap to Salem Depot	27.1	100	27.1	0.1	Phase 1,2
2027	2352	Olde Trolley Tap to Olde Trolley	40.0	90	35.9	0	Phase 1,2
2027	2393	Olde Trolley Tap to Olde Trolley	40.0	90	35.9	0	Phase 1,2

**Table 15 Predicted Concern 23kV Supply Line Loading in excess of 90% Summer Emergency – during Contingency**

---

## 4 Recommended Plan

Several plans were evaluated to address the existing and future system needs of the area. The study took into consideration existing distribution asset concerns while establishing possible recommendations.

The recommended plan for consideration addresses all existing and predicted system capacity and asset replacement requirements. It also addresses capacity requirements that result from large customer expansions in the Rockingham Park area. The plan will be achieved in three (3) phases. It addresses all concerns in the most complete way while moving the system from the legacy 23 kV supplied system to a more reliable and sustainable 115 kV supplied system.

### 4.1 Plan Description

#### **Phase One (New 115/13.2 kV Transformer at Golden Rock Station with Baron Ave Station Elimination & Mitigation of Planning Criteria)**

Phase One will initially address the conductor, in excess of 100% of Summer Normal ratings, on the Salem Depot 9L3, and Olde Trolley 18L3. All conductor upgrades would be accomplished using 477 Al open wire or 477 Al spacer depending upon field conditions consisting of the following:

1. Re-conductor 830' of 4/0 Al to 477 Al on distribution circuit 18L3. This re-conductor would start at pole 55 on S Policy Street then to Pole 1 on Fairmont Road up to pole 7 on Fairmont Road replacing the existing 4/0 Al conductor.

Phase One consists of a second 115 kV line into Golden Rock Station supplying a new 115 kV/13.2 kV, 33/44/55 MVA substation transformer with three (3) new circuit positions and one (1) future circuit position. The future circuit 19L8 will be installed during Phase 2 when the new underground conduit system along the ROW is installed.

It also consists of the removal of the existing 23kV bus tie breakers and the relocation of the 23kV OH tie line between the 2393 and 2376 circuits outside of the substation. The 2352 circuit will also be removed from Golden Rock to Baron Ave.

The total cost of the Phase One project is estimated at \$5,584,000.

#### **Phase Two (Two-New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination)**

Liberty Utilities  
Salem Area Study

---

Phase Two of the recommended plan consists of a new double ended 115kV/13.2kV station in the Rockingham area, Station #21, with two (2) 33/44/55 MVA substation transformers. Each new transformer would have four circuits, with secondary breakers and a bus tie breaker. An automatic bus transfer system would be utilized to improve reliability and simplify maintenance.

The two (2) 23kv supply circuits 2352 and 2393 will be relocated from OH to UG to make way in the right of way for the two (2) new 115kV transmission supply lines supplying the new Rockingham Substation. This new underground system along the ROW will also be used for future distribution feeders out of Golden Rock Substation (Phase 3) and for the 19L8 feeder out of Golden Rock T2.

If the implementation of a new Rockingham Station is significantly delayed, Salem Depot Station upgrades should be pursued. This includes upgrading the two 6.25 MVA, 23kV/13.2kV auto transformers at Salem Depot Station with new 9.376 MVA two winding 23kV/13.2kV transformers along with upgraded bus, new primary breakers and new secondary breakers.

In addition, if the implementation of a new Rockingham Station is significantly delayed, the temporary installation of a 23/13.2kV 9.375 MVA transformer within the Rockingham Park should be pursued. One transformer from the retired Baron Avenue substation could be reserved for this application. Although this transformer and sub-transmission supply system would not have the full capacity to supply all of the forecasted expansions in the park, it could buy enough time to supply some new developments in the Park as the new Rockingham Station is being implemented.

The total cost of the Phase Two project is estimated at \$20,648,000.

**Phase Three (New 115/13.2 KV Transformer at Golden Rock Station with Olde Trolley Station and 23kV Supply System Elimination)**

Phase three of the recommended plan consists of a second 115kV/13.2kV substation transformer at Golden Rock with three (3) new 13.2kV feeder positions. The existing 115kV/23kV Golden Rock transformer is to be removed and the substation is to be converted into a 13.2kV with a breaker and a half scheme. The existing 23kV lines will be converted to 13.2kV distribution circuits. The 13.2 kV circuits would be constructed to provide contingency support to Rockingham Station and Spicket River Station and to convert the Olde Trolley Station to a regulator/switching station and to eliminate the 23kV supply system in the area.

The total cost of the Phase Three project is estimated at \$4,684,000.

---

## 5 Plan Summary

The following is a summary of the Plans that were considered as part of this study:

### Recommended Plan:

**Phase 1** – Golden Rock T2 with Baron Ave Elimination and Spicket River Backup.

**Phase 2** – New Rockingham Substation with Salem Depot Elimination and Planning Criteria Mitigation. Installs new UG facilities along 23kV ROW.

**Phase 3** – Golden Rock T1 with 23kV Supply System Elimination.

### Alternate Plan 1:

**Phase 1** – Golden Rock T2 with Baron Ave Elimination and Spicket River Backup. 23kV Supply line 2393 will be extended to Spicket River on city streets utilizing over-build construction.

**Phase 2** – New Rockingham Substation with Salem Depot Elimination and Planning Criteria Mitigation.

**Phase 3** – None.

### Alternate Plan 2:

**Phase 1** – Golden Rock T2 with Baron Ave Elimination and Spicket River Backup. A new National Grid 23 kV supply circuit will be extended to the Spicket River Station. This would be jointly constructed in the existing 23kV Right of Way by Liberty and National Grid.

**Phase 2** – New Rockingham Substation with Salem Depot Elimination and Planning Criteria Mitigation.

**Phase 3** – None.

### Alternate Plan 3:

**Phase 1** – Golden Rock T2 with Baron Ave Elimination and Spicket River Backup.

**Phase 2** – New Rockingham Substation with Salem Depot Elimination and Planning Criteria Mitigation. Relocates two (2) 23kv supply circuits 2352 and 2393 to South Broadway to make way in the right of way for the two (2) new 115kV transmission supply lines supplying the new Rockingham Substation. The relocated 23kV lines will be overbuild along existing and new infrastructure along city street South Broadway.

**Phase 3** – Golden Rock T1 with 23kV Supply System Elimination.

### Alternate Plan 4:

**Phase 1** – Golden Rock T2 with Baron Ave Elimination and Spicket River Backup. This plan relocates the two (2) 23kv supply circuits 2352 and 2393 along the ROW to a new underground conduit system along same ROW to make way for the two (2) new 115kV transmission supply lines supplying the new Rockingham Substation. This plan differs from the Recommended Plan Phase



Liberty Utilities  
Salem Area Study

---

One in the configuration of the distribution line circuits.

**Phase 2** – New Rockingham Substation with Salem Depot Elimination and Planning Criteria Mitigation.

**Phase 3** – Golden Rock T1 with 23kV Supply System Elimination.

**Alternate Plan 5:**

**Phase 1** – Golden Rock T2 with Baron Ave Elimination and Spicket River Backup.

**Phase 2** – New Rockingham Substation with Salem Depot Elimination and Planning Criteria Mitigation. Relocates two (2) 23kv supply circuits 2352 and 2393 to South Broadway to make way in the right of way for the two (2) new 115kV transmission supply lines supplying the new Rockingham Substation. The relocated 23kV lines will be installed via new underground conduit system along city street South Broadway.

**Phase 3** – Golden Rock T1 with 23kV Supply System Elimination.

Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 35 of 218

5.1.1 Recommended Plan Phase One Estimate:

**Table 16 Recommended Plan Phase One Estimate**

<b>Recommended Plan Phase One: First New 115/13.2kV Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
115 kV Line Extension	Extend second 115 kV line to the existing Golden Rock Station.	TBD	Only one 115 kV Line extension is required.	Requires interconnection and extension of NGRID's 115 kV system. More permitting associated with 115 kV line Extension.	Transmission owned project.
T2 - 115/13.2 kV - 33/44/55 MVA Xfmr (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four feeder breakers. Include an automatic transfer system on the 115 kV lines.	\$3,000	Adds significant capacity to the system, addresses the Spicket River contingency and eliminates Baron Ave Station asset concerns. Minimizes dependency on the NGRID 23 kV system for load support. Makes 23-13kV transformer available to temporarily supply new Rockingham Park loads.	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers	Portions of the existing 23 kV bus may be utilized in the new 115/13.2 kV transformer installation. NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
	<b>Total Station Work</b>	<b>\$3,000</b>			

<b>Recommended Plan Phase One: First New 115/13.2kV Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Feeder – 19L2	1000 MCM CU UG cable from Golden Rock Station to P21 Hampshire St (700ft) on new 4X4-6" UG conduit system. Reconductor former Baron Ave 10L2 with 477 spacer cable from Golden Rock to Cuomo St (3,600ft) . Reconductor Cuomo St with 477 spacer cable from Garabeddian Dr to South Broadway (900ft). New 19L2 feeder picks up portion of 10L1 at Garabeddian Dr (112Amps) and picks up portion of 10L2 at Baron Ave, Bagnell Ave and Kelly Rd (70A). Install one recloser	\$647	Eliminates Baron Ave Station and Back up Olde Trolley. Makes way for future tie with Pelham Substation. Does not construct facilities along South Broadway.		Assumes 33% of the getaway civil project - (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft). City Construction.
Feeder – 19L4	1000 MCM CU UG cable from Golden Rock Station to P149 Hampshire St (700ft) on new 4X4-6" UG conduit system. Reconductor former Baron Ave 10L1 Hampshire St with 477 spacer cable from Golden Rock to South Broadway (1,900ft). New 19L4 feeder picks up portion of 10L1 at Hampshire St (48Amps) Pond St (50Amps), picks up portion of 10L4 at Pattee Rd (48Amps) and picks up portion of 10L2 Cluff Rd West (107A). Install one recloser.	\$426	Eliminates Baron Ave Station and Backup Olde Trolley. Does not construct facilities along South Broadway.		Assumes 33% of the getaway civil project - (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft). City Construction
Feeder – 19L6	1000 MCM CU UG cable from Golden Rock Station to Hampshire St (700ft) on new 4X4-6" UG conduit system. Install new double circuit 477 Spacer Cable along Hampshire St to South Broadway to Lawrence Rd (2,100ft). Install new 477 Spacer cable OH three phase line along Lawrence Rd (5,000ft) from Pond St to Ansel St. Reconductor Lawrence Rd (4,700ft) from Ansel St to Cole St with 477 spacer cable. New 19L6 feeder picks up portion of 10L4 at Lawrence Rd (90Amps) and picks up portion on 10L2 at Cluff Rd East (43Amps). Install one recloser. Install one load break at P69 Main St on 13L3 for option to pick up 113Amps.	\$1,327	Eliminates Baron Ave Station and Backup Spicket River Station. Does not construct facilities along South Broadway.		Assumes 33% of the getaway civil project - (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft). City Construction
Future Feeder – 19L8	Future Feeder to be installed during Phase 2.	\$0	Takes advantage of Phase 2 UG conduit system along ROW.		Future 19L8 is to be installed during Phase 2 to take advantage of new underground conduit system along the ROW.
	<b>Total Line Work Eliminate Baron Ave &amp; Spicket River Backup Alternative</b>	<b>\$2,400</b>			

Liberty Utilities  
 Salem Area Study

<b>Recommended Plan Phase One: First New 115/13.2kV Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
23 kV Line Tie from the 2393 to the 2376	23 kV OH Tie line outside of the Sub Station from the existing 2393 line to the 2376 (removed from Golden Rock Sta) approximately 1,200'	\$150	Maintains access to NGRID's 2376 line for contingency use.		Relocates the tie between 2393 and 2376 to outside of the station yard.
23 kV Line Removal 2353	Remove 23 kV Circuit 2353 that runs along 23kV ROW from Golden Rock to Baron Ave (4,000ft)	\$34	Makes room in the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. (Phase 2).		Removal Costs - Assumes 10% of \$85/ft.
	<b>Total Sub transmission Line Work Eliminate Baron Ave &amp; Spicket River Backup Alternative</b>	<b>\$184</b>			

Liberty Utilities  
 Salem Area Study

5.1.2 Recommended Plan Phase Two Estimate:

**Table 17 Recommended Plan Phase Two Estimate**

<b>Recommended Plan Phase 2: Two New 115/13.2 KV Transformers at New Rockingham Station #21 with Salem Depot Station Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Two - 115 kV Line Extensions	Extend two 115 kV line to the proposed Rockingham Station.	<b>TBD</b>	New 115kV lines could be installed in existing ROW in a low profile style construction.	Requires interconnection and extension of NGRID's 115 kV system. More permitting associated with 115 kV line Extension. Requires relocation of the existing 23kV sub-transmission system along ROW.	
T1 - 115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four distribution circuit breakers.	\$2,800	Adds significant capacity to the system, addresses Liberty Planning Criteria violations and eliminates Salem Depot asset condition issues. Minimizes dependency on the NGRID 23 kV system for load support.	Challenges with outage coordination and cutovers. Requires land acquisition within the Rockingham Park.	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
T2 -115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus + 13.2 Bus Tie breaker	Perform all necessary construction to convert the new Rockingham Station into a double ended station with a tie breaker and auto-transfer of the secondary bus for a loss of either transformer.	\$3,000	Adds significant capacity to the system, addresses Liberty Planning Criteria violations and eliminates Salem Depot asset condition issues. Minimizes dependency on the NGRID 23 kV system for load support.	Challenges with outage coordination and cutovers. Requires land acquisition within the Rockingham Park.	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
	<b>Total Station Work T1</b>	<b>\$2,800</b>			
	<b>Total Station Work T2</b>	<b>\$3,000</b>			
	<b>Total Station Work</b>	<b>\$5,800</b>			

<b>Recommended Plan Phase 2: Two New 115/13.2 KV Transformers at New Rockingham Station #21 with Salem Depot Station Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Distribution Circuit - 21L1	From Rockingham Station install 1000 MCM CU UG cable to P104 South Broadway (1800ft) on new UG conduit system. New 21L1 circuit picks up portion of 9L1 along South Broadway north of P104, North Broadway and Taylor St (164Amps). Install New LB tie at P104 S Broadway.	\$468	Eliminates Salem Depot Station issues with asset condition and adds Back up supply to Olde Trolley Station.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
Distribution Circuit - 21L2	From Rockingham Station install 1000 MCM CU UG cable to P104 South Broadway (1800ft) on new UG conduit system. Install second circuit along North Broadway from P104 to Old Rockingham Rd (6600ft) using 477 spacer cable. Install New LB tie at P5-1 North Policy St. New 21L2 circuit picks up portion of 9L1 along Old Rockingham Rd and portion of 9L3 along Range Rd (121Amps).	\$1,155	Eliminates Salem Depot Station issues with asset condition and adds Back up supply to Olde Trolley Station.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
Distribution Circuit - 21L3	From Rockingham Station install new 477 spacer cable to Rocktrack. Reconductor wires along Rocktrack/Pleasant St from P8 Rocktrack to P17 Pleasant St (1200ft) with 477 spacer cable. New 21L3 circuit picks up portion of 18L3 Pleasant St including Mall Switchgears 3,4 and 5 (160Amps).	\$102	Could become future spare feeder.  Initially could be used to carry Mall load while Phase 3 Olde Trolley 23kV retirement takes place.		Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
Distribution Circuit - 21L4	From Rockingham Station install 1000 MCM CU UG cable to P104 South Broadway (1800ft) on new UG conduit system. New 21L4 circuit picks up portion of 9L1 along South Broadway south of P104 and portion of 18L2 along Veteran's Memorial Pkwy (145Amps).	\$448	Could be used to carry Olde Trolley load while Phase 3 Olde Trolley 23kV retirement takes place.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
	<b>Total Distribution Circuit - T1</b>	<b>\$2,173</b>			
	<b>Total Station and Distribution - T1</b>	<b>\$4,973</b>			

<b>Recommended Plan Phase 2: Two New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Distribution Circuit - 21L5	From Rockingham Station install 1000 MCM CU UG cable to P16 Pleasant St (2200ft) on new UG conduit system. Reconductor wires along Pleasant St from P16 Pleasant St to P7 Main St (1700ft). New 21L5 circuit picks up portion of 9L3 along Main St and South Policy Rd including Canobie Lake Park. (120Amps).	\$636	Eliminates Salem Depot Station and add Back up supply to Olde Trolley and Spicket River Stations.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft) Assumes 50% of the costs for new double circuit pole line along Pleasant St
Distribution Circuit - 21L6	From Rockingham Station install 1000 MCM CU UG cable to P16 Pleasant St (2200ft) on new UG conduit system. Install second circuit along Pleasant St for L6 (1700ft). New 21L6 circuit picks up feeder 9L2. (224Amps).	\$588	Eliminates Salem Depot Station and add Back up supply to Olde Trolley and Spicket River Stations.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft) Assumes 50% of the costs for new double circuit pole line along Pleasant St
Distribution Circuit - 21L7	Future	\$0			Future Feeder 1 of 2 for Tuscan Park
Distribution Circuit - 21L8	Future	\$0			Future Feeder 2 of 2 for Tuscan Park
Golden Rock Feeder - 19L8 Spicket River Mitigation	1000 MCM CU UG cable from Golden Rock Station to ROW (850ft) to Veteran's Memorial Hwy (10,000) on new 4X3-6" UG conduit system. Install second OH three phase line along existing South Broadway pole line (2,000ft) from Veteran's Memorial Pkwy to Belmont St. Install new OH three phase line along Belmont St and Granite Ave (3,900ft) from South Broadway to Main St. New Golden Rock 19L8 feeder picks up portion of 9L1 at Main St east of Broadway (18Amps), picks up a portion of 13L2 at Millville south of Bluff St (103Amps) and picks up portion of 13L3 East Main St LB 701108 (221Amps). Install one recloser.	\$2,946	Utilizes proposed UG conduit system along ROW for 23kV relocation. Resolves contingency loading violations for Spicket River Substation. Provides backup to Olde Trolley substation. Does not build UG facilities along South Broadway.	Pole congestion along South Broadway from Veteran's Memorial Pkwy to Belmont St due to double circuit pole line. (2,000ft). This could create challenges with guying and easements. Pole hit could impact two 13.2kV feeders although from two different substations. Need to acquire rights in the ROW to build underground facilities.	Assumes 33% of the (4X3) 6" underground conduit system from Golden Rock to ROW (850ft) to Veteran's Memorial Hwy (10,000ft)
	<b>Rockingham Sub Total Distribution Circuit - T2</b>	<b>\$1,224</b>			
	<b>Rockingham Sub Total Station and Distribution - T2</b>	<b>\$4,224</b>			
	<b>Phase 2 Total Distribution Line Work</b>	<b>\$6,343</b>			

<b>Recommended Plan Phase 2: Two New 115/13.2 KV Transformers at New Rockingham Station #21 with Salem Depot Station Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
23kV 2352 Relocation to South Broadway OH Option	Install two new 1000 MCM CU UG parallel cable from Golden Rock Station to ROW (850ft) to Veteran's Memorial Hwy (10,000) on new 4X3-6" UG conduit system. Tie in new UG conduit system along South Broadway to existing MH 15 Rockingham Park (200ft). Tie into existing 2352 at MH 15.	\$4,137	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Does not create pole congestion along S Broadway. Does not install UG facilities along South Broadway. Will allow re-purposing underground cables as part of Phase 3 project as new 13.2kV feeders out of Golden Rock to pick up Olde Trolley load.	Need to acquire rights in the ROW to build underground facilities.	Assumes 33% of the (4X3) 6" underground conduit system from Golden Rock to ROW (850ft) to Veteran's Memorial Hwy (10,000ft) This will make way and pay for future repurpose of the Olde Trolley feeders for retirement (Phase 3) Going with 1 set of 1000MCM Cu rather than 2 parallel sets reduces the total cost by approx. \$2M
23kV 2393 Relocation to South Broadway OH Option	Install two new 1000 MCM CU UG parallel cable from Golden Rock Station to ROW (850ft) to Veteran's Memorial Hwy (10,000) on new 4X3-6" UG conduit system. Tie in new UG conduit system along S Broadway to existing MH 15 Rockingham Park (200ft). Tie into existing 2393 at MH 15.	\$4,137	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Does not create pole congestion along S Broadway. Does not install UG facilities along South Broadway. Will allow re-purposing underground cables as part of Phase 3 project as new 13.2kV feeders out of Golden Rock to pick up Olde Trolley load.	Need to acquire rights in the ROW to build underground facilities.	Assumes 33% of the (4X3) 6" underground conduit system from Golden Rock to ROW (850ft) to Veteran's Memorial Hwy (10,000ft) This will make way and pay for future repurpose of the Olde Trolley feeders for retirement (Phase 3) 2393 does not run along ROW between Golden Rock and Baron Ave. It runs along ROW between Baron Ave and Rockingham Park. Going with 1 set of 1000MCM Cu rather than 2 parallel sets reduces the total cost by approx. \$2M
23 kV ROW Line Removal 2352	Remove 23 kV Circuit 2352 that runs along 23kV ROW from Golden Rock to Baron Ave to Salem Depot. (15,500ft)	\$132	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Removes 23kV lines that run along the ROW from the Rockingham Park to Salem Depot.		Removal Costs - Assumes 10% of \$85/ft.
23 kV ROW Line Removal 2393	Remove 23 kV Circuit 2393 that runs along 23kV ROW from Baron Ave to Salem Depot. (11,500ft) 2393 circuit from Golden Rock to Baron Ave will be re-purposed as a 13.2kV feeder as part of Phase 3.	\$98	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Will allow re-purposing 23kV circuit 2393 as a new 13.2kV feeder out of Golden Rock (Phase 3).		Removal Costs - Assumes 10% of \$85/ft.
<b>Total Sub-transmission Line Work</b>		<b>\$8,504</b>			



Liberty Utilities  
 Salem Area Study

5.1.3 Recommended Plan Phase Two Delays - Estimate Salem Depot Upgrade:

If the implementation of a new Rockingham Station is significantly delayed, Salem Depot Station upgrades should be pursued. This includes upgrading the two 6.25 MVA, 23kV/13.2kV auto transformers at Salem Depot Station with new 9.376 MVA two winding 23kV/13.2kV transformers along with upgraded bus, new primary breakers and new secondary breakers.

**Table 18 Recommended Plan Phase Two Salem Depot Upgrade Estimate**

<b>Recommended Plan Phase Two Salem Depot Station Upgrade Station Estimate</b>			
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Comments</b>
At Salem Depot Station Replace the two existing 23/13.2 kV, 6.25 MVA Auto Transformers with new 23/13.2 kV, 9.375 MVA two winding transformers (SN = 13.9 MVA, SE = 14.4 MVA)	Perform all necessary construction to remove two (2) existing 23/13.2 kV, 6.25 MVA auto transformers and install two new 23/13.2 kV, 9.75 MVA two winding transformers along with their 25 kV primary and 15 kV secondary breakers.	\$1,550	Recommended if Phase Two - New Rockingham Station - will be significantly delayed.
	<b>Total Station Work</b>	<b>\$1,550</b>	

Liberty Utilities  
 Salem Area Study

5.1.4 Recommended Plan Phase Three Estimate:

**Table 19 Recommended Plan Phase Three Estimate**

<b>Recommended Plan Phase 3: Replace 115/23 KV Transformer with new 115/13 kV Transformer at Golden Rock with 23kV Supply Elimination</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
T1 - 115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus Bus tie breakers	Perform all necessary construction to replace existing 115 kV/23 kV transformer with new 115kV / 13kV - 33/44/55 MVA transformer with a secondary breaker and four distribution circuit breakers.	\$4,500	Moves the system from the legacy 23 kV supplied system to a more reliable and sustainable 115 kV supplied system. Re-purposes the 23kV circuits installed during Phase 2 as new 13.2kV circuits.	Extensive outage planning.	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
<b>Total Station Work T1</b>		<b>\$4,500</b>			

Liberty Utilities  
 Salem Area Study

<b>Recommended Plan Phase 3: Replace 115/23 KV Transformer with new 115/23 kV Transformer at Golden Rock with 23kV Supply Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Distribution Circuit – 19L1	Use UG conduit system installed during Phase 1 and one of two new 25kV 1000 MCM CU UG cables (2352) installed during Phase 2 for new 19L1 circuit from Golden Rock Station to South Broadway. (2300ft). Use UG conduit system and one of two new 1000 MCM Cu UG cables (2352) installed during Phase 2 for new 19L1 circuit to Veterans Memorial Parkway to Rockingham Park MH15. Tie 19L1 circuit to existing 2352 at MH 15. At MH 3 Rockingham Mall tie 19L1 circuit (2352) to 18L1 feeder.	\$50	Eliminates Olde Trolley 18L1 circuit Utilizes existing infrastructure along Rockingham Mall and re-purposes installed infrastructure during Phase 1 and Phase 2 for new Golden Rock 19L1 feeder (2352). Removes pole congestion and double pole contingency risk along South Broadway.	Concerns with asset condition of existing 25kV 1000 MCM cables along Rockingham Mall.	
Distribution Circuit – 19L3	Use UG conduit system installed during Phase 1 and one of two new 25kV 1000 MCM CU UG cables (2393) installed during Phase 2 for new 19L6 circuit from Golden Rock Station to South Broadway (2300ft). Use UG conduit system and one of two new 1000 MCM Cu UG cables (2393) installed during Phase 2 for new 19L3 circuit to Veterans Memorial Parkway to MH 15. Tie 19L3 circuit to existing 2393 at MH 15. At MH 3 Rockingham Mall tie 19L3 circuit (2393) to 18L2 feeder.	\$50	Eliminates Olde Trolley 18L2 circuit Utilizes existing infrastructure along Rockingham Mall and re-purposes installed infrastructure during Phase 1 and Phase 2 for new Golden Rock 19L3 feeder (2393). Removes pole congestion and double pole contingency risk along South Broadway.	Concerns with asset condition of existing 25kV 1000 MCM cables along Rockingham Mall.	Consider tying 19L3 feeder with Olde Trolley 18L2 feeder at Cluff Crossing instead of routing feeder via UG mall system.
Distribution Circuit – 19L5	Use UG conduit system installed during Phase 1 and one of two new 25kV 1000 MCM CU UG cables (2393) installed during Phase 2 for new 19L5 circuit from Golden Rock Station to South Broadway (2300ft). Use UG conduit system and one of two new 1000 MCM Cu UG cables (2393) installed during Phase 2 for new 19L5 circuit to Veterans Memorial Parkway to MH 15. Tie 19L5 circuit to existing 2393 at MH 15. At Olde Trolley tie L7 circuit (2393) to 18L3 feeder.	\$50	Eliminates Olde Trolley 18L3 circuit Utilizes existing infrastructure along Rockingham Mall and re-purposes installed infrastructure during Phase 1 and Phase 2 for new Golden Rock 19L5 feeder (2393). Removes pole congestion and double pole contingency risk along South Broadway.	Concerns with asset condition of existing 25kV 1000 MCM cables along Rockingham Mall.	
Distribution Circuit – 19L7 (Future)					Second 23kV 1000 MCM Cu Cables from previous 2352 circuit could be re-purposed for future 19L7 feeder. This circuit would run from Golden Rock to Veteran's Memorial Hwy.
	<b>Total Distribution Circuit - T1</b>	<b>\$150</b>			

<b>Recommended Plan Phase 3: Replace 115/23 KV Transformer with new 115/23 kV Transformer at Golden Rock with 23kV Supply Elimination</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
23 kV Line Removal 2393	Remove 23 kV Circuit 2393 from Golden Rock to Baron Ave (4,000ft)	\$34			Removal Costs - Assumes 10% of \$85/ft.  2393 Circuit could be re-purposed for future 19L8 feeder. This circuit runs from Golden Rock to Baron Ave.
	<b>Total Sub transmission Line Work</b>	<b>\$34</b>			

5.1.5 Summary Recommended Plan Phase Estimates:

<b>Item</b>	<b>Recommended Plan Cost - \$k</b>
Phase 1 - Total Station Work	<b>\$3,000</b>
Phase 1 - Total Line Work	<b>\$2,400</b>
Phase 1 - Total Sub-transmission Line Work	<b>\$184</b>
Phase 2 - Total Sub-transmission Line Work	<b>\$8,504</b>
Phase 2 - Total Distribution Line Work	<b>\$6,343</b>
Phase 2 - Total Distribution Station Work	<b>\$5,800</b>
Phase 3 - Total Distribution Circuit - T1	<b>\$150</b>
Phase 3 - Total Station Work T1	<b>\$4,500</b>
Phase 3 - Total Sub-transmission Line Work	<b>\$34</b>
<b>Golden Rock Phase 1 - Total Project</b>	<b>\$5,584</b>
<b>Rockingham Phase 2 - Total Project</b>	<b>\$20,648</b>
<b>Golden Rock Phase 3 - Total Project</b>	<b>\$4,684</b>
<b>Project Totals</b>	<b>\$30,916</b>


*Table 20 Summary of Recommended Plan Estimates*

Liberty Utilities  
 Salem Area Study

5.2 Recommended Plan One-lines

5.2.1 Recommended Plan Phase One One Lines:


Figure 5 Recommended Plan Phase One Golden Rock Station Proposed Layout





Liberty Utilities  
 Salem Area Study


Figure 6 Recommended Plan Phase One Golden Rock Station Arrangement



Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 48 of 218

Figure 7 Recommended Plan Phase One Golden Rock 13.2 kV Station One-Line




★ DEMARCATION LINE OF AUTHORITY



Liberty Utilities  
 Salem Area Study

**Figure 8 Recommended Plan Phase One Golden Rock 13.2 kV Distribution Circuit Tie Map**





Liberty Utilities  
 Salem Area Study

Figure 9 Recommended Plan Phase One Golden Rock 13.2 kV 19L2 Distribution Circuit






Figure 10 Recommended Plan Phase One Golden Rock 13.2 kV 19L4 Distribution Circuit








Figure 11 Recommended Plan Phase One Golden Rock 13.2 kV 19L6 Distribution Circuit



Liberty Utilities  
 Salem Area Study

5.2.2 Recommended Plan Phase Two One-Lines:

**Figure 12 Recommended Plan Phase Two Rockingham Station Proposed Layout**






Liberty Utilities  
 Salem Area Study


Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 54 of 218

Figure 13 Recommended Plan Phase Two Rockingham Station One-Line



Liberty Utilities  
 Salem Area Study

Figure 14 Recommended Plan Phase Two Rockingham 13.2 kV Distribution Circuit Tie Map





Liberty Utilities  
 Salem Area Study

Figure 15 Recommended Plan Phase Two Rockingham 13.2 kV Underground Cable Getaways







Figure 16 Recommended Plan Phase Two Rockingham 13.2 kV 21L1 Distribution Circuit





Liberty Utilities  
 Salem Area Study

**Figure 17 Recommended Plan Phase Two Rockingham 13.2 kV 21L2 Distribution Circuit**






Figure 18 Recommended Plan Phase Two Rockingham 13.2 kV 21L3 Distribution Circuit








Figure 19 Recommended Plan Phase Two Rockingham 13.2 kV 21L4 Distribution Circuit





Liberty Utilities  
 Salem Area Study


Figure 20 Recommended Plan Phase Two Rockingham 13.2 kV 21L5 Distribution Circuit





Liberty Utilities  
 Salem Area Study

Figure 21 Recommended Plan Phase Two Rockingham 13.2 kV 21L6 Distribution Circuit



Liberty Utilities  
 Salem Area Study

Figure 22 Recommended Plan Phase Two Rockingham 13.2 kV 21L5 and 21L6 Distribution Circuits






Figure 23 Recommended Plan Phase Two Golden Rock 13.2 kV 19L8 Distribution Circuit







Figure 24 Recommended Plan Phase Two Proposed Right-of-Way Underground Conduit System






Liberty Utilities  
 Salem Area Study

5.2.3 Recommended Plan Phase Three One-Lines:


**Figure 25 Recommended Plan Phase Three Proposed Golden Rock Station Proposed Layout**



Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 67 of 218


Figure 26 Recommended Plan Phase Three Proposed Golden Rock Station One-Line





Liberty Utilities  
 Salem Area Study

Figure 27 Recommended Plan Phase Three Golden Rock 13.2 kV Distribution Circuit Tie Map





Liberty Utilities  
 Salem Area Study

Figure 28 Recommended Plan Phase Three Proposed Golden Rock 13.2 kV 19L1 Distribution Circuit








Figure 29 Recommended Plan Phase Three Proposed Golden Rock 13.2 kV 19L3 Distribution Circuit





Liberty Utilities  
Salem Area Study

Figure 30 Recommended Plan Phase Three Proposed Golden Rock 13.2 kV 19L5 Distribution Circuit



Liberty Utilities  
Salem Area Study

Docket No. DE 21-004  
Attachment DOE 10-1.e.1  
Page 72 of 218

---

## **6 Recommended Plan Problems Resolved**

The recommended plan will be achieved in three phases and accomplishes all system capacity and asset replacement requirements. It addresses all forecasted planning criteria violations within the 15 year planning horizon in the most complete way while moving the system from the legacy 23 kV supplied system to a more reliable and sustainable 115 kV supplied system. It also provides the capacity needed to supply the proposed business park development in the former Rockingham Park Track. Refer to Table 21 below for forecasted distribution circuit loading with Phase 1, 2 and 3.

Liberty Utilities  
 Salem Area Study

Substation	Voltage (kV)	Feeder	SN Rating (Amps)	EXISTING LOAD		PROJECTED LOAD		PHASE 1		PHASE 2		PHASE 3			
				2016		2017		2018		2019		2020		2021	
				Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN
BARRON AVENUE 10	13.2	10L1	387	197	51%	198	51%	0	0%	0	0%	0	0%	0	0%
BARRON AVENUE 10	13.2	10L2	526	312	59%	314	60%	0	0%	0	0%	0	0%	0	0%
BARRON AVENUE 10	13.2	10L4	339	229	68%	231	68%	0	0%	0	0%	0	0%	0	0%
OLDE TROLLEY 18	13.2	18L1	503	280	56%	282	56%	285	57%	162	32%	162	32%	0	0%
OLDE TROLLEY 18	13.2	18L2	503	366	73%	368	73%	384	76%	221	44%	222	44%	0	0%
OLDE TROLLEY 18	13.2	18L3	515	321	62%	285	55%	313	61%	110	21%	111	21%	0	0%
OLDE TROLLEY 18	13.2	18L4	516	328	64%	163	32%	325	63%	327	63%	329	64%	0	0%
SALEM DEPOT 9	13.2	9L1	322	135	42%	240	75%	242	75%	0	0%	0	0%	0	0%
SALEM DEPOT 9	13.2	9L2	322	284	88%	286	89%	288	90%	0	0%	0	0%	0	0%
SALEM DEPOT 9	13.2	9L3	507	346	68%	380	75%	515	102%	0	0%	0	0%	0	0%
SPICKET RIVER 13	13.2	13L1	515	304	59%	306	59%	309	60%	311	60%	312	61%	314	61%
SPICKET RIVER 13	13.2	13L2	515	424	82%	427	83%	431	84%	291	56%	292	57%	293	57%
SPICKET RIVER 13	13.2	13L3	522	362	69%	364	70%	367	70%	118	23%	118	23%	119	23%
GOLDEN ROCK 19	13.2	19L1	530											163	31%
GOLDEN ROCK 19	13.2	19L2	530					207	39%	209	39%	210	40%	210	40%
GOLDEN ROCK 19	13.2	19L3	530											223	42%
GOLDEN ROCK 19	13.2	19L4	530					329	62%	331	63%	333	63%	334	63%
GOLDEN ROCK 19	13.2	19L5	530											330	62%
GOLDEN ROCK 19	13.2	19L6	592					213	36%	215	36%	216	36%	216	37%
GOLDEN ROCK 19	13.2	19L8	592							413	70%	415	70%	417	70%
ROCKINGHAM 21	13.2	21L1	530							217	41%	218	41%	219	41%
ROCKINGHAM 21	13.2	21L2	530							307	58%	308	58%	309	58%
ROCKINGHAM 21	13.2	21L3	530							143	27%	143	27%	255	48%
ROCKINGHAM 21	13.2	21L4	530							146	28%	147	28%	148	28%
ROCKINGHAM 21	13.2	21L5	530							215	41%	216	41%	217	41%
ROCKINGHAM 21	13.2	21L6	530							284	54%	285	54%	287	54%
ROCKINGHAM 21	13.2	21L7	592							249	42%	250	42%	251	42%
ROCKINGHAM 21	13.2	21L8	592							233	39%	234	40%	235	40%

**Table 21 Forecasted Distribution Circuit Loading with Recommended Projects**



Liberty Utilities  
 Salem Area Study

Refer to Table 22 below for forecasted distribution feeder loading with and without recommended Phase 1.

Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2016		2017		WITHOUT PHASE 1		WITH PHASE 1	
					2018		2018		2018		2018	
					Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN
BARRON AVENUE 10	13.2	10L1	387	462	197	51%	198	51%	200	52%	0	0%
BARRON AVENUE 10	13.2	10L2	526	578	312	59%	314	60%	317	60%	0	0%
BARRON AVENUE 10	13.2	10L4	339	339	229	68%	231	68%	232	69%	0	0%
GOLDEN ROCK 19	13.2	19L2	530	612							207	39%
GOLDEN ROCK 19	13.2	19L4	530	612							329	62%
GOLDEN ROCK 19	13.2	19L6	592	612							213	36%

**Table 22 Forecasted Distribution Circuit Loading with and without Recommended Projects Phase One**

Refer to Table 23 below for forecasted distribution feeder loading with and without recommended Phase 2.

Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2016		2017		2018		WITHOUT PHASE 2		WITH PHASE 2	
					2019		2019		2019		2019			
					Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN
OLDE TROLLEY 18	13.2	18L1	503	565	280	56%	282	56%	285	57%	287	57%	162	32%
OLDE TROLLEY 18	13.2	18L2	503	515	366	73%	368	73%	384	76%	475	94%	221	44%
OLDE TROLLEY 18	13.2	18L3	515	515	321	62%	285	55%	313	61%	425	83%	110	21%
OLDE TROLLEY 18	13.2	18L4	516	612	328	64%	163	32%	325	63%	327	63%	327	63%
SALEM DEPOT 9	13.2	9L1	322	371	135	42%	240	75%	242	75%	294	91%	0	0%
SALEM DEPOT 9	13.2	9L2	322	371	284	88%	286	89%	288	90%	325	101%	0	0%
SALEM DEPOT 9	13.2	9L3	507	507	346	68%	380	75%	515	102%	519	102%	0	0%
SPICKET RIVER 13	13.2	13L2	515	515	424	82%	427	83%	431	84%	434	84%	291	56%
SPICKET RIVER 13	13.2	13L3	522	522	362	69%	364	70%	367	70%	370	71%	118	23%
GOLDEN ROCK 19	13.2	19L8	592	612									413	70%
ROCKINGHAM 21	13.2	21L1	530	612									217	41%
ROCKINGHAM 21	13.2	21L2	530	612									307	58%
ROCKINGHAM 21	13.2	21L3	530	612									143	27%
ROCKINGHAM 21	13.2	21L4	530	612									146	28%
ROCKINGHAM 21	13.2	21L5	530	612									215	41%
ROCKINGHAM 21	13.2	21L6	530	612									284	54%
ROCKINGHAM 21	13.2	21L7	592	612									249	42%
ROCKINGHAM 21	13.2	21L8	592	612									233	39%

**Table 23 Forecasted Distribution Circuit Loading with and without Recommended Projects Phase Two**

Liberty Utilities  
 Salem Area Study

Refer to Table 24 below for forecasted distribution feeder loading with and without recommended Phase 3.

Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)											WITHOUT PHASE 3		WITH PHASE 3	
					2016		2017		2018		2019		2020		2021		2021	
					Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN	Amps	%SN
OLDE TROLLEY 18	13.2	18L1	503	565	280	56%	282	56%	285	57%	162	32%	162	32%	162	32%	0	0%
OLDE TROLLEY 18	13.2	18L2	503	515	366	73%	368	73%	384	76%	221	44%	222	44%	222	44%	0	0%
OLDE TROLLEY 18	13.2	18L3	515	515	321	62%	285	55%	313	61%	110	21%	111	21%	111	21%	0	0%
OLDE TROLLEY 18	13.2	18L4	516	612	328	64%	163	32%	325	63%	327	63%	329	64%	329	64%	0	0%
GOLDEN ROCK 19	13.2	19L1	530	612													163	31%
GOLDEN ROCK 19	13.2	19L3	530	612													223	42%
GOLDEN ROCK 19	13.2	19L5	530	612													330	62%
ROCKINGHAM 21	13.2	21L3	530	612							143	27%	143	27%	143	27%	255	48%

**Table 24 Forecasted Distribution Circuit Loading with and without Recommended Projects Phase Three**

Refer to Table 25 below for forecasted distribution transformer loading with recommended Phase 1, 2 and 3.

Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		ACTUAL LOAD		PROJECTED LOAD		PHASE 1		PHASE 2		PHASE 3			
		From	To		SN	SE	2016		2017		2018		2019		2020		2021	
					MVA	% SN	MVA	% SN	MVA	% SN	MVA	% SN	MVA	% SN	MVA	% SN	MVA	% SN
GOLDEN ROCK 19	T1	115	23	50	83.9	94.4	56.4	67%	55.2	66%	51.6	62%	18.0	21%	18.1	22%	0.0	0%
BARRON AVENUE 10	L1	23	13.2	7	9.4	10.9	4.5	48%	4.5	48%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
BARRON AVENUE 10	L2	23	13.2	7	13.6	14.2	7.1	52%	7.2	53%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
BARRON AVENUE 10	L4	23	13.2	7	9.1	10.3	5.2	58%	5.3	58%	0.0	0%	0.0	0%	0.0	0%	0.0	0%
OLDE TROLLEY 18	L1	23	13.2	9.375	12.4	12.9	6.4	52%	6.5	52%	6.5	52%	3.7	30%	3.7	30%	0.0	0%
OLDE TROLLEY 18	L2	23	13.2	9.375	12.4	12.9	8.4	67%	8.4	68%	8.8	71%	5.1	41%	5.1	41%	0.0	0%
OLDE TROLLEY 18	L3	23	13.2	9.375	12.5	13	7.3	59%	6.5	52%	7.2	57%	2.5	20%	2.5	20%	0.0	0%
OLDE TROLLEY 18	L4	23	13.2	9.375	12.5	13	7.5	60%	3.7	30%	7.4	59%	7.5	60%	7.5	60%	0.0	0%
SALEM DEPOT 9	L1	23	13.2	7	7.36	10.1	3.1	42%	5.5	75%	5.5	75%	0.0	0%	0.0	0%	0.0	0%
SALEM DEPOT 9	L2	23	13.2	7	7.36	9.2	6.5	88%	6.5	89%	6.6	90%	0.0	0%	0.0	0%	0.0	0%
SALEM DEPOT 9	L3	23	13.2	9.375	11.6	11.6	7.9	68%	8.7	75%	11.8	102%	0.0	0%	0.0	0%	0.0	0%
SPICKET RIVER 13	L1	23	13.2	9.375	14.4	14.4	7.0	48%	7.0	49%	7.1	49%	7.1	49%	7.1	50%	7.2	50%
SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	9.7	70%	9.8	70%	9.8	71%	6.7	48%	6.7	48%	6.7	48%
SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	8.3	59%	8.3	60%	8.4	60%	2.7	19%	2.7	19%	2.7	20%
GOLDEN ROCK 19	T2	115	13.2	50	83.9	94.4					17.1	20%	26.7	32%	26.8	32%	26.9	32%
ROCKINGHAM 21	T1	115	13.2	50	83.9	94.4							18.8	22%	18.9	23%	21.5	26%
ROCKINGHAM 21	T2	115	13.2	50	83.9	94.4							22.2	26%	22.3	27%	22.4	27%
GOLDEN ROCK 19	T1	115	13.2	50	83.9	94.4											16.4	20%

**Table 25 Forecasted Distribution Transformer Loading with Recommended Projects**

Liberty Utilities  
 Salem Area Study

Refer to Table 26 below for forecasted sub-transmission loading with recommended Phase 1, 2 and 3.

Circuit	Voltage (kV)	Line Section		Rating (MVA)		ACTUAL LOAD		PROJECTED LOAD		PHASE 1		PHASE 2		2020		PHASE 3	
						2016		2017		2018		2019		2020		2021	
						MVA	%SN	MVA	%SN	MVA	%SN	MVA	%SN	MVA	%SN	MVA	%SN
2352	23	Golden Rock	Barron Ave. Tap	54.7	67.4	32.3	59%	35.6	65%	39.2	72%	8.7	16%	8.8	16%	0.0	0%
2352	23	Barron Ave. Tap	Olde Trolley Tap	72.5	72.5	32.3	44%	35.6	49%	39.2	54%	8.7	12%	8.8	12%	0.0	0%
2352	23	Olde Trolley Tap	Olde Trolley	34.0	40.0	14.8	43%	14.9	44%	15.3	45%	8.7	26%	8.8	26%	0.0	0%
2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	17.5	65%	20.7	76%	23.9	88%	0.0	0%	0.0	0%	0.0	0%
2393	23	Golden Rock	Barron Ave. Tap	54.7	67.4	26.5	48%	22.0	40%	14.6	27%	10.0	18%	10.1	18%	0.0	0%
2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	14.9	33%	10.2	23%	14.6	32%	10.0	22%	10.1	22%	0.0	0%
2393	23	Olde Trolley Tap	Olde Trolley	34.0	40.0	14.9	44%	10.2	30%	14.6	43%	10.0	29%	10.1	30%	0.0	0%
2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%	0.0	0%

**Table 26 Forecasted Sub-Transmission Circuit Loading with Recommended Projects**

Liberty Utilities  
 Salem Area Study

6.1 Recommended Plan Problems Resolved Phase One

The conductor upgrades recommended in Phase One will address the overloads, increase capacity, and result in the following % of Summer Normal ratings, refer to Table 27 Conductor Thermal Overload Updated % of Normal Rating.

<i>Year</i>	<i>Distribution Circuit</i>	<i>Street &amp; Pole #</i>	<i>Conductor Type</i>	<i>Length Feet</i>	<i>% of Summer Normal Rating</i>
2016	18L3	S Policy P55 to Fairmont P7	3P_477_AL	830	61

**Table 27 Conductor Thermal Overload Updated % of Normal Rating**

Additionally, the proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Spicket River Station. The addition of the fourth feeder would be installed during Phase Two to benefit from the new underground conduit system along the ROW. This phase will allow the retirement of Baron Ave substation due to issues with asset condition.

For a list of specific issues resolved with the Recommended Plan Phase One please refer to tables under Section 3.7 and 3.8 columns Targeted Mitigation.

6.2 Recommended Plan Problems Resolved Phase Two

As part of Phase Two, the 23kV sub-transmission lines 2393 and 2352 will be relocated from the right-of-way to accommodate the 115kV transmission lines that will supply the new Rockingham #21 substation. The recommended plan avoids building sub-transmission lines along city streets and chooses a route that does not impede with needed clearances along the right-of-way. It also sets the stage for the future retirement of the 23kV system and re-purposes the sub-transmission lines as future distribution circuits (Phase Three).

As part of Phase Two, the Rockingham #21 Distribution Circuits would be used to supply a reconfigured 13.2kV distribution system to bring the system into compliance with Liberty's Distribution Planning Criteria. The configuration would be targeted to improve reliability and better balance loading on all circuits while taking into account the upcoming expansions in the Rockingham Park.

In addition the Rockingham #21 distribution circuits would be used to eliminate the Salem Depot Substation due to issues with asset condition.

The fourth circuits on both Rockingham #21 station transformers would be dedicated to serve the proposed business park load.

Liberty Utilities  
Salem Area Study

---

If the implementation of a new Rockingham Station is significantly delayed, Salem Depot Station upgrades should be pursued. This includes upgrading the two 6.25 MVA, 23kV/13.2kV auto transformers at Salem Depot Station with new 9.376 MVA two winding 23kV/13.2kV transformers along with upgraded bus, new primary breakers and new secondary breakers.

In addition, if the implementation of a new Rockingham Station is significantly delayed, the temporary installation of a 23/13.2kV 9.375 MVA transformer within the Rockingham Park should be pursued. One transformer from the retired Baron Avenue substation could be reserved for this application. Although this transformer and sub-transmission supply system would not have the full capacity to supply all of the forecasted expansions in the park, it could buy enough time to supply some new developments in the Park as the new Rockingham Station is being implemented.

For a list of specific issues resolved with the Recommended Plan Phase Two please refer to tables under Section 3.7 and 3.8 columns Targeted Mitigation.

### 6.3 Recommended Plan Problems Resolved Phase Three

The proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand and provides adequate capacity to ensure that there are no violations of the planning criteria within the fifteen year planning horizon. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Rockingham #21 substation and Spicket River #13 substation. This project will allow the retirement of Olde Trolley as asset condition issues become prevalent, It will also allow the retirement of the 23kV sub-transmission system and 23/13kV transformers in the area while moving the system to a more reliable and sustainable 115 kV supplied system.

For a list of specific issues resolved with the Recommended Plan Phase Three please refer to tables under Section 3.7 and 3.8 columns Targeted Mitigation.

---

## 7 Alternate Plans

A total of eleven (11) plans were evaluated to address the existing and future system needs. Six (6) of these plans were eliminated because of transmission costs and construction challenges due to site locations; refer to Appendix A for a list of all Eliminated Plans.

Five Alternate plans were developed and described in this section.

Alternate Plan One and Alternate Plan Two install a second 115 kV transmission line into Golden Rock Station supplying a new 115 kV/13.2 kV, 33/44/55 MVA, substation transformer with four (4) new circuit positions. Alternate Plan One also extends 23kV supply circuit 2393 to Spicket River on city streets utilizing over-build construction. Alternate Plan Two extends 23kV supply circuit 2376 to Spicket River up the existing ROW from the existing tap position by NGRID. Both Alternate Plan One and Alternate Plan Two split the Spicket River 23kV bus and install an Auto-transfer system.

Alternate Plan Three is similar to the Recommended Plan with the exception that all new Golden Rock distribution and sub-transmission circuits are built along South Broadway and installed using overhead pole construction rather than via an underground conduit system. It also installs new Golden Rock 19L4 circuit during Phase 1 and not during Phase 2 as in the Recommended Plan.

Alternate Plan Four is similar to the Recommended Plan; however it proposes different distribution feeder configurations as compared to the Recommended Plan..

Alternate Plan Five is similar to the Recommended Plan with the exception that the new underground conduit system would be installed along South Broadway instead of the ROW.

All Alternate Plans will require the installation of one new 115/13.2kV transformer at Golden Rock Station with Baron Ave Station Elimination (Phase 1).

All Alternate Plans will require the installation of two new 115/13.2kV transformers at New Rockingham Substation with Salem Depot Station Elimination (Phase 2). All Alternate Plans will require the acquisition of land for new Rockingham Substation #21 (Phase2).

Alternate Plan One and Alternate Plan Two do not provide for a future retirement of Olde Trolley and the 23kV Sub-Transmission system (Phase 3). Alternate Plan Three, Alternate Plan Four and Alternate Plan Five provide for a future retirement of Olde Trolley and the 23kV Sub-Transmission system (Phase 3).

Liberty Utilities  
Salem Area Study

---

7.1 Alternate Plan One Description

Alternate Plan One Phase One (One New 115/13.2 kV Transformer at Golden Rock Station with Baron Ave Station Elimination - 23 kV to Spicket River Station by Liberty Utilities)

Phase One of Alternate Plan One consists of a second 115 kV transmission line into Golden Rock Station supplying a second 115 kV/13.2 kV, 33/44/55 MVA, substation transformer with three (3) new circuit positions.

Additionally, the 2393 supply will be extended to Spicket River on city streets utilizing over-build construction.

The cost of Alternate Plan One Phase One is estimated at \$8,265,000

Alternate Plan One Phase Two (Two New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination)

Alternate Plan One Phase Two will require two New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination.

For Alternate Plan One Phase Two Estimates and One-Lines please refer to Alternate Plan Four Phase Two Estimates and One-Lines.

The cost of Alternate Plan One Phase Two is estimated at \$9,375,000

Alternate Plan One does not include a retirement of the 23kV Supply system (Phase 3).

Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 81 of 218

7.1.1 Alternate Plan One Phase One Estimates  
**Table 28 Alternate Plan One Phase One Estimate**

<b>Alternative Plan One - Phase One: New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination - 23 kV to Spicket River Station by LIBERTY Station Estimate</b>			
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Comments</b>
115 kV Line Extension	Extend second 115 kV line to the existing Golden Rock Station.	TBD	Installation of an auto transfer on the 115 kV system recommended because the low side busses operate at different voltages.
At Golden Rock Station 115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four feeder breakers. Include an automatic transfer system on the 115 kV lines.	\$3,000	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
	<b>Total Station Work</b>	<b>\$3,000</b>	



**Alternative Plan One - Phase One: New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination - 23 kV to Spicket River Station by LIBERTY  
 Distribution Circuit Estimate**

Item	Required construction	Liberty Cost - \$k	Comments
Distribution Circuit - L1 Baron Ave Elimination	Build a 13.2 kV line from Golden Rock Station to W Hampshire Road approximately 700', then reconductor existing conductor on W Hampshire, South Broadway and Cuomo that is not 477 to 477, approximately 2,350'. This will supply the 10L1 distribution circuit.	\$240	
Distribution Circuit - L2 Baron Ave Elimination	Under build a 13.2 kV express line from Golden Rock Station along the 23 kV Right of Way to Baron Ave Station approximately 5,600' ROW. This will supply the 10L2 distribution circuit.	\$610	Installs facilities along ROW. It is expected that this ROW will be needed for future 115kV transmission lines supplying Rockingham Substation. There is only enough space in the ROW to accommodate 2-115kV transmission lines.
Distribution Circuit - L3 Baron Ave Elimination	Over build a 13.2 kV express line from Golden Rock Station onto Hampshire Road then north on S. Broadway to the switch on pole # 31, approximately 4,000' (700' new - 3,300' over build) on the Street. This will supply the 10L4 distribution circuit.	\$365	Adds pole congestion along South Broadway. Creates a double circuit pole line along South Broadway. This could create challenges with guying and acquisition of easements.  Large poles could create pushback from town.  Pole hit could impact two 13.2kV distribution circuits.
Distribution Circuit - L4	Future	TBD	
	<b>Total Distribution Circuit Work</b>	<b>\$1,215</b>	

**Alternative Plan One - Phase One: New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination - 23 kV to Spicket River Station by LIBERTY  
 23 kV Supply Circuit Estimate**

Item	Required construction	Liberty Cost - \$k	Comments
23 kV Line Tie from the 2393 to the 2376	23 kV OH Tie line outside of the Sub Station from the existing 2393 line to the 2376 (removed from Golden Rock Station) approximately 1,200'	\$150	Relocates the tie between 2393 and 2376 to outside of the station yard.
23 kV Extension to Spicket River Station by Liberty Utilities	Tap the 2393 23 kV Line at Kelly Road and over build the 23 kV heading south on S Broadway to Pattee Road to Otis Ave to Baldwin Street to Lawrence Road to Main Street to N Main Street then to Town Farm Road to Spicket River Station. Approximately 24,000'. Install an auto transfer system to the 23 kV supply circuits to improve reliability performance.	\$3,900	Installation of an auto transfer system on the 23 kV supply lines to Spicket recommended to improve reliability. Cost includes \$ 200 k for auto transfer system.  Adds to pole congestion along city streets. Creates pole line along city streets with 23kV overbuild 1113 ACSR and 13.2kV underbuild 477 ACSR. This could create challenges with guying and acquisition of easements.  Large poles could create pushback from town.  Pole hit could impact one 23kV supply and one 13.2kV feeder
	<b>Total Sub-Transmission Line Work</b>	<b>\$4,050</b>	
	<b>Total Distribution Line Work</b>	<b>\$1,215</b>	
	<b>Total Station Work</b>	<b>\$3,000</b>	
	<b>Project Total</b>	<b>\$8,265</b>	

Liberty Utilities  
Salem Area Study

---

### 7.1.2 Alternate Plan One Problems Resolved

The proposed 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide larger capacity to be utilized in supplying system demand.

Three (3) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to eliminate Baron Ave Station, a current asset concern.

The fourth circuit will be for future load growth. This will free up capacity on the existing 2393 supply circuit which can be used to address concerns with the loss of supply contingency at Spicket River Station.

Alternate Plan One was rejected due to the complexities of installing a 23kV overbuild distribution line along city streets. It was also rejected because it under-builds new 13.2kV distribution overhead circuits along the ROW which will be needed for future 115kV transmission lines supplying Rockingham Substation.

It was also rejected because it increases the reliance on the 23kV supply line system and its continued dependence on the Transmission Company to allocate 23kV capacity for Liberty Utilities. Liberty's preferred approach is to move the system from a 23kV/13.2kV to a more robust 115kV/13.2kV substation transformer based system. In addition, Liberty's preferred approach is to ultimately retire its 23kV system including supply lines and substation transformers.

### 7.2 Alternate Plan Two Description

#### **Alternate Plan Two Phase One (New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination - 23 kV to Spicket River Station by National Grid)**

Phase One of Alternate Plan Two consists of a second 115 kV line into Golden Rock Station supplying a second 115kV/13.2 kV, 33/44/55 MVA substation transformer with three (3) new circuit positions.

A new National Grid 23 kV supply circuit will be extended to the Spicket River Station. This would be jointly constructed in the existing 23kV Right of Way by Liberty and National Grid.

The cost of Alternate Plan Two Phase One is estimated at \$8,395,000.

#### **Alternate Plan Two Phase Two (New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination)**

Liberty Utilities  
Salem Area Study

---

Alternate Plan Two Phase Two will require the same plans described in the Alternate Plan One Phase Two (New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination).

For Alternate Plan Two Phase Two Estimates and One-Lines please refer to Alternate Plan Four Phase Two Estimates and One-Lines.

The cost of Alternate Plan Two Phase Two is estimated at \$9,375,000

Alternate Plan Two does not include a retirement of the 23kV Supply system (Phase 3).

Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 86 of 218

7.2.1 Alternate Plan Two Phase One Estimates  
**Table 29 Alternate Plan Two Phase One Estimate**

<b>Alternate Plan Two - Phase One: New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination - 23 kV to Spicket River Station by NGRID Station Estimate</b>			
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Comments</b>
115 kV Line Extension	Construct 115 kV line extension with an automatic transfer system (Costs included in the Substation's Estimate) installed on between the two 115 kV lines at Golden Rock Station.	TBD	Installation of an auto transfer on the 115 kV system recommended because low side busses operate at different voltages.
115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four distribution circuit breakers. Include an automatic transfer system on the 115 kV lines.	\$3,000	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
	<b>Total Station Work</b>	<b>\$3,000</b>	

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Two - Phase One: New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination - 23 kV to Spicket River Station by NGRID Distribution Circuit Estimate</b>			
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Comments</b>
Distribution Circuit - L1 Alternate cost for Baron Ave Elimination	Build a 13.2 kV line from Golden Rock Station to W Hampshire Road approximately 700', then reconductor existing conductor on W Hampshire, South Broadway and Cuomo that is not 477 to 477, approximately 2,350'. This will supply the 10L1 distribution circuit.	\$240	
Distribution Circuit - L2 Alternate cost for Baron Ave Elimination	Under build a 13.2 kV express line from Golden Rock Station along the 23 kV Right of Way to Baron Ave Station approximately 5,600' ROW. This will supply the 10L2 distribution circuit.	\$610	Installs facilities along ROW. It is expected that this ROW will be needed for future 115kV transmission lines supplying Rockingham Substation. There is only enough space in the ROW to accommodate 2-115kV transmission lines.
Distribution Circuit - L3 Alternate cost for Baron Ave Elimination	Over build a 13.2 kV express line from Golden Rock Station onto Hampshire Road then north on S. Broadway to the switch on pole # 31, approximately 4,000' (700' new - 3,300' over build) on the Street. This will supply the 10L4 distribution circuit.	\$365	Adds pole congestion along South Broadway. Creates a double circuit pole line along South Broadway. This could create challenges with guying and acquisition of easements.  Large poles could create pushback from town.  Pole hit could impact two 13.2kV distribution circuits.
Distribution Circuit - L4 Alternate cost for Baron Ave Elimination	Future	TBD	
	<b>Total Distribution Circuit Work</b>	<b>\$1,215</b>	

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Two - Phase One: New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination - 23 kV to Spicket River Station by NGRID</b>			
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Comments</b>
23 kV Line Tie from the 2393 to the 2376	23 kV OH Tie line outside of the Sub Station from the existing 2393 line to the 2376 (removed from Golden Rock Station) approximately 1,200'	\$150	Relocates the tie between 2393 and 2376 to outside of the station yard.
23 kV Extension to Spicket River Station by Liberty	Install a second 23 kV line up the existing ROW from the NH/MA state line to Spicket River (0.9 miles).  Split 23 kV bus and install Auto-transfer system at Spicket River Station by LIBERTY  Add a protective device with monitoring to determine fault location to expedite repair - by LIBERTY	\$880	Installation of an auto transfer system on the 23 kV supply lines to Spicket recommended to improve reliability.  Cost includes \$ 200 k for auto transfer system.  This project is dependent of a second 23kV line from the Methuen Junction to the MA/NH state line by National Grid.
23 kV Extension to Spicket River Station by National Grid	Install a second 23 kV line up the existing ROW from the Methuen Junction to the NH/MA state line (4.3 miles).  Split 23 kV bus and install Auto-transfer system at Spicket River Station by LIBERTY  Add a protective device with monitoring to determine fault location to expedite repair - by LIBERTY	\$3,300	The load at risk condition at Spicket River does not violate National Grid's Planning Criteria of 20MW / 240MWH of load at risk. As such it is unlikely that National Grid would undertake this project given that the lack of justification per their planning criteria.
	<b>Total Supply Line Work</b>	<b>\$4,180</b>	
	<b>Total Distribution Circuit Work</b>	<b>\$1,215</b>	
	<b>Total Station Work</b>	<b>\$3,000</b>	
	<b>Project Total Baron Ave Alternative</b>	<b>\$8,395</b>	

Liberty Utilities  
Salem Area Study

---

**\*\*For Alternate Plan Two Phase Two Estimates and One-Lines please refer to Alternate Plan Four Phase Two Estimates and One-Lines. Alternate Plan Two does not provide for Phase Three.**

## 7.2.2 Alternate Plan Two Problems Resolved

Three (3) of the 13.2 kV circuits would be constructed to eliminate the Baron Ave Station, which is currently supplied by the Golden Rock 2393 and the National Grid Methuen 2353 circuit.

Three of the new circuits will be used to eliminate the Baron Ave Station. The fourth will be for future load growth.

The loss of supply contingency at Spicket River Station would be addressed by extending a new National Grid 23 kV supply circuit to the Spicket River Station.

Alternate Plan Two was rejected because it under-builds new 13.2kV overhead distribution circuits along the ROW which will be needed for future 115kV transmission lines supplying Rockingham Substation.

It was also rejected because it increases the reliance on the 23kV supply line system and its continued dependence on the Transmission Company to allocate 23kV capacity for Liberty Utilities. Liberty's preferred approach is to move the system from a 23kV/13.2kV to a more robust 115kV/13.2kV substation transformer based system. In addition, Liberty's preferred approach is to ultimately retire its 23kV system including supply lines and substation transformers.

The load at risk condition at Spicket River does not violate National Grid's Planning Criteria of 20MW / 240MWH of load at risk. As such it is unlikely that National Grid would undertake this project given that the lack of justification per their planning criteria.

## 7.3 Alternate Plan Three Description

### **Alternate Plan Three Phase One (New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Backup)**

Phase One of the Alternate Plan Three consists of a second 115 kV transmission line into Golden Rock Station supplying a new 115kV/13.2 kV, 33/44/55 MVA substation transformer with four (4) new 13.2 kV circuit positions. The 13.2 kV circuits would be constructed to provide contingency support to Spicket River Station and to eliminate the Baron Ave Station.

Phase One of the Alternate Plan Three will require the same plans as described in the Alternate Plan Five with one exception:



Liberty Utilities  
Salem Area Study

- 
- Phase One installs new Golden Rock 19L8 circuit during Phase One not Phase Two. The new distribution circuit 19L8 will be installed along South Broadway via a new overhead pole line instead of new underground conduit system.

The cost of Alternate Plan Three Phase One is estimated at \$9,165,000

**Alternate Plan Three Phase Two (New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination)**

Phase Two of the Alternate Plan Three will require the same plans described in the Alternate Plan Five Phase Two (New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination).

However the two (2) 23kv supply circuits 2352 and 2393 will be relocated to South Broadway to make way in the right of way for the two (2) new 115kV transmission supply lines supplying the new Rockingham Substation. This plan differs from the Alternate Plan Five Phase Two in that the relocated 23kV lines will be overbuild along existing and new infrastructure along city street South Broadway. Alternate Plan Five installs new underground system along South Broadway.

The cost of Alternate Plan Three Phase Two is estimated at \$13,696,000.

**Alternate Plan Three Phase Three (New 115/13.2 KV Transformer at Golden Rock with Olde Trolley Elimination and 23KV Supply System Elimination)**

Phase Three of the Alternate Plan Three will require a New 115/13.2 KV Transformer at Golden Rock with the conversion of Olde Trolley Substation into a switching/regulating Substation and eliminate the 23kV Supply System.

The cost of Alternate Plan Three Phase Three is estimated at \$5,579,000.

Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 91 of 218

7.3.1 Alternate Plan Three Phase One Estimates  
**Table 30 Alternate Plan Three Phase One Estimate**

<b>Alternate Plan Three Phase One - First New 115/13.2kV Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
115 kV Line Extension	Extend second 115 kV line to the existing Golden Rock Station.	TBD	Only one 115 kV Line extension is required.	Requires interconnection and extension of NGRID's 115 kV system. More permitting associated with 115 kV line Extension.	
T2 - 115/13.2 kV - 33/44/55 MVA Xfmr (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four feeder breakers. Include an automatic transfer system on the 115 kV lines.	\$3,000	Adds significant capacity to the system, addresses the Spicket River contingency and eliminates Baron Ave Station asset concerns. Minimizes dependency on the NGRID 23 kV system for load support. Makes 23-13kV transformer available to temporarily supply new Rockingham Park loads.	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers	Portions of the existing 23 kV bus may be utilized in the new 115/13.2 kV transformer installation. NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
	<b>Total Station Work</b>	<b>\$3,000</b>			

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Three Phase One - First New 115/13.2kV Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Feeder - 19L2	1000 MCM CU UG cable from Golden Rock Station to P21 Hampshire St (700ft) on new 4X4 - 6" UG conduit system. Reconductor former Baron Ave 10L1 from Golden Rock to Cuomo St (3,600ft using 477 Spacer Cable). Reconductor Cuomo St from Garabeddian Dr to South Broadway using 477 Spacer Cable (900ft). New 19L2 feeder picks up portion of 10L1 at Garabeddian Dr (112Amps) and picks up portion of 10L2 at Baron Ave, Bagnell Ave and Kelly Rd (70A). Install one recloser	\$652	Eliminates Baron Ave Station and Backs up Olde Trolley. Makes way for future tie with Pelham Substation. Does not construct facilities along ROW.		Assumes 25% of the (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft) Circuits from Golden Rock to Hampshire St are 19L2, 19L4, 19L6,19L8, future 2352 and future 2393. This will make way and pay for future relocation of 2-23kV circuits 2352 and 2393 (Phase 2)
Feeder - 19L4	1000 MCM CU UG cable from Golden Rock Station to P149 Hampshire St (700ft) on new 4X4-6" UG conduit system. Reconductor former Baron Ave 10L1 Hampshire St from Golden Rock to South Broadway (1,900ft) using 477 Spacer Cable. New 19L4 feeder picks up portion of 10L1 at Hampshire St (48Amps) Pond St (50Amps), picks up portion of 10L4 at Pattee Rd (48Amps) and picks up portion of 10L2 Cluff Rd West (107A). Install one recloser.	\$431	Eliminates Baron Ave Station and Backup Olde Trolley. Does not construct facilities along ROW.		Assumes 25% of the (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft) Circuits from Golden Rock to Hampshire St are 19L2, 19L4, 19L6, 19L8, future 2352 and future 2393. This will make way and pay for future relocation of 2-23kV circuits 2352 and 2393 (Phase 2)
Feeder - 19L6	1000 MCM CU UG cable from Golden Rock Station to South Broadway to Lawrence Rd (2,300ft) on new 4X3-6" UG conduit system. Install new OH three phase line and reconductor along Lawrence Rd (5,000ft) from Pond St to Ansel St using 477 spacer cable. Reconductor Lawrence Rd (4,700ft) from Ansel St to Cole St using 477 Spacer Cable. New 19L6 feeder picks up portion of 10L4 at Lawrence Rd (90Amps) and picks up portion on 10L2 at Cluff Rd East (43Amps). Install one recloser. Install one load break at P69 Main St on 13L3 for option to pick up 113Amps.	\$1,770	Eliminates Baron Ave Station and Backup Spicket River Station. Does not construct facilities along ROW.	Underground along Hampshire Rd would cross underneath rail at ROW	Assumes 25% of the (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft) and 50% of the (3X4) 6" underground conduit system along Hampshire St (1600ft). Circuits from Golden Rock to Hampshire St are 19L2, 19L4, 19L6, 19L8, future 2352 and future 2393. Circuits along Hampshire St are 19L6, 19L8, future 2352 and future 2393. This will make way and pay for future relocation of 2-23kV circuits 2352 and 2393 (Phase 2)
Feeder - 19L8 Spicket River Mitigation	1000 MCM CU UG cable from Golden Rock Station to South Broadway. (2,300ft) on new 4X3-6" UG conduit system. Install new OH three phase line along South Broadway (13,000ft) from Pond St to Belmont St using 477 Spacer Cable. Reconductor to 477 Spacer Cable OH three phase line along Belmont St and Granite Ave (3,900ft) from South Broadway to Main St. New 19L8 feeder picks up portion of 9L1 at Main St east of Broadway (18Amps), picks up a portion of 13L2 at Millville south of Bluff St (103Amps) and picks up portion of 13L3 East Main St LB 701108 (221Amps). Install one recloser.	\$3,129	Backup Spicket River Station and Salem Depot. Does not construct facilities along ROW. Second pole line along South Broadway makes way for future overbuild construction and relocation of the 23kV supply lines.	Underground along Hampshire Rd would cross underneath rail at ROW. Pole congestion along South Broadway. Creates two pole lines along South Broadway with 23kV overbuild 1113 ACSR and 13.2kV underbuild 477 ACSR. This could create challenges with guying and acquisition of easements. Large poles could create pushback from town. Pole hit could impact one 23kV supply and one 13.2kV feeder	Assumes 25% of the (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft) and 50% of the (3X4) 6" underground conduit system along Hampshire St (1600ft). Circuits from Golden Rock to Hampshire St are 19L2, 19L4, 19L6, 19L8, future 2352 and future 2393. Circuits along Hampshire St are 19L6, 19L8, future 2352 and future 2393. This will make way and pay for future relocation of 2-23kV circuits 2352 and 2393 (Phase 2)
	<b>Total Line Work Eliminate Baron Ave &amp; Spicket River Backup Alternative</b>	<b>\$5,981</b>			

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Three Phase One - First New 115/13.2kV Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
23 kV Line Tie from the 2393 to the 2376	Relocate 23 kV OH Tie line outside of the Sub Station from the existing 2393 line to the 2376 (removed from Golden Rock Sta) approximately 1,200'	\$150	Maintains access to NGRID's 2376 line for contingency use.		Relocates the tie between 2393 and 2376 to outside of the station yard.
23 kV Line Removal 2353	Remove 23 kV Circuit 2353 that runs along 23kV ROW from Golden Rock to Baron Ave (4,000ft)	\$34	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. (Phase 2).		Removal Costs - Assumes 10% of \$85/ft.
	<b>Total Sub-transmission Line Work Eliminate Baron Ave &amp; Spicket River Backup Alternative</b>	<b>\$184</b>			



7.3.2 Alternate Plan Three Phase Two Estimates  
**Table 31 Alternate Plan Three Phase Two Estimate**

<b>Alternate Plan Three – Phase Two</b>					
<b>Two New 115/13.2 KV Transformers at Rockingham Station #21 with Salem Depot Station Elimination, and 23kV Sub-Transmission Line Relocation Estimates</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Two - 115 kV Line Extensions	Extend two 115 kV line to the proposed Rockingham Station.	<b>TBD</b>	New 115kV lines could be installed in existing 23kV ROW in a low profile style construction.	Requires interconnection and extension of NGRID's 115 kV system.  More permitting associated with 115 kV line Extension.  Requires relocation of the existing 23kV sub transmission system along ROW.	
T1 - 115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four distribution circuit breakers.	\$2,800	Adds significant capacity to the system, addresses Olde Trolley contingency and eliminates Salem Depot. Minimizes dependency on the NGRID 23 kV system for load support.	Challenges with outage coordination and cutovers.  Requires land acquisition within the Rockingham Park.	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
T2 -115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus + 13.2 Bus Tie breaker	Perform all necessary construction to convert the new Rockingham Station into a double ended station with a tie breaker and auto-transfer of the secondary bus for a loss of either transformer.	\$3,000	Adds significant capacity to the system, addresses Olde Trolley contingency and eliminates Salem Depot. Minimizes dependency on the NGRID 23 kV system for load support.	Challenges with outage coordination and cutovers.  Requires land acquisition within the Rockingham Park.	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
	<b>Total Station Work T1</b>	<b>\$2,800</b>			
	<b>Total Station Work T2</b>	<b>\$3,000</b>			
	<b>Total Station Work</b>	<b>\$5,800</b>			

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Three – Phase Two</b>					
<b>Two New 115/13.2 KV Transformers at Rockingham Station #21 with Salem Depot Station Elimination, and 23kV Sub-Transmission Line Relocation Estimates</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Distribution Circuit - 21L1	From Rockingham Station install 1000 MCM CU UG cable to P104 South Broadway (1800ft) on new UG conduit system. New 21L1 circuit picks up portion of 9L1 along South Broadway north of P104, North Broadway and Taylor St (164Amps). Install New LB tie at P104 S Broadway.	\$532	Eliminates Salem Depot Station and add Back up supply to Olde Trolley Station.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
Distribution Circuit - 21L2	From Rockingham Station install 1000 MCM CU UG cable to P104 South Broadway (1800ft) on new UG conduit system. Install second circuit along North Broadway from P104 to Old Rockingham Rd (6600ft) Install New LB tie at P5-1 North Policy St. New 21L2 circuit picks up portion of 9L1 along Old Rockingham Rd and portion of 9L3 along Range Rd (121Amps).	\$1,219	Eliminates Salem Depot Station and add Back up supply to Olde Trolley and Spicket River Stations.	Requires easements for new construction within the Rockingham Park.  Creates pole congestion along South Broadway from Rockingham Substation to Old Rockingham Rd (6,600ft).  Could create challenges with pole guying and acquisition of easements.	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
Distribution Circuit - L3	From Rockingham Station install new 477 AL TW to Rocktrack. Reconductor wires along Rocktrack/Pleasant St from P8 Rocktrack to P17 Pleasant St (1200ft). New 21L3 circuit picks up portion of 18L3 Pleasant St including Mall Switchgears 3,4 and 5 (160Amps).	\$102	Could become future spare feeder.  Initially could be used to carry Mall load while Phase 3 Olde Trolley 23kV retirement takes place.		Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
Distribution Circuit - L4	From Rockingham Station install 1000 MCM CU UG cable to P104 South Broadway (1800ft) on new UG conduit system. New 21L4 circuit picks up portion of 9L1 along South Broadway south of P104 and portion of 18L2 along Veteran's Memorial Pkwy (145Amps).	\$512	Could be used to carry Olde Trolley load while Phase 3 Olde Trolley 23kV retirement takes place.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
	<b>Total Distribution Circuit - T1</b>	<b>\$2,365</b>			
	<b>Total Station and Distribution - T1</b>	<b>\$5,165</b>			

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Three – Phase Two</b>					
<b>Two New 115/13.2 KV Transformers at Rockingham Station #21 with Salem Depot Station Elimination, and 23kV Sub-Transmission Line Relocation Estimates</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
Distribution Circuit - 21L5	From Rockingham Station install 1000 MCM CU UG cable to P16 Pleasant St (2200ft) on new UG conduit system. Reconductor wires along Pleasant St from P16 Pleasant St to P7 Main St (1700ft). New 21L5 circuit picks up portion of 9L3 along Main St and South Policy Rd including Canobie Lake Park. (120Amps).	\$714	Eliminates Salem Depot Station and add Back up supply to Olde Trolley and Spicket River Stations.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)  Assumes 50% of the costs for new double circuit pole line along Pleasant St
Distribution Circuit - 21L6	From Rockingham Station install 1000 MCM CU UG cable to P16 Pleasant St (2200ft) on new UG conduit system. Install second circuit along Pleasant St for 21L6. New 21L6 circuit picks up feeder 9L2. (224Amps).	\$666	Eliminates Salem Depot Station and add Back up supply to Olde Trolley and Spicket River Stations.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)  Assumes 50% of the costs for new double circuit pole line along Pleasant St
Distribution Circuit - 21L7	Future	\$0			Future Feeder 1 of 2 for Tuscan Park
Distribution Circuit - 21L8	Future	\$0			Future Feeder 2 of 2 for Tuscan Park
	<b>Total Distribution Circuit - T2</b>	<b>\$1,380</b>			
	<b>Total Station and Distribution - T2</b>	<b>\$4,380</b>			

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Three – Phase Two</b>					
<b>Two New 115/13.2 KV Transformers at Rockingham Station #21 with Salem Depot Station Elimination, and 23kV Sub-Transmission Line Relocation Estimates</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
23kV 2352 Relocation to South Broadway OH Option	Use existing UG conduit system installed during Phase 1 and Install two new parallel 1000 MCM CU UG cables from Golden Rock Station to South Broadway. (2300ft). Use existing pole line along South Broadway installed during Phase 1 and add new 1113 ACSR overbuild circuit to Veterans Memorial Parkway P84 (11,000ft). Install two new parallel 1000MCM Cu cables from P84 South Broadway to existing MH 15 Rockingham Park on new UG conduit system. (200ft) Tie into existing 2352 at MH 15.	\$1,526	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Utilizes future underground cable system along Hampshire Rd and future pole line along South Broadway. Will allow to repurpose 23kV circuits to pick up Olde Trolley load.	Underground along Rockingham Park would cross underneath rail at ROW. Pole congestion along South Broadway. Creates two pole lines along South Broadway with 23kV overbuild 1113 ACSR and 13.2kV underbuild 477 ACSR. This could create challenges with pole guying and acquisition of easements. Large poles could create pushback from town. Pole hit could impact one 23kV supply and one 13.2kV feeder	Assumes 50% of the (3X3) 6" underground conduit system from P84 Hampshire St to MH 15 Rockingham Park. (200ft) This will make way and pay for future repurpose of the Olde Trolley feeders for retirement (Phase 3) Assumes \$59 per foot to install overbuilt 23kV circuit along South Broadway (\$144-\$85)
23kV 2393 Relocation to South Broadway OH Option	Use existing UG conduit system installed during Phase 1 and Install two new 1000 MCM CU UG cables from Golden Rock Station to South Broadway. (2300ft). Use existing pole line along South Broadway and install new 1113 ACSR overbuild circuit to Veterans Memorial Parkway P83 (11,000ft). Install two new 1000MCM Cu cables from P83 South Broadway to existing MH 15 Rockingham Park on new UG conduit system. (200ft) Tie into existing 2393 at MH 15.	\$2,395	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Utilizes future underground cable along Hampshire Rd and future pole line along South Broadway. Will allow to repurpose 23kV circuits to pick up Olde Trolley load.	Underground along Rockingham Park would cross underneath rail at ROW. Pole congestion along South Broadway. Creates two pole lines along South Broadway with 23kV overbuild 1113 ACSR and 13.2kV underbuild 477 ACSR. This could create challenges with pole guying and acquisition of easements. Large poles could create pushback from town. Pole hit could impact one 23kV supply and one 13.2kV feeder	Assumes 50% of the (3X3) 6" underground conduit system from P84 Hampshire St to MH 15 Rockingham Park. (200ft) This will make way and pay for future repurpose of the Olde Trolley feeders for retirement (Phase 3) Assumes \$144 per foot to install new overbuilt 23kV circuit pole line along South Broadway. 2393 does not run along ROW between Golden Rock and Baron Ave. It runs along ROW between Baron Ave and Rockingham Park.
23 kV ROW Line Removal 2352	Remove 23 kV Circuit 2352 that runs along 23kV ROW from Golden Rock to Baron Ave to Salem Depot. (15,500ft)	\$132	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Removes 23kV lines that run along the ROW from the Rockingham Park to Salem Depot.		Removal Costs - Assumes 10% of \$85/ft.
23 kV ROW Line Removal 2393	Remove 23 kV Circuit 2393 that runs along 23kV ROW from Baron Ave to Salem Depot. (11,500ft) 2393 circuit from Golden Rock to Baron Ave will be re-purposed as a 13.2kV feeder as part of Phase 3.	\$98	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Will allow to re-purpose 23kV circuit 2393 as a new 13.2kV feeder out of Golden Rock (Phase 3).		Removal Costs - Assumes 10% of \$85/ft.
<b>Total Sub-transmission Line Work</b>		<b>\$4,151</b>			



Liberty Utilities  
 Salem Area Study

7.3.3 Alternate Plan Three Phase Three Estimates

**Table 32 Alternate Plan Three Phase Three Estimate**

<b>Alternate Plan Three - Phase Three</b>					
<b>Replace 115/23 KV Transformer with new 115/23 kV Transformer at Golden Rock with 23kV Supply Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
T1 - 115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus Bus tie breakers	Perform all necessary construction to replace existing 115 kV/23 kV transformer with new 115kV / 23kV 33/44/55 MVA transformer with a secondary breaker and four distribution circuit breakers.	\$4,500	Adds significant capacity to the system and eliminates Olde Trolley substation and 23kV supply system. Removes dependency on the NGRID 23 kV system for load support.	Challenges with outage coordination and cutovers.	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
<b>Total Station Work T1</b>		<b>\$4,500</b>			

<b>Alternate Plan Three - Phase 3</b>					
<b>Replace 115/23 KV Transformer with new 115/23 kV Transformer at Golden Rock with 23kV Supply Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Distribution Circuit – 19L1	Use UG conduit system installed during Phase 1 and one of two new 25kV 1000 MCM CU UG cables (2352) installed during Phase 2 for new L5 circuit from Golden Rock Station to South Broadway. (2300ft). Use pole line along South Broadway installed during Phase 1 and 25kV 1113 ACSR (2352) overbuild circuit installed during Phase 2 for new L5 circuit to Veterans Memorial Parkway P84. Use one of two new 1000MCM Cu cables from P84 South Broadway to existing MH 15 Rockingham Park installed during Phase 2 (200ft) and tie 19L1 circuit to existing 2352 at MH 15. At MH 3 Rockingham Mall tie L5 circuit (2352) to 18L1 feeder.	\$50	Eliminates Olde Trolley 18L1 circuit  Utilizes existing infrastructure along Rockingham Mall and re-purposes installed infrastructure during Phase 1 and Phase 2 for new Golden Rock L5 feeder.	Concerns with asset condition of existing 25kV 1000 MCM cables along Rockingham Mall.  Pole hit along South Broadway could impact 2-13.2kV distribution circuits	
Distribution Circuit – 19L3	Use UG conduit system installed during Phase 1 and one of two new 25kV 1000 MCM CU UG cables (2393) installed during Phase 2 for new L6 circuit from Golden Rock Station to South Broadway. (2300ft). Use pole line along South Broadway installed during Phase 2 and 25kV 1113 ACSR (2393) overbuild circuit installed during Phase 2 for new L6 circuit to Veterans Memorial Parkway P83. Use one of two new 1000MCM Cu cables from P84 South Broadway to existing MH 15 Rockingham Park installed during Phase 2 (200ft) and tie L6 circuit to existing 2393 at MH 15. At MH 3 Rockingham Mall tie 19L3 circuit (2393) to 18L2 feeder.	\$50	Eliminates Olde Trolley 18L2 circuit  Utilizes existing infrastructure along Rockingham Mall and re-purposes installed infrastructure during Phase 1 and Phase 2 for new Golden Rock L6 feeder.	Concerns with asset condition of existing 25kV 1000 MCM cables along Rockingham Mall.  Pole hit along South Broadway could impact 2-13.2kV distribution circuits	Consider tying L6 feeder with Olde Trolley 18L2 feeder at Cluff Crossing instead of routing feeder via UG mall system.
Distribution Circuit – 19L5	Use existing 2393 circuit from Golden Rock to Baron Ave substation. Install new second circuit 477 AL OH along Bagnell Ave, Kelly Rd and South Policy St to Pole 22 (8,500 ft.). Install new 1000 MCM Cu EPR Cables and (1X2) 6" underground conduit under the Exit 1 I-93 interstate along South Policy. (150ft)	\$979	Eliminates Olde Trolley 18L3 circuit  Utilizes existing infrastructure along 2393 from Golden Rock to Baron Ave	2393 from Golden Rock to Baron Ave runs through wetlands area.  Pole hit along Kelly Rd or South Policy St could impact 2-13.2kV distribution circuits	
Distribution Circuit – 19L7 (Future)					
	<b>Total Distribution Circuit - T1</b>	<b>\$1,079</b>			

## Liberty Utilities Salem Area Study

---

### 7.3.4 Alternate Plan Three Problems Resolved

As part of Phase One, the proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Spicket River Station. This project will allow the retirement of Baron Ave substation due to issues with asset condition.

As part of Phase Two, the Rockingham #21 Distribution Circuits would be used to supply a reconfigured 13.2kV distribution system to bring the system into compliance with Liberty's Distribution Planning Criteria. This project will allow the retirement of Salem Depot substation due to issues with asset conditions. The configuration would be targeted to improve reliability and better balance loading on all circuits while taking into account the upcoming expansions in the Rockingham Park. Phase Two relocates the existing 23kV supply along the ROW to South Broadway and provides room to install new 115kV Supply to Rockingham Substation.

As part of Phase Three, the proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand and provides adequate capacity to ensure that there are no violations of the planning criteria within the fifteen year planning horizon. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Rockingham #21 substation and Spicket River #13 substation. This project will allow the conversion of Olde Trolley substation to a regulator/switching substation. . It will also allow the retirement of the 23kV sub-transmission system in the area while moving the system to a more reliable and sustainable 115 kV supplied system. Phase Three re-purposes the new double circuit pole lines along South Broadway installed during Phase Two as new 13.2kV feeders.

Alternate Plan Three was rejected due to the complexities of installing a 23kV overbuild distribution line along city streets. Adding to pole congestion along South Broadway could create push back from the town. In addition it creates two pole lines along South Broadway both with 23kV overbuild 1113 ACSR and 13.2kV underbuild 477 ACSR. This could create challenges with pole guying and acquisition of easements. A Pole hit could impact one 23kV supply and one 13.2kV feeder which could result in load at risk that is above the allowable limit per the planning criteria.

---

#### 7.4 Alternate Plan Four Description

##### **Alternate Plan Four Phase One (New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Backup)**

Phase One of the Alternate Plan Four consists of a second 115 kV transmission line into Golden Rock Station supplying a new 115kV/13.2 kV, 33/44/55 MVA substation transformer with four (4) new 13.2 kV circuit positions. The 13.2 kV circuits would be constructed to provide contingency support to Spicket River Station and to eliminate the Baron Ave Station.

This plan also relocates the two (2) 23kv supply circuits 2352 and 2393 along the ROW to a new underground conduit system along same ROW to make way for the two (2) new 115kV transmission supply lines supplying the new Rockingham Substation. This plan differs from the Recommended Plan Phase One in the configuration of the distribution line circuits. This project also installs the new underground conduit system during Phase One rather than Phase Two.

The cost of Alternate Plan Four Phase One is estimated at \$31,482,000.

##### **Alternate Plan Four Phase Two (New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination)**

Alternate Plan Four Phase Two will require the same plans described in the Alternate Plan One Phase Two and Alternate Plan Two Phase Two (New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination).

The cost of Alternate Plan Four Phase Two is estimated at \$9,375,000

##### **Alternate Plan Four Phase Three (New 115/13.2 KV Transformer at Golden Rock with Olde Trolley Elimination and 23KV Supply System Elimination)**

Phase Three of the Alternate Plan Four will require a New 115/13.2 KV, 33/44/55 MVA substation transformer at Golden Rock with three (3) new 13.2 kV circuit positions. The 13.2 kV circuits would be constructed to provide contingency support to Rockingham Substation #21 and to convert Olde Trolley Substation into a switching/regulating substation. It will also allow the retirement of the 23kV Sub-Transmission System. The relocated 23kV supply installed during Phase One would be repurposed as new 13.2kV distribution circuits.

The cost of Alternate Plan Four Phase Three is estimated at \$6,238,000.



Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 102 of 218

7.4.1 Alternate Plan Four Phase One Estimates  
**Table 33 Alternate Plan Four Phase One Estimate**

<b>Alternate Plan Four Phase One - First New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
115 kV Line Extension	Construct 115 kV line extension with a Ring Bus (Costs included in the Substation's Estimate) installed on between the two 115 kV lines at Golden Rock Station.	TBD	Only one 115 kV Line extension is required.	Requires interconnection and extension of NGRID's 115 kV system. More permitting associated with 115 kV line Extension.	
115/13.2 kV - 33/44/55 MVA Xfmr (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four feeder breakers. Include an automatic transfer system on the 115 kV lines.	\$3,000	Adds significant capacity to the system, addresses the Spicket River contingency and eliminates Baron Ave Station. Minimizes dependency on the NGRID 23 kV system for load support.	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
	<b>Total Station Work</b>	<b>\$3,000</b>			

<b>Alternate Plan Four Phase One - First New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
Feeder - L1 Alternate cost for Baron Ave Elimination	1000 MCM CU UG cable from Golden Rock Station to tap at Cluff Road (pole #71 S Broadway) then to proposed location of Rockingham Station. Then overbuilt OH along S Broadway then N Broadway on to pole # 38 on Lake Street to pick up a portion of 10L2 and 13L2. (15,000' UG and 14,800' OH + 2 Reclosers)	\$3,900	Eliminates Baron Ave Station and Backup Spicket River Station. (10L2)	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers. Adds pole congestion along South Broadway. Creates a double circuit pole line along South Broadway. This could create challenges with guying and acquisition of easements. Large poles could create pushback from town. Pole hit could impact two 13.2kV distribution circuits.	
Feeder - L2 Alternate cost for Baron Ave Elimination	1000 MCM CU UG cable from Golden Rock Station to the proposed location of Rockingham Station. Then underbuilt OH along existing 23 kV Right of Way to new pole 124.5 to pick up a portion of 9L1 and 13L2. (15,000' UG and 4,300' OH + 1 Recloser)	\$3,045	Eliminates Baron Ave Station and Backup Spicket River Station.	Installs new distribution circuit along the 23kV Right of Way. There is only enough space in the ROW to accommodate two-115kV transmission lines.	
Feeder - L3 Alternate cost for Baron Ave Elimination	Over build a 13.2 kV express line from Golden Rock Sta onto Hampshire Road then north on S. Broadway to pole # 42 to pick up 10L4 then to corner of Veterans Memorial Parkway, east on Veterans Memorial to pole 11 to pick up a portion of 18L2, approximately 14,000' (700' new - 13,300' over build + 2 Reclosers) on the Street.	\$1,287	Eliminates Baron Ave Station and Backup Spicket River Station. (10L4)		
Feeder - L4 Alternate cost for Baron Ave Elimination	Over build a 13.2 kV express line from Golden Rock Sta onto Hampshire Road then across S. Broadway to new pole # 1.5 on Hampshire Street to pick up 10L1. Close Tie Switch on pole # 6 on Bagnell Ave and open Switch on Pole # 67 on S Broadway and pick up a portion of 10L2.	\$200	Eliminates Baron Ave Station and Backup Spicket River Station. (10L1, 10L2)		

<b>Alternate Plan Four Phase One - First New 115/13.2 Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
23 kV Line Tie from the 2393 to the 2376	23 kV OH Tie line outside of the Sub Station from the existing 2393 line to the 2376 (removed from Golden Rock Sta) approximately 1,200'	\$150	Maintains access to NGRID's 2376 line for contingency use.		Relocates the tie between 2393 and 2376 to outside of the station yard.
Relocate existing 2352 23 kV Line from OH to UG along the Right of Way - Cable Only	Two 1000 MCM CU UG cables from Golden Rock Station to tap at Baron Ave to a tap at Rockingham Park Blvd, then to proposed location of Rockingham Station. Then connect to existing OH line to Salem Depot Station. (15,000')	\$2,350	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. The cables will be repurposed for the new feeders associated with the second Golden Rock 115/13.2 transformer. They will feed two of the circuits to be retired at Olde Trolley Station		
Relocate existing portions of the 2353 and 2393 23 kV Lines from OH to UG along the Right of Way - Cable Only	Two 1000 MCM CU UG cables from Golden Rock Station to tap at Baron Ave to a tap at Rockingham Park Blvd, then to proposed location of Rockingham Station. Then connect to existing OH line to Salem Depot Station. (15,000')	\$2,350	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. The cables will be repurposed for the new feeders associated with the second Golden Rock 115/13.2 transformer. One will feed one of the circuits to be retired at Olde Trolley Station, the other will be for future use.		
Duct Bank #1 to accommodate relocation of distribution OH facilities to UG to allow for two new 115 kV lines in ROW.	Construct a (3X3), 6", duct and manhole system for 15,950 feet. Included are 30 manholes and two branches one at Cluff Road the other at Rockingham Park Blvd. Also the cost to install a 500 MCM bare Cu cable as a ground is included. The installation is planned to be installed along the west side of the existing 23 kV Right of Way.	\$7,600	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. The duct bank will accommodate the relocated portions of the 2353 and 2393 25 kV lines and the 13.2 kV feeders required by the new #1 Golden Rock Station 115/13.2 kV transformer.	Need to procure rights in the ROW to build underground facilities.	
Duct Bank #2 to accommodate relocation of distribution OH facilities to UG to allow for two new 115 kV lines in ROW.	Construct a (3X3), 6", duct and manhole system for 15,950 feet. Included are 30 manholes and two branches one at Baron Ave the other at Rockingham Park Blvd. Also the cost to install a 500 MCM bare Cu cable as a ground is included. The installation is planned to be installed along the west side of the existing 23 kV Right of Way.	\$7,600	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. The duct bank will accommodate the relocated 2352 25 kV line and the 13.2 kV feeders required by the new #2 Golden Rock Station 115/13.2 kV transformer.	Need to procure rights in the ROW to build underground facilities.	
	<b>Total Sub-Transmission Line Work</b>	<b>\$20,050</b>			

Liberty Utilities  
 Salem Area Study

7.4.2 Alternate Plan Four Phase Two Estimates  
**Table 34 Alternate Plan Four Phase Two Estimate**

<b>Alternate Plan Four Phase Two: New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination</b>			
<b>Station Estimate</b>			
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Comments</b>
Two - 115 kV Line Extensions	Extend two 115 kV line to the proposed Rockingham Station.	TDB	NGRID Project.
T1 - 115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four distribution circuit breakers.	\$2,800	
T2 -115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus + 13.2 Bus Tie breaker	Perform all necessary construction to convert the new Rockingham Station into a double ended station with a tie breaker and auto-transfer of the secondary bus for a loss of either transformer.	\$3,000	
	<b>Total Station Work T1</b>	<b>\$2,800</b>	
	<b>Total Station Work T2</b>	<b>\$3,000</b>	
	<b>Total Station Work</b>	<b>\$5,800</b>	

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Four Phase Two: New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination Distribution Circuit Estimate T1</b>			
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Comments</b>
Distribution Circuit - L1	From Rockingham Station extend an overbuilt a 13.2 kV express line to reconfigure the distribution system to provide compliance with Liberty's Distribution Planning Criteria and Strategy approximately 5,300'.	\$500	
Distribution Circuit - L2	From Rockingham Station extend an overbuilt a 13.2 kV express line to reconfigure the distribution system to provide compliance with Liberty's Distribution Planning Criteria and Strategy approximately 5,300'.	\$500	
Distribution Circuit - L3	From Rockingham Station extend an overbuilt a 13.2 kV express line to reconfigure the distribution system to provide compliance with Liberty's Distribution Planning Criteria and Strategy approximately 5,300'.	\$500	Includes \$ 400 k in UG costs (approximately 1,200'). Get away congestion at S Broadway and Veterans Memorial Pkwy. May require 3,500' of reconductoring to 477 (\$225 k)
Distribution Circuit - L4	Future		Future position 1 of 2 for Rockingham Park
	<b>Total Distribution Circuit - T1</b>	<b>\$1,500</b>	
	<b>Total Station and Distribution - T1</b>	<b>\$4,300</b>	



Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Four Phase Two: New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination Distribution Circuit Estimate T2</b>			
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Comments</b>
Distribution Circuit - L5 Salem Depot Alternative	From Rockingham UG to the switch on pole 86 on S Broadway (1,000') to supply the Salem Depot 9L1. Additional \$50 k for minor system reconfiguration.	\$375	
Distribution Circuit - L6 Salem Depot Alternative	From Rockingham Station to the 23 kV Right of Way under build a 13.2 kV express line along the 23 kV Right of Way to Salem Depot Station approximately 5,000' to supply the Salem Depot 9L2.	\$500	Installs facilities along ROW. It is expected that this ROW will be needed for future 115kV transmission lines supplying Rockingham Substation. There is only enough space in the ROW to accommodate 2-115kV transmission lines.
Distribution Circuit - L7 Salem Depot Alternative	From Rockingham Station UG through Rockingham (3,200') to existing line, overbuild a 13.2 kV express line along line to Pleasant Street to the tie switch on pole 16 (1,500') to supply the 9L3.	\$1,200	
Distribution Circuit - L8 Salem Depot Alternative	Future		Future position 2 of 2 for Rockingham Park
	<b>Total Distribution Circuit – T2</b>	<b>\$2,075</b>	
	<b>Total Distribution Circuit - T1</b>	<b>\$1,500</b>	
	<b>Total Station Work T1</b>	<b>\$2,800</b>	
	<b>Total Station Work T2</b>	<b>\$3,000</b>	
	<b>Project Total</b>	<b>\$9,375</b>	

Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 108 of 218

7.4.3 Alternate Plan Four Phase Three Estimates  
**Table 35 Alternate Plan Four Phase Three Estimate**

<b>Alternate Plan Four Phase Three - Second New 115/13.2 Transformer at Golden Rock Station with Olde Trolley Elimination</b>					
<b>Item</b>	<b>Required construction</b>	<b>Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
115 kV Line Interconnection	Transfer existing 115 kV line to new 115/13.2 kV Transformer	TBD			
115/13.2 kV - 33/44/55 MVA Xfmr (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four feeder breakers and a bus tie breaker to T1 (115/13.2 kV) secondary bus.	\$4,500	Adds significant capacity to the system, eliminates Olde Trolley Station. Minimizes dependency on the NGRID 23 kV system for load support.	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers	
	<b>Total Station Work</b>	<b>\$4,500</b>			

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Four Phase Three - Second New 115/13.2 Transformer at Golden Rock Station with Olde Trolley Elimination</b>					
Item	Required construction	Cost - \$k	Pro	Con	Comments
Feeder - L5	Use one of the new 25 kV 1000 MCM CU Line 2393 Line cables installed in Phase One and the Line 2393 existing 25 kV 1000 MCM CU and existing 15 kV 1000 MCM CU Ckt 18L1 cable on S. Policy Street	\$150	Eliminate Olde Trolley Circuit 18L1 Repurposes existing 25 kV facilities to retire Olde Trolley	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers	
Feeder - L6	New 15 kV UG - 1000 MCM CU cable from Golden Rock to Baron Ave then double circuit 477 OH along Bagnell Ave then up Kelly Road to Pole 13 ( 4550' UG, 2600' OH - 1 Recloser)	\$1,015	Eliminate Olde Trolley Circuit 18L2	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers	
Feeder - L7	Use one of the new 25 kV 1000 MCM CU Line 2352 Line cables installed in Phase One and the Line 2352 existing 25 kV 1000 MCM CU and existing 15 kV 1000 MCM CU Ckt 18L3 cable on S. Policy Street ( UG Cutover, 1 Recloser)	\$125	Eliminate Olde Trolley Circuit 18L3 Repurposes existing 25 kV facilities to retire Olde Trolley	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers	
Feeder - L8	Use one of the new 25 kV 1000 MCM CU Line 2352 Line cables installed in Phase One and the Line 2352 existing 25 kV 1000 MCM AL and existing 15 kV 1000 MCM CU Ckt 18L4 cable at Olde Trolley Station (UG Cutover, 1 Recloser)	\$150	Eliminate Olde Trolley Circuit 18L4 Repurposes existing 25 kV facilities to retire Olde Trolley	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers	
	<b>Total Line Work</b>	<b>\$1,440</b>			

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Four Phase Three - Second New 115/13.2 Transformer at Golden Rock Station with 23kV Supply Elimination</b>					
Item	Required construction	Cost - \$k	Pro	Con	Comments
23 kV ROW Line Removal 2352	Remove 23 kV Circuit 2352 that runs along 23kV ROW from Golden Rock to Baron Ave to Salem Depot. (15,500ft)	\$132	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station.  Removes 23kV lines that run along the ROW from the Rockingham Park to Salem Depot.		Removal Costs - Assumes 10% of \$85/ft.
23 kV ROW Line Removal 2393	Remove 23 kV Circuit 2393 that runs along 23kV ROW from Baron Ave to Salem Depot. (11,500ft) 2393 circuit from Golden Rock to Baron Ave will be re-purposed as a 13.2kV feeder as part of Phase 3.	\$98	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station.  Will allow to re-purpose 23kV circuit 2393 as a new 13.2kV feeder out of Golden Rock (Phase 3).		Removal Costs - Assumes 10% of \$85/ft.
23 kV Line Removal 2353	Remove 23 kV Circuit 2353 that runs along 23kV ROW from Golden Rock to Baron Ave (4,000ft)	\$34	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. (Phase 2).		Removal Costs - Assumes 10% of \$85/ft.
23 kV Line Removal 2393	Remove 23 kV Circuit 2393 from Golden Rock to Baron Ave (4,000ft)	\$34			Removal Costs - Assumes 10% of \$85/ft.  2393 Circuit could be re-purposed for future L8 feeder. This circuit runs from Golden Rock to Baron Ave.
	<b>Total Sub-Transmission Line</b>	<b>\$298</b>			

## Liberty Utilities Salem Area Study

---

### 7.4.4 Alternate Plan Four Problems Resolved

As part of Phase One, the proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Spicket River Station. This project will allow the retirement of Baron Ave substation due to issues with asset condition.

As part of Phase Two, the Rockingham #21 Distribution Circuits would be used to supply a reconfigured 13.2kV distribution system to bring the system into compliance with Liberty's Distribution Planning Criteria. This project will allow the retirement of Salem Depot substation due to issues with asset conditions. The configuration would be targeted to improve reliability and better balance loading on all circuits while taking into account the upcoming expansions in the Rockingham Park.

As part of Phase Three, the proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand and provides adequate capacity to ensure that there are no violations of the planning criteria within the fifteen year planning horizon. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Rockingham #21 substation and Spicket River #13 substation. This project will allow the retirement of Olde Trolley substation due to issues with asset condition. It will also allow the retirement of the 23kV sub-transmission system in the area while moving the system to a more reliable and sustainable 115 kV supplied system.

Alternate Plan Four was rejected due added cost of recommended distribution line configurations. In addition adding to pole congestion along South Broadway could create push back from the town. Installation of double circuit facilities on city streets could create challenges with pole guying and acquisition of easements. A Pole hit could impact two 13.2kV distribution circuits which could result in load at risk that is above the allowable limit per the planning criteria. Alternate Plan Four was also rejected because it underbuilds new overhead 13.2kV facilities along the 23kV Right of Way. There is only enough space in the ROW to accommodate two-115kV transmission lines that will supply the new Rockingham #21 substation.

### 7.5 Alternate Plan Five Description

Alternate Plan Five is similar to the Recommended Plan with the exception that the new underground conduit system would be installed along South Broadway instead of the



Liberty Utilities  
Salem Area Study

---

ROW.

In addition, a new underground conduit system would be built along Hampshire Rd to route new distribution feeders and supply lines along South Broadway.

Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 113 of 218

7.5.1 Alternate Plan Five Phase One Estimates  
**Table 36 Alternate Plan Five Phase One Estimate**

<b>Alternate Plan Five: First New 115/13.2kV Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
115 kV Line Extension	Extend second 115 kV line to the existing Golden Rock Station.	TBD	Only one 115 kV Line extension is required.	Requires interconnection and extension of NGRID's 115 kV system. More permitting associated with 115 kV line Extension.	Transmission owned project.
T2 - 115/13.2 kV - 33/44/55 MVA Xfmr (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four feeder breakers. Include an automatic transfer system on the 115 kV lines.	\$3,000	Adds significant capacity to the system, addresses the Spicket River contingency and eliminates Baron Ave Station asset concerns. Minimizes dependency on the NGRID 23 kV system for load support. Makes 23-13kV transformer available to temporarily supply new Rockingham Park loads.	Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers	Portions of the existing 23 kV bus may be utilized in the new 115/13.2 kV transformer installation. NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
<b>Total Station Work</b>		<b>\$3,000</b>			

<b>Alternate Plan 5 Phase One: First New 115/13.2kV Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Feeder – 19L2	1000 MCM CU UG cable from Golden Rock Station to P21 Hampshire St (700ft) on new 4X4-6" UG conduit system. Reconductor former Baron Ave 10L2 with 477 spacer cable from Golden Rock to Cuomo St (3,600ft) . Reconductor Cuomo St with 477 spacer cable from Garabeddian Dr to South Broadway (900ft). New 19L2 feeder picks up portion of 10L1 at Garabeddian Dr (112Amps) and picks up portion of 10L2 at Baron Ave, Bagnell Ave and Kelly Rd (70A). Install one recloser	\$564	Eliminates Baron Ave Station and Back up Olde Trolley. Makes way for future tie with Pelham Substation. Does not construct facilities along ROW.		Assumes UG conduit system will be funded under 19L8 project - (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft) Circuits from Golden Rock to Hampshire St are 19L2, 19L4, 19L6, future 19L8, future 2352 and future 2393. This will make way and pay for future relocation of 2-23kV circuits 2352 and 2393 (Phase 2)
Feeder – 19L4	1000 MCM CU UG cable from Golden Rock Station to P149 Hampshire St (700ft) on new 4X4-6" UG conduit system. Reconductor former Baron Ave 10L1 Hampshire St with 477 spacer cable from Golden Rock to South Broadway (1,900ft). New 19L4 feeder picks up portion of 10L1 at Hampshire St (48Amps) Pond St (50Amps), picks up portion of 10L4 at Pattee Rd (48Amps) and picks up portion of 10L2 Cluff Rd West (107A). Install one recloser.	\$343	Eliminates Baron Ave Station and Backup Olde Trolley. Does not construct facilities along ROW.		Assumes UG conduit system will be funded under 19L8 project - (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft) Circuits from Golden Rock to Hampshire St are 19L2, 19L4, 19L6, future 19L8, future 2352 and future 2393. This will make way and pay for future relocation of 2-23kV circuits 2352 and 2393 (Phase 2)
Feeder – 19L6	1000 MCM CU UG cable from Golden Rock Station to South Broadway to Lawrence Rd (2,300ft) on new 4X3-6" UG conduit system. Install new 477 Spacer cable OH three phase line along Lawrence Rd (5,000ft) from Pond St to Ansel St. Reconductor Lawrence Rd (4,700ft) from Ansel St to Cole St with 477 spacer cable. New 19L6 feeder picks up portion of 10L4 at Lawrence Rd (90Amps) and picks up portion on 10L2 at Cluff Rd East (43Amps). Install one recloser. Install one load break at P69 Main St on 13L3 for option to pick up 113Amps.	\$1,280	Eliminates Baron Ave Station and Backup Spicket River Station. Does not construct facilities along ROW.		Assumes UG conduit system will be funded under 19L8 project - (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft) and (3X4) 6" underground conduit system along Hampshire St (1600ft). Circuits from Golden Rock to Hampshire St are 19L2, 19L4, 19L6, future 19L8, future 2352 and future 2393. Circuits along Hampshire St are 19L6, future 19L8, future 2352 and future 2393.
Future Feeder – 19L8	Install new 4X4 - 6" UG conduit system from Golden Rock to Hampshire St (700ft) and new 4X3 - 6" UG conduit system from Hampshire St to South Broadway (1,600ft).	\$828	Could re-use UG cable system along Hampshire Rd (2300ft) for future 19L8 feeder, future 2352 and future 2393 (Phase 2). And could also re-use UG conduit system for future Phase 3 project feeders.	Underground along Hampshire Rd would cross underneath rail at ROW	Future 19L8 is to be installed during Phase 2 to take advantage of new underground conduit system along South Broadway. This underground project will make way and pay for future relocation of 2-23kV circuits 2352 and 2393 (Phase 2) along Hampshire St (1600ft) and future Phase 3 feeders.
	<b>Total Line Work Eliminate Baron Ave &amp; Spicket River Backup Alternative</b>	<b>\$3,015</b>			

Liberty Utilities  
 Salem Area Study

<b>Recommended Plan Phase One: First New 115/13.2kV Transformer at Golden Rock Station with Baron Ave Station Elimination and Spicket River Station Back Up</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
23 kV Line Tie from the 2393 to the 2376	23 kV OH Tie line outside of the Sub Station from the existing 2393 line to the 2376 (removed from Golden Rock Sta) approximately 1,200'	\$150	Maintains access to NGRID's 2376 line for contingency use.		Relocates the tie between 2393 and 2376 to outside of the station yard.
23 kV Line Removal 2353	Remove 23 kV Circuit 2353 that runs along 23kV ROW from Golden Rock to Baron Ave (4,000ft)	\$34	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. (Phase 2).		Removal Costs - Assumes 10% of \$85/ft.
	<b>Total Sub transmission Line Work Eliminate Baron Ave &amp; Spicket River Backup Alternative</b>	<b>\$184</b>			

Liberty Utilities  
 Salem Area Study

7.5.2 Alternate Plan Five Phase Two Estimate:

**Table 37 Alternate Plan Five Phase Two Estimate**

<b>Alternate Plan Five Phase 2: Two New 115/13.2 KV Transformers at New Rockingham Station #21 with Salem Depot Station Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Two - 115 kV Line Extensions	Extend two 115 kV line to the proposed Rockingham Station.	<b>TBD</b>	New 115kV lines could be installed in existing ROW in a low profile style construction.	Requires interconnection and extension of NGRID's 115 kV system. More permitting associated with 115 kV line Extension. Requires relocation of the existing 23kV sub-transmission system along ROW.	
T1 - 115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus	Perform all necessary construction to install a 115 kV/13.2 kV 33/44/55 MVA transformer with a secondary breaker and four distribution circuit breakers.	\$2,800	Adds significant capacity to the system, addresses Liberty Planning Criteria violations and eliminates Salem Depot asset condition issues. Minimizes dependency on the NGRID 23 kV system for load support.	Challenges with outage coordination and cutovers. Requires land acquisition within the Rockingham Park.	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
T2 -115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus + 13.2 Bus Tie breaker	Perform all necessary construction to convert the new Rockingham Station into a double ended station with a tie breaker and auto-transfer of the secondary bus for a loss of either transformer.	\$3,000	Adds significant capacity to the system, addresses Liberty Planning Criteria violations and eliminates Salem Depot asset condition issues. Minimizes dependency on the NGRID 23 kV system for load support.	Challenges with outage coordination and cutovers. Requires land acquisition within the Rockingham Park.	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
	<b>Total Station Work T1</b>	<b>\$2,800</b>			
	<b>Total Station Work T2</b>	<b>\$3,000</b>			
	<b>Total Station Work</b>	<b>\$5,800</b>			



<b>Alternate Plan Five Phase 2: Two New 115/13.2 KV Transformers at New Rockingham Station #21 with Salem Depot Station Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Distribution Circuit - 21L1	From Rockingham Station install 1000 MCM CU UG cable to P104 South Broadway (1800ft) on new UG conduit system. New 21L1 circuit picks up portion of 9L1 along South Broadway north of P104, North Broadway and Taylor St (164Amps). Install New LB tie at P104 S Broadway.	\$468	Eliminates Salem Depot Station issues with asset condition and adds Back up supply to Olde Trolley Station.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
Distribution Circuit - 21L2	From Rockingham Station install 1000 MCM CU UG cable to P104 South Broadway (1800ft) on new UG conduit system. Install second circuit along North Broadway from P104 to Old Rockingham Rd (6600ft) using 477 spacer cable. Install New LB tie at P5-1 North Policy St. New 21L2 circuit picks up portion of 9L1 along Old Rockingham Rd and portion of 9L3 along Range Rd (121Amps).	\$1,155	Eliminates Salem Depot Station issues with asset condition and adds Back up supply to Olde Trolley Station.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
Distribution Circuit - 21L3	From Rockingham Station install new 477 spacer cable to Rocktrack. Reconductor wires along Rocktrack/Pleasant St from P8 Rocktrack to P17 Pleasant St (1200ft) with 477 spacer cable. New 21L3 circuit picks up portion of 18L3 Pleasant St including Mall Switchgears 3,4 and 5 (160Amps).	\$102	Could become future spare feeder.  Initially could be used to carry Mall load while Phase 3 Olde Trolley 23kV retirement takes place.		Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
Distribution Circuit - 21L4	From Rockingham Station install 1000 MCM CU UG cable to P104 South Broadway (1800ft) on new UG conduit system. New 21L4 circuit picks up portion of 9L1 along South Broadway south of P104 and portion of 18L2 along Veteran's Memorial Pkwy (145Amps).	\$448	Could be used to carry Olde Trolley load while Phase 3 Olde Trolley 23kV retirement takes place.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft)
	<b>Total Distribution Circuit - T1</b>	<b>\$2,173</b>			
	<b>Total Station and Distribution - T1</b>	<b>\$4,973</b>			

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Five Phase 2: Two New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
Distribution Circuit - 21L5	From Rockingham Station install 1000 MCM CU UG cable to P16 Pleasant St (2200ft) on new UG conduit system. Reconductor wires along Pleasant St from P16 Pleasant St to P7 Main St (1700ft). New 21L5 circuit picks up portion of 9L3 along Main St and South Policy Rd including Canobie Lake Park. (120Amps).	\$636	Eliminates Salem Depot Station and add Back up supply to Olde Trolley and Spicket River Stations.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft) Assumes 50% of the costs for new double circuit pole line along Pleasant St
Distribution Circuit - 21L6	From Rockingham Station install 1000 MCM CU UG cable to P16 Pleasant St (2200ft) on new UG conduit system. Install second circuit along Pleasant St for L6 (1700ft). New 21L6 circuit picks up feeder 9L2. (224Amps).	\$588	Eliminates Salem Depot Station and add Back up supply to Olde Trolley and Spicket River Stations.	Requires easements for new construction within the Rockingham Park	Assumes 25% of the (4X4) 6" underground conduit system from Rockingham to South Broadway (1800ft) Assumes 50% of the costs for new double circuit pole line along Pleasant St
Distribution Circuit - 21L7	Future	\$0			Future Feeder 1 of 2 for Tuscan Park
Distribution Circuit - 21L8	Future	\$0			Future Feeder 2 of 2 for Tuscan Park
Golden Rock Feeder - 19L8 Spicket River Mitigation	Use existing UG conduit system installed during Phase 1 and install one new 1000 MCM CU UG cable from Golden Rock Station to South Broadway. (2,300ft) Install new UG 1000 MCM Cu UG cables and new UG conduit system along South Broadway from Hampshire Rd to Veteran's Memorial Pkwy (11,000ft) Install second OH three phase line along existing South Broadway pole line (2,000ft) from Veteran's Memorial Pkwy to Belmont St. Install new OH three phase line along Belmont St and Granite Ave (3,900ft) from South Broadway to Main St. New Golden Rock 19L8 feeder picks up portion of 9L1 at Main St east of Broadway (18Amps), picks up a portion of 13L2 at Millville south of Bluff St (103Amps) and picks up portion of 13L3 East Main St LB 701108 (221Amps). Install one recloser.	\$4,032	Backup Spicket River Station and Salem Depot. Does not construct facilities along ROW. Does not create pole congestion along S Broadway from Hampshire Rd to Veteran's Memorial Pkwy	Underground along Hampshire Rd would cross underneath rail at ROW. Pole congestion along South Broadway from Veteran's Memorial Pkwy to Belmont St due to double circuit pole line. (2,000ft). This could create challenges with guying and easements. Large poles could create pushback from town. Pole hit could impact two 13.2kV feeders although from two different substations.	Assumes 25% of the (4X4) 6" underground conduit system from Golden Rock to Hampshire St (700ft) and 50% of the (3X4) 6" underground conduit system along Hampshire St (1600ft). Circuits from Golden Rock to Hampshire St are 19L2, 19L4, 19L6, 19L8, future 2352 and future 2393. Circuits along Hampshire St are 19L6, 19L8, future 2352 and future 2393. This will make way and pay for future relocation of 2-23kV circuits 2352 and 2393 (Phase 2)
	<b>Rockingham Sub Total Distribution Circuit - T2</b>	<b>\$1,224</b>			
	<b>Rockingham Sub Total Station and Distribution - T2</b>	<b>\$4,224</b>			
	<b>Phase 2 Total Distribution Line Work</b>	<b>\$7,429</b>			

<b>Alternate Plan Five Phase 2: Two New 115/13.2 KV Transformers at New Rockingham Station #21 with Salem Depot Station Elimination</b>					
Item	Required construction	Liberty Cost - \$k	Pro	Con	Comments
23kV 2352 Relocation to South Broadway OH Option	Use existing UG conduit system installed during Phase 1 and Install two new parallel 1000 MCM CU UG cables from Golden Rock Station to South Broadway. (2300ft). Install two new parallel 1000 MCM Cu UG cables and new UG conduit system along South Broadway from Hampshire Rd to Veteran's Memorial Pkwy (11,000ft). Tie in new UG conduit system along South Broadway to existing MH 15 Rockingham Park (200ft). Tie into existing 2352 at MH 15.	\$5,594	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Does not create pole congestion along S Broadway. Will allow re-purposing underground cables as part of Phase 3 project as new 13.2kV feeders out of Golden Rock to pick up Olde Trolley load.	Underground along Rockingham Park would cross underneath rail at ROW.	Assumes 33% of the (4X3) 6" underground conduit system from Hampshire St to MH 15 Rockingham Park. (11,200ft) This will make way and pay for future repurpose of the Olde Trolley feeders for retirement (Phase 3) Going with 1 set of 1000MCM Cu rather than 2 parallel sets reduces the total cost by approx. \$2M
23kV 2393 Relocation to South Broadway OH Option	Use existing UG conduit system installed during Phase 1 and Install two new parallel 1000 MCM CU UG cables from Golden Rock Station to South Broadway. (2300ft). Install two new paralleled 1000 MCM Cu UG cables and new UG conduit system along South Broadway from Hampshire Rd to Veteran's Memorial Pkwy (11,000ft). Tie in new UG conduit system along S Broadway to existing MH 15 Rockingham Park (200ft). Tie into existing 2393 at MH 15.	\$5,594	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Does not create pole congestion along S Broadway. Will allow re-purposing underground cables as part of Phase 3 project as new 13.2kV feeders out of Golden Rock to pick up Olde Trolley load.	Underground along Rockingham Park would cross underneath rail at ROW.	Assumes 33% of the (4X3) 6" underground conduit system from Hampshire St to MH 15 Rockingham Park. (11,200ft) This will make way and pay for future repurpose of the Olde Trolley feeders for retirement (Phase 3) 2393 does not run along ROW between Golden Rock and Baron Ave. It runs along ROW between Baron Ave and Rockingham Park. Going with 1 set of 1000MCM Cu rather than 2 parallel sets reduces the total cost by approx. \$2M
23 kV ROW Line Removal 2352	Remove 23 kV Circuit 2352 that runs along 23kV ROW from Golden Rock to Baron Ave to Salem Depot. (15,500ft)	\$132	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Removes 23kV lines that run along the ROW from the Rockingham Park to Salem Depot.		Removal Costs - Assumes 10% of \$85/ft.
23 kV ROW Line Removal 2393	Remove 23 kV Circuit 2393 that runs along 23kV ROW from Baron Ave to Salem Depot. (11,500ft) 2393 circuit from Golden Rock to Baron Ave will be re-purposed as a 13.2kV feeder as part of Phase 3.	\$98	Makes room on the Right of Way for the 115 kV line extensions to the proposed new 115/13.2 kV Rockingham Station. Will allow re-purposing 23kV circuit 2393 as a new 13.2kV feeder out of Golden Rock (Phase 3).		Removal Costs - Assumes 10% of \$85/ft.
<b>Total Sub-transmission Line Work</b>		<b>\$11,417</b>			

Liberty Utilities  
 Salem Area Study

7.5.3 Alternate Plan Five Phase Two Delays - Estimate Salem Depot Upgrade:

If the implementation of a new Rockingham Station is significantly delayed, Salem Depot Station upgrades should be pursued. This includes upgrading the two 6.25 MVA, 23kV/13.2kV auto transformers at Salem Depot Station with new 9.376 MVA two winding 23kV/13.2kV transformers along with upgraded bus, new primary breakers and new secondary breakers.

**Table 38 Alternate Plan Five Phase Two Salem Depot Upgrade Estimate**

<b>Alternate Plan Five Phase Two Salem Depot Station Upgrade Station Estimate</b>			
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Comments</b>
At Salem Depot Station Replace the two existing 23/13.2 kV, 6.25 MVA Auto Transformers with new 23/13.2 kV, 9.375 MVA two winding transformers (SN = 13.9 MVA, SE = 14.4 MVA)	Perform all necessary construction to remove two (2) existing 23/13.2 kV, 6.25 MVA auto transformers and install two new 23/13.2 kV, 9.75 MVA two winding transformers along with their 25 kV primary and 15 kV secondary breakers.	\$1,550	Recommended if Phase Two - New Rockingham Station - will be significantly delayed.
	<b>Total Station Work</b>	<b>\$1,550</b>	

Liberty Utilities  
 Salem Area Study

7.5.4 Alternate Plan Five Phase Three Estimate:

**Table 39 Alternate Plan Five Phase Three Estimate**

<b>Alternate Plan Five Phase 3: Replace 115/23 KV Transformer with new 115/23 kV Transformer at Golden Rock with 23kV Supply Elimination</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
T1 - 115/13.2 kV - 33/44/55 MVA Transformer (SN = 83.9 MVA, SE = 94.4 MVA) Four position OH bus Bus tie breakers	Perform all necessary construction to replace existing 115 kV/23 kV transformer with new 115kV / 23kV - 33/44/55 MVA transformer with a secondary breaker and four distribution circuit breakers.	\$4,500	Moves the system from the legacy 23 kV supplied system to a more reliable and sustainable 115 kV supplied system. Re-purposes the 23kV circuits installed during Phase 2 as new 13.2kV circuits.	Extensive outage planning.	NGRID is responsible for the 115 kV equipment through the transformer secondary bushings and Liberty is responsible for the 13.2kV equipment from the secondary taps out.
<b>Total Station Work T1</b>		<b>\$4,500</b>			



Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Five Phase 3: Replace 115/23 KV Transformer with new 115/23 kV Transformer at Golden Rock with 23kV Supply Elimination</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
Distribution Circuit – 19L1	Use UG conduit system installed during Phase 1 and one of two new 25kV 1000 MCM CU UG cables (2352) installed during Phase 2 for new 19L1 circuit from Golden Rock Station to South Broadway. (2300ft). Use UG conduit system and one of two new 1000 MCM Cu UG cables (2352) installed during Phase 2 for new 19L1 circuit to Veterans Memorial Parkway to Rockingham Park MH15. Tie 19L1 circuit to existing 2352 at MH 15. At MH 3 Rockingham Mall tie 19L1 circuit (2352) to 18L1 feeder.	\$50	Eliminates Olde Trolley 18L1 circuit Utilizes existing infrastructure along Rockingham Mall and re-purposes installed infrastructure during Phase 1 and Phase 2 for new Golden Rock 19L1 feeder (2352). Removes pole congestion and double pole contingency risk along South Broadway.	Concerns with asset condition of existing 25kV 1000 MCM cables along Rockingham Mall.	
Distribution Circuit – 19L3	Use UG conduit system installed during Phase 1 and one of two new 25kV 1000 MCM CU UG cables (2393) installed during Phase 2 for new 19L6 circuit from Golden Rock Station to South Broadway (2300ft). Use UG conduit system and one of two new 1000 MCM Cu UG cables (2393) installed during Phase 2 for new 19L3 circuit to Veterans Memorial Parkway to MH 15. Tie 19L3 circuit to existing 2393 at MH 15. At MH 3 Rockingham Mall tie 19L3 circuit (2393) to 18L2 feeder.	\$50	Eliminates Olde Trolley 18L2 circuit Utilizes existing infrastructure along Rockingham Mall and re-purposes installed infrastructure during Phase 1 and Phase 2 for new Golden Rock 19L3 feeder (2393). Removes pole congestion and double pole contingency risk along South Broadway.	Concerns with asset condition of existing 25kV 1000 MCM cables along Rockingham Mall.	Consider tying L6 feeder with Olde Trolley 18L2 feeder at Cluff Crossing instead of routing feeder via UG mall system.
Distribution Circuit – 19L5	Use UG conduit system installed during Phase 1 and one of two new 25kV 1000 MCM CU UG cables (2393) installed during Phase 2 for new 19L5 circuit from Golden Rock Station to South Broadway (2300ft). Use UG conduit system and one of two new 1000 MCM Cu UG cables (2393) installed during Phase 2 for new 19L5 circuit to Veterans Memorial Parkway to MH 15. Tie 19L5 circuit to existing 2393 at MH 15. At Olde Trolley tie L7 circuit (2393) to 18L3 feeder.	\$50	Eliminates Olde Trolley 18L3 circuit Utilizes existing infrastructure along Rockingham Mall and re-purposes installed infrastructure during Phase 1 and Phase 2 for new Golden Rock 19L5 feeder (2393). Removes pole congestion and double pole contingency risk along South Broadway.	Concerns with asset condition of existing 25kV 1000 MCM cables along Rockingham Mall.	
Distribution Circuit – 19L7 (Future)					Second 23kV 1000 MCM Cu Cables from previous 2352 circuit could be re-purposed for future 19L7 feeder. This circuit would run from Golden Rock to Veteran's Memorial Hwy.
	<b>Total Distribution Circuit - T1</b>	<b>\$150</b>			

Liberty Utilities  
 Salem Area Study

<b>Alternate Plan Five Phase 3: Replace 115/23 KV Transformer with new 115/23 kV Transformer at Golden Rock with 23kV Supply Elimination</b>					
<b>Item</b>	<b>Required construction</b>	<b>Liberty Cost - \$k</b>	<b>Pro</b>	<b>Con</b>	<b>Comments</b>
23 kV Line Removal 2393	Remove 23 kV Circuit 2393 from Golden Rock to Baron Ave (4,000ft)	\$34			Removal Costs - Assumes 10% of \$85/ft.  2393 Circuit could be re-purposed for future L8 feeder. This circuit runs from Golden Rock to Baron Ave.
	<b>Total Sub transmission Line Work</b>	<b>\$34</b>			

Liberty Utilities  
Salem Area Study

---

### 7.5.5 Alternate Plan Five Problems Resolved

Alternate Plan Five is similar to the Recommended Plan with the exception that the underground conduit system would be installed along South Broadway instead of the right-of-way.

As part of Phase One, the proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Spicket River Station. This project will allow the retirement of Baron Ave substation due to issues with asset condition.

As part of Phase Two, the Rockingham #21 Distribution Circuits would be used to supply a reconfigured 13.2kV distribution system to bring the system into compliance with Liberty's Distribution Planning Criteria. This project will allow the retirement of Salem Depot substation due to issues with asset conditions. The configuration would be targeted to improve reliability and better balance loading on all circuits while taking into account the upcoming expansions in the Rockingham Park. As part of Phase Two a new underground conduit system would be installed along South Broadway to relocate the existing 23kV supply and accommodate the 115kV Transmission system.

As part of Phase Three, the proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand and provides adequate capacity to ensure that there are no violations of the planning criteria within the fifteen year planning horizon. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Rockingham #21 substation and Spicket River #13 substation. This project will allow the conversion of Olde Trolley substation into a regulating/switching station. It will also allow the retirement of the 23kV sub-transmission system in the area while moving the system to a more reliable and sustainable 115 kV supplied system. The underground facilities installed during Phase 2 would be re-purposed as 13.2kV feeders.

Alternate Plan Three was rejected due to the complexities of installing a 23kV underground conduit system along city streets. It was also rejected due to the higher cost of installing underground facilities along city streets as compared to ROW construction.

Liberty Utilities  
 Salem Area Study

**8 Plan Cost Comparison**

*Table 40 Plan Comparison*

Item	Item	Recommended Plan Cost - \$k	Alternate Plan 5 Cost - \$k	Alternate Plan 4 Cost - \$k	Alternate Plan 3 Cost - \$k	Alternate Plan 2 Cost - \$k	Alternate Plan 1 Cost - \$k
Golden Rock with Baron Ave Elimination and Spicket River backup	Phase 1 - Total Station Work	\$3,000	\$3,000	\$3,000	\$3,000	\$3,000	\$3,000
Golden Rock with Baron Ave Elimination and Spicket River backup	Phase 1 - Total Line Work	\$2,400	\$3,015	\$8,432	\$5,981	\$1,215	\$1,215
Golden Rock with Baron Ave Elimination and Spicket River backup	Phase 1 - Total Sub-transmission Line Work	\$184	\$184	\$20,050	\$184	\$4,180	\$4,050
Rockingham with Salem Depot Elimination and Criteria Mitigation	Phase 2 - Total Sub-transmission Line Work	\$8,504	\$11,417	\$0	\$4,151	\$0	\$0
Rockingham with Salem Depot Elimination and Criteria Mitigation	Phase 2 - Total Distribution Line Work	\$6,343	\$7,429	\$3,575	\$3,745	\$3,575	\$3,575
Rockingham with Salem Depot Elimination and Criteria Mitigation	Phase 2 - Total Distribution Station Work	\$5,800	\$5,800	\$5,800	\$5,800	\$5,800	\$5,800
Golden Rock with Olde Trolley and 23kV Supply Elimination	Phase 3 - Total Distribution Circuit - T1	\$150	\$150	\$1,440	\$1,079	N/A	N/A
Golden Rock with Olde Trolley and 23kV Supply Elimination	Phase 3 - Total Station Work T1	\$4,500	\$4,500	\$4,500	\$4,500	N/A	N/A
Golden Rock with Olde Trolley and 23kV Supply Elimination	Phase 3 - Total Sub-transmission Line Work	\$34	\$34	\$298	\$0	N/A	N/A
<b>Golden Rock with Baron Ave Elimination and Spicket River backup</b>	<b>Phase 1 - Total Project</b>	<b>\$5,584</b>	<b>\$6,199</b>	<b>\$31,482</b>	<b>\$9,165</b>	<b>\$8,395</b>	<b>\$8,265</b>
<b>Rockingham with Salem Depot Elimination and Criteria Mitigation</b>	<b>Phase 2 - Total Project</b>	<b>\$20,648</b>	<b>\$24,646</b>	<b>\$9,375</b>	<b>\$13,696</b>	<b>\$9,375</b>	<b>\$9,375</b>
<b>Golden Rock with Olde Trolley and 23kV Supply Elimination</b>	<b>Phase 3 - Total Project</b>	<b>\$4,684</b>	<b>\$4,684</b>	<b>\$6,238</b>	<b>\$5,579</b>	<b>N/A</b>	<b>N/A</b>
	<b>Project Total</b>	<b>\$30,916</b>	<b>\$35,529</b>	<b>\$47,095</b>	<b>\$28,440</b>	<b>\$17,770</b>	<b>\$17,640</b>

Liberty Utilities  
Salem Area Study

---

## 9 Conclusion

Evaluations identified a number of existing and predicted system Circuit, Supply Line, and Transformer capacity concerns that did not meet the requirements of the Liberty Distribution Planning Criteria. Criteria violations were identified by year for both the Normal Loading and the Contingency Loading cases.

In addition to the existing distribution evaluation the study also focused on the distribution requirements needed to supply the proposed 14-17 MW business park spot load located at the Rockingham Park. The existing distribution system cannot support this load increase.

Existing distribution asset concerns were taken into consideration during this study, including the poor asset condition of Baron Ave Substation and Wood Pole Structures and limited clearance at Salem Depot Substation.

Several plans were evaluated to address the existing and future system needs of the area taking into consideration existing distribution asset concerns, proposed business park located at the Rockingham Park and company strategy to move away from the 23kV sub-transmission system and into a more reliable and robust 115kV system based system.

The recommended plan addresses present and predicted normal and contingency operational, capacity, and asset challenges associated with the existing 23kV/13.2kV distribution system, based on the existing System Planning Criteria. In addition, the plan addresses capacity loading concerns developed with the addition of the proposed business park and other known spot loads in the area.

The plan will be achieved in two (3) phases. It addresses the existing concerns and the future concerns in the most complete way while moving the system from the legacy 23 kV supplied system to a more reliable and sustainable 115 kV supplied system.

### **Phase One (New 115/13.2 kV Transformer at Golden Rock Station with Baron Ave Station Elimination & Spicket River Mitigation)**

Phase One of the recommended plan consists of a second 115 kV transmission line into Golden Rock Station supplying a second 115kV/13.2 kV substation transformer with four (4) new 13.2 kV circuit positions. The 13.2 kV circuits would be constructed to provide contingency support to Spicket River Station and to eliminate the Baron Ave Station.

This phase would also include the replacement of existing conductor in excess of 100% of Summer Normal ratings, on the Salem Depot 9L3, Olde Trolley 18L3, and 18L4 circuits. All conductor upgrades would be accomplished using 477 Al open wire or 477 Al spacer depending upon field conditions.



Liberty Utilities  
Salem Area Study

---

Additionally, the proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Spicket River Station. This project will allow the retirement of Baron Ave substation due to issues with asset condition.

**Phase Two (New 115/13.2 KV Transformers at New Rockingham Station with Salem Depot Station Elimination)**

Phase Two of the recommended plan consists of an extension of the 115 kV transmission system from Golden Rock Station to a proposed new double ended 115kV/13.2kV station in the Rockingham area.

Each new 115 kV/ 13.2 kV supply transformer, T1 and T2, would have four (4) circuits, eight (8) total, with secondary breakers and a bus tie breaker. An automatic bus transfer system would be utilized to improve reliability and simplify maintenance.

As part of Phase Two, the Rockingham #21 Distribution Circuits would be used to supply a reconfigured 13.2kV distribution system to bring the system into compliance with Liberty's Distribution Planning Criteria. The configuration would be targeted to improve reliability and better balance loading on all circuits while taking into account the upcoming expansions in the Rockingham Park.

In addition the Rockingham #21 distribution circuits would be used to eliminate the Salem Depot Substation due to issues with asset condition.

The fourth circuits on both Rockingham #21 station transformers would be dedicated to serve the proposed business park load.

As part of Phase Two, the 23kV sub-transmission lines 2393 and 2352 will be relocated from the right-of-way to accommodate the 115kV transmission lines that will supply the new Rockingham #21 substation. The recommended plan avoids building sub-transmission lines along city streets and chooses a route that does not impede with needed clearances along the right-of-way. It also set the stage for the future retirement of the 23kV system and re-purposes the sub-transmission lines as future distribution circuits (Phase Three).

If the implementation of a new Rockingham Station is significantly delayed, Salem Depot Station upgrades should be pursued. This includes upgrading the two 6.25 MVA, 23kV/13.2kV auto transformers at Salem Depot Station with new 9.376 MVA two winding 23kV/13.2kV transformers along with upgraded bus, new primary breakers and new secondary breakers.

Liberty Utilities  
 Salem Area Study

In addition, if the implementation of a new Rockingham Station is significantly delayed, the temporary installation of a 23/13.2kV 9.375 MVA transformer within the Rockingham Park should be pursued. One transformer from the retired Baron Avenue substation could be reserved for this application. Although this transformer and sub-transmission supply system would not have the full capacity to supply all of the forecasted expansions in the park, it could buy enough time to supply some new developments in the Park as the new Rockingham Station is being implemented.

**Phase Three (New 115/13.2 KV Transformer at Golden Rock Station with Olde Trolley Station and 23kV Supply System Elimination)**

Phase three of the recommended plan consists of a second 115kV/13.2kV substation transformer at Golden Rock with three (3) new 13.2kV feeder positions. The existing 115kV/23kV Golden Rock transformer is to be removed and the substation is to be converted into a 13.2kV with a breaker and a half scheme. The existing 23kV lines will be converted to 13.2kV distribution circuits. The 13.2 kV circuits would be constructed to provide contingency support to Rockingham Station and Spicket River Station and to eliminate the Olde Trolley Station and 23kV supply system in the area.

The proposed new 115kV/13.2kV transformer at Golden Rock, with a summer normal rating of 83.9 MVA, will provide additional capacity to be utilized in supplying system demand and provides adequate capacity to ensure that there are no violations of the planning criteria within the fifteen year planning horizon. Four (4) new circuit positions, with higher ratings than the existing distribution circuits in the area, would be constructed to provide contingency support to Rockingham #21 substation and Spicket River #13 substation. This project will allow the retirement of Olde Trolley due to issues with asset condition. It will also allow the retirement of the 23kV sub-transmission system in the area while moving the system to a more reliable and sustainable 115 kV supplied system.

The following tables provide estimated costs, by phase, for the Recommended Plan.

<b>Recommended Plan Phase One Estimate</b>	
<b>Required Construction</b>	<b>Cost - \$k</b>
Baron Ave Station Elimination & Spicket River Mitigation Distribution Circuit Estimate	<b>\$3,341</b>
Baron Ave Station Elimination & Spicket River Mitigation Sub-Transmission Circuit Estimate	<b>\$184</b>
New 115/13.2 kV Transformer at Golden Rock Station Estimate	<b>\$3,000</b>

Liberty Utilities  
 Salem Area Study

<b>Phase One Project Total</b>	<b>\$6,525</b>
--------------------------------	----------------

<b>Recommended Plan Phase Two Estimate</b>	
<b>Required Construction</b>	<b>Cost - \$k</b>
Salem Depot Station Elimination Distribution Circuit Estimate and Design Criteria Compliance	<b>\$8,293</b>
Salem Depot Station Elimination Sub-transmission Circuit Estimate and 23kV Relocation.	<b>\$12,467</b>
New 115/13.2 KV Transformer, T1, at New Rockingham Station Estimate	<b>\$2,800</b>
New 115/13.2 KV Transformer, T2, at New Rockingham Station Estimate	<b>\$3,000</b>
<b>Phase Two Project Total</b>	<b>\$26,560</b>

<b>Recommended Plan Phase Three Estimate</b>	
<b>Required Construction</b>	<b>Cost - \$k</b>
Olde Trolley Elimination Distribution Circuit Estimate	<b>\$150</b>
Olde Trolley Elimination Sub-transmission Circuit Estimate and 23kV Supply Retirement	<b>\$34</b>
New 115/13.2 kV Transformer at Golden Rock Station Estimate	<b>\$4,500</b>
<b>Phase Three Project Total</b>	<b>\$4,684</b>

If the implementation of a new Rockingham Station is significantly delayed, Salem Depot Station upgrades should be pursued.

<b>Recommended Plan Phase Two Delay Estimate</b>	
<b>Required Construction</b>	<b>Cost - \$k</b>
<b>Salem Depot Station Upgrades Station Estimate</b>	<b>\$1,550</b>
<b>Phase Two Project Total (Delay)</b>	<b>\$1,550</b>

**Appendix A Eliminated Plans**

Plan	Description	Required construction	Liberty Station Cost - \$M	Line Cost - \$M	Total Cost - \$M	Pro	Con	Comments
115/23 kV Station Expansion at Golden Rock Station	<p><b><u>New 115/23 kV Transformer at Golden Rock Station</u></b></p> <p>Add the following to Golden Rock Station</p> <ul style="list-style-type: none"> <li>- A second 115 kV line</li> <li>- 115/23 kV - 33/44/55 MVA Xfmr</li> </ul> <p>With (SN = 83.9 MVA, SE = 91.4 MVA)</p> <ul style="list-style-type: none"> <li>- Bus with three 1200 Amp breaker positions + one 2000 Amp tie breaker.</li> </ul> <p>NGRID responsible for the 115 kV equipment through the transformer secondary bushings.</p> <p>LIBERTY from the secondary taps out.</p>	<ul style="list-style-type: none"> <li>- Build 115 kV line extension - NGRID</li> <li>- Install new Transformer at Golden Rock Station - NGRID</li> <li>- Reconfigure 23 kV lines at the Station - LIBERTY</li> <li>- Build a new 23 kV line to Spicket River Station - LIBERTY</li> <li>- Build new line for Rockingham Park Load - LIBERTY</li> </ul>	\$2.00 M	\$3.85 M	<b>\$5.85 M</b>	<ul style="list-style-type: none"> <li>- Provides a robust and redundant supply system</li> <li>- Addresses Spicket River contingency</li> <li>- Allows for future Rockingham Park load</li> <li>- Increases 23 kV reliability and ease of maintenance</li> <li>- Minimizes dependency on NGRID for 23 kV support</li> </ul>	<ul style="list-style-type: none"> <li>- Requires extension of NGRID's 115 kV system</li> <li>- Permitting required for a 115 kV extension</li> <li>- Continues the 23 kV sub transmission system</li> <li>- Adds new upgrade or capacity increases to the 13.2 kV system</li> <li>- Does not address existing asset conditions</li> </ul>	<ul style="list-style-type: none"> <li>- The NGRID 2353 line will be removed from Golden Rock Station and will no longer be required to back up the 2376 supply to Spicket River.</li> <li>- Provides operational flexibility.</li> <li>- NGRID may desire to reconfigure their remaining feeds to Golden Rock and Spicket River</li> <li>- Includes \$150 k to maintain one tie to the NGRID 23 kV system at Golden Rock Station</li> </ul>
				Cost with Rockingham Park Line = \$5.50 M	<b>Cost with Rockingham Park Line = \$7.50 M</b>			

**Eliminated - Limited benefits, does not address any existing asset issues**

Liberty Utilities  
 Salem Area Study

Plan	Description	Required construction	Liberty Station Cost - \$M	Line Cost - \$M	Total Cost - \$M	Pro	Con	Comments
115/13.2 kV Station Addition at Golden Rock Station Maintaining the Existing Stations Alternative	<p><b><u>New 115/13.2 kV Transformer at Golden Rock Station</u></b></p> <p>Add the following to Golden Rock Sta</p> <ul style="list-style-type: none"> <li>- A second 115 Kv Line</li> <li>- 115/13.2 kV 33/44/55 MVA Xfmr With SN = 83.9 MVA, SE = 94.4 MVA</li> <li>- Four breaker position bus</li> <li>- Build three new 13.2 feeder circuits</li> </ul> <p>NGRID responsible for the 115 kV equipment through the transformer secondary bushings. LIBERTY from the secondary taps out.</p>	<ul style="list-style-type: none"> <li>- Build 115 kV line extension - NGRID</li> <li>- Install a 115 kV tie breaker between the two lines and an automatic transfer system - NGRID (LIBERTY COST?)</li> <li>- Install the Ckt Sw and the transformer at Golden Rock Station - NGRID</li> <li>- Install the secondary breaker, 13.2 kV bus with four feeder breakers at Golden Rock Station - LIBERTY</li> <li>- Build three new 13.2 kV feeder circuits and reconfigure 13.2 kV system - LIBERTY</li> </ul>	\$3.00 M	\$5.00 M	\$8.00 M	<ul style="list-style-type: none"> <li>- Only requires one 115 kV line extension</li> <li>- Adds capacity to the system</li> <li>- Addresses the Spicket River contingency</li> <li>- Reduces dependency on NGRID's 23 kV system</li> <li>- Redistributes loading on the existing stations and provides capacity to address loss of supply to Spicket River Station.</li> </ul>	<ul style="list-style-type: none"> <li>- Requires extension of NGRID's 115 kV system</li> <li>- Permitting required for a 115 kV extension</li> <li>- Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers</li> </ul>	Installation of an auto transfer on the 115 kV system recommended because low side busses operate at different voltages.

Eliminated - Limited benefits, does not address any existing asset issues



Liberty Utilities  
 Salem Area Study

Plan	Description	Required construction	Liberty Station Cost - \$M	Line Cost - \$M	Total Cost - \$M	Pro	Con	Comments
115/13.2 kV Station Addition at Golden Rock Station with the Elimination of Salem Depot Alternative	<p><b><u>New 115/13.2 kV Transformer at Golden Rock Station</u></b></p> <p>Add the following to Golden Rock Sta</p> <ul style="list-style-type: none"> <li>- A second 115 Kv Line</li> <li>- 115/13.2 kV 33/44/55 MVA Xfmr</li> <li>With SN = 83.9 MVA, SE = 94.4 MVA</li> <li>Four breaker position bus</li> <li>- Eliminate Salem Depot Station</li> <li>- Build 23 kV line to Spicket River Station with an auto transfer system at Spicket River Station.</li> </ul> <p>NGRID responsible for the 115 kV equipment through the transformer secondary bushings. LIBERTY from the secondary taps out.</p>	<ul style="list-style-type: none"> <li>- Build 115 kV line extension - NGRID</li> <li>- Install a 115 kV tie breaker between the two lines and an automatic transfer system - NGRID (LIBERTY COST?)</li> <li>- Install the Ckt Sw and the transformer at Golden Rock Station - NGRID</li> <li>- Install the secondary breaker, 13.2 kV bus with four feeder breakers at Golden Rock Station - LIBERTY</li> <li>- Build three new 13.2 kV feeder circuits and reconfigure 13.2 kV system - LIBERTY</li> <li>- Build a 23kV line to Spicket River Station and install auto transfer system - LIBERTY</li> </ul>	\$3.00 M	\$8.43 M	\$11.43 M	<ul style="list-style-type: none"> <li>- Only requires one 115 kV line extension</li> <li>- Adds capacity to the system</li> <li>- Addresses the Spicket River contingency</li> <li>- Improves reliability due to loss of supply at Spicket River Station restoration &lt; 1 min.</li> <li>- Constructs a second 23 kV supply to Spicket River, addresses loss of supply to Spicket River Station.</li> <li>- Eliminates Salem Depot Station</li> </ul>	<ul style="list-style-type: none"> <li>- Requires extension of NGRID's 115 kV system</li> <li>-Permitting required for a 115 kV extension</li> <li>- Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers</li> </ul>	<p>Installation of an auto transfer on the 115 kV system recommended because low side busses operate at different voltages.</p> <ul style="list-style-type: none"> <li>- Installation of an auto transfer system on the 23 kV supply lines to Spicket recommended to improve reliability.</li> <li>\$200k cost included for the 23 kV auto transfer at Spicket River.</li> </ul>

Eliminated - Additional distribution costs required to eliminate Salem Depot Station

Liberty Utilities  
 Salem Area Study

Plan	Description	Required construction	Liberty Station Cost - \$M	Line Cost - \$M	Total Cost - \$M	Pro	Con	Comments
Olde Trolley Salem Depot Retirement Alternative	<p><b><u>New 115/13.2 Transformer at Olde Trolley Station Part 1</u></b></p> <ul style="list-style-type: none"> <li>- 115 Kv Line #1</li> <li>- T1 115/13.2 kV 33/44/55 MVA Xfmr With SN = 83.9 MVA, SE = 91.4 MVA</li> <li>- Four breaker position bus</li> <li>- Build three new 13.2 feeder circuits</li> </ul> <p>NGRID responsible for the 115 kV equipment through the transformer secondary bushings. LIBERTY from the secondary taps out.</p>	<ul style="list-style-type: none"> <li>- Build first 115 kV line extension - NGRID</li> <li>- Build and install first Ckt Sw and Transformer at the new Olde Trolley Station - NGRID</li> <li>- Install secondary breaker and 13.2 kV bus with four feeder breakers at Olde Trolley Station - LIBERTY</li> <li>- Build three new 13.2 kV feeder circuits and reconfigure 13.2 kV system - LIBERTY</li> </ul>	\$2.80 M	\$6.82 M	<b>Part 1 Total \$9.62 M</b>	<ul style="list-style-type: none"> <li>- Adds capacity to the system to address the Spicket River contingency.</li> <li>- Minimizes dependency on NGRID for 23 kV support</li> </ul>	<ul style="list-style-type: none"> <li>- Requires extension of NGRID's 115 kV system</li> <li>- Permitting required for a 115 kV extension</li> <li>- Acquisition of line and for a double ended station required</li> <li>- Long UG getaways required</li> </ul>	<p>Costs include \$1,300k/circuit for UG get-away (Approximately 4,000').</p> <p>There may be some cost savings with consolidating of duct banks, one per transformer.</p> <p>May require the reconductoring of 3,500' from 336 to 477 (\$225 k)</p>

**Eliminated - Additional distribution and transmission costs and construction challenges due to site location**

Liberty Utilities  
 Salem Area Study

Plan	Description	Required construction	Liberty Station Cost - \$M	Line Cost - \$M	Total Cost - \$M	Pro	Con	Comments
Olde Trolley Salem Depot Retirement Alternative 2	<b><u>New 115/13.2 Transformer at Olde Trolley Station Part 2</u></b> - 115 Kv Line #2 - T2 115/13.2 kV 33/44/55 MVA Xfmr With SN = 83.9 MVA, SE = 94.4 MVA - Four breaker position bus plus a bus tie breaker - Eliminate Salem Depot Station  NGRID responsible for the 115 kV equipment through the transformer secondary bushings. LIBERTY from the secondary taps out.	- Build second 115 kV line extension - NGRID - Build and install second Ckt Sw and Transformer at the new Olde Trolley Sta - NGRID  -Install secondary breaker and 13.2 kV bus with four feeders breakers and a tie breaker at Olde Trolley Sta - LIBERTY - Build three new 13.2 kV feeder circuits and reconfigure 13.2 kV system - LIBERTY	\$3.00 M	\$4.11 M	Part 2 total = \$7.11 M	- Provides a robust and redundant supply system - Allows for the retirement of Salem Depot Sta - Adds operational flexibility - Adds 13.2 kV load capacity	- Requires extension of NGRID's 115 kV system -Permitting required for a 115 kV extension - Acquisition of the land for a double ended station required - Utilizes new capacity to replace existing capacity - Rockingham Park load will require three breaker positions (two left available), will require additional reconfiguration of the 13.2 kV system - Long UG get-ways required	Costs include \$1,300k/circuit for UG get-away (Approximately 4,000'). There may be some cost savings with consolidating of duct banks, one per transformer.
					Project Total = \$16.73 M			

Eliminated - Additional distribution and transmission costs and construction challenges due to site location



Liberty Utilities  
 Salem Area Study

Plan	Description	Required construction	Liberty Station Cost - \$M	Line Cost - \$M	Total Cost - \$M	Pro	Con	Comments
Olde Trolley Baron Ave Retirement Alternative	<p><b>New 115/13.2 Transformer at Olde Trolley Station Part 1</b></p> <ul style="list-style-type: none"> <li>- 115 Kv Line #1</li> <li>- T1 115/13.2 kV 33/44/55 MVA Xfmr With SN = 88.9 MVA SE = 94.4 MVA</li> <li>- Four breaker position bus</li> <li>- Build three new 13.2 kV feeder circuits</li> </ul> <p>NGRID responsible for the 115 kV equipment through the transformer secondary bushings. LIBERTY from the secondary taps out.</p>	<ul style="list-style-type: none"> <li>- Build first 115 kV line extension - NGRID</li> <li>- Build and install first Ckt Sw and Transformer at the new Olde Trolley Station - NGRID</li> <li>- Install secondary breaker and 13.2 kV bus with four feeder breakers at Olde Trolley Station - LIBERTY</li> <li>- Build three new 13.2 kV feeder circuits and reconfigure 13.2 kV system - LIBERTY</li> </ul>	\$2.80 M	\$7.35M	<b>Part 1 Total \$10.15 M</b>	<ul style="list-style-type: none"> <li>- Adds capacity to the system to address the Spicket River contingency.</li> <li>- Minimizes dependency on NGRID for 23 kV support</li> </ul>	<ul style="list-style-type: none"> <li>- Requires extension of NGRID's 115 kV system</li> <li>- Permitting required for a 115 kV extension</li> <li>- Acquisition of the land for a double ended station required</li> <li>- Long UG getaways required</li> </ul>	<p>Costs include \$1,300k/circuit for UG get-away (Approximately 4,000').</p> <p>There may be some cost savings with consolidating of duct banks, one per transformer.</p> <p>May require the reconductoring of 3,500' from 336 to 477 (\$225 k)</p>

Eliminated - Additional distribution and transmission costs and construction challenges due to site location

Liberty Utilities  
 Salem Area Study

Plan	Description	Required construction	Liberty Station Cost - \$M	Line Cost - \$M	Total Cost - \$M	Pro	Con	Comments
Olde Trolley Baron Ave Retirement Alternative 2	<p><b><u>New 115/13.2 Transformer at Olde Trolley Station Part 2</u></b></p> <ul style="list-style-type: none"> <li>- 115 Kv Line #2</li> <li>- T2 115/13.2 kV 33/44/55 MVA Xfmr With SN = 83.9 MVA, 85 = 84.4 MVA</li> <li>- Four breaker position bus plus a bus tie breaker</li> <li>- Eliminate Baron Ave Station</li> </ul> <p>NGRID responsible for the 115 kV equipment through the transformer secondary bushings. LIBERTY from the secondary taps out.</p>	<ul style="list-style-type: none"> <li>- Build second 115 kV line extension - NGRID</li> <li>- Build and install second Ckt Sw and Transformer at the new Olde Trolley Station - NGRID</li> <li>- Install secondary breaker and 13.2 kV bus with four feeders breakers and a tie breaker at Olde Trolley Station - LIBERTY</li> <li>- Build three new 13.2 kV feeder circuits and reconfigure 13.2 kV system - LIBERTY</li> </ul>	\$3.00 M	\$5.55 M	<p><b>Part 2 Total \$8.55 M</b></p> <p><b>Project Total = \$18.79 M</b></p>	<ul style="list-style-type: none"> <li>- Provides a robust and redundant supply system</li> <li>- Allows for the retirement of Baron Ave Sta</li> <li>- Adds operational flexibility</li> <li>- Adds 13.2 kV load capacity</li> </ul>	<ul style="list-style-type: none"> <li>- Requires extension of NGRID's 115 kV system</li> <li>- Permitting required for a 115 kV extension</li> <li>- Acquisition of the land for a double ended station required</li> <li>- Utilizes new capacity to replace existing capacity</li> <li>- Rockingham Park load will require three breaker positions (two left available), will require additional reconfiguration of the 13.2 kV system</li> <li>- Long UG get-ways required</li> </ul>	<p>Costs include \$1,300k/circuit for UG get-away (Approximately 4,000').</p> <p>There may be some cost savings with consolidating of duct banks, one per transformer.</p>

Eliminated - Additional distribution and transmission costs and construction challenges due to site location



Liberty Utilities  
 Salem Area Study

Plan	Description	Required construction	Liberty Station Cost - \$M	Line Cost - \$M	Total Cost - \$M	Pro	Con	Comments
Spicket River Sta	<p><b><u>New 115/13.2 Transformer at Spicket River Station</u></b></p> <ul style="list-style-type: none"> <li>- 115 Kv Line</li> <li>- 115/13.2 kV 33/44/55 MVA Xfmr</li> <li>With SN = 83.9 MVA, SE = 94.4 MVA</li> <li>- Four breaker position bus</li> <li>- Build three new feeder circuits</li> </ul> <p>NGRID responsible for the 115 kV equipment through the transformer secondary bushings.                      LIBERTY from the secondary taps out.</p>	<ul style="list-style-type: none"> <li>- Build 115 kV line extension - NGRID</li> <li>- Build and install Ckt Sw and Transformer at the Spicket River Station - NGRID</li> <li>- Install secondary breaker and 13.2 kV bus with four feeder breakers at Spicket River Station - LIBERTY</li> <li>- Build three new 13.2 kV feeder get-ways and supply the existing 13.2 kV system - LIBERTY</li> </ul>	\$3.05 M	\$0.90 M	<b>\$3.95 M</b>	<ul style="list-style-type: none"> <li>- Provides a robust and redundant supply system</li> <li>- Adds operational flexibility</li> <li>- Adds 13.2 kV load capacity</li> <li>- Addresses Spicket River Contingency</li> <li>- Utilizes Liberty's Existing land for Station</li> <li>- Minimizes reliance on the NGRID 23 kV</li> </ul>	<ul style="list-style-type: none"> <li>- Requires extension of NGRID's 115 kV system</li> <li>- Permitting required for a 115 kV extension</li> <li>- Extensive 13.2 kV distribution construction required to get the added capacity to the system's load centers</li> <li>- Requires the existing facilities at Spicket River to be maintained to cover contingency outage.</li> <li>- Does not address the loading and condition concerns at the Salem Depot and Baron Ave Stations.</li> </ul>	

Eliminated added capacity is too far from load centers to be practicable

**Appendix B Alternate Plan One-Lines**

**Figure 31 Alternate Plan One Golden Rock Station One-line Phase One**





Figure 32 Alternate Plan One Spicket River Station Upgrade One-line Phase One





Liberty Utilities  
 Salem Area Study



Figure 33 Alternate Plan One 23 kV One-line Phase One




Figure 34 Alternate Plan Two New Golden Rock 115/13.2 kV Station Phase One






Figure 35 Alternate Plan Two Upgrades to Spicket River Station Phase One






Figure 36 Alternate Plan Two 23 kV One-line Phase One






Note that only one-lines that are different from Alternate Plan Five are shown. Refer to Alternate Plan Five One-Lines for all other drawings.  
**Figure 37 Alternate Plan Three New Golden Rock 115/13.2 kV Station Phase One**





Liberty Utilities  
 Salem Area Study


Figure 38 Alternate Plan Three New Golden Rock 13.2kV Distribution Circuit Tie Map Phase One






Liberty Utilities  
 Salem Area Study

Figure 39 Alternate Plan Three New Golden Rock 13.2kV Distribution Circuit 19L8 Phase One






Note that only one-lines that are different from Alternate Plan Five are shown. Refer to Alternate Plan Five One-Lines for all other drawings.  
**Figure 40 Alternate Plan Three New Golden Rock 23kV Line Relocation South Broadway Phase Two**






Liberty Utilities  
Salem Area Study

Figure 41 Alternate Plan Three New Rockingham 13.2kV Distribution Circuit Tie Map Phase Two





Note that only one-lines that are different from Alternate Plan Five are shown. Refer to Alternate Plan Five One-Lines for all other drawings.  
**Figure 42 Alternate Plan Three New Golden Rock 13.2kV Distribution Circuit 19L1 Phase Three**





Liberty Utilities  
 Salem Area Study

Figure 43 Alternate Plan Three New Golden Rock 13.2kV Distribution Circuit 19L3 Phase Three







Figure 44 Alternate Plan Three New Golden Rock 13.2kV Distribution Circuit 19L5 Phase Three





Liberty Utilities  
Salem Area Study

Figure 45 Alternate Plan Three New Golden Rock 13.2kV Distribution Circuit Tie Map Phase Three





Figure 46 Alternate Plan Four New Golden Rock 13.2kV Station Arrangement Phase One






Liberty Utilities  
Salem Area Study

Docket No. DE 21-004  
Attachment DOE 10-1.e.1  
Page 154 of 218

Figure 47 Alternate Plan Four New Golden Rock 13.2kV Distribution Circuit Tie Map Phase One





**Figure 48 Alternate Plan Four New Rockingham 13.2kV Station Arrangement Phase Two**






Figure 49 Alternate Plan Four New Rockingham 13.2kV Distribution Circuit Tie Map Phase Two







Figure 50 Alternate Plan Four New Rockingham 13.2kV Station Arrangement Phase Three



Liberty Utilities  
Salem Area Study

Docket No. DE 21-004  
Attachment DOE 10-1.e.1  
Page 158 of 218

Figure 51 Alternate Plan Four New Rockingham 13.2kV Distribution Circuit Tie Map Phase Three






Figure 52 Alternate Plan Five Phase One Golden Rock Station Proposed Layout





Liberty Utilities  
 Salem Area Study


Figure 53 Alternate Plan Five Phase One Golden Rock Station Arrangement



Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 161 of 218


Figure 54 Alternate Plan Five Phase One Golden Rock 13.2 kV Station One-Line





Liberty Utilities  
 Salem Area Study


Figure 55 Alternate Plan Five Phase One Golden Rock 13.2 kV Distribution Circuit Tie Map






Liberty Utilities  
 Salem Area Study

Figure 56 Alternate Plan Five Phase One Golden Rock 13.2 kV 19L2 Distribution Circuit





**Figure 57 Alternate Plan Five Phase One Golden Rock 13.2 kV 19L4 Distribution Circuit**





Liberty Utilities  
Salem Area Study

Figure 58 Alternate Plan Five Phase One Golden Rock 13.2 kV 19L6 Distribution Circuit








Figure 59 Alternate Plan Five Phase One Golden Rock Underground Civil Construction



**Figure 60 Alternate Plan Five Phase Two Rockingham Station Proposed Layout**






Liberty Utilities  
 Salem Area Study


Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 168 of 218

Figure 61 Alternate Plan Five Phase Two Rockingham Station One-Line



Liberty Utilities  
 Salem Area Study


Figure 62 Alternate Plan Five Phase Two Rockingham 13.2 kV Distribution Circuit Tie Map





Liberty Utilities  
 Salem Area Study


Figure 63 Alternate Plan Five Phase Two Rockingham 13.2 kV Underground Cable Getaways





Liberty Utilities  
Salem Area Study

Figure 64 Alternate Plan Five Phase Two Rockingham 13.2 kV 21L1 Distribution Circuit





**Figure 65 Alternate Plan Five Phase Two Rockingham 13.2 kV 21L2 Distribution Circuit**






Figure 66 Alternate Plan Five Phase Two Rockingham 13.2 kV 21L3 Distribution Circuit








Figure 67 Alternate Plan Five Phase Two Rockingham 13.2 kV 21L4 Distribution Circuit





Liberty Utilities  
Salem Area Study


Figure 68 Alternate Plan Five Phase Two Rockingham 13.2 kV 21L5 Distribution Circuit





Liberty Utilities  
 Salem Area Study

Figure 69 Alternate Plan Five Phase Two Rockingham 13.2 kV 21L6 Distribution Circuit



Liberty Utilities  
 Salem Area Study

Figure 70 Alternate Plan Five Phase Two Rockingham 13.2 kV 21L5 and 21L6 Distribution Circuits







Figure 71 Alternate Plan Five Phase Two Golden Rock 13.2 kV 19L4 Distribution Circuit





**Figure 72 Alternate Plan Five Phase Two Proposed South Broadway Underground Conduit System**





Figure 73 Alternate Plan Five Phase Three Proposed Golden Rock Station Proposed Layout






Liberty Utilities  
 Salem Area Study

Docket No. DE 21-004  
 Attachment DOE 10-1.e.1  
 Page 181 of 218


Figure 74 Alternate Plan Five Phase Three Proposed Golden Rock Station One-Line





Liberty Utilities  
 Salem Area Study


**Figure 75 Alternate Plan Five Phase Three Golden Rock 13.2 kV Distribution Circuit Tie Map**





Liberty Utilities  
 Salem Area Study


Figure 76 Alternate Plan Five Phase Three Proposed Golden Rock 13.2 kV 19L1 Distribution Circuit





Liberty Utilities  
 Salem Area Study


Figure 77 Alternate Plan Five Phase Three Proposed Golden Rock 13.2 kV 19L3 Distribution Circuit





Liberty Utilities  
 Salem Area Study

Figure 78 Alternate Plan Five Phase Three Proposed Golden Rock 13.2 kV 19L5 Distribution Circuit



Liberty Utilities  
 Salem Area Study

### Appendix C Distribution Estimates

The following estimates do not reflect any 115 kV Transmission Supply costs, as those will be developed by National Grid. Distribution Estimates are based on the following:

<i>Description OH</i>	<i>Cost Each</i>	<i>Qualifier</i>
<i>13.2 kV over/under build street per ft.</i>	\$85	Extensive plant rebuild
<i>13.2 kV over/under build ROW per ft.</i>	\$100	Extensive plant rebuild
<i>13.2 KV reconductor to 477 open wire per ft.</i>	\$65	Replace ~ 1/2 poles
<i>13.2 KV reconductor to 477 spacer cable per ft.</i>	\$85	Replace ~ 1/2 poles
<i>13.2 KV new construction 477 open wire per ft.</i>	\$47	New poles and cross arms
<i>13.2 KV new construction 477 spacer cable per ft.</i>	\$70	New poles
<i>13.2 kV new 477 spacer cable double circuit per ft.</i>	\$104	New poles
<i>13.2 kV add 477 spacer cable for double circuit per ft.</i>	\$47	Existing built for double circuit
<i>23 kV over/under build ROW &amp; street per ft.</i>	\$144	New poles
<i>23 kV regular new construction per ft.</i>	\$85	New poles
<i>23 kV add 1113 ACSR for double circuit per ft.</i>	\$65	Existing built for over/under
<i>Load break Switch</i>	\$20,000	Upgrade pole
<i>Recloser</i>	\$70,000	Upgrade pole

**Table 41 Investment Grade Overhead Distribution Estimates**

<i>Description UG</i>	<i>Cost Each</i>
<i>1000 MCM CU - per Ckt mile</i>	\$840
<i>3 X 3, 6" duct and Manhole system, Manhole every 500' per mile</i>	\$2,507
<i>4 X 3, 6" duct and Manhole system, Manhole every 500' per mile - City</i>	\$1,900
<i>Padmounted SCADA controlled SWGR</i>	\$100
<i>4 X 3, 6" duct and Manhole system, Manhole every 500' per mile - Country</i>	\$900

**Table 42 Investment Grade Underground Distribution Estimates**

Liberty Utilities  
 Salem Area Study

<b>Description Substation</b>	<b>Cost Each (\$k)</b>
<i>Feeder Breaker 1200 Amp</i>	\$50
<i>Relay Package</i>	\$15
<i>Secondary Breaker 2000 Amp</i>	\$65
<i>Tie Breaker 2000 Amp</i>	\$65
<i>Auto Transfer</i>	\$120
<i>Secondary Bus</i>	\$150
<i>Civil Site Prep</i>	\$75
<i>Civil Foundations</i>	\$150
<i>Civil Conduit</i>	\$70
<i>Civil UG Getaway Conduit &amp; Manholes</i>	\$250
<i>Ground Grid</i>	\$100
<i>SCADA</i>	\$125
<i>Battery System</i>	\$30
<i>Control House</i>	\$30
<i>Additional Land Purchase</i>	\$100

**Table 43 Investment Grade Substation Distribution Estimates**

**Appendix D Recommended Plan Project Schedules**

<b>Phase 1 Project Milestones</b>	<b>Target Date: (Month/Year)</b>
<b>Start Preliminary Engineering</b>	January 2017
Engineering Design Complete	<i>August 2017</i>
<b>Project Sanction</b>	September 2017
<b>Construction Start</b>	November 2017



Liberty Utilities  
 Salem Area Study

<b>Phase 1 Project Milestones</b>	<b>Target Date: (Month/Year)</b>
<b>Construction Complete</b>	July 2018
<b>Ready for Load</b>	July 2018
<b>Project Closure</b>	December 2018

***Table 44 Phase 1 - Golden Rock #19 Project Schedule***

<b>Phase 2 Project Milestones</b>	<b>Target Date: (Month/Year)</b>
<b>Start Preliminary Engineering</b>	September 2017
Engineering Design Complete	<i>May 2018</i>
<b>Project Sanction</b>	June 2018
<b>Construction Start</b>	August 2018
<b>Construction Complete</b>	July 2019
<b>Ready for Load</b>	July 2019
<b>Project Closure</b>	December 2019

***Table 45 Phase 2 – Rockingham #21 Project Schedule***

<b>Phase 3 Project Milestones</b>	<b>Target Date: (Month/Year)</b>
<b>Start Preliminary Engineering</b>	July 2020
Engineering Design Complete	<i>June 2021</i>
<b>Project Sanction</b>	August 2021
<b>Construction Start</b>	October 2021
<b>Construction Complete</b>	October 2022
<b>Ready for Load</b>	October 2022
<b>Project Closure</b>	April 2023

***Table 46 Phase 3 – Golden Rock#19 Project Schedule***

**Appendix D Asset Condition Reports**

**Asset Condition Report – Golden Rock 19**



**O&M Services**

**Date: August 17, 2006**

**Purpose**

The document is developed to assess the condition of the Golden Rock 19 Substation located in Salem New Hampshire.

**Asset Health Summary**

Asset	Average Age	Condition Description	Rating
#1 Transformer	5	Acceptable	
1T115 CS	5	Acceptable	
23kV Line VCB's	5	Acceptable	
23kV C1 VCB	5	Acceptable	
23kV C3 VS	5	Acceptable	
23kV Disconnects	5	Acceptable	
23kV Cables	5	Acceptable	
Station Battery	5	Acceptable	
Safety Component Station Design		Acceptable	
Environmental Component		Acceptable	

**Definitions of Asset Health Summary Rating**

Rating	Rating Description
Green	No condition issues found and equipment is likely to operate as designed for the next ten years. Safety/Environmental rating is less than or equal to one
Yellow	Equipment showing signs of deterioration or significant family trouble history. Above average resources will be expended on the equipment over the next ten years. Safety/Environmental rating is equal to 2
Red	Equipment is likely to fail or will require to be replaced over the next five years. No support remains to perform required maintenance on equipment. Safety/Environmental rating is greater than or equal to 3


**Overall Recommendation**

The condition of all equipment in the station is acceptable.

**Asset Condition Report – Golden Rock 19**

nationalgrid  
**Draft**

**O&M Services  
 One-Line**



**Specific Equipment Information - #1 Transformer**

**Equipment Information**

Operating Position	App Type	Mfr	Ref #	S/N	Volts (kV)	MVA	Family Population	Date Mfr
#1	Trans	PT	023425	C-07529-5-1	115-23	33/44/55	1	7/01

**Oil and Insulation Quality**

Dissolved Gas	Oil Quality	Paper Insulation
Normal	Normal	Normal

**Transformer Asset Condition Review**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal		Supported	0	0





**Asset Condition Report – Golden Rock 19**

**O&M Services**

**Recommendation - Transformer**

The present condition and of the transformer is acceptable.

**Specific Equipment Information – 115kV Circuit Switcher**

**Equipment Information**

Operating Position	App Type	Mfr	Ref #	S/N	(kV)	Amps	Date Mfr
1T115	2010	S&C	096262	00-18781	115	1200	3/01

**Recommendation – 115kV Circuit Switcher**

The present condition and of the device is acceptable.

**Specific Equipment Information – 2393, 93-76, 2352, 52-53 VCB**

**Equipment Information**

Operating Position	App Type	Mfr	Type	Ref #	S/N	(kV)	Amps	Date Mfr
2352	VCB	GE	PVDB2 25.8-20-0	017041	0357A7233-001-03	28.5	2000	3/01
2393	VCB	GE	PVDB2 25.8-20-0	017042	0357A7233-001-02	28.5	2000	3/01
93-76	VCB	GE	PVDB2 25.8-20-0	017043	0357A7233-001-01	28.5	2000	3/01
5253	VCB	GE	PVDB2 25.8-20-0	017044	0357A7233-001-04	28.5	2000	3/01

**Asset Condition Review**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – 23kV Line Breakers**

The present condition and of the breakers are acceptable.

**Specific Equipment Information – C1 VCB**

**Equipment Information**

Operating Position	App Type	Mfr	Type	Ref #	S/N	(kV)	Amps	Date Mfr
C1	VCB	S&C	FVR2121520A	017281	17-15252	27	1200	12/01

Draft

**Asset Condition Report – Golden Rock 19**

**O&M Services**

**Asset Condition Review**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – C1 VCB**

On January 17, 2005 the breaker failed and was replaced. Cause of failure was a faulty gasket. The condition of all equipment in the station is acceptable.

**Specific Equipment Information – C3 VS**

**Equipment Information**

Operating Position	App Type	Mfr	Type	Ref #	S/N	(kV)	Amps	Date Mfr
C3	VBM	JOS	VBM	017282	AH010360	23	300	12/01

**Asset Condition Review**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – C3 VS**

The present condition and of the switch is acceptable.

**Specific Equipment Information – 23kV Disconnects**

Asset Condition Rating (Thermovision)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – 23kV Disconnects**

The Royal disconnects are acceptable.

**Asset Condition Report – Golden Rock 19**



**O&M Services**

**Specific Equipment Information – 23kV Feeder Cables**

**Asset Condition Rating and Safety (BIT - Budget Impact Tool) Scoring**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – 23kV Feeder Cables**

The cables are acceptable

---

**Specific Equipment Information – Battery**

**Control House Asset Condition Review**

The battery is acceptable.

---

**Documented Outages 2001 to Present**

Designation	Ref#	Date	Condition comment	CI	CMI
Bus PT	None	7/25/05	23kV bus pot failure	8486	129600
C1 CVB	017281	1/17/05	VCB failure	0	0

---

**Safety Rating Summary**

Equipment ID	Severity	Occurrence	Detection	Score	Risk
#1 Trans	2	2	2	8	No Impact
Breakers	2	2	2	8	No Impact
Disconnects	2	2	2	8	No Impact
Cables	2	2	2	8	No Impact

---

**Environmental Rating Summary**

Equipment ID	PCB	Severity	Occurrence	Detection	Score	Risk
#1 Trans	2	2	2	2	8	No Impact


---



Asset Condition Report – Golden Rock 19

O&M Services  
Oil Analysis

nationalgrid  
**Draft**



**Asset Condition Report – Olde Trolley 18**



**O&M Services**

**Date: August 26, 2006**

**Purpose**

The document is developed to assess the condition of the Olde Trolley #18 Substation located in Salem New Hampshire.

**Asset Health Summary**

Asset	Average Age	Condition Description	Rating
18L1 Transformer	15	The equipment condition is acceptable.	Green
18L2 Transformer	5	The equipment condition is acceptable.	Green
18L3 Transformer	new	The equipment condition is acceptable.	Green
18L4 Transformer	new	The equipment condition is acceptable.	Green
18L1 Recloser	15	The equipment condition is acceptable.	Green
18L2 Recloser	5	The equipment condition is acceptable.	Green
18L3 & 18L4 Recloser	new	The equipment condition is acceptable.	Green
18L1 Regulators	15	The 18L1 B phase regulator failed and was replaced. 18L2 A and C phase regulator tanks are severely rusted. The regulators will require replacement with 10 years.	Yellow
18L2 Regulators	5	The equipment condition is acceptable.	Green
18L3 & 18L4 Regulators	new	The equipment condition is acceptable.	Green
13kV Disconnects	15	The equipment condition is acceptable.	Green
23kV Airbreaks	15	The equipment condition is acceptable.	Green
Battery	15	The equipment condition is acceptable.	Green
Safety Component Station Design		The height of the 18L1 cables should be reviewed to determine if barriers are needed. There are no other safety related issues.	Yellow
Environmental Component		No environmental impacts	Green

**Definitions of Asset Health Summary Rating**

Rating	Rating Description
Green	No condition issues found and equipment is likely to operate as designed for the next ten years. Safety/Environmental rating is less than or equal to one
Yellow	Equipment showing signs of deterioration or significant family trouble history. Above average resources will be expended on the equipment over the next ten years. Safety/Environmental rating is equal to 2
Red	Equipment is likely to fail or will require to be replaced over the next five years. No support remains to perform required maintenance on equipment. Safety/Environmental rating is greater than or equal to 3

Draft

## Asset Condition Report – Olde Trolley 18

### O&M Services

#### Overall Recommendation (Based on Specific Equipment Information)

##### 18L1 Transformer

The equipment condition is acceptable.

##### 18L2 Transformer

The equipment condition is acceptable.

##### 18L3 and 18L4 Transformer

The equipment condition is acceptable.

##### 18L1 Recloser

The equipment condition is acceptable.

##### 18L2 Recloser

The equipment condition is acceptable.

##### 18L3 and 18L4 Recloser

The equipment condition is acceptable.

##### 18L1 Regulator

The 18L1 B phase regulator failed and was replaced. 18L2 A and C phase regulator tanks are severely rusted. The regulators will require replacement with 10 years.

##### 18L2 Regulator

The equipment condition is acceptable.

##### 18L3 and 18L4 Regulator

The equipment condition is acceptable.

##### 13kV Disconnects

The equipment condition is acceptable.


##### 23kV Airbreaks

The equipment condition is acceptable.

##### Battery

The equipment condition is acceptable.

### One-Line





**Asset Condition Report – Olde Trolley 18**



**O&M Services**

**Specific Equipment Information – 18L1 Transformer**

**Equipment Information**

Operating Position	App Type	Mfr	Ref #	S/N	Volts (kV)	MVA	Family Population	Date Mfr
18L1	Transformer	FPE	023298	S-15086-01	22.9-13.2	7.5/9.375	9 inservice and 0 failure	1991

**Oil and Insulation Quality**

Dissolved Gas	Oil Quality	Paper Insulation
Normal	Normal	Normal

**Transformer Asset Condition Review**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

Date	Trouble Condition
4/11/01	Found bad H2 PRC bushing – replaced with O+C

**Recommendation – 18L1 Transformer**

The present condition of the transformer is acceptable.

**Specific Equipment Information – 18L2, 18L3, 18L4 Transformer**

**Equipment Information**

Operating Position	App Type	Mfr	Ref #	S/N	Volts (kV)	MVA	Family Population	Date Mfr
18L2	Trans	ABB	023451	HA08862-001	22.9-13.2	7.5/9.375	22 inservice and 0 failure	2001
18L3	Trans	ABB	023452	HA19192-001	22.9-13.2	7.5/9.375	22 inservice and 0 failure	2005
18L4	Trans	ABB	023453	HA19192-002	22.9-13.2	7.5/9.375	22 inservice and 0 failure	2005

**Oil and Insulation Quality**

Dissolved Gas	Oil Quality	Paper Insulation
Normal	Normal	Normal

**Asset Condition Report – Olde Trolley 18**



**O&M Services**

**Transformer Asset Condition Review**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – 18L2, 18L3, 18L4 Transformer**

The present condition of the transformers are acceptable.

**Specific Equipment Information – 18L1 VCR and 18L2,L3,L4 VCB**

**Equipment Information**

Operating Position	App Type	Mfr	Type	Ref #	S/N	(kV)	Amps	Family Population	Date Mfr
18L1	VCR	CP	VSA	015015	219	15	800	9 in-service	1991
18L2	VCB	SC	FVR1121 120A	017074	17- 14919	15	1200	114 in-service	2001
18L3	VCB	SC	FVR1121 120A			15	1200	114 in-service	2006
18L4	VCB	SC	FVR1121 120A			15	1200	114 in-service	2006

**Asset Condition Review L1,L2,L3,L4**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Trouble History**

Ref#	Date	Trouble Condition
015015	6/8/97	Squirrel contact – replaced all six bushings
015015	4/11/01	Breaker did not trip – found defective battery

**Recommendation – Circuit Reclosers**

The equipment condition is acceptable.

**Specific Equipment Information – 18L1, 18L2, 18L3, 18L4 Regulators**

**Equipment Information**

Operating Position	Mfr	Type	Counter	Ref #	(kV)	KVA	Date Mfr
13L1-A	GE	VR-1	180594	044076	15	333	1/91
13L1-B	GE	VR-1	19135	044077	15	333	1/00
13L1-C	GE	VR-1	203098	044078	15	333	1/91
13L2-A	GE	VR-1	35002	045017	15	333	1/01
13L2-B	GE	VR-1	33808	045057	15	333	1/01

**Asset Condition Report – Olde Trolley 18**



**O&M Services**

Operating Position	Mfr	Type	Counter	Ref #	(kV)	KVA	Date Mfr
13L2-C	GE	VR-1	34157	045058	15	333	1/01
13L3-A	GE	VR-1	New		15	333	1/06
13L3-B	GE	VR-1	New		15	333	1/06
13L3-C	GE	VR-1	New		15	333	1/06
13L4-A	GE	VR-1	New		15	333	1/06
13L4-B	GE	VR-1	New		15	333	1/06
13L4-C	GE	VR-1	New		15	333	1/06

**Asset Condition Review Regulators**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – Regulators**

The 18L1 B phase regulator failed and was replaced. 18L2 A and C phase regulator tanks are severely rusted. The regulators will require replacement with 10 years. All other regulators are acceptable.

**Specific Equipment Information – 13kV Disconnects**

**13kV Disconnect Asset Condition Review**

The equipment condition is acceptable.

**Specific Equipment Information – 23kV Airbreaks**

**23kV Airbreak Asset Condition Review**

The equipment condition is acceptable.

**Specific Equipment Information – Battery**

**Battery Asset Condition Review**

The equipment condition is acceptable.

**Documented Outages 1990 to Present**

Designation	Ref#	Date	Condition comment	CI	CMI
Transmission		2/1/93	Loss of supply	2348	56280
Transmission		12/6/96	Loss of supply	142	15300
18L1	015015	6/8/97	Squirrel on recloser	142	14940
Station		7/21/97	Squirrel	140	2820
23kV Fault		8/14/97	Loss of sub-transmission to repair guy wire on 23kV line	140	2820
Transmission		6/15/98	Loss of supply	145	15960
Station		9/3/98	Squirrel	141	660





**Asset Condition Report – Olde Trolley 18**

**O&M Services**

Station		12/20/03	Squirrel	141	2400
Transmission		7/25/05	Loss of supply	1054	33000


**Safety Rating Summary**

Equipment ID	Severity	Occurrence	Detection	Score	Risk
Trans	2	2	2	8	No Impact
Breakers	2	2	2	8	No Impact
Regulators	2	2	2	8	No Impact
L1 Cable	10	4	10	400	High Impact

**Environmental Rating Summary**

Equipment ID	PCB	Severity	Occurrence	Detection	Score	Risk
Trans	non	2	2	2	8	No Impact


**Oil Analysis**



**Asset Condition Report – Olde Trolley 18**



**O&M Services**



**Photos**



**18L1 Regulators**

**Asset Condition Report – Olde Trolley 18**

**O&M Services**

national  
**Draft**



**18L1 Regulators and relationship to cables**



**Asset Condition Report – Barron Ave 10**



**O&M Services**

**Date: August 26, 2006**

**Purpose**

The document is developed to assess the condition of the Barron Ave #10 Substation located in Salem New Hampshire.

**Asset Health Summary**

Asset	Average Age	Condition Description	Rating
10L1 Transformer	44	The bushings installed had a high power factor – the transformer should be re-tested. <b>If the bushings are tested normal, the condition can be changed to acceptable.</b>	Yellow
10L2 Transformer	4	The present condition and of the transformer is acceptable. This transformer was installed due to a failure of a GE transformer. It looks like the protection did not get upgraded with the new equipment that was installed.	Green
10L4 Transformer	35	The present condition of the transformer is acceptable	Green
10L1 Recloser	32	The 10L1 has a higher than normal failure rate, however, its current condition is acceptable. It has a form 3A control and the current interchange should be replaced to improve reliability. Refer to replacement policy EOP 401.41.1	Yellow
10L2 Recloser	3	The equipment condition is acceptable.	Green
10L4 Recloser	36	86 in-service 40 retired. These units are no longer supported with spare parts and the controls have a high failure rate. Refer to replacement policy EOP 401.40.1	Red
C1 Switch	19	The equipment condition is acceptable.	Green
10L1 Regulators	18	The equipment condition is acceptable.	Green
10L2 Regulators	5	The equipment condition is acceptable.	Green
10L4 Regulators	25	The L4 regulator contacts are at end of life and the height to live parts are below NGrid new minimum height requirements. It is recommended that the regulators be replaced.	Red
13kV Disconnects	Misc	All original HPL disconnects have been replaced	Green
23kV Airbreaks	37	The mechanisms are reaching end of life	Yellow
Safety Component Station Design		10L4 regulator height to live parts are below NGrid new minimum height requirements.	Yellow
Environmental Component		There are no environmental concerns.	Green

**Definitions of Asset Health Summary Rating**

Rating	Rating Description
Green	No condition issues found and equipment is likely to operate as designed for the next ten years. Safety/Environmental rating is less than or equal to one
Yellow	Equipment showing signs of deterioration or significant family trouble history. Above average resources will be expended on the equipment over the next ten years. Safety/Environmental rating is equal to 2
Red	Equipment is likely to fail or will require to be replaced over the next five years. No support remains to perform required maintenance on equipment. Safety/Environmental rating is greater than or equal to 3

**Asset Condition Report – Barron Ave 10**

**O&M Services**



**Overall Recommendation (Based on Specific Equipment Information)**

**10L1 Transformer**

The bushings installed had a high power factor – the transformer should be re-tested. **If the bushings are tested normal, the condition can be changed to acceptable.**

**10L2 Transformer**

The present condition of the transformer is acceptable.

**10L4 Transformer**

The present condition of the transformer is acceptable.

**10L1 Recloser**

The 10L1 has a higher than normal failure rate, however, its current condition is acceptable. It has a form 3A control and the current interchange should be replaced to improve reliability. This recloser fits in the current VSA replacement policy.

**10L2 Recloser**

The equipment condition is acceptable.

**10L4 Recloser**

86 in-service 40 retired. These units are no longer supported with spare parts and the controls have a high failure rate. There is a current VIR replacement policy.

**C1 Switch**

The equipment condition is acceptable.

**10L1 Regulator**

The equipment condition is acceptable.

**10L2 Regulator**

The equipment condition is acceptable.

**10L4 Regulator**

The L4 regulator contacts are at end of life and the height to live parts are below NGrid new minimum height requirements. It is recommended that the regulators be replaced.

**13kV Disconnects**

The equipment condition is acceptable.


**23kV Airbreaks**

The mechanisms are reaching end of life

**Asset Condition Report – Barron Ave 10**



**O&M Services  
 One-Line**



**Specific Equipment Information – 10L1 Transformer**

**Equipment Information**

Operating Position	App Type	Mfr	Ref #	S/N	Volts (kV)	MVA	Family Population	Date Mfr
10L1	Trans	WE	020775	6993018	22.9-13.2	5/6.25	31 inservice and 2 failures	1962

**Oil and Insulation Quality**

Dissolved Gas	Oil Quality	Paper Insulation
Normal	None – PCB unknown	Normal

**Transformer Asset Condition Review**



**Asset Condition Report – Barron Ave 10**

**O&M Services**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0
Bushings have High PF						

Date	Trouble Condition
1/12/98	Squirrel caused damage to three bushings – replaced all three with used bushings with elevated PF
2/21/01	Transformer tripped due to squirrel contact on LV

**Recommendation – 10L1 Transformer**

The bushings installed had a high power factor – the transformer should be re-tested. **If the bushings are tested normal, the condition can be changed to acceptable.**

**Specific Equipment Information – 10L2 Transformer**

**Equipment Information**

Operating Position	App Type	Mfr	Ref #	S/N	Volts (kV)	MVA	Family Population	Date Mfr
10L2	Trans	ABB	024304	HA08863-002	22.9-13.2	7.5/9.375	22 inservice and 0 failures	2002

**Oil and Insulation Quality**

Dissolved Gas	Oil Quality	Paper Insulation
Normal	Normal – Non pcb	Normal

**Transformer Asset Condition Review**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – 10L2 Transformer**

The present condition and of the transformer is acceptable. This transformer was installed due to a failure of a GE transformer. It looks like the protection did not get upgraded with the new equipment that was installed.

**Specific Equipment Information – 10L4 Transformer**

**Equipment Information**

Operating Position	App Type	Mfr	Ref #	S/N	Volts (kV)	MVA	Family Population	Date Mfr
10L4	Trans	GE	021649	G-853504	22.9-13.2	5/6.25	28 inservice and 5 failures	1971

**Oil and Insulation Quality**

Dissolved Gas	Oil Quality	Paper Insulation
Normal	Normal – Non pcb	Normal

**Asset Condition Report – Barron Ave 10**



**O&M Services**

**Transformer Asset Condition Review**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	2x	Normal	Supported	0	0

Date	Trouble Condition
10/27/98	Replaced HV type U bushings
5/2/01	Bird contact caused trans to trip
2/21/01	Transformer tripped due to squirrel contact on LV

**Recommendation – 10L4 Transformer**

The present condition of the transformer is acceptable, however, has a high failure rate.

**Specific Equipment Information – Reclosers**

**Equipment Information**

Operating Position	App Type	Mfr	Type	Ref #	S/N	(kV)	Amps	Family Population	Date Mfr
10L1	VCR	ME	VSA	013800	1896	15	560		1974
10L2	VCR	CP	VSA-12	017563	3092	15	800		2003
10L3	VCR	GE	VIR	012036	0442A4460-201	15	560	86 in-service 40 retired	1969


**Asset Condition Review L1**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	2X Avg	Normal	Supported	1	0
		The VSA has a high failure rate	The unit has a Form 3A control			

**Asset Condition Review L2**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	1	0

**Asset Condition Report – Barron Ave 10**



**O&M Services**

**Asset Condition Review L3**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	5X Avg	Normal	Incompatible	1	0
		The controls have very poor reliability		GE no longer supports parts		

**Trouble History**

Ref#	Date	Trouble Condition
012036	8/27/01	While switching out – switch would not open
011146	6/3/03	Removed VIR switch because it was found defective – installed VSA

**Recommendation – Circuit Reclosers**

10L1 - Unit has a higher than normal failure rate, however, its current condition is acceptable. It has a form 3A control.

10L2 - The equipment condition is acceptable.

10L4- 86 in-service 40 retired. These units are no longer supported with spare parts and the controls have a high failure rate.

**Specific Equipment Information – Capacitor**

**Equipment Information**

Operating Position	App Type	Mfr	Type	Ref #	S/N	(kV)	Amps	Family Population	Date Mfr
C1	VS	JS	VBM	014701	AH-87040	34.5	400	108 in serv. 13 retired	1987
C1	VS	JS	VBM	014701	AH-87048	34.5	400	108 in serv. 13 retired	1987
C1	VS	JS	VBM	014701	AH-87041	34.5	400	108 in serv. 13 retired	1987

**Trouble History**

Date	Trouble Condition
8/14/95	Switch would not close – found bad relay in circuit
8/11/03	VCB would not close – found counter shorted and 89X1 relay welded closed – Replaced counter and relay

**Asset Condition Review C1**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – C1**

The equipment condition is acceptable.



**Asset Condition Report – Barron Ave 10**



**O&M Services**

**Specific Equipment Information – 10L1, 10L2, 10L4 Regulators**

**Equipment Information**

Operating Position	Mfr	Type	Counter	Ref #	(kV)	KVA	Date Mfr
10L1-A	GE	VR-1	43172	043606	15	250	1/88
10L1-B	GE	VR-1	163860	043607	15	250	1/88
10L1-C	GE	VR-1	186674	042792	15	250	1/88
10L2-A	GE	VR-1	52883	045112	15	333	1/01
10L2-B	GE	VR-1	10366	045227	15	333	1/01
10L2-C	GE	VR-1	52922	045059	15	333	1/01
10L4-A	GE	ML-32	232103	042766	15	250	6/77
10L4-B	GE	ML-32	202424	042768	15	250	6/77
10L4-C	GE	ML-32	255454	042767	15	250	6/77

**Asset Condition Review Regulators**

Asset Condition Rating (Diagnostic Tests)	Asset Condition Rating (Visual Inspection)	Asset Failure History (Similar Assets)	Operability Condition	State of Obsolescence	Safety Rating	Env. Rating
Normal	Normal	Normal	Normal	Supported	0	0

**Recommendation – Regulators**

- 10L1 - The equipment condition is acceptable.
- 10L2 - The equipment condition is acceptable.
- 10L4 - The L4 regulator contacts are at end of life and the height to live parts are below NGrid new minimum height requirements. It is recommended that the regulators be replaced.

**Specific Equipment Information – 13kV Disconnects**

**13kV Disconnect Asset Condition Review**

The equipment condition is acceptable.

**Specific Equipment Information – 23kV Airbreaks**

**Equipment Information**

Operating Position	App Type	Mfr	Type	Ref #	(kV)	Amps	Family Population	Date Mfr
2393	AB	ITE	MO9	095291	23	600		1962
52-93	AB	ITE	MO9	095290	23	600		1969
2352	AB	ITE	MO9	095352	23	600		1962

**23kV Airbreak Asset Condition Review**

The mechanisms are reaching end of life

**Asset Condition Report – Barron Ave 10**



**O&M Services**

**Documented Outages 1990 to Present**

Designation	Ref#	Date	Condition comment	CI	CMI
10L1		11/8/94	Squirrel on breaker	1862	65700
10L1		1/11/98	Squirrel in sub	1909	113940
10L1		3/7/98	Squirrel in sub	1903	118920
Loss of Supply		6/15/98	?	3944	322800
10L1		2/16/01	Squirrel	1652	109320
10L2		4/10/01	Squirrel	1065	20220
10L4		4/19/01	Mylar balloon	1065	6720
10L2 Trans		4/28/03	Transformer failure – replaced trans	454	31320
10L4		5/28/03	Bird on a transformer	2493	149580
Loss of Supply		7/25/05	Fault at Golden Rock	4252	55320

**Safety Rating Summary**

Equipment ID	Severity	Occurrence	Detection	Score	Risk
10L1 Trans	2	2	2	8	No Impact
10L2 Trans	2	2	2	8	No Impact
10L4 Trans	2	2	2	8	No Impact
Breakers	2	2	2	8	No Impact
10L1 Regs	2	2	2	8	No Impact
10L2 Regs	2	2	2	8	No Impact
10L4 Regs	6	6	4	144	Med Impact

**Environmental Rating Summary**



Equipment ID	PCB	Severity	Occurrence	Detection	Score	Risk
10L1 Trans	?	2	2	2	8	No Impact
10L2 Trans	non	2	2	2	8	No Impact
10L4 Trans	?	2	2	8	8	No Impact

**Oil Analysis**

**Asset Condition Report – Barron Ave 10**




**O&M Services**



**Asset Condition Report – Barron Ave 10**



**O&M Services**



**Photos**



**Asset Condition Report – Barron Ave 10**

Draft

**O&M Services**



*Asset Condition Report- Barron Ave 10*

**O&M Services**



national  
**Draft**

## United Power Group, Inc.

Liberty Utilities  
9 Lowell Road  
Salem, NH 03079

Date. 8/27/14  
Project No.

### **Project Location:**

Barron Ave. Substation

### **Scope:**

Perform testing & maintenance on the following equipment:

1. 10L1 Transformer
2. 10L1 Recloser and Form 3A Controller
3. 10L1 Voltage Regulators
4. Substation Perimeter Fence Grounding

### **Remarks:**

1. Transformer 10L1's bushings are showing signs of deterioration. UPG would like to see past test data for the transformer.  
The transformer is over 40 years old. UPG recommends retesting the transformer in 1 year to see if the condition worsens.
2. Recloser 10L1 and form 3A controller test results are acceptable for service.
3. Voltage regulators 10L1 test results are acceptable for service.
4. UPG was asked to inspect the ground on the perimeter fence. It was discovered that most of the fence was ungrounded;  
a 2-point test was used to find this issue. UPG recommends adding grounds to the fence posts and adding a ground wire along the chain link.

**Submitted by:** James Fazio



## United Power Group, Inc.

Liberty Utilities  
9 Lowell Road  
Salem, NH 03079

Date. 9/5/14  
Project No.

### **Project Location:**

Barron Ave. Substation

### **Scope:**

Perform testing & maintenance on the following equipment:

1. 10L2 Transformer
2. 10L2 Recloser and Form 6 Controller
3. 10L2 Voltage Regulators

### **Remarks:**

1. Transformer 10L2 test results are acceptable for service.
2. Breaker 10L2 initially would not close. The breaker would trip free. The breaker was cleaned and lubricated.  
After maintenance was performed the breaker was able to close. Periodically the 120 volt control circuit breaker would trip when the breaker operated. UPG recommends replacing the 20 amp control circuit breaker. If the issue continues, further investigation of the circuit breaker's operating mechanism should be performed.
3. Voltage regulators 10L2 test results are acceptable for service.

**Submitted by:** James Fazio



## United Power Group, Inc.

Liberty Utilities  
9 Lowell Road  
Salem, NH 03079

Date. 9/18/14  
Project No.

### **Project Location:**

Barron Ave. Substation

### **Scope:**

Perform testing & maintenance on the following equipment:

1. 10L4 Transformer
2. 10L4 Recloser and Form 6 Controller
3. 10L4 Voltage Regulators

### **Remarks:**

1. Transformer 10L4's X1 and X2 bushings are showing signs of deterioration. UPG would like to see past test data for the transformer. There is also signs of oil leaking around the bottom valve. A closer look will be taken when the oil sample is extracted.
2. Recloser 10L4 and form 6 controller test results are acceptable for service.
3. Voltage regulators 10L4 test results are acceptable for service.

**Submitted by:** James Fazio

**Project**

**Location:** Salem

Depot Substation

**Scope:**

Perform testing & maintenance on the following equipment:

1. Transformer 9T3
2. Transformer 9L1T
3. 9L3 Recloser and Form 6 Controller
4. 9L3 Voltage Regulators

**Remarks:**

1. Transformer 9T3's H3 bushing is showing signs of deterioration; the bushing's power factor value has doubled and needs to be replaced. The oil temperature and tank pressure gauges are in poor condition. UPG also recommends replacing both gauges.
2. Transformer 9L1T test results are acceptable for service.
3. Recloser 9L3 and form 6 controller test results are acceptable for service.
4. Voltage regulator 9L3 "A phase" stopped operating on the 15L tap. It was discovered that the limit switch located in the regulator tap indication gauge was misaligned. Adjustments were made and the regulator operated correctly. All other test results are acceptable.

**Submitted by:** James Fazio

REDACTED



## Salem Area Study 2020



Liberty Utilities  
System Planning  
Salem Area Study 2020

## Version History

<b>REV</b>	<b>DATE</b>	<b>Description</b>	<b>Prepared</b>	<b>Reviewed</b>
0	9/1/2020	Final for NHPUC Filing	ControlPoint Technologies	Liberty Utilities



Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Table of Contents**

<b>1.0</b>	<b>EXECUTIVE SUMMARY .....</b>	<b>8</b>
<b>2.0</b>	<b>INTRODUCTION.....</b>	<b>9</b>
2.1	PURPOSE.....	9
2.2	PROBLEM.....	9
<b>3.0</b>	<b>BACKGROUND.....</b>	<b>10</b>
3.1	GEOGRAPHIC SCOPE.....	10
3.2	ELECTRICAL SCOPE.....	11
3.3	LOAD AND LOAD FORECAST .....	12
3.4	MODELING AND CRITERIA.....	15
3.5	ACTIVE & COMPLETED PROJECTS .....	16
<b>4.0</b>	<b>PROBLEM IDENTIFICATION .....</b>	<b>17</b>
4.1	THERMAL LOADING – EXISTING VIOLATIONS.....	17
4.1.1	<i>Normal Configuration – based on 2019 peak loads .....</i>	<i>17</i>
4.1.2	<i>N-1 Contingency &amp; Load-At-Risk.....</i>	<i>17</i>
4.2	THERMAL LOADING – PREDICTED VIOLATIONS .....	19
4.2.1	<i>Normal Configuration.....</i>	<i>19</i>
4.2.2	<i>N-1 Contingency &amp; Load at Risk .....</i>	<i>20</i>
4.3	ASSET CONDITION .....	21
4.3.1	BARRON AVE SUBSTATION.....	21
4.3.2	SALEM DEPOT SUBSTATION .....	22
4.3.3	NEW 22.8 / 13.2 kV SUBSTATION CONSTRUCTION FEASIBILITY.....	23
4.4	POWER QUALITY & VOLTAGE PERFORMANCE .....	25
4.4.1	<i>Supply System Loss Comparison .....</i>	<i>25</i>
4.4.2	<i>13.2 kV Distribution System Loss Comparison.....</i>	<i>25</i>
4.4.3	<i>Power Quality – Existing Violations.....</i>	<i>26</i>
4.4.4	<i>Power Quality – Proposed Plans.....</i>	<i>26</i>
<b>5.0</b>	<b>PLAN DEVELOPMENT .....</b>	<b>27</b>
5.1	PLAN SUMMARY .....	27
<b>6.0</b>	<b>PLAN CONSIDERATIONS AND COMPARISONS.....</b>	<b>29</b>
6.1	PLAN ONE.....	30
6.1.1	<i>System Performance.....</i>	<i>30</i>
6.1.2	<i>Operability .....</i>	<i>30</i>
6.1.3	<i>Future Growth / Expansion Opportunities.....</i>	<i>31</i>
6.1.4	<i>Capacity Provided.....</i>	<i>31</i>
6.1.5	<i>Economic Comparison .....</i>	<i>31</i>
6.1.6	<i>Other Considerations.....</i>	<i>31</i>
6.2	PLAN TWO .....	32
6.2.1	<i>System Performance.....</i>	<i>32</i>
6.2.2	<i>Operability .....</i>	<i>32</i>
6.2.3	<i>Future Growth / Expansion Opportunities.....</i>	<i>33</i>
6.2.4	<i>Capacity Provided.....</i>	<i>33</i>
6.2.5	<i>Economic Comparison .....</i>	<i>33</i>
6.2.6	<i>Other Considerations.....</i>	<i>33</i>
6.3	PLAN THREE .....	34
6.3.1	<i>System Performance.....</i>	<i>34</i>

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

6.3.2	Operability .....	34
6.3.3	Future Growth / Expansion Opportunities.....	35
6.3.4	Capacity Provided.....	35
6.3.5	Economic Comparison .....	35
6.3.6	Other Considerations.....	35
6.4	PLAN FOUR.....	36
6.4.1	System Performance.....	36
6.4.2	Operability.....	36
6.4.3	Future Growth / Expansion Opportunities.....	36
6.4.4	Capacity Provided.....	36
6.4.5	Economic Comparison .....	36
6.4.6	Other Considerations.....	37
6.5	PLAN FIVE.....	37
6.5.1	System Performance.....	37
6.5.2	Operability.....	38
6.5.3	Future Growth / Expansion Opportunities.....	38
6.5.4	Capacity Provided.....	38
6.5.5	Economic Comparison .....	38
6.5.6	Other Considerations.....	39
6.6	PLAN SIX .....	39
6.6.1	System Performance.....	39
6.6.2	Operability.....	39
6.6.3	Future Growth / Expansion Opportunities.....	40
6.6.4	Capacity Provided.....	40
6.6.5	Economic Comparison .....	40
6.6.6	Other Considerations.....	40
6.7	PLAN SEVEN .....	41
6.7.1	System Performance.....	41
6.7.2	Operability.....	42
6.7.3	Future Growth / Expansion Opportunities.....	42
6.7.4	Capacity Provided.....	42
6.7.5	Economic Comparison .....	42
6.7.6	Other Considerations.....	43
<b>7.0</b>	<b>OTHER PLAN CONSIDERATIONS AND COMPARISONS.....</b>	<b>44</b>
7.1	NON-WIRES ALTERNATIVES CONSIDERATIONS.....	44
<b>8.0</b>	<b>CONCLUSIONS AND RECOMMENDATIONS.....</b>	<b>45</b>
<b>9.0</b>	<b>APPENDICES.....</b>	<b>47</b>
9.1	APPENDIX A – SYSTEM ONE LINES.....	47
9.2	APPENDIX B – ASSET CONDITION DOCUMENTS .....	90
9.3	APPENDIX C – AREA LOADING ANALYSIS .....	100
9.4	APPENDIX D – MWHR SUMMARY .....	130
9.5	APPENDIX E – SPICKET RIVER BACKUP ANALYSIS.....	131
9.6	APPENDIX F – 22.8 kV VOLTAGE ANALYSIS .....	132
9.7	APPENDIX G – COMPARISON OF PLANS – COST VS ADDED CAPACITY .....	133
9.8	APPENDIX H – COMPARABLE PAST STUDIES TO SALEM .....	134
<b>10.0</b>	<b>ANNEX LIST.....</b>	<b>135</b>
	<i>Annex A - National Grid Internal Strategy Document Distribution Substation Transformers Revised Strategy – October 2009.....</i>	<i>135</i>
	<i>Annex B – 10L1 Testing &amp; Maintenance Report: United Power Group - August 2014.....</i>	<i>135</i>

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

*Annex C – 10L4 Testing & Maintenance Report: United Power Group - September 2014.....135*  
*Annex D – 9L3 Testing & Maintenance Report: United Power Group - August 2014.....135*  
*Annex E – 2020 Dissolved Gas Analysis: Weidmann .....135*  
*Annex F – Liberty Utilities Electrical Substation Clearances Standard - Doc. # ENG-SUB006 – August 2020...135*

**Figures**

FIGURE 1 SALEM, NH GEOGRAPHICAL MAP .....10  
 FIGURE 2 SALEM 22.8 kV SUPPLY SYSTEM.....47  
 FIGURE 3 SALEM 13.2 kV TIE MAP (ALTERNATE).....48  
 FIGURE 4 SALEM 13.2kV DISTRIBUTION SYSTEM.....49  
 FIGURE 5 ALTERNATIVE #1 GOLDEN ROCK SUBSTATION 115kV/13.2kV EXPANSION - ONE LINE.....50  
 FIGURE 6 ALTERNATE #1 - BARRON AVE STATION - ONE LINE.....51  
 FIGURE 7 ALTERNATE #1 SALEM DEPOT STATION - ONE LINE .....52  
 FIGURE 8 ALTERNATE #1 SPICKET RIVER STATION - ONE LINE .....53  
 FIGURE 9 ALTERNATE #1 13.2kV OVERVIEW ONE LINE.....54  
 FIGURE 10 ALTERNATIVE #2 GOLDEN ROCK SUBSTATION 115kV/13.2kV EXPANSION - ONE LINE.....55  
 FIGURE 11 ALTERNATE #2 22.8 kV OVERVIEW ONE LINE .....56  
 FIGURE 12 ALTERNATE #2 BARRON AVE STATION REBUILD - ONE LINE .....57  
 FIGURE 13 ALTERNATE #2 SALEM DEPOT STATION REBUILD - ONE LINE .....58  
 FIGURE 14 ALTERNATIVE #3 GOLDEN ROCK SUBSTATION 115kV/13.2kV EXPANSION - ONE LINE.....59  
 FIGURE 15 ALTERNATIVE #3 22.8 kV OVERVIEW ONE LINE .....60  
 FIGURE 16 ALTERNATE #3 BARRON AVE STATION REBUILD – ONE LINE.....61  
 FIGURE 17 ALTERNATIVE #3 SALEM DEPOT REBUILD - ONE LINE .....62  
 FIGURE 18 ALTERNATIVE #4 22.8 kV OVERVIEW ONE LINE .....63  
 FIGURE 19 ALTERNATE #4 GOLDEN ROCK SUBSTATION 115kV/22.8kV EXPANSION – ONE LINE .....64  
 FIGURE 20 ALTERNATE #4 BARRON AVE STATION REBUILD – ONE LINE.....65  
 FIGURE 21 ALTERNATE #4 SALEM DEPOT STATION REBUILD – ONE LINE .....66  
 FIGURE 22 ALTERNATIVE #5 - 22.8 kV OVERVIEW ONE LINE .....67  
 FIGURE 23 ALTERNATE #5 GOLDEN ROCK SUBSTATION 115kV/22.8kV EXPANSION – ONE LINE .....68  
 FIGURE 24 ALTERNATE #5 BARRON AVE STATION REBUILD – ONE LINE.....69  
 FIGURE 25 ALTERNATE #5 SALEM DEPOT STATION REBUILD – ONE LINE .....70  
 FIGURE 26 ALTERNATIVE #5 New 22.8 kV/13.2kV TUSCAN VILLAGE SUBSTATION ONE LINE .....71  
 FIGURE 27 ALTERNATIVE #6 13.2kV OVERVIEW ONE LINE .....72  
 FIGURE 28 ALTERNATE #6 GOLDEN ROCK SUBSTATION 115kV/13,2kV EXPANSION PHASE ONE - ONE LINE.....73  
 FIGURE 29 ALTERNATE #6 FEEDER 19L4 – ONE LINE.....74  
 FIGURE 30 ALTERNATE #6 FEEDER 19L6 - ONE LINE .....75  
 FIGURE 31 ALTERNATE #6 FEEDER 19L8 - ONE LINE .....76  
 FIGURE 32 ALTERNATIVE #6 ROCKINGHAM SUBSTATION 115kV/13.2kV PHASE TWO - ONE LINE.....77  
 FIGURE 33 PROPOSED PLAN #6 115kV ROUTE.....78  
 FIGURE 34 ALTERNATE #6 NEW ROCKINGHAM STATION - FEEDER 21L1 - ONE LINE .....79  
 FIGURE 35 ALTERNATE #6 NEW ROCKINGHAM STATION – FEEDER 21L5 - ONE LINE .....80  
 FIGURE 36 ALTERNATE #6 NEW ROCKINGHAM STATION – FEEDER 21L6 - ONE LINE .....81  
 FIGURE 37 ALTERNATE #6 NEW ROCKINGHAM STATION – FEEDER 21L7 & 21L8 - ONE LINE .....82  
 FIGURE 38 ALTERNATIVE #7 GOLDEN ROCK SUBSTATION 115kV/13.2kV EXPANSION – ONE LINE.....83  
 FIGURE 39 ALTERNATE #7 BARRON AVE 10L1 – ONE LINE.....84  
 FIGURE 40 ALTERNATE #7 GOLDEN ROCK 19L4 – ONE LINE .....85  
 FIGURE 41 ALTERNATE #7 GOLDEN ROCK 19L6 - ONE LINE .....86  
 FIGURE 42 ALTERNATE #7 OLDE TROLLEY 18L2 AND 18L4 – ONE LINE .....87  
 FIGURE 43 ALTERNATE #7 PELHAM 14L4 AND 14L6 – ONE LINE .....88  
 FIGURE 44 ALTERNATIVE #7 SPICKET RIVER 13L3 - ONE LINE.....89

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

FIGURE 45 BARRON AVE CONCEPTUAL STATION EQUIPMENT LAYOUT .....90  
 FIGURE 46 SALEM DEPOT CONCEPTUAL STATION EQUIPMENT LAYOUT.....91  
 FIGURE 47 BARRON AVE SITE LAYOUT.....92  
 FIGURE 48 SALEM DEPOT SITE LAYOUT .....93  
 FIGURE 49 BARRON AVE 10L1 CLEARANCE SKETCH.....94  
 FIGURE 50 BARRON AVE 10L2 CLEARANCE SKETCH.....95  
 FIGURE 51 BARRON AVE 10L4 CLEARANCE SKETCH.....96  
 FIGURE 52 SALEM DEPOT 9L1 CLEARANCE SKETCH.....97  
 FIGURE 53 SALEM DEPOT 9L2 CLEARANCE SKETCH.....98  
 FIGURE 54 SALEM DEPOT 9L3 CLEARANCE SKETCH.....99  
 FIGURE 55: VOLTAGE PERFORMANCE DURING 13L1 CONTINGENCY (LOW VOLTAGE <0.95 PER-UNIT SHOWN IN RED) .....131

**Tables**

TABLE 1: SALEM AREA ELECTRIC SYSTEM ..... 11  
 TABLE 2 SALEM AREA 2019 PEAK LOADS ..... 12  
 TABLE 3 LUNH 2020-2036 90/10 SEASONAL PEAK FORECAST..... 13  
 TABLE 4 SALEM AREA SPOT LOADS ..... 13  
 TABLE 5 TUSCAN VILLAGE DIVERSIFIED LOADS ..... 14  
 TABLE 6 LIBERTY UTILITIES PLANNING CRITERIA..... 16  
 TABLE 7 13.2 kV FEEDER LOSSES BY ALTERNATIVE ..... 25  
 TABLE 8: PLAN COMPARISON MATRIX..... 44  
 TABLE 9 BASE CASE - NORMAL CONFIGURATION – 13.2 kV FEEDER LOADING ..... 100  
 TABLE 10 BASE CASE - NORMAL CONFIGURATION - TRANSFORMER LOADING ..... 101  
 TABLE 11 BASE CASE 2019 SUPPLY LINE NORMAL LOADING ..... 101  
 TABLE 12 BASE CASE 2019 TRANSFORMER CONTINGENCY LOADING ..... 102  
 TABLE 13 BASE CASE 2019 SUPPLY LINE CONTINGENCY LOADS ..... 102  
 TABLE 14 BASE CASE (w/ GOLDEN ROCK 13.2 kV) FEEDER NORMAL LOADING ..... 103  
 TABLE 15 BASE CASE (w/ GOLDEN ROCK 13.2 kV) TRANSFORMER NORMAL LOADS ..... 104  
 TABLE 16 BASE CASE (w/ GOLDEN ROCK 13.2 kV) SUPPLY LINE NORMAL LOADING ..... 105  
 TABLE 17 BASE CASE (w/ GOLDEN ROCK 13.2 kV) TRANSFORMER CONTINGENCY LOADING ..... 105  
 TABLE 18 BASE CASE (w/ GOLDEN ROCK 13.2 kV) SUPPLY LINE CONTINGENCY LOADING ..... 106  
 TABLE 19 ALT #1 FEEDER NORMAL LOADING ..... 107  
 TABLE 20 ALT #1 TRANSFORMER NORMAL LOADING ..... 108  
 TABLE 21 ALT #1 SUPPLY LINE NORMAL LOADING ..... 108  
 TABLE 22 ALT #1 TRANSFORMER CONTINGENCY LOADING ..... 109  
 TABLE 23 ALT #1 SUPPLY LINE CONTINGENCY LOADING ..... 109  
 TABLE 24 ALT #2 FEEDER NORMAL LOADING ..... 110  
 TABLE 25 ALT #2 TRANSFORMER NORMAL LOADING ..... 111  
 TABLE 26 ALT #2 SUPPLY LINE NORMAL LOADING ..... 111  
 TABLE 27 ALT #2 TRANSFORMER CONTINGENCY LOADING ..... 112  
 TABLE 28 ALT #2 SUPPLY LINE CONTINGENCY LOADING ..... 112  
 TABLE 29 ALT #3 FEEDER NORMAL LOADING ..... 113  
 TABLE 30 ALT #3 TRANSFORMER NORMAL LOADING ..... 114  
 TABLE 31 ALT #3 SUPPLY LINE NORMAL LOADING ..... 114  
 TABLE 32 ALT #3 TRANSFORMER CONTINGENCY LOADING ..... 115  
 TABLE 33 ALT #3 SUPPLY LINE CONTINGENCY LOADING ..... 115  
 TABLE 34 ALT #4 FEEDER NORMAL LOADING ..... 116  
 TABLE 35 ALT #4 TRANSFORMER NORMAL LOADING ..... 117  
 TABLE 36 ALT #4 SUPPLY LINES NORMAL LOADING ..... 117  
 TABLE 37 ALT #4 TRANSFORMER CONTINGENCY LOADING ..... 118  
 TABLE 38 ALT #4 SUPPLY LINE CONTINGENCY LOADING ..... 119



Liberty Utilities  
 System Planning  
 Salem Area Study 2020

TABLE 39 ALT #5 FEEDER NORMAL LOADING .....	120
TABLE 40 ALT #5 TRANSFORMER NORMAL LOADING .....	121
TABLE 41 ALT #5 SUPPLY LINE NORMAL LOADING.....	121
TABLE 42 ALT #5 TRANSFORMER CONTINGENCY LOADING.....	122
TABLE 43 ALT #5 SUPPLY LINE CONTINGENCY LOADING .....	123
TABLE 44 ALT #6 FEEDER NORMAL LOADING .....	124
TABLE 45 ALT #6 TRANSFORMER NORMAL LOADING .....	125
TABLE 46 ALT #6 SUPPLY LINE NORMAL LOADING.....	125
TABLE 47 ALT #6 TRANSFORMER CONTINGENCY LOADING.....	126
TABLE 48 ALT #6 SUPPLY LINE CONTINGENCY LOADING .....	126
TABLE 49 ALT #7 FEEDER NORMAL LOADING .....	127
TABLE 50 ALT #7 TRANSFORMER NORMAL LOADING .....	128
TABLE 51 ALT # 7 SUPPLY LINE NORMAL LOADING.....	128
TABLE 52 ALT #7 TRANSFORMER CONTINGENCY LOADING.....	129
TABLE 53 ALT #7 SUPPLY LINE CONTINGENCY LOADING .....	129
TABLE 54 2022 PREDICTED CONTINGENCY N-1 PROBLEMS .....	130
TABLE 55 COMPARISON OF PLANS – COST VS ADDED CAPACITY .....	133

Liberty Utilities  
System Planning  
Salem Area Study 2020

## 1.0 Executive Summary

ControlPoint Technologies with the assistance of Liberty Utilities completed the Salem, NH distribution planning study for 2020. The revised Liberty Utilities Distribution Planning Criteria<sup>1</sup> was used to determine any Electric Supply System upgrades required to meet existing and future capacity requirements. The study focused on the distribution requirements needed to supply the proposed 13.5-18.5-megawatt (MW) (See Table 5) Tuscan Village business park development located at the former Rockingham Park Track. The study also focused on addressing asset concerns at Barron Ave Substation and Salem Depot Substation. The recommended solution would address Distribution Planning Criteria violations at Golden Rock Substation and Spicket River Substation while integrating system operation and maintenance enhancements in an economically responsible manner.

This study is a revision of the 2016 Salem Area Study performed by ControlPoint. The Study's main objective is to review prudence of the 115kV Rockingham supply alternative (Plan 6) and to compare with New Hampshire Public Utilities Commission (NHPUC) Staff's recommended alternative, which further relies on the 22.8kV sub-transmission system supply and existing 13.2kV distribution substations as an overall solution to address the area's deficiencies (Plan 1). Additional 22.8 kV alternatives were also evaluated for comparison.

As described in this report, there exists multiple alternatives for addressing the problems identified in the area. These plans resolved the issues with differing effectiveness and with differing costs. The plans that involve investing and relying on the 22.8 kV system were shown to be similar or more costly than the recommended plan.

The major components of the recommended plan are focused on upgrading the source of supply to the 13.2 kV distribution system from a 22.8kV/13.2 modular substation-based system to a 115kV/13.2kV bulk substation-based system. This shift towards a 115kV based bulk system has been utilized in Liberty's rebuild of Pelham Substation, Michael Ave Substation and Mt Support Substation. See Appendix H – Comparable Past Studies to Salem for details.

Thus far, Liberty and National Grid have completed the work listed below related to the preferred 115kV alternative<sup>2</sup>:

- Phase 1 - Installation of a 115/13.2 kV - 33/44/55 MVA transformer, a 115kV in-line breaker and two 13.2kV feeders at the Golden Rock Substation and the offload of Barron Avenue Substation was completed in 2019<sup>3</sup>. Extension of Pelham 14L4 was completed in 2018 to provide temporary load relief and system capacity in the Salem Area. This temporary transfer of approximately 7 MVA enables Liberty to

---

<sup>1</sup> As approved under Order No. 26,376 in DE 19-064 Liberty Utilities (Granite State Electric) Corp. d/b/a Liberty Utilities, Petition for Permanent and Temporary Rates.

<sup>2</sup> For purposes of this review, the resulting loading from the completed work below will not be included in the 2019 base case load model for Alternative #4 and #5 to allow an even comparison between alternatives.

<sup>3</sup> The Liberty Utilities portion of the Golden Rock project has been approved by the New Hampshire Public Utilities Commission under Order No. 26,376 in DE 19-064 Liberty Utilities (Granite State Electric) Corp. d/b/a Liberty Utilities, Petition for Permanent and Temporary Rates.

Liberty Utilities  
System Planning  
Salem Area Study 2020

provide electric service to a portion, but not all, of Tuscan Village Development anticipated load while the Rockingham Substation is constructed. Installation of a third Golden Rock feeder to reduce load at risk at Spicket River substation is expected to be completed in 2021. Installation of a second 115kV transmission line into Golden Rock Substation is expected to be completed in 2020 by National Grid.

- Phase 2 – Purchase of land within the Tuscan Village Development to construct the new Rockingham #21 Substation was completed. Liberty is in the process of finalizing engineering activities for the Transmission Line and Substation projects and ordering long lead material items. Construction of the 115kV line project will begin in the winter of 2020 and is expected to be completed in 2022. The Rockingham Substation and associated feeders are expected to be completed in 2021. The Rockingham Substation will be designed to ultimately have ten feeder positions and two capacitor bank positions. Five feeders and one capacitor bank would be supplied by each transformer. Initially, five feeders, two and three from each transformer, will be installed in 2021. These will be utilized to supply the Tuscan Village load, allow the retirement of the Salem Depot Substation and provide backup to the Spicket River Substation.
- Phase 3 – Liberty has not developed any firm plans in its capital budget for Phase 3 within the 15-year planning horizon. For future reference, Phase 3 could replace the 115/22.8 kV transformer at Golden Rock with a 115/13.2kV transformer, convert the substation to a breaker and half scheme and re-purpose the 22.8 kV lines as 13.2kV feeders.

## 2.0 Introduction

### 2.1 Purpose

The purpose of this study was to resolve all identified area concerns in the Salem Area through the 15-year 2020-2036 study horizon. An in-depth review of the area was performed that included the analysis of thermal loading, voltage, reliability, asset condition, power quality, environmental, safety and voltage performance. Alternative plans were developed, which included NHPUC Staff's proposed alternative, and a preferred plan was recommended as being most prudent after detailed plan comparisons.

### 2.2 Problem

A study's initial system assessment is typically based on the needs identified through the problem identification process guided by the Company's Planning Criteria. In addition to the assessment performed in the 2016 version of the Study, updated system characteristics were evaluated to use 2019 loading and existing system configuration to identify a variety of normal and contingency capacity issues in the Salem Area.

A major point of concern is several existing asset condition concerns with substation equipment and layout.

Furthermore, another concern is the proposed 13.5-18.5-megawatt (MW) business park at Tuscan Village. Available capacity to supply the proposed development is not sufficient from

Liberty Utilities  
System Planning  
Salem Area Study 2020

the existing system.

### 3.0 Background

#### 3.1 Geographic Scope

This study was performed on the Liberty Utilities Distribution System supplying Salem, New Hampshire. The system is confined to the City of Salem, NH with small excursions into Windham and Derry, NH and Methuen, MA. See Figure 1 below:




Figure 1 Salem, NH Geographical Map



Liberty Utilities  
 System Planning  
 Salem Area Study 2020

### 3.2 Electrical Scope

The Salem Area includes 115 kV, 22.8 kV, and 13.2 kV facilities interconnected through five area substations. The Table 1 below summarizes these interconnections:

Supply	Alternate Supply	Station	Feeder	Customers
2352	2393	Salem Depot 9	9L1	967
2352	2393		9L2	128
2352	2393		9L3	1,261
2393	2353 (National Grid)	Barron Ave 10	10L1	813
2393	2353 (National Grid)		10L2	884
2353 (National Grid)	2393		10L4	775
2376 (National Grid)	2353 (National Grid) <sup>4</sup>	Spicket River 13	13L1	2,081
			13L2	1,899
			13L3	2,438
2352	2393	Olde Trolley 18	18L1	62
2352	2393		18L2	1,929
2393	2352		18L3	842
2393	2352		18L4	693
G133W (National Grid)	2353 & 2376 (National Grid)	Golden Rock 19 <sup>5</sup>	2352	4,347
			2393	3,232

*Table 1: Salem Area Electric System*

One 115 kV radial transmission supply line crosses the Massachusetts/New Hampshire border from Methuen, MA to feed two transformers at the Golden Rock Substation. Figure 2 in Appendix A – System One Lines shows the 22.8 kV Supply System. Figure 4 in Appendix A – System One Lines shows the 13.2 kV Distribution System.

Liberty Utilities serves 22,351 Customers in the Salem Area. In 2019, the Salem Planning Study Area generated a peak demand of 98.72 MW. The Salem area consists of approximately 13.1 miles of 22.8 kV three-phase supply line and approximately 143 miles of 13.2 kV three-phase mainline.

<sup>4</sup> Approximately 5.2 miles of the 2376 is exposed to outages without any backup, with 4.3 miles in National Grid maintenance territory and 0.9 miles in Liberty Utilities territory.

<sup>5</sup> Customers supplied by the 2352 and 2393 supply lines are a summation of customers supplied from the related substation transformers. These supply lines do not directly serve customers at 22.8 kV service voltage.

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

### 3.3 Load and Load Forecast

The Salem Study Area is a summer peaking area and is limited by summer equipment ratings. The study was conducted using load data beginning with the recorded 2019 peak load; refer to Table 2, below:

Station	Circuit	2019 Peak Load (Amps)	Limiting Element	SN Amps	% of SN
BARRON AVENUE 10	10L1	107	250 E Fuse	387	28%
BARRON AVENUE 10	10L2	268	4/0 CU Bus	526	51%
BARRON AVENUE 10	10L4	176	1-5/6.25 MVA Xfmr	339	52%
OLDE TROLLEY 18	18L1	133	1000 Al Cable	503	26%
OLDE TROLLEY 18	18L2	404	1000 Al Cable	503	80%
OLDE TROLLEY 18	18L3	375	336.4 Al	515	73%
OLDE TROLLEY 18	18L4	387	333 kVA Reg	516	75%
SALEM DEPOT 9	9L1	271	1-5/6.25/7 MVA Xfmr	322	84%
SALEM DEPOT 9	9L2	224	1-5/6.25/7 MVA Xfmr	322	70%
SALEM DEPOT 9	9L3	319	1-7.5/9.375 MVA Xfmr	507	63%
SPICKET RIVER 13	13L1	326	333 kVA	522	62%
SPICKET RIVER 13	13L2	290	333 kVA	522	56%
SPICKET RIVER 13	13L3	442	333 kVA	522	85%
Golden Rock	2352	776	2 X 1000 CU Cable	1376	56%
Golden Rock	2393	654	2 X 1000 CU Cable	1376	47%

*Table 2 Salem Area 2019 Peak Loads*

The Company developed an econometric model to forecast peak demands through 2036. The forecast model incorporates the impact of weather as well as demographic and local economic conditions on peak demands. The load was escalated through 2036 using the seasonal peak forecast under a 90/10 extreme weather scenario; refer to Table 3, below:

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

Year	MW	% Increase
2019	192.581	
2020	207.731	7.87%
2021	208.283	0.27%
2022	208.823	0.26%
2023	209.373	0.26%
2024	209.899	0.25%
2025	210.407	0.24%
2026	210.901	0.23%
2027	211.378	0.23%
2028	211.837	0.22%
2029	212.282	0.21%
2030	212.719	0.21%
2031	213.149	0.20%
2032	213.562	0.19%
2033	213.958	0.19%
2034	214.336	0.18%
2035	214.698	0.17%
2036	215.051	0.16%

Table 3 LUNH 2020-2036 90/10 seasonal peak forecast

The forecast model was then adjusted for spot loads to reflect new customer demands larger than 300 kilowatts (“kW”), refer to Table 4 below. The Distribution System was modeled and analyzed using the CYME application to perform the load flow analysis.

Year	Distribution Circuit	Location	Load (Amps)
2020	18L1	Rockingham Mall	65
2020	18L4	Tuscan Village Development South	274
2020	9L1	Tuscan Village Development North	174
2020	9L2	Data Center Expansion	44
2020	9L3	Commercial Development / Medical / Nursing	36
2021	18L4	Tuscan Village Development South	363

Table 4 Salem Area Spot Loads

Table 5 below tabulates detailed estimated loads for the Tuscan Village business park. This includes completed, under construction, in progress and no current tenant categories. Consistent with Company practice, anticipated kW demand represents diversified load, understanding that all loads are not active at the same time, at full power.

REDACTED  
 Liberty Utilities  
 System Planning  
 Salem Area Study 2020

<b>Tuscan Village Demand</b>			
<b>End Use</b>	<b>Diversified kW Demand</b>	<b>Tuscan Section</b>	<b>Status</b>
Dolben 1		North	Complete
Blackbrook		North	Complete
Ford		North	Complete
Market Basket		North	Opened July 2019
Home Sense		North	Opened Sept 2019
Sierra		North	Awaiting opening due to covid
MB Retail 3	71	North	No tenant due to Covid
MB Retail 4	56	North	No tenant due to Covid
Starbucks & Retail		North	Under Construction
Retail 1 - 4	30	North	Under Construction
Restaurant 1	87	North	2021
Restaurant 2	127	North	2021
35 N BROADWAY		North	Sal's Redevelopment - added by JR 6/3/2020
Hanover Apts		South	In Progress
Klemms		South	Complete
St Lt 1		South	In Progress
St Lt2+3 and well		South	In Progress
OMJ Buildings		South	In Progress
Pressed		South	In Progress
Mass General (with Solar)		South	In Progress
Building 100 (11.7)	245	South	In Progress
Building 200 (15.2)	317	South	In Progress
Building 300 (5.2)	109	South	In Progress
Building 400 (9)	188	South	In Progress
Building 500 (6.5)	107	South	In Progress
Building 520 (2.1) EV	44	South	In Progress
Building 600 w/ev (18.4)	386	South	In Progress
Building 700 (8.1)	154	South	In Progress
Building 800 w/ev (11.2)	235	South	In Progress
Building 900 (1.3)	28	South	In Progress
Building 1100 Drive (11.3)	236	South	In Progress
Hotel/Conf/Retail	1,300	South	No tenant
Resi Village	368	South	No tenant
Offices Spaces	4,025	South	No tenant
Over 55+	166	South	No tenant
Retail	2,426	South	No tenant
Dolben 2 (255 units)		South	In Progress
<b>Total North</b>	3,961		Includes Sal's Redevelopment (378kVA)
<b>Total South</b>	14,494		
<b>Total Tuscan Village</b>	<b>18,433</b>		
<b>Total Tuscan Village Completed/In-Progress</b>	<b>10,043</b>		These are for secured tenants
<b>Total Tuscan Village without signed tenant</b>	<b>8,412</b>		This is an estimate based on targeted end use

*Table 5 Tuscan Village Diversified Loads*



Liberty Utilities  
System Planning  
Salem Area Study 2020

### 3.4 Modeling and Criteria

CYME models were created for the Salem area 13.2 kV distribution system. PSS/e models were created for the 22.8 kV supply system. Transformers, supply lines, and distribution circuits were evaluated and modeled for each year thru 2036. The peak load and the available tie capacity for each component of the system was determined. Contingencies for the loss of a major component of the electrical system (N-1) were developed, and the system consequences reviewed.

As the Golden Rock 19L6 and 19L8 13.2 kV feeders were new additions to the area, energized in December 2019, the original 2019 base models did not include the feeders. Area load was allocated under the prior system configuration before the installation of the 19L6 and 19L8. Subsequently, the system model was reconfigured to depict 19L6 and 19L8 as planned. It should be noted that this study would have resulted in increased loading violations if these feeders were not present.

The in-progress construction of the Tuscan Village business park was modeled for all Plans as a total load of 13.5 MW, which is a minimum expected demand, and is 5 MW or 37% lower than Liberty's expected, diversified demand for the development as proposed at 18.5 MW. See Table 5. This demand assumes a conservative 1.5 MW for the northern Tuscan parcel and 12 MW for the southern parcel. If the Tuscan Village development grows to a demand closer to what is reflected in Table 5, the overloads and voltages presented in this study worsen considerably and could result in new violations not currently identified.

Each Alternative Plan was reviewed on the 13.2 kV and 22.8 kV system.

Distribution System Ratings were used to identify any station, supply line, and distribution circuit system capacity and reliability deficiencies, as applicable to Liberty Utilities Planning Criteria. The Liberty Utilities Planning Criteria has been reviewed and updated with PUC Staff input.

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

Condition	Sub-Transmission	Substation Transformer	Distribution Circuit
Normal	Loading to remain within 100% of normal rating.  Voltage at customer meter to remain within acceptable range.  Circuit phasing is to remain balanced.	Loading to remain within 100% of normal rating.  Voltage at customer meter to remain within acceptable range.  Circuit phasing is to remain balanced.	Loading to remain within 100% of normal rating.  Voltage at customer meter to remain within acceptable range.  Circuit phasing is to remain balanced.
N-1 Contingency, which results in facilities operating above their Long-Term Emergency (LTE) rating but below their Short-Term Emergency (STE) rating.	Load must be transferred to other supply lines in the area to within their LTE rating.  Repairs are expected to be made within 24 hours.  Evaluate alternatives if more than <b>120 MWhr</b> of load at risk results following post-contingency switching.	Load must be transferred to nearby transformer to within their LTE rating.  Repairs or installation of Mobile Transformer expected to take place within 24 hours.  For transformers larger than 10 MVA nameplate, evaluate alternatives if more than <b>180 MWhr</b> of load at risk results following post-contingency switching.	Load must be transferred to nearby feeder to within their LTE rating.  Repairs expected to be made within 24 hours.  Evaluate alternatives if more than <b>16 MWhr</b> of load at risk results following post. (Guideline)
N-1 Contingency, which results in facilities operating above their Short-Term Emergency (STE) rating.	As Needed - Typically 15 min for OH conductors and 24 hours for UG cables.	Loads must be reduced within 15 minutes to operate within their LTE rating.	As Needed - Typically 15 min for OH conductors and 1-24 hours for UG cables.

*Table 6 Liberty Utilities Planning Criteria*

### 3.5 Active & Completed Projects

Installation of a 115 kV/13.2 kV - 33/44/55 MVA transformer, a 115kV in-line breaker and two 13.2kV feeders at the Golden Rock Substation and the offload of Barron Avenue Substation was completed in December 2019 (Barron Ave Substation modular feeders will remain available for emergency use throughout construction of the recommended plan).

- An extension of Pelham 14L4 was completed in 2018 to provide temporary load relief and system capacity in the Salem Area. This temporary solution enables Liberty to

Liberty Utilities  
System Planning  
Salem Area Study 2020

provide electric service to a portion, but not all, of Tuscan Village Development anticipated load while the Rockingham Substation is constructed.

- Installation of the third Golden Rock feeder to reduce load at risk at Spicket River substation is expected to be completed in 2020. Installation of a second 115kV at Golden Rock is expected to be completed in 2020.

## 4.0 Problem Identification

### 4.1 Thermal Loading – Existing Violations

Existing system analysis reviewed two base cases, one being the 2019 peak case, without a new 115 kV / 22.8 kV supply transformer at Golden Rock. A second base case was also reviewed, as the recent addition of a 115 kV / 22.8 kV supply transformer at Golden Rock with three distribution feeders is needed to adequately reflect the Salem Area system modifications that have been approved by the NHPUC. Analysis results in this section represent the 2019 peak base case.

#### 4.1.1 Normal Configuration – based on 2019 peak loads

##### 4.1.1.1 Sub-Transmission System

Analysis resulted in no violations.

##### 4.1.1.2 Transformers

Analysis resulted in no violations.

##### 4.1.1.3 Feeders

The 13.2 kV distribution system supplies the peak load demand with no violations. However, to accommodate this loading the feeder 14L4 supplied from the Pelham Substation has been temporarily placed in an abnormal configuration. It is supplying load transferred from Salem to allow for the Tuscan Village increasing load.

#### 4.1.2 N-1 Contingency & Load-At-Risk

##### 4.1.2.1 Sub-Transmission System

Base Case 22.8 kV Analysis determined that the 22.8 kV supply system is nearing Summer Emergency limits in certain first contingency scenarios, refer to Appendix C – Area Loading Analysis, Table 13. As a result, no additional load should be added to the Salem 22.8 kV system, and no future load growth can occur without future overloads.

The Spicket River No.13 Station is currently supplied at 22.8 kV by the 2376 circuit from the National Grid Ward Hill Substation in Methuen, MA.

Liberty Utilities  
System Planning  
Salem Area Study 2020

The 2376 circuit ties with the 2353 circuit, which also originates from Ward Hill, via a pole mounted recloser loop scheme. The tie is located in the Spicket River Massachusetts Right of Way. Downstream of the 2376/2353 tie, the 2376 continues for 4.3 miles in National Grid territory crossing into New Hampshire and continuing 0.9 miles to the Spicket River No. 13 Substation. Approximately 5.2 miles of the 2376 is exposed to outages without any backup, with 4.3 miles in National Grid maintenance territory and 0.9 miles in Liberty Utilities territory.

The loss of the 22.8 kV source for an outage on the 5.2-mile section would require the Spicket River circuits to be backed up by existing distribution circuit ties, however area feeders are not positioned geographically to re-supply the Spicket River distribution feeders. To resolve low voltage issues during contingency, even cascading load does not re-supply Spicket River in all scenarios. While analysis shows that Spicket River distribution feeders can be partially re-supplied via distribution ties to avoid exceeding MWhr criteria, a minimum of fifteen switching steps would be required for partial re-supply; presenting operability challenges. Appendix E – Spicket River Backup Analysis for details.

Liberty Utilities relies on the Transmission provider to expedite repairs should an outage related problem occur anywhere along the 4.2 miles of transmission owned 2376 sub-transmission line downstream of the 2376/2353 tie. Loss of the 23 kV sub-transmission supply circuit to the Spicket River No.13 Station could cause Liberty Utilities to have up to 226 MWhrs of load at risk, after restorative switching occurs and for an assumed repair time of 12 hours. This violates Liberty's planning criteria of 120 MWhrs. In 2021 an express feeder 19L4 will be installed from the Golden Rock Substation to Spicket River to reduce the load at risk to below 120 MWhrs.

#### 4.1.2.2 Transformers

The Golden Rock Station is currently supplied radially from National Grid's G133 115 kV line which originates in West Methuen Station in MA. The station is backed up by National Grid's 22.8 kV lines 2376 and 2353 which originate in Methuen and West Methuen Stations in MA. Liberty Utilities relies on the Transmission provider to expedite repairs should an outage related problem occur on the 115 kV line or on the substation transformer. Loss of either could cause Liberty Utilities to have up to 300 MWhrs of load at risk, after restorative switching occurs and for an assumed repair time of 24 hours. This violates Liberty's planning criteria of 180 MWhrs. In 2021, a new 115kV transmission line will be installed from Methuen to Salem NH to resolve the load at risk related to the loss of the 115 kV transmission line. This however does not address the load at risk issue with the loss of the 115-22.8 kV transformer at Golden Rock. See Appendix D – MWhr Summary for details.



Liberty Utilities  
System Planning  
Salem Area Study 2020

#### 4.1.2.3 Feeders

Analysis resulted in no violations.

## 4.2 Thermal Loading – Predicted Violations

System analysis for this section reviewed two base cases, one being the 2019 peak case, without a new 115 kV / 22.8 kV supply transformer at Golden Rock. A second base case was also reviewed, as the recent addition of a 115 kV / 22.8 kV supply transformer at Golden Rock with three distribution feeders is needed to adequately reflect the Salem Area system modifications that have been approved by the NHPUC. Analysis results in this section represent the 2022 Base Case with Tuscan Village development, and the recent addition of a 115 kV / 22.8 kV supply transformer at Golden Rock in-service.

### 4.2.1 Normal Configuration

#### 4.2.1.1 Sub-Transmission System

Analysis resulted in no violations.

#### 4.2.1.2 Transformers

Analysis resulted in the following violations:

- Salem Depot 9L1 Feeder at 99% in 2022, up to 102% in 2036

Loading percentages are versus Summer Normal Ratings. See Appendix C – Area Loading Analysis, Table 15. It is assumed that the predicted demand for the Tuscan Village Development would normally be supplied by the 9L1 and 18L4 feeders. The 14L4 feeder has been extended from Pelham NH to Salem NH to provide temporary load relief on the 18L4 feeder to allow Tuscan Village to grow as the recommended solution is implemented. Until the recommended solution is implemented, the development will not be able to fully expand to its final configuration due to the lack of capacity of the distribution system.

#### 4.2.1.3 Feeders

Analysis resulted in the following violations:

- Salem Depot 9L1 Feeder at 99% in 2022, up to 102% in 2036

Loading percentages are versus Summer Normal Ratings. See Appendix C – Area Loading Analysis, Table 14.

Liberty Utilities  
System Planning  
Salem Area Study 2020

## 4.2.2 N-1 Contingency & Load at Risk

### 4.2.2.1 Sub-Transmission System

The Salem 22.8 kV distribution system was originally designed as a dual fed and redundant system with automatic transfer schemes at the substations. If loading exceeds the emergency rating on the adjacent line, steps need to be taken to block transfer at substation which could potentially result in prolonged outages to avoid overload and damage to equipment. While some overloads may not result in excess of 120 MWhr criteria, all supply line overloads are prevented, as they could constitute a conductor sag hazard or could cause permanent damage to equipment. Once an interruption occurs, there are several steps that are taken to ensure that the load can be strategically and safely be placed back in service to within ratings of the equipment. This could result in many customer outages of long duration.

Analysis resulted in the following predicted violations:

- 2352 overloads:
  - Golden Rock to Barron Ave Tap at 99% in 2022, up to 102% in 2036
  - Olde Trolley Tap to Olde Trolley at 104% in 2022, up to 107% in 2036
- 2393 overloads:
  - Golden Rock to Barron Ave Tap at 99% in 2022, up to 102% in 2036
  - Barron Ave Tap to Olde Trolley Tap at 115% in 2022, up to 118% in 2036
  - Olde Trolley Tap to Olde Trolley at 104% in 2022, up to 107% in 2036
- 2353 Meco to Golden Rock at 142% in 2022, up to 149% in 2036.

Loading percentages are versus Summer Emergency Ratings. See Appendix C – Area Loading Analysis, Table 18.

### 4.2.2.2 Transformers

Analysis resulted in the following violations:

- Salem Depot 9L1 Transformer at 119% in 2022, up to 123% in 2036
- Salem Depot 9L2 Transformer at 131% in 2022, up to 135% in 2036
- Salem Depot 9L3 Transformer at 104% in 2022, up to 107% in 2036
- Olde Trolley 18L1 Transformer at 98% in 2022, up to 101% in 2036
- Olde Trolley 18L2 Transformer at 98% in 2022, up to 101% in 2036
- Olde Trolley 18L3 Transformer at 97% in 2022, up to 100% in 2036
- Olde Trolley 18L4 Transformer at 97% in 2022, up to 100% in 2036

Loading percentages are versus Summer Emergency Ratings. See Appendix C – Area Loading Analysis, Table 17).

Liberty Utilities  
System Planning  
Salem Area Study 2020

#### 4.2.2.3 Feeders

Analysis resulted in the following Year 2022 violations:

- Spicket River 13L2 Feeder has a MWhr violation at 17.5 MWhrs
- Olde Trolley 18L3 Feeder has a MWhr violation at 23.5 MWhrs
- Olde Trolley 18L4 Feeder has a MWhr violation at 23.4 MWhrs

### 4.3 Asset Condition

ControlPoint and Liberty Utilities' Engineering and Substation teams reviewed asset conditions within the Study Area. The evaluation included the following:

1. Site visits to all Salem area Stations.
2. Review of past condition assessment reports provided to Liberty Utilities by National Grid and by United Power Group, Inc in 2014.
3. Review - National Grid Internal Strategy Document Distribution Substation Transformers Revised Strategy – October 2009.
4. Recent DGA Tests for available transformers at Barron Ave and Salem Depot.
5. Consultation with Liberty Utilities' Operations and Control Center personnel
6. Walkthrough of the area substations with PUC Staff. This walkthrough was performed in June 2020 with PUC Staff to visit all of the Salem Area substations to discuss benefits of the 115kV sourced substations and drawbacks and limitations of the existing 23kV sourced substations. Preliminary findings of the Salem Area Study was provided for discussion.

Field reviews assessed the feasibility of adding additional modular feeder positions at each substation and upgrading existing equipment. Asset condition concerns were found at Barron Ave and Salem Depot Substations and are documented below.

#### 4.3.1 Barron Ave Substation

The following is a list of asset condition concerns at Barron Ave Substation:

- The substation was originally constructed in early 1960s
- In 2009, the 10L1 supply transformer was deemed in "need of replacement" by 2014 due to "combustible gasses present"<sup>6</sup>
- The 10L1 Transformer bushings are showing signs of deterioration.<sup>7</sup>
- In 2009, the 10L4 supply transformer was deemed in "need of replacement" by 2025 due to "combustible gasses present"<sup>8</sup>

<sup>6</sup> Annex A - National Grid Internal Strategy Document Distribution Substation Transformers Revised Strategy – October 2009

<sup>7</sup> Annex B – 10L1 Testing & Maintenance Report: United Power Group - August 2014

<sup>8</sup> Annex A - National Grid Internal Strategy Document Distribution Substation Transformers Revised

Liberty Utilities  
System Planning  
Salem Area Study 2020

- The 10L4 Transformer bushings are showing signs of deterioration and are leaking oil around the bottom valve.<sup>9</sup>
- The 10L1 recloser has a McGraw-Edison Form 3 Control, which uses cartridges to select a limited number of protection curves. The device is obsolete, so finding a reliable source for new cartridges or parts is difficult. Other area utilities are actively retiring Form 3s because of its shortcomings with protection coordination and parts availability.
- Circuit Regulator Contacts are nearing end of useful life. The internal contacts are not a regular maintenance items, typical practice would be to replace the units entirely.
- Height to live parts inside the substation is below minimum height clearance requirements for a modern substation (See Appendix B – Asset Condition Documents, Figure 49, Figure 50, and Figure 51). Space is limited for new equipment access for installation & maintenance. Maintenance work near live parts requires extra time and/or outages to be able to maintain worker safety. The load growth in the area will further strain the equipment and will limit the ability of the Company to re-supply the load from alternate supplies to perform maintenance and/or emergency restorations.
- Recent Dissolved Gas Analysis (DGA) tests from April 2020 concluded that 10L1 and 10L2 transformers are both showing elevated levels of carbon monoxide and/or carbon dioxide, indicating signs of overheated cellulose insulation.<sup>10</sup>
- System Control has multiple concerns with operating the facilities at Barron Ave Station. Lack of monitoring and remote control of the equipment is a major concern. It is difficult to react efficiently while being forced to rely on customer calls for outages. Additional safety concerns exist given the lack of ability to remotely de-energize facilities quickly in emergency situations.

### 4.3.2 Salem Depot Substation

The following is a list of asset condition concerns at Salem Depot Substation:

- The substation was originally constructed in 1950s
- The existing 9L1 and 9L2 Breaker Positions and bus are constructed on Wood Pole Structures with limited clearance. The concern with wood pole structures is they lose their structural integrity over time. This deterioration causes equipment and brackets containing equipment to not function as designed and could lead to catastrophic equipment failure and faults during operation. In addition, maintenance work near live parts requires extra time and/or outages to be able to maintain worker safety. The added load growth will limit the ability of the Company to re-supply load from alternate supplies to perform maintenance and/or emergency restorations.
- Both the 9L1 and 9L2 transformers contain Polychlorinated Biphenyl (PCB) oil. The 9L1 contains 690 gallons of PCB oil. The 9L2 transformer contains 1,010 gallons of PCB oil. PCB oil is a widely recognized environmental risk.

---

Strategy – October 2009

<sup>9</sup> Annex C – 10L4 Testing & Maintenance Report: United Power Group - September 2014

<sup>10</sup> Annex E – 2020 Dissolved Gas Analysis: Weidmann



Liberty Utilities  
System Planning  
Salem Area Study 2020

- Height to live parts inside the substation is below minimum height clearance requirements for a modern substation (See Appendix B – Asset Condition Documents, Figure 52, Figure 53, and Figure 54).
- 9L1 has shown previous history of combustible gas over 1,000 (µL/L). In 2009 it was recommended to be replaced by 2014.<sup>11</sup>
- 9L2 has shown previous history of combustible gas over 1,000 (µL/L). In 2009 it was recommended to be replaced by 2014. Recent tests indicate an immediate risk of failure.<sup>12</sup>
- 9L3 has shown previous history of elevated combustible gas. In 2009 it was recommended to be replaced by 2025.<sup>13</sup>
- 9L1 and 9L2 Circuit Regulator Contacts are nearing end of useful life. Typical practice would be to replace the units entirely.
- The existing bus structure configuration for two of the existing feeders greatly restricts the ability to upgrade/replace the existing transformers and require a complete rebuild.
- The 9L3 Transformer 9T3's H3 bushing is showing signs of deterioration.<sup>14</sup>
- System Control has multiple concerns with operating the facilities at Salem Depot Station. Lack of monitoring and remote control of the equipment is a major concern. It is difficult to react efficiently while being forced to rely on customer calls for outages. Additional safety concerns exist given the lack of ability to remotely de-energize facilities quickly in emergency situations.

### 4.3.3 New 22.8 / 13.2 kV Substation Construction Feasibility

It is expected per the Asset Condition Review performed by ControlPoint that any new feeder additions or equipment replacements at either Barron Ave or Salem Depot Substations will trigger significant modifications and the need for complete rebuild of the substations to ensure proper OSHA/NESC clearances for worker safety, and conformance with Company requirements for SCADA, GridMod, communications, and other monitoring and control protocols.

Safety concerns with improper clearances would require large portions of the substation to be de-energized and re-supplied from alternate feeds while the modifications are made. The load growth in the area will prevent these planned outages from taking place and could impact the Company's ability to modify these substations and meet customer expectations of electric service in a timely manner.

Conceptual designs were developed as a part of the review to approximate the required footprint needed to rebuild Barron Ave and Salem Depot Substations. The conceptual designs account for the space needed for incoming 22.8 kV supply lines, 22.8 kV protective devices, supply transformers, 13.2 kV breakers, circuit regulators

---

<sup>11</sup> Annex A - National Grid Internal Strategy Document Distribution Substation Transformers Revised Strategy – October 2009

<sup>12</sup> **Annex E – 2020 Dissolved Gas Analysis: Weidmann**

Barron Ave 10L2 - Test Report #

<sup>13</sup> Annex A - National Grid Internal Strategy Document Distribution Substation Transformers Revised Strategy – October 2009

<sup>14</sup> Annex D – 9L3 Testing & Maintenance Report: United Power Group - August 2014

Liberty Utilities  
System Planning  
Salem Area Study 2020

and space to accommodate maintenance for each modular feeder position. See Appendix B – Asset Condition Documents, Figure 45 and Figure 46 for conceptual equipment layouts, and Figure 47 and Figure 48 for site layout sketches. Please note that the substation designs are conceptual, meant only to approximate required space for new facilities.

At Barron Ave Substation, the space for a substation rebuild to accommodate an anticipated (4) four 13.2 kV feeders is limited by the existing parcel. The Spicket River travels along the southern border of the parcel, Public Way limits the northern border, and the Salem Rail Trail limits the eastern border.

A rebuild of the substation would require much of the existing infrastructure to be temporarily moved or taken out of service to make room for new construction. Operating the system with these facilities unavailable presents many challenges. With the existing off-schedule equipment, construction would be limited to light loading periods, and additional outages could prove difficult to restore. Care would need to be taken to avoid environmental concerns associated with temporary or permanent construction in the vicinity of Spicket River. Integrating adequate access to the equipment for operation and maintenance, expanding the station footprint, adding a control house, developing feeder getaway routes, all present challenges.

Salem Depot Substation also has space constraints for additions or rebuild of the substation. To get an anticipated five (5) 13.2 kV feeders served from Salem Depot, the required substation footprint challenges the limits of the parcel. A rebuild of the substation would require much of the existing infrastructure to be temporarily moved or taken out of service to make room for new construction. Operating the system with these facilities unavailable presents many challenges. With the existing off-schedule equipment, additional outages could prove difficult to restore. Integrating adequate access to the equipment for operation and maintenance, expanding the station footprint, adding a control house, developing feeder getaway routes, all present challenges.

At Salem Depot Substation, purchase of the parcels adjacent to the existing substation parcel was investigated. The property owner of the nearby residential property was not interested in selling. When contacted, the now vacant lot which previously held a restaurant was not interested in selling. Since then, the restaurant is no longer operating due to fire damage.

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

## 4.4 Power Quality & Voltage Performance

### 4.4.1 Supply System Loss Comparison

Each of the studied supply system configurations was evaluated for performance from a system losses perspective. These values represent losses on the supply system, including supply transformers, with proposed Tuscan Village load. See Section 3.4 for configuration descriptions.

- Supply Configuration #1 (@ 22.8 kV): Area losses: 2.1 + j26.9 MVA = 26.98 MVA
- Supply Configuration #2 (@ 115 kV): Area losses: 1.0 + j15.4 MVA = 15.43 MVA

Results show that the options utilizing a 115 kV supply system would have approximately half the kW supply losses when compared to a 22.8 kV supply system. Under a 115kV supply configuration, Liberty's distribution customers could save up to \$761,813 annually. With regards to energy service, customers could save up to \$623,633 annually. This reflects transmission savings.

### 4.4.2 13.2 kV Distribution System Loss Comparison

Each of the studied distribution system configurations was evaluated for performance from a system losses perspective. These values represent losses on the primary (13.2 kV) lines only, with proposed Tuscan Village load.

Alt # 1 Feeder	Alt # 1 Feeder kW Losses	Alt # 2 Feeder	Alt # 2 Feeder kW Losses	Alt # 3 Feeder	Alt # 3 Feeder kW Losses	Alt # 4 Feeder	Alt # 4 Feeder kW Losses	Alt # 5 Feeder	Alt # 5 Feeder kW Losses	Alt # 6 Feeder	Alt # 6 Feeder kW Losses	Alt # 7 Feeder	Alt # 7 Feeder kW Losses
10L1	110.55	10L1	132.17	10L1	157.74	10L1	8.17	10L1	8.24	21L1	46.23	10L1	51.58
10L2	31.55	10L2	156.07	10L2	57.75	10L2	150.35	10L2	149.90	21L5	127.82	10L2	19.50
10L4	40.01	10L4	33.86	10L4	33.86	10L4	40.01	10L4	40.03	13L1	196.33	10L4	33.84
13L1	206.79	13L1	194.34	13L1	41.11	10L5	40.88	21L11	23.18	13L2	95.54	13L1	195.38
13L2	114.89	13L2	95.55	13L2	20.11	13L1	22.26	13L1	41.11	13L3	93.59	13L2	94.44
13L3	79.22	13L3	96.92	13L3	9.94	13L2	23.59	13L2	23.31	18L1	7.06	13L3	91.90
18L1	5.79	18L1	7.01	18L1	192.02	13L3	5.79	13L3	25.18	18L2	35.43	18L1	7.01
18L2	0.02	18L2	2.82	18L2	7.06	14L4	123.17	14L4	262.18	18L3	109.96	18L2	78.56
18L3	118.16	18L3	110.14	18L3	2.82	18L1	108.8	18L1	7.06	18L4	123.94	18L3	108.79
18L4	3.26	18L4	10.55	18L4	108.79	18L2	3.31	18L2	124.55	21L6	45.27	18L4	48.07
9L1	29.06	9L1	29.06	9L1	10.55	18L3	294.01	18L3	108.79	21L7	7.95	9L1	27.28
9L2	26.53	9L2	35.84	9L2	10.14	18L4	6.09	18L4	3.31	21L8	31.22	9L2	35.84
9L3	76.50	9L3	106.51	9L3	35.84	9L1	9.68	9L1	9.69	19L4	13.14	9L3	104.70
19L4	8.34	19L4	13.14	19L4	106.51	9L2	35.83	9L2	35.84	19L6	48.27	19L4	98.87
19L6	3.23	19L6	60.11	19L6	13.14	9L3	106.51	9L3	106.51	19L8	50.78	19L6	1.64
19L8	388.96	19L8	205.17	19L8	310.16	9L4	49.47	21L9	317.47	14L4	3.71	14L6	112.50
14L4	486.26	14L4	192.02	14L4	205.17	9L5	334.24	21L10	43.63			14L4	401.91
				10L5	33.06								
				9L4	0.08								
				9L5	334.24								
Alt # 1 Total Losses	1,729.12	Alt # 2 Total Losses	1,481.28	Alt # 3 Total Losses	1,690.09	Alt # 4 Total Losses	1,362.16	Alt # 5 Total Losses	1,329.98	Alt # 6 Total Losses	1,036.24	Alt # 7 Total Losses	1,511.81

Table 7 13.2 kV Feeder Losses by Alternative

Liberty Utilities  
System Planning  
Salem Area Study 2020

#### 4.4.3 Power Quality – Existing Violations

##### 4.4.3.1 Normal Configuration

###### 22.8 kV Sub Transmission System

Olde Trolley 23 kV bus at .9411 per-unit and Salem Depot 23 kV bus at .9328 per-unit.

###### Feeders

Analysis resulted in no violations.

##### 4.4.3.2 N-1 Contingency

###### Sub Transmission System

Olde Trolley 23 kV bus at .87171 per-unit for either 2352 or Golden Rock 115/23 kV transformer out-of-service.

Salem Depot 23 kV bus at .86229 per-unit for either 2352 or Golden Rock 115/23 kV transformer out-of-service.

###### Feeders

Voltage violations exist during 13L1 contingency. Refer to Appendix C – Area Loading Analysis, Figure 55.

#### 4.4.4 Power Quality – Proposed Plans

Analysis of multiple Alternative Plans resulted in the following remaining voltage violations. See Appendix F – 22.8 kV Voltage Analysis for details.

Alternative Plan 3 analysis resulted in the following voltage violations during contingency:

- Salem Depot 23 kV bus at .9375 per-unit. Olde Trolley 23 kV bus at .9471 per-unit during normal operating conditions.
- Olde Trolley 23 kV bus at .87857 per-unit for 2352 and Golden Rock 115/23 kV transformer out-of-service.
- Salem Depot 23 kV bus at .8676 per-unit for 2352 and Golden Rock 115/23 kV transformer out-of-service.

Alternative Plan 5 analysis resulted in the following voltage violations during contingency:

- Salem Depot 23 kV bus at .87524 per-unit for 2352 out-of-service.  
Rockingham 23 kV bus at .88188 per-unit for 2352 or second new line out-of-



Liberty Utilities  
System Planning  
Salem Area Study 2020

service.

Alternative Plan 7 analysis resulted in the following voltage violations during contingency:

- Olde Trolley 23 kV bus at .89932 per-unit for Golden Rock 115/23 kV transformer out-of-service.
- Salem Depot 23 kV bus at .89206 per-unit for Golden Rock 115/23 kV transformer out-of-service.

## 5.0 Plan Development

After identifying all existing and anticipated problems with the Salem Area, plans were developed to address system deficiencies.

Plan One through Plan Five focused on alternatives that made attempts to utilize and invest in the 22.8 kV system to address area issues. Plan Six was very similar to the 2016 Study recommended plan, utilizing the new Golden Rock Substation's 115kV/13.2kV transformer and proposed Rockingham Station's two 115 kV / 13.2 kV transformers to provide area load relief and support retirement of deteriorating 22.8 kV assets. Plan Seven utilizes the new Golden Rock Station 115kV/13.2kV transformer along with the existing 22.8kV/13.2kV modular feeders and installs an additional new 13.2 kV feeder circuit from Pelham Station #14 to offload Olde Trolley Station load.

It should be noted that Plans Four and Five are no longer feasible given the recent installation of a 115kV / 13.2kV transformer at Golden Rock Substation, which has been approved by NHPUC Staff. The installation of a 115kV / 13.2kV transformer at Golden Rock, common in Plans One, Two, Three, Six, and Seven of this study, provides much needed load relief to the 13.2 kV system in the area, and allows load to be transferred from the 22.8 kV supply system that without it, has existing first contingency MWhr violations. Plans Four and Five were developed for this study as a hindsight review to compare Plan 6 to Plans Four and Five, which are focused on expanding the 22.8 kV Sub-transmission system in the area.

Plans One through Three, and Plan Seven rely on an adequate supply from the *existing* 22.8 kV supply system to satisfy the area needs. The 22.8 kV supply system capabilities were analyzed in parallel with the distribution study. See Section 6.0 and Appendix C – Area Loading Analysis for details.

### 5.1 Plan Summary

- Plan One – NH PUC Staff Recommended Plan - Install a second 115 kV transmission line into Golden Rock Station supplying a new 115 kV/13.2 kV, 33/44/55 MVA, substation transformer with up to four (4) new circuit positions. Install three 13.2 kV feeders at Golden Rock Substation to reduce Spicket River Station load at risk, supply Tuscan Village and support system contingencies. Add four 2,500 kVA generators to provide additional non-wires contingency support. This plan is estimated at \$11,410,000. (See Figure 5, Figure 6, Figure 7, Figure 8, Figure 9).
- Plan Two – Install a second 115 kV transmission line into Golden Rock Station supplying

Liberty Utilities  
System Planning  
Salem Area Study 2020

a new 115 kV/13.2 kV, 33/44/55 MVA, substation transformer with up to four (4) new circuit positions. Install three 13.2 kV feeders at Golden Rock Substation to reduce Spicket River Station load at risk supply Tuscan Village and support system contingencies. Rebuild Barron Ave and Salem Depot Substations to resolve issues with equipment condition. This plan is estimated at \$24,000,000. (See Figure 10, Figure 11, Figure 12, Figure 13).

- Plan Three - Install a second 115 kV transmission line into Golden Rock Station supplying a new 115 kV/13.2 kV, 33/44/55 MVA, substation transformer with up to four (4) new circuit positions. Install three 13.2 kV feeders at Golden Rock Substation to reduce Spicket River Station load at risk, supply Tuscan Village and support system contingencies. Install one new feeder at Barron Ave and two new feeders at Salem Depot substations to supply Tuscan Village and support system contingencies. Rebuild remaining modular feeder at Barron Ave and Salem Depot Stations to resolve issues with equipment condition. This plan is estimated at \$35,310,000. (See Figure 14, Figure 15, Figure 16, Figure 17)
- Plan Four - Install a second 115 kV transmission line into Golden Rock Station supplying a new 115 kV/22.8 kV, 33/44/55 MVA, substation transformer with four (4) new circuit positions. From the Golden Rock Substation, install one new double circuit 22.8 kV pole line along the 22.8 kV Right of Way. Install one new 13.2kV modular feeder at Barron Ave and two new 13.2kV modular feeders at Salem Depot substations to supply Tuscan Village and support system contingencies. Rebuild remaining modular feeder at Depot Ave and Salem Depot Stations to resolve issues with equipment condition. This plan is estimated at \$33,940,000. (See Figure 18, Figure 19, Figure 20, Figure 21)
- Plan Five - Install a second 115 kV transmission line into Golden Rock Station supplying a new 115 kV/22.8 kV, 33/44/55 MVA, substation transformer with up to four (4) new circuit positions. From the Golden Rock Substation, install two new double circuits 22.8 kV pole line along the 22.8 kV Right of Way. Rebuild Barron Ave and Salem Depot Stations to resolve issues with equipment condition. Install a 22.8/13.2 kV Substation with three modular feeders at Tuscan Village. This plan is estimated at \$33,150,000. (See Figure 22, Figure 23, Figure 24, Figure 25, Figure 26)
- Plan Six - Install a second 115 kV transmission line into Golden Rock Station supplying a new 115 kV/13.2 kV, 33/44/55 MVA, substation transformer with up to four (4) new circuit positions. Install three 13.2 kV feeders at Golden Rock Substation to reduce Spicket River Station load at risk and retire the Barron Ave Substation. Install two 115 kV transmission lines into Rockingham Station supplying two new 115 kV/13.2 kV, 33/44/55 MVA, substation transformers with up to five (5) new circuit positions each. Install five 13.2 kV feeders at Rockingham Substation to supply Tuscan Village, support system contingencies and retire Salem Depot Substation. This plan is estimated at \$35,490,000. (See Figure 27, Figure 28, Figure 29, Figure 30, Figure 31, Figure 32, Figure 33, Figure 34, Figure 35, Figure 36, Figure 37, and Figure 37)
- Plan Seven – Installs a 115 kV transmission line into Golden Rock Station supplying a new 115 kV/13.2 kV, 33/44/55 MVA, substation transformer with up to four (4) new circuit positions. Install two 13.2 kV feeders at Golden Rock Substation to reduce

Liberty Utilities  
System Planning  
Salem Area Study 2020

Spicket River Station load at risk and support system contingencies. Add a second 13.2 kV feeder 14L5 from the Pelham 115kV/13.2kV Station to off load the Olde Trolley 22.8kV/13.2kV Station to supply Tuscan Village and support system contingencies. Rebuild Barron Ave and Salem Depot Substations to resolve issues with equipment condition. This plan is estimated at \$25,100,000. (See Figure 38, Figure 39, Figure 40, Figure 41, Figure 42, Figure 43, Figure 44)

## 6.0 Plan Considerations and Comparisons

The effectiveness of each plan to address the identified system deficiencies, including asset conditions, and meet company strategies are evaluated based on System Performance, Operability, Future Growth/Expansion Opportunities, Cost and Reserve Capacity Provided.

System Performance is evaluated based on the plan's potential to deliver reliable power to customers. In general, new supply sources should be located as close as possible to the load centers to minimize line losses, maintain voltages within limits and to minimize exposure of circuits to outages. Densely populated feeders and longer feeders experience more losses, have a higher rate of interruption and impact to system reliability. In addition, long feeders pose a challenge in maintaining nominal voltages within acceptable range. Each plan is evaluated on its ability to maintain nominal voltage within +/- 5% of nominal voltage during peak loading conditions and customer exposure to interruptions.

Operability is evaluated based on how the plan impacts the safe and efficient operation of the electric system. It evaluates how the plan's proposed additions affects the safety of field personnel and utility workers operating the electric distribution system and how it improves the ease of operation. Operability is also evaluated on how the plan aligns with the Company's strategy to be local and responsive to the needs of our customers and to reduce the reliance on the transmission provider. It is based on the plan's ability to meet the company's distribution planning criteria which represents the capability of the distribution system to provide reliable power during system intact conditions and first contingency conditions. It also represents the ability for the company to appropriately manage day-to-day contingency and storm operating risks given the company's resource base.

Future Growth is evaluated based on the plan's potential to enable future infrastructure additions and provide for expansion opportunities. For example, a plan that installs a substation nearest the load centers and has room for expansion, has better growth opportunities than a plan that installs a substation with a smaller footprint, away from the load centers.

Capacity provided is evaluated based on the plan's amount of reserve capacity gained for distribution feeders, substation transformers and supply lines beyond the present distribution system capabilities. Capacity provided is analyzed by determining the ratio of reserve capacity gained per dollar invested.

Each plan specifies capacity in two classes; Total MVA capacity and Firm MVA capacity. Total MVA capacity can be defined in this study as overall capacity made available. Firm MVA capacity gives a measure of the ability of the Plan to continue to provide capacity in absence of one major component. Total MVA capacity is often never fully available or utilized, as excess capacity always needs to be available for contingency scenarios. For example, a double-ended substation containing two supply transformers, each rated at 50 MVA thermal, would provide

Liberty Utilities  
System Planning  
Salem Area Study 2020

100 MVA of Total MVA capacity, and 50 MVA of Firm MVA capacity. To responsibly plan for first contingency (i.e. bus, transformer, or supply failure), the loading on the substation should not be designed to serve much more than the Firm capacity, 50 MVA in this example, during normal peak conditions, so that capacity can be available in a first contingency scenario. The geographical location and ratings of feeders can also limit the available or utilized capacity of a transformer.

The effectiveness of each plan in addressing each of these areas in a cost-effective manner was evaluated.

## 6.1 Plan One

### 6.1.1 System Performance

Plan One installs a new 115 kV supply to a new 115/13.2kV transformer and three distribution feeders at the Golden Rock Substation. It adds four 2.5 MVA generators for backup power, one at Barron Ave, one at Salem Depot and two at Spicket River. This plan extends the Golden Rock 19L8 feeder and the Barron Ave 10L2 feeder approximately 2.5 miles and 1.6 miles respectively to supply the Tuscan Village Development. This results in long feeders to reach the load centers, resulting in increased kW losses. Please note that the 14L4 circuit was used during analysis to serve load planned for the 10L2 under this Plan. It is expected that kW losses shown on the 14L4 would be transferred to the extension of the 10L2.

### 6.1.2 Operability

Plan One does not resolve existing concerns with substation equipment at Salem Depot and Barron Ave and will further increase safety hazard risk, maintenance activities, risk of equipment failure and other concerns described in Section 4.3. Generator refueling and maintenance located at a substation that already has existing maintenance concerns also presents an operability challenge. Locating diesel fuel storage in close proximity to aging substation equipment could also prove hazardous in the event of a fire.

Strategically placed voltage support equipment such as line capacitors and regulators are required to resolve low voltage issues during a Spicket River supply contingency. Cascading load and adding voltage support results in operability challenges with partial re-supply, occupying valued resources during major outage events. Refer to Appendix E – Spicket River Backup Analysis for backup overview.

This plan is not consistent with the company's initiatives in resiliency and grid modernization and could negatively impact the Company's response to storms and emergencies. The lack of SCADA at Salem Depot and Barron Ave Substations limits visibility for emergency response. The Plan does not address any of the asset needs at those substations and limits the ability to implement any automated restoration schemes, or protection schemes related to future DER or smart grid integration.

This plan does the bare minimum to serve Tuscan Village, leaving 22.8 kV circuits mostly unavailable to re-supply Golden Rock during a contingency event. See



Liberty Utilities  
System Planning  
Salem Area Study 2020

Appendix C – Area Loading Analysis, Table 23. This plan results in a load at risk at Golden Rock that is above the allowable per the Distribution Planning Criteria. See Appendix D – MWhr Summary. This makes outage planning longer and more difficult. It also does not reduce the reliance on the transmission provider.

### 6.1.3 Future Growth / Expansion Opportunities

Plan One provides limited opportunities for future expansion of the distribution system. It provides capacity to supply predicted growth in the Tuscan Village during system intact conditions but fails to adequately support the area's predicted demand during first contingency condition. This plan only provides four feeders to be used for future load growth at the Golden Rock Substation, three of which would be utilized under this plan. With no additional capacity available on the 22.8 kV sub-transmission system, future growth will require a large investment to provide additional capacity similar to what is being proposed with Plan Six.

### 6.1.4 Capacity Provided

Plan One provides the least capacity from all plans considered. Appendix G – Comparison of Plans – Cost vs Added Capacity shows predicted feeder capacity resulting from Plan One and how it compares with other Alternative Plans considered. It is estimated that this plan will provide a total MVA increase of 88.7 MVA and available Firm increase of 10.0 MVA.

### 6.1.5 Economic Comparison

Plan One is estimated at \$11,410,000<sup>15</sup>, of which \$3,500,000 has been spent to date.

When reviewing cost per MVA capacity provided, Plan One has a cost of approximately \$129,000 per MVA of total capacity provided, and It also has a cost of approximately \$1,410,000 per MVA of firm capacity provided.

Here is where this Plan compares with the other proposed Plans:

- Overall Cost: Lowest
- Cost per Total MVA Capacity: Lowest
- Cost per Firm MVA Capacity: Highest

### 6.1.6 Other Considerations

Alternative Plan #1 incorporates the use of “non-wires”, using local diesel generation to help support contingency issues.

Alternative Plan #1 comes with unique siting challenges for diesel generation, fuel

---

<sup>15</sup> It should be noted that Plan One also carries with it an estimated annual operating expense of \$200,000 per year for the proposed diesel generation.

Liberty Utilities  
System Planning  
Salem Area Study 2020

storage, and electrical facilities to accommodate connection to the 13.2 kV distribution at each substation. While there exists adequate real estate to add diesel generators, installations at Barron Ave and Salem Depot will require modification of the substation fence to fit the new facilities. Diesel generator installation at the substations will be challenging due to its proximity to residential customers, where noise pollution will be a concern. Storage of diesel fuel and the refueling of the generator would present an environmental hazard and permitting challenge. Furthermore, wetlands just to the south (Spicket River) pose environmental concerns for any new construction at Barron Ave.

Alternative Plan #1 presents concerns with noise pollution and air pollution from burning diesel fuel. The installation includes two large tractor trailers containing the generator, fuel tank transformer and protective equipment. Barron Ave Substation will require electrical facilities to be expanded closer to the residential customer on the western parcel boundary. A Residential customer adjacent to the substation has been vocal with complaints with the Substation aesthetics, noise, and work being performed at Barron Ave.

## 6.2 Plan Two

### 6.2.1 System Performance

Plan Two installs a new 115 kV supply to a new 115/13.2kV transformer and three distribution feeders at the Golden Rock Substation. It builds on Plan One by rebuilding the existing modular feeders at Barron Ave Station and at Salem Depot Station. This plan extends the Golden Rock 19L8 feeder and the Barron Ave 10L2 feeder approximately 2.5 miles and 1.6 miles respectively to supply the Tuscan Village Development. This results in long feeders and the same system performance issues as discussed in Plan One.

### 6.2.2 Operability

Plan Two, with the rebuilding of the substation equipment at Salem Depot and Barron Ave, resolves the asset condition concerns. The rebuilding of these substations also improves resiliency, providing SCADA for system operators and adequate work clearances for line workers.

However, this plan lacks the necessary capacity to re-supply the Golden Rock substation during first contingency, resulting in MWhr violations that are above the allowable limit per the Planning Criteria. Refer to Appendix D – MWhr Summary. Refer to Appendix E – Spicket River Backup Analysis for backup overview. It also does not reduce the reliance on the transmission provider. Increasing modular transformer capacity while not addressing loaded supply lines will not add useable capacity to address area issues. The limitation of the 22.8 kV system to supply the increased load during contingency conditions make system restoration difficult or impossible, making this Plan impractical.

Liberty Utilities  
System Planning  
Salem Area Study 2020

### 6.2.3 Future Growth / Expansion Opportunities

Similar to Plan One, Plan Two provides limited opportunities for future expansion of the distribution system. It provides capacity to supply predicted growth in the Tuscan Village during system intact conditions but fails to adequately support the area's predicted demand during first contingency condition.

This plan only provides four feeders to be used for future load growth at the Golden Rock substation, three of which would be utilized under this plan. Although Salem Depot Substation and Barron Ave Substations are rebuilt under this plan with additional feeder availability, lacking capacity available on the 22.8 kV sub-transmission system limits the overall load-carrying capability of the two substations. See Appendix C – Area Loading Analysis, Table 27 and Table 28. As a result, future growth will also require a large investment to provide additional capacity, similar to what is being proposed with Plan Six.

### 6.2.4 Capacity Provided

Plan Two provides the third least capacity from all plans considered. Appendix G – Comparison of Plans – Cost vs Added Capacity shows predicted feeder capacity resulting from Plan Two and how it compares with other Alternative Plans considered. It is estimated that this plan will provide a total MVA increase of 104.7 MVA and available Firm increase of 17.1 MVA.

### 6.2.5 Economic Comparison

Plan Two is estimated at \$24,000,000, of which \$3,500,000 has been spent to date.

When reviewing cost per MVA capacity provided, Plan One has a cost of approximately \$229,000 per MVA of total capacity provided, and It also has a cost of approximately \$1,403,000 per MVA of firm capacity provided.

Here is where this Plan compares with the other proposed Plans:

- Overall Cost: 2<sup>nd</sup> Lowest
- Cost per Total MVA Capacity: 2<sup>nd</sup> Highest
- Cost per Firm MVA Capacity: 2<sup>nd</sup> Highest

### 6.2.6 Other Considerations

Alternative Plans #2 and #3 (described below) each require complete rebuilds of Barron Ave and Salem Depot Substations, where Salem Depot would likely require additional real estate acquisition. Refer to Section 4.3.3 for further discussion. The land required for a Substation rebuild at Barron Ave may be available, but is limited, due to Spicket River along the southern border of the parcel, Barron Ave to the north, residential property to the west, and Salem Rail Trail to the east. To utilize the existing parcel, the existing Barron Ave facilities would require removal. This puts added stress on the other modular substation transformers and further limits the system during contingency. Wetlands concern also limits the space available at Barron Ave for a complete rebuild. To rebuild Salem Depot, additional real estate

Liberty Utilities  
System Planning  
Salem Area Study 2020

acquisition would be required on parcels just north of the Substation, where the Customer was approached by Liberty and was not interested in selling. Liberty Utilities owns a 6,100' square foot strip of land adjacent to Salem Depot on Middle Street, where could be made available for an additional feeder position, however two underground feeder getaways (9L2 and 9L3) are currently routed through the parcel, along with one overhead line (9L1) and pole mounted recloser, that would require relocation. It should be noted that these feeder relocations were not considered in the Plan (applicable to Plans 2,3,4,5,7) estimates.

## 6.3 Plan Three

### 6.3.1 System Performance

Similar to Plan Two, Plan Three installs a new 115 kV supply to a new 115/13.2 kV transformer and three distribution feeders at Golden Rock Substation. Like Plan Two, It rebuilds the existing modular feeders at Barron Ave Station and at Salem Depot Station. It builds on Plan Two by installing one new modular feeder at Barron Ave Station and two new modular feeders at Salem Depot Station.

Modeling of the 23kV system identified the following violations of the Distribution Planning Criteria related to voltage performance. Refer to Appendix F – 22.8 kV Voltage Analysis.

During normal operation, Plan 3 results in voltages as low as 0.9375 per-unit at the Salem Depot 23kV bus and 0.9471 per-unit at the Olde Trolley 23kV bus.

During contingency operation, Plan 3 results in voltages as low as 0.879 per-unit at the Olde Trolley 23kV bus for either a 2352 outage or a Golden Rock T1 transformer outage. It also results in voltages as low as 0.877 per-unit for either a 2352 outage or a Golden Rock T1 transformer outage.

### 6.3.2 Operability

Plan Three proposes to rebuild the substation equipment at Salem Depot and Barron Ave, resolving the asset condition concerns. Refer to Section 4.3.3 for further discussion. This plan is consistent with the company's initiatives in resiliency and available capacity but still has shortcomings due to lack of supply capacity during contingencies. This plan lacks the necessary capacity to re-supply the Golden Rock substation during first contingency, resulting in MWhr violations that are above the allowable limit per the Planning Criteria. Refer to Appendix D – MWhr Summary. It also does not reduce the reliance on the transmission provider. This plan is not sustainable due to the existing 22.8 kV sub-transmission system's lack of capacity with no available source to supply it. See Appendix C – Area Loading Analysis, Table 33. The limitation of the 22.8 kV system to supply the increased load make this Plan impractical.



Liberty Utilities  
System Planning  
Salem Area Study 2020

### 6.3.3 Future Growth / Expansion Opportunities

Plan Three does not provide for future capacity additions, as substations are expanded to their maximum footprint. The ultimate design of five feeders from the Salem Depot Substation, four feeders from Barron Ave coupled with the opportunity to install an additional four feeders from the Golden Rock substation adds adequate capacity on the 13.2 kV system. However, as stated for Plan Two, increasing modular transformer capacity while not addressing loaded supply lines will not add useable capacity to address area issues. There is no capacity available to support the installed capacity from the 22.8 kV sub-transmission system and as such this Plan is not viable. See Appendix C – Area Loading Analysis, Table 33.

To accommodate any future expansion or growth, a plan such as Plan Six will be required.

### 6.3.4 Capacity Provided

Plan Three provides the fourth least capacity from all plans considered. Appendix G – Comparison of Plans – Cost vs Added Capacity shows predicted feeder capacity resulting from Plan Three and how it compares with other Alternative Plans considered. It is estimated that this plan will provide a total MVA increase of 146.9 MVA and available Firm increase of 60.3 MVA. Lack of capacity provided by this plan on the 22.8 kV system makes this Plan not viable.

### 6.3.5 Economic Comparison

Plan Three is estimated at \$35,310,000, of which \$3,500,000 has been spent to date.

When reviewing cost per MVA capacity provided, Plan Three has a cost of approximately \$240,000 per MVA of total capacity provided, and It also has a cost of approximately \$586,000 per MVA of firm capacity provided.

Here is where this Plan compares with the other proposed Plans:

- Overall Cost: 2<sup>nd</sup> Highest
- Cost per Total MVA Capacity: Highest
- Cost per Firm MVA Capacity: 4<sup>th</sup> Highest

### 6.3.6 Other Considerations

Plan Three has the same siting concerns as discussed in Plan Two.

Liberty Utilities  
System Planning  
Salem Area Study 2020

## 6.4 Plan Four

This plan review was for comparison only and is not feasible. See Section 5.0.

### 6.4.1 System Performance

Plan Four installs a new 115 kV supply to a new 115/22.8 kV transformer and one 22.8 kV feeder at Golden Rock Substation. It rebuilds the existing modular feeders at Barron Ave Station and at Salem Depot Station. It also installs one new modular feeder at Barron Ave Station and two new modular feeders at Salem Depot Station. This plan extends the Barron Ave 10L2 feeder approximately 1.6 miles to supply the Tuscan Village Development. Reliability concerns posed by aging and obsolete equipment is mitigated by the replacement of the aging equipment at Salem Depot and Barron Ave Substations.

### 6.4.2 Operability

Plan Four has operability required to operate the system. It rebuilds two substations with six 23/13.2kV transformers, eliminating aging equipment, maintenance and operating concerns. Adds three additional modular feeders one at Barron Ave and two at Salem Depot. Refer to Section 4.3.3 for further discussion. This plan provides capacity to allow future distribution automation further improving operability of the system and storm response. The added capacity allows Liberty to re-supply the Spicket River and Golden Rock substations during first contingency condition.

### 6.4.3 Future Growth / Expansion Opportunities

Plan Four provides for future capacity additions in an area expected to experience significant growth. The ultimate design of five feeders from the Salem Depot Substation, four feeders from Barron Ave coupled with the additional four feeders at the Golden Rock substation adds adequate capacity on the 22.8 kV system to support the additional modular feeders. It should be noted that Barron Ave and Salem Depot Substations would be expanded to their maximum footprint after addition of the new modular feeder positions.

### 6.4.4 Capacity Provided

Plan Four provides the second most capacity from all plans considered. Appendix G – Comparison of Plans – Cost vs Added Capacity shows predicted feeder capacity resulting from Plan Four and how it compares with other Alternative Plans considered. It is estimated that this plan will provide a total MVA increase of 152.1 MVA and available Firm increase of 108.1 MVA.

### 6.4.5 Economic Comparison

Plan Four is estimated at \$33,940,000, of which \$0 has been spent to date.

When reviewing cost per MVA capacity provided, Plan Three has a cost of

Liberty Utilities  
System Planning  
Salem Area Study 2020

approximately \$223,000 per MVA of total capacity provided, and  
It also has a cost of approximately \$314,000 per MVA of firm capacity provided.

Here is where this Plan compares with the other proposed Plans:

- Overall Cost: 3<sup>rd</sup> Highest
- Cost per Total MVA Capacity: 3<sup>rd</sup> Highest
- Cost per Firm MVA Capacity: 6<sup>th</sup> Highest

#### 6.4.6 Other Considerations

Due to asset concerns and the need for complete substation rebuilds at Barron Ave and Salem Depot to implement a 22.8 kV-based solution, the considerations described for Plan Two are also associated with Alternatives #4 and #5. Alternative #4 also requires new 22.8 kV supply lines, however existing right-of-way corridors are expected to be adequate for the new lines. Permits for new pole locations and vegetation management would be necessary to implement Alternative #4.

Plan Four shifts the demand further out towards the end of the 23kV system which could require additional infrastructure improvements not identified in this study. At a minimum it would require replacement of two 22.8 kV line reclosers rated at 1,000 Amps continuous operating current to handle contingency power flows. A detailed protection study would be required to determine if overcurrent pickups could be increased and still achieve proper coordination among devices at Golden Rock Substation, 22.8 kV line reclosers, and Salem Depot Substation, which, based on past review may not be achievable.

### 6.5 Plan Five

This plan review was for comparison only and is not feasible. See Section 5.0.

#### 6.5.1 System Performance

Plan Five installs a new 115 kV supply to a new 115/22.8 kV transformer and one 22.8 kV feeder at Golden Rock Substation. It rebuilds the existing modular feeders at Barron Ave Station and at Salem Depot Station. It installs a new 22.8/13.2 kV Tuscan Village Substation with three 13.2kV modular feeders with space for a fourth feeder. Being located centrally in the town of Salem, results in shorter feeders to supply load from Rockingham Substation and flexibility to support other parts of the study area during first contingency conditions. Shorter feeders consist of fewer elements that can fail and typically have fewer outages and less losses. Reliability concerns posed by aging and obsolete equipment is mitigated by the replacement of the aging Salem Depot and Barron Ave.

This plan results in facilities that can maintain adequate voltage on all distribution feeders during system intact and first contingency conditions but cannot maintain adequate voltages on the 23kV system during contingency conditions.

Liberty Utilities  
System Planning  
Salem Area Study 2020

During contingency operation, Plan 5 results in voltages as low as 0.875 per-unit at the Salem Depot 23kV bus for a 2352 outage. It also results in voltages as low as 0.88 per-unit at the Rockingham 23kV bus for a Line #2 outage. Refer to Appendix F – 22.8 kV Voltage Analysis.

### 6.5.2 Operability

Plan Five has operability required to operate the system. It rebuilds two substations with six 23/13.2kV transformers, eliminating aging equipment, maintenance and operating concerns. Refer to Section 4.3.3 for further discussion. Adds a new substation with three additional modular feeders close to the load center. This plan provides capacity to allow future distribution automation further improving operability of the system and storm response. The added capacity allows Liberty to re-supply the Spicket River and Golden Rock substations during first contingency condition.

### 6.5.3 Future Growth / Expansion Opportunities

Plan Five provides for future capacity additions in an area expected to experience significant growth. The ultimate design of three updated feeders at the Salem Depot Substation, three updated feeders from Barron Ave coupled three new 22.8/13.2 kV modular feeder at the new Tuscan Village Station with the additional four feeders at the Golden Rock substation adds adequate capacity on the 22.8 kV system to support the additional modular feeders, although somewhat limited by the 23kV voltage performance.

### 6.5.4 Capacity Provided

Similar to Plan Four, Plan Five provides the second most capacity from all plans considered. However, it has 14.4 MVA less Firm capacity added. Appendix G – Comparison of Plans – Cost vs Added Capacity shows predicted feeder capacity resulting from Plan Five and how it compares with other Alternative Plans considered. It is estimated that this plan will provide a total MVA increase of 152.1 MVA and available Firm increase of 93.7 MVA.

### 6.5.5 Economic Comparison

Plan Four is estimated at \$33,150,000, of which \$1,500,000 has been spent to date.

When reviewing cost per MVA capacity provided, Plan Three has a cost of approximately \$218,000 per MVA of total capacity provided, and It also has a cost of approximately \$354,000 per MVA of firm capacity provided.

Here is where this Plan compares with the other proposed Plans:

- Overall Cost: 4<sup>th</sup> Highest
- Cost per Total MVA Capacity: 4<sup>th</sup> Highest
- Cost per Firm MVA Capacity: 5<sup>th</sup> Highest



Liberty Utilities  
System Planning  
Salem Area Study 2020

### 6.5.6 Other Considerations

Alternative #5 requires the same considerations as Alternatives #2 through #4, with the addition of a new substation at Tuscan Village, which will require real estate acquisition and environmental permitting. Liberty has purchased the land required for a proposed Rockingham Substation.

Plan Five also has the same concerns as Plan Four regarding system demand being shifted further out the 22.8 kV system and even more so with Plan 5. Like Plan Four this would require an additional protection study to determine required infrastructure improvements and if adequate coordination can be achieved.

## 6.6 Plan Six

### 6.6.1 System Performance

Plan Six installs a new 115/13.2kV Rockingham substation at the load center in the Tuscan Village Development. Being located centrally in the town of Salem, results in shorter feeders to supply load from Rockingham Substation and flexibility to support other parts of the study area during first contingency conditions. Shorter feeders consist of fewer elements that can fail and typically have fewer outages and less losses. Refer to Section 4.4 for loss comparison. This plan results in facilities that can maintain adequate voltage on all distribution feeders during system intact and first contingency conditions. Reliability concerns posed by aging and obsolete equipment is mitigated by the retirement of the aging Salem Depot and Barron Ave Substations, and the installation a more modern and robust Rockingham substation.

### 6.6.2 Operability

Plan Six has the best operability over the other plans. It retires two substations including six 23/13.2kV transformers, with aging, maintenance and operating concerns. This plan provides capacity to allow future distribution automation further improving operability of the system and storm response. The added capacity allows Liberty to re-supply the Spicket River and Golden Rock substations during first contingency condition resulting in the plan that most reduces the reliance in the transmission provider.

The breaker-and-a-half substation design proposed for Rockingham Substation is commonly used by utilities for new substations because it is easy to expand, provides high reliability, and allows flexibility in operation, allowing for breaker, bus, or transformer maintenance without taking an outage. This new substation would also meet Liberty Standards for SCADA, which provides valuable data for system operators and engineering.

Alternative Plan Six, compared to other Plans, installs three new supply transformers. Plans Two through Five, and Seven, invest in the limited 22.8 kV system that utilize up to nine supply transformers that require regular maintenance.

Liberty Utilities  
System Planning  
Salem Area Study 2020

### 6.6.3 Future Growth / Expansion Opportunities

Plan Six provides for future capacity additions in an area expected to experience significant growth. The ultimate design of ten feeders from the Rockingham Substation coupled with the opportunity to install an additional four feeders from the Golden Rock substation makes this plan the most attractive from a future growth standpoint. At Tuscan Village, there still exist empty lots with unsecured tenants, which present the potential for future high energy applications. Possible development on these lots presents future load growth that needs to be planned for. Tuscan Village will also attract “spill-over” growth from neighboring businesses given its economic effect and strategic location in the study area.

In addition to the available capacity for additional feeders to be installed at the Rockingham station, this plan provides a path for re-purposing the 22.8 kV distribution system from Golden Rock as 13.2kV to allow for an additional four distribution feeders beyond the planning horizon.

### 6.6.4 Capacity Provided

Plan Six provides the most capacity from all plans considered. Appendix G – Comparison of Plans – Cost vs Added Capacity shows predicted feeder capacity resulting from the Alternative Plans. It is estimated that this Plan will provide a total MVA increase of 177.7 MVA and available Firm increase of 142.3 MVA, even with the retirement of Barron Ave and Salem Depot Substations. After installing the six 13.2kV feeders at Rockingham Substation to resolve predicted deficiencies, Liberty will have the ability to install as required, the remaining four 13.2kV distribution feeders to address future capacity, reliability and asset condition deficiencies for many years to come.

### 6.6.5 Economic Comparison

Plan Four is estimated at \$34,900,000, of which \$5,000,000 has been spent to date.

When reviewing cost per MVA capacity provided, Plan Three has a cost of approximately \$196,000 per MVA of total capacity provided, and It also has a cost of approximately \$245,000 per MVA of firm capacity provided.

Here is where this Plan compares with the other proposed Plans:

- Overall Cost: Highest
- Cost per Total MVA Capacity: 6<sup>th</sup> Highest
- Cost per Firm MVA Capacity: Lowest

### 6.6.6 Other Considerations

Alternative #6 utilizes the existing 22.8 kV right-of-way that parallels Route 28 to extend 115kV lines approximately 2.25 miles up to a proposed substation near Rockingham Park Boulevard. This 115kV line extension has already undergone several key approvals, including a NPCC-approved E1 exclusion afforded by the approved BES Definition. Also, ISO-New England determined no significant adverse

Liberty Utilities  
System Planning  
Salem Area Study 2020

effect identified with regard to the PPA - Rockingham project. This complex construction will also require DOT Permitting and traffic management, environmental review, town permits, and aerial easements.

Liberty has purchased the land required for the proposed Rockingham Substation.

Alternative #6 proposes new 115 kV infrastructure, which will require significantly taller structures, however with routing through a primarily commercial area, community impact is expected to be the least of all alternatives. Largest impacts may be aerial easements, construction of footings for structures, and construction at roadway crossings that could disrupt traffic. Additional lines across the street from residences on Duffy Ave may cause complaints. Some construction may temporarily disrupt use of a portion of the Salem Rail Trail.

## 6.7 Plan Seven

### 6.7.1 System Performance

Plan Seven installs a new 115 kV supply to a new 115/13.2 kV transformer and two distribution feeders at Golden Rock Substation and installs a new 13.2 kV feeder (14L5) from the rebuilt Pelham Substation. The new 13.2 kV feeder 14L5 along with the 14L4 from Pelham Station will be used to unload the Olde Trolley feeders 18L2 and 18L4. These two feeders (14L4 and 14L5) are approximately 3.4 miles long and will be on the same structures increasing the vulnerability to a hit by auto event to a significant portion of the system. In some areas three feeders (14L3, 14L4 and 14L5) will be on the same structures further increasing the vulnerability to a hit by auto event. Appendix D – MWHr Summary contains MWHr totals for losses of multiple circuits in such a scenario.

Similar to Plans One and Two, this plan lacks the necessary capacity and voltage support to re-supply the Spicket River substation during the loss of supply contingency. This plan resolves the existing concerns with substation equipment at Salem Depot and Barron Ave.

This plan results in facilities that can't maintain adequate voltages on the 23kV system during contingency conditions.

During contingency operation, Plan 7 results in voltages as low as 0.899 per-unit at the Olde Trolley 23kV bus and as low as .892 per-unit at the Salem Depot 23 kV bus for a Golden Rock T1 outage. Refer to Appendix F – 22.8 kV Voltage Analysis for details.

Liberty Utilities  
System Planning  
Salem Area Study 2020

### 6.7.2 Operability

Plan Seven proposes to rebuild the substation equipment at Salem Depot and Barron Ave, resolving the asset condition concerns and providing for opportunities in Grid Modernization. Refer to Section 4.3.3 for further discussion. This plan has shortcomings due to lack of supply capacity during contingencies. This plan lacks the necessary capacity to re-supply the Golden Rock substation during first contingency, resulting in MWhr violations that are above the allowable limit per the Planning Criteria. Refer to Appendix D – MWhr Summary. It does not reduce the reliance on the transmission provider. This plan is not sustainable due to the existing 22.8 kV sub-transmission system’s lack of capacity with no available source to supply it. See Appendix C – Area Loading Analysis, Table 53. The limitation of the 22.8 kV system to supply the increased load make this Plan impractical.

### 6.7.3 Future Growth / Expansion Opportunities

Similar to Plan One and Plan Two, Plan Seven provides limited opportunities for future expansion of the distribution system. It provides capacity to supply predicted growth in the Tuscan Village during system intact conditions but fails to adequately support the area’s predicted demand during first contingency condition.

This plan only provides four feeders to be used for future load growth at the Golden Rock substation, three of which would be utilized under this plan. Although Salem Depot Substation and Barron Ave Substations are rebuilt under this plan with additional feeder availability, lacking capacity available on the 22.8 kV sub-transmission system limits the overall load-carrying capability of the two substations. See Section 4.1.2.1 for violations, which are unchanged with this Plan. As a result, future growth will also require a large investment to provide additional capacity, similar to what is being proposed with Plan Six.

### 6.7.4 Capacity Provided

Plan Seven provides the 5<sup>th</sup> most capacity from all plans considered. Appendix G – Comparison of Plans – Cost vs Added Capacity shows predicted feeder capacity resulting from Plan Seven and how it compares with other Alternative Plans considered. It is estimated that this plan will provide a total MVA increase of 116.7 MVA and available Firm increase of 29.1 MVA.

Plan Seven leaves considerable capacity for Golden Rock 13.2 kV feeders to offload the 22.8 kV supply system, however in contingency scenarios such as loss of the Golden Rock 115 kV / 13.2 kV supply transformer, capacity limits are exceeded on the 22.8 kV supply system.

### 6.7.5 Economic Comparison

Plan Four is estimated at \$25,010,000, of which \$3,500,000 has been spent to date.

When reviewing cost per MVA capacity provided, Plan Three has a cost of approximately \$214,000 per MVA of total capacity provided, and



Liberty Utilities  
System Planning  
Salem Area Study 2020

It also has a cost of approximately \$859,000 per MVA of firm capacity provided.

Here is where this Plan compares with the other proposed Plans:

- Overall Cost: 5<sup>th</sup> Highest
- Cost per Total MVA Capacity: 5<sup>th</sup> Highest
- Cost per Firm MVA Capacity: 3<sup>rd</sup> Highest

#### **6.7.6 Other Considerations**

Due to asset concerns and the need for complete substation rebuilds at Barron Ave and Salem Depot to implement a 22.8 kV-based solution, the considerations described for Plan Two are also associated with Alternatives #7.

Plan Seven extends a new feeder for approximately 3.4 miles from Pelham to Salem and will result in multiple feeders on the same structures, increasing the vulnerability to a hit by vehicle event to a significant portion of the system. Liberty Utilities is strongly against unnecessary double and triple-circuiting for this reason. An alternative would be underground construction, which is not cost effective, as the additional feeder would only be providing a limited 12 MVA of capacity into Salem for an estimated cost of \$6,800,000

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

See Appendix G – Comparison of Plans – Cost vs Added Capacity for a side-by-side comparison of plans that reviews cost versus added capacity. For a further comparison of the Alternative Plans, a matrix was assembled to compare each Plan’s ranking in each of the criteria used to evaluate the plans. This methodology is similar to what is being used at another New Hampshire Utility. See Table 8 below:

Plan Comparison Matrix								
Evaluation Criteria	Weight Factor	Plan 1	Plan 2	Plan 3	Plan 4	Plan 5	Plan 6	Plan 7
1- SYSTEM PERFORMANCE	20%	1	3	4	5.5	5.5	7	2
2- OPERABILITY	25%	1	3	4	5.5	5.5	7	2
3- FUTURE EXPANSION	10%	1	3	4	5	6	7	2
5- CAPACITY PROVIDED	15%	1	2	4	5.5	5.5	7	3
4- COST	30%	7	6	2	3	4	1	5
<b>Total</b>		<b>2.8</b>	<b>3.75</b>	<b>3.4</b>	<b>4.7</b>	<b>5.1</b>	<b>5.2</b>	<b>3.05</b>
<b>RANK</b>		<b>7</b>	<b>4</b>	<b>5</b>	<b>3</b>	<b>2</b>	<b>1</b>	<b>6</b>

*Table 8: Plan Comparison Matrix*

The matrix considers the importance of each criteria, calculating a higher weight to Plans that rank higher in the most important areas.

Given this evaluation, Plans Five and Six are the highest-scoring plans. It should be noted that cost comparison may be unevenly factored in this evaluation, as several plans are relatively close in estimated cost. For example, while Plan Five is only 6% less than Plan Six, it’s rank (4<sup>th</sup>) boosts it score considerably, even though the cost difference is relatively minor between the four most expensive plans.

## 7.0 Other Plan Considerations and Comparisons

### 7.1 Non-Wires Alternatives Considerations

Given the widespread loading concerns and MWhr totals, Battery Energy Storage was not found to be a cost-effective method for addressing capacity and reliability concerns in the area. Preliminary estimates at \$1.876M per MW<sup>16</sup> (assuming 4-hour Energy/Power ratio) far exceed Cost/MVA when compared to other alternatives. Non-Wires Alternatives were only considered for Plan 1.

<sup>16</sup> U.S. Department of Energy Hydrowires, July 2019. Energy Storage Technology and Cost Characterization Report, Table ES.1. [https://www.energy.gov/sites/prod/files/2019/07/f65/Storage%20Cost%20and%20Performance%20Characterization%20Report\\_Final.pdf](https://www.energy.gov/sites/prod/files/2019/07/f65/Storage%20Cost%20and%20Performance%20Characterization%20Report_Final.pdf)

Liberty Utilities  
System Planning  
Salem Area Study 2020

## 8.0 Conclusions and Recommendations

The goal of system planning is to provide adequate capacity for safe, reliable, and economic service to customers with minimal impact on the environment. To achieve that goal, the distribution system is planned, measured, and operated with the objective of providing electric service to customers under system intact conditions (i.e., “normal”) and first contingency conditions (“N-1”). System Planning also includes careful management of system assets; addressing asset conditions where present to avoid failures and provide a safe working environment for workers.

The seven Alternative Plans were evaluated on how they address the needs of Salem area electric supply system. Alternatives were reviewed and compared for cost-effectiveness and their ability to address system performance, operability, reliability, and future growth.

Plan One does the bare minimum to serve Tuscan Village, leaving 13.2 kV and 22.8 kV circuits mostly unavailable to re-supply during contingencies. It also has several siting and environmental concerns for diesel generation. Plan One also still leaves existing Planning Criteria violations and substation condition unresolved. For these reasons, Plan One is not recommended.

The inability to add capacity to the 22.8 kV sub transmission system effectively precludes the ability to utilize any alternatives based on any expansion or upgrade of 22.8kV/13.2kV modular feeders substations. Also refer to Section 4.3.3 for constructability challenges. For these reasons, Plans Two, Three, and Plan Seven are not recommended.

As stated in Section 5.0, Plans Four and Five were developed for this study as a hindsight review, and are not feasible or buildable. The study concludes that while these options would have been feasible if pursued, they are similar in cost to Plan Six, but do not provide the MVA capacity and ability for future growth that Plan Six provides. Plan Six also retires facilities from areas facing neighborly opposition, while Plans Four and Five expand or maintain electrical equipment closer to neighboring parcels. Plan Six installs three supply transformers to serve the area, while Plans Four and Five each install nine supply transformers. Plan Six simplifies the power delivery system in the Salem Area. Plans Four and Five conflict with Liberty’s general initiative to transition towards a 115 / 13.2kV system. For these reasons, Plans Four and Five are not recommended.

Based on the comparisons of the Alternative Plans, Plan #6 is the recommended Plan. This is recommended because this provides the best solution to the identified system issues in the Salem area which include concerns with equipment condition at the Baron Ave and Salem Depot Substations and predicted overloads in the area. It is the best plan to enable Liberty to be a locally managed Company and responsive to the needs of its customers while reducing its dependence on the transmission provider. This plan best meets the Company Distribution Planning Criteria and will allow the Company to best manage its day to day, contingency, and storm operating risks given its resource base. Unlike Plans One, Two, Three and Seven, Plan Six solves all Planning Criteria violations.

The three proposed 115 kV/13.2 kV transformers (one of which has already been installed at Golden Rock) would satisfy the capacity requirements now and into the future.

Liberty Utilities  
System Planning  
Salem Area Study 2020

It addresses the asset condition issues and safety risks by retiring end of life facilities. This eliminates the maintenance, environmental and community issues associated with the three modular feeders at Barron Ave Station and the three modular feeders at Salem Depot Station.

The installation of the new 115 kV/13.2 kV supply transformer design substations supports the integration of distribution automation and grid-modernization systems. These systems are designed to improve the operation of the distribution system. System reliability benefits from the automatic identification, isolation and minimizing of system outages along with speedy restoration to non-damaged sections. The robust nature of the updated system improves the ability to operate the system. Scheduled and emergency maintenance requirements can be addressed efficiently.

The cost per total MVA added for Plan Six is the second lowest and the cost per firm MVA added is the lowest. This means that this solution is cost-effective in providing reliable capacity today and for the future, for normal conditions and contingency scenarios.



Liberty Utilities  
System Planning  
Salem Area Study 2020

### 9.0 Appendices

#### 9.1 Appendix A – System One Lines




Figure 2 Salem 22.8 kV Supply System




Figure 3 Salem 13.2 kV Tie Map (Alternate)




Figure 4 Salem 13.2kV Distribution System





Figure 5 Alternative #1 Golden Rock Substation 115kV/13.2kV Expansion - One Line



Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Alternative #1**  
**Existing Baron Ave**



★ DEMARCATION LINE OF AUTHORITY  
 + MOBILE SUB TAP


**BARRON AVE. NO. 10**  
 NORTH & GRANITE DIVISION

**N4234**

Figure 6 Alternate #1 - Barron Ave Station - One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Alternative #1**  
**Existing Salem Depot**



★ DEMARCATION LINE OF AUTHORITY  
 + MOBILE SUB TAP


**SALEM DEPOT NO. 9**  
 NORTH & GRANITE DIVISION

**N4235**

Figure 7 Alternate #1 Salem Depot Station - One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Alternative #1**  
**Existing Spicket River**



PRINTED COPIES ARE NOT CONTROLLED.  
 FOR THE LATEST AUTHORIZED VERSION  
 PLEASE REFER TO INFONET.US.

**SPICKET RIVER NO. 13**  
 NORTH & GRANITE DIVISION

**N4240**

01-09-14

Figure 8 Alternate #1 Spicket River Station - One Line




Figure 9 Alternate #1 13.2kV Overview One Line






Figure 10 Alternative #2 Golden Rock Substation 115kV/13.2kV Expansion - One Line





Figure 11 Alternate #2 22.8 kV Overview One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Alternative #2**  
**Baron Ave Upgrade**



★ DEMARCATION LINE OF AUTHORITY  
 + MOBILE SUB TAP

**BARRON AVE. NO. 10**  
 NORTH & GRANITE DIVISION


**N4234**

Upgraded Breakers and Bus	Upgraded Transformer	Upgraded Regulator
------------------------------	-------------------------	-----------------------

Figure 12 Alternate #2 Barron Ave Station Rebuild - One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Alternative #2**  
**Salem Depot Upgrade**



★ DEMARCATION LINE OF AUTHORITY  
 + MOBILE SUB TAP

**SALEM DEPOT NO. 9**  
 NORTH & GRANITE DIVISION

**N4235**




Figure 13 Alternate #2 Salem Depot Station Rebuild - One Line






Figure 14 Alternative #3 Golden Rock Substation 115kV/13.2kV Expansion - One Line





Figure 15 Alternative #3 22.8 kV Overview One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Alternative #3**  
**Baron Ave Upgrade**



★ DEMARCATION LINE OF AUTHORITY  
 + MOBILE SUB TAP

**BARRON AVE. NO. 10**  
 NORTH & GRANITE DIVISION


**N4234.**

Upgraded Breakers and Bus	Upgraded Transformer	Upgraded Regulator
------------------------------	-------------------------	-----------------------

Figure 16 Alternate #3 Barron Ave Station Rebuild – One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Alternative #3**  
**Salem Depot Upgrade**



★ DEMARCATION LINE OF AUTHORITY  
 + MOBILE SUB TAP

**SALEM DEPOT NO. 9**  
 NORTH & GRANITE DIVISION

**N4235**

Upgraded Breakers and Bus	Upgraded Transformer	Upgraded Regulator
------------------------------	-------------------------	-----------------------

Figure 17 Alternative #3 Salem Depot Rebuild - One Line



Liberty Utilities  
 System Planning  
 Salem Area Study 2020




Figure 18 Alternative #4 22.8 kV Overview One Line





Figure 19 Alternate #4 Golden Rock Substation 115kV/22.8kV Expansion – One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Alternative #4**  
**Baron Ave Upgrade**



★ DEMARCATION LINE OF AUTHORITY  
 + MOBILE SUB TAP

**BARRON AVE. NO. 10**  
 NORTH & GRANITE DIVISION

**N4234**


Upgraded Breakers and Bus	Upgraded Transformer	Upgraded Regulator
------------------------------	-------------------------	-----------------------

Figure 20 Alternate #4 Barron Ave Station Rebuild – One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020



**Alternative #4**  
**Salem Depot Upgrade**



★ DEMARCATION LINE OF AUTHORITY  
 + MOBILE SUB TAP

**SALEM DEPOT NO. 9**  
 NORTH & GRANITE DIVISION

**N4235**



Figure 21 Alternate #4 Salem Depot Station Rebuild – One Line



Liberty Utilities  
 System Planning  
 Salem Area Study 2020




Figure 22 Alternative #5 - 22.8 kV Overview One Line





Figure 23 Alternate #5 Golden Rock Substation 115kV/22.8kV Expansion – One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

**Alternative #5**  
**Baron Ave Upgrade**



**BARRON AVE. NO. 10**  
 NORTH & GRANITE DIVISION

**N4234.**


Upgraded Breakers and Bus	Upgraded Transformer	Upgraded Regulator
------------------------------	-------------------------	-----------------------

Figure 24 Alternate #5 Barron Ave Station Rebuild – One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020



**Alternative #5**  
**Salem Depot Upgrade**



★ DEMARCATION LINE OF AUTHORITY  
 + MOBILE SUB TAP

**SALEM DEPOT NO. 9**  
 NORTH & GRANITE DIVISION

**N4235**



Figure 25 Alternate #5 Salem Depot Station Rebuild – One Line



**Alternative Plan 5-New Tuscan Village Substation**




Figure 26 Alternative #5 New 22.8 kV/13.2kV Tuscan Village Substation One Line




Figure 27 Alternative #6 13.2kV Overview One Line




Figure 28 Alternate #6 Golden Rock Substation 115kV/13,2kV Expansion Phase One - One Line




Figure 29 Alternate #6 Feeder 19L4 – One Line






Figure 30 Alternate #6 Feeder 19L6 - One Line




Figure 31 Alternate #6 Feeder 19L8 - One Line

DE 21-004  
 Technical Statement of Jay E. Dudley,  
 Ronald D. Willoughby & Joseph J. DeVirgilio  
 Attachment TS-JED/RDW/JUD-1 DOE Data Requests Set 10  
 Page 297 of 472  
 Docket No. DE 21-004  
 Attachment DOE 10-1.e.2  
 Page 76 of 245




Figure 32 Alternative #6 Rockingham Substation 115kV/13.2kV Phase Two - One Line

Liberty Utilities  
 System Planning  
 Salem Area Study 2020



Figure 33 Proposed Plan #6 115kV Route







Figure 34 Alternate #6 New Rockingham Station - Feeder 21L1 - One Line



Synergi Electric, Version 6.2.0.134, 29Oct2018

Scale: (1 in = 3822.6 Feet)

Issued to Liberty Utilities (EnergyNorth Natural)

Figure 35 Alternate #6 New Rockingham Station – Feeder 21L5 - One Line





Figure 36 Alternate #6 New Rockingham Station – Feeder 21L6 - One Line



Rockingham 115 kV Plan  
 Rockingham 21L7 and 21L8 feeders  
 Tuscan South Development Supply



Synergi Electric, Version 6.2.0.134, 29Oct2018

Scale: (1 in = 980.5 Feet)

Issued to Liberty Utilities (EnergyNorth Natural)

Figure 37 Alternate #6 New Rockingham Station – Feeder 21L7 & 21L8 - One Line

DE 21-004  
 Technical Statement of Jay E. Dudley,  
 Ronald D. Willoughby & Joseph J. DeVirgilio  
 Attachment TS-JED/RDW/JJD-1 DOE Data Requests Set 10  
 Page 303 of 472  
 Docket No. DE 21-004  
 Attachment DOE 10-1.e.2  
 Page 82 of 245






Figure 38 Alternative #7 Golden Rock Substation 115kV/13.2kV Expansion – One Line




Figure 39 Alternate #7 Barron Ave 10L1 – One Line




Figure 40 Alternate #7 Golden Rock 19L4 – One Line




Figure 41 Alternate #7 Golden Rock 19L6 - One Line






Figure 42 Alternate #7 Olde Trolley 18L2 and 18L4 – One Line




Figure 43 Alternate #7 Pelham 14L4 and 14L6 – One Line




Figure 44 Alternative #7 Spicket River 13L3 - One Line

9.2 Appendix B – Asset Condition Documents




Figure 45 Barron Ave Conceptual Station Equipment Layout






Figure 46 Salem Depot Conceptual Station Equipment Layout



Figure 47 Barron Ave Site Layout




Figure 48 Salem Depot Site Layout




Figure 49 Barron Ave 10L1 Clearance Sketch






Figure 50 Barron Ave 10L2 Clearance Sketch




Figure 51 Barron Ave 10L4 Clearance Sketch




Figure 52 Salem Depot 9L1 Clearance Sketch




Figure 53 Salem Depot 9L2 Clearance Sketch






Figure 54 Salem Depot 9L3 Clearance Sketch

### 9.3 Appendix C – Area Loading Analysis

#### Base Case - 2019

Salem NH Feeder Analysis														
Study Area	Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2019			2022			2036		
						Amps	N-1	%SN	Amps	N-1	%SN	Amps	N-1	%SN
						Salem NH	BARRON AVENUE 10	13.2	10L1	387	462	107	355	28%
Salem NH	BARRON AVENUE 10	13.2	10L2	526	578	268	310	51%	290	288	55%	299	279	57%
Salem NH	BARRON AVENUE 10	13.2	10L4	339	339	176	163	52%	193	146	57%	198	141	59%
Salem NH	OLDE TROLLEY 18	13.2	18L1	503	565	133	432	27%	221	344	44%	227	338	45%
Salem NH	OLDE TROLLEY 18	13.2	18L2	503	515	404	111	80%	384	131	76%	396	119	79%
Salem NH	OLDE TROLLEY 18	13.2	18L3	515	515	375	140	73%	346	169	67%	356	159	69%
Salem NH	OLDE TROLLEY 18	13.2	18L4	516	612	387	225	75%	488	124	95%	502	110	97%
Salem NH	PELHAM 14	13.2	14L4	530	589	44	545	8%	392	197	74%	404	185	76%
Salem NH	SALEM DEPOT 9	13.2	9L1	322	371	271	100	84%	470	-99	146%	484	-113	150%
Salem NH	SALEM DEPOT 9	13.2	9L2	322	371	224	147	70%	292	79	91%	301	70	93%
Salem NH	SALEM DEPOT 9	13.2	9L3	507	507	319	188	63%	391	116	77%	402	105	79%
Salem NH	SPICKET RIVER 13	13.2	13L1	515	515	326	189	63%	352	163	68%	363	152	70%
Salem NH	SPICKET RIVER 13	13.2	13L2	515	515	290	225	56%	316	199	61%	325	190	63%
Salem NH	SPICKET RIVER 13	13.2	13L3	522	522	442	80	85%	463	59	89%	477	45	91%

Table 9 Base Case - Normal Configuration – 13.2 kV Feeder Loading

Salem NH Transformer Analysis																
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)										
			From	To		2019		2022		2036						
						MVA	% SN	MVA	% SN	MVA	% SN					
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.7	91.6	56.9	34.7	72%	68.6	23.0	87%	70.6	21.0	90%
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.4	10.9	2.4	8.5	26%	2.7	8.2	29%	2.8	8.1	29%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.6	14.2	6.1	8.1	45%	6.6	7.6	49%	6.8	7.4	50%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.1	10.3	4.0	6.3	44%	4.4	5.9	48%	4.5	5.8	50%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.4	12.9	3.0	9.9	25%	5.0	7.9	41%	5.2	7.7	42%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.4	12.9	9.2	3.7	75%	8.8	4.1	71%	9.0	3.9	73%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.5	13	8.6	4.4	69%	7.9	5.1	63%	8.1	4.9	65%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.5	13	8.8	4.2	71%	11.2	1.8	89%	11.5	1.5	92%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.1	6.2	3.9	84%	10.7	-0.6	146%	11.1	-1.0	150%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.2	5.1	4.1	70%	6.7	2.5	91%	6.9	2.3	93%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.6	11.6	7.3	4.3	63%	8.9	2.7	77%	9.2	2.4	79%
Salem NH	SALEM DEPOT 13	L1	23	13.2	9.375	14.4	14.4	7.5	6.9	52%	8.1	6.3	56%	8.3	6.1	58%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	6.6	7.8	48%	7.2	7.2	52%	7.4	7.0	53%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	10.1	4.3	73%	10.6	3.8	76%	10.9	3.5	78%

Table 10 Base Case - Normal Configuration - Transformer Loading

Salem NH Supply Line Analysis														
Study Area	Circuit	Voltage	Line Section		Element	Rating (MVA)			Projected Load					
			From	To		Limiting	SN	SE	2019		2022		2036	
									MVA	%SN	MVA	%SN	MVA	%SN
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	2-1000 Cu	54.8	65.4	30.9	56%	40.2	73%	41.4	75%	
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	1113 ACSR	56.4	72.5	30.9	55%	40.2	71%	41.4	73%	
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	Recloser	31.9	31.9	12.3	39%	13.8	43%	14.2	45%	
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	Relay	27.1	27.1	18.6	69%	26.4	97%	27.1	100%	
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	2-1000 Cu	54.8	65.4	26.0	47%	28.4	52%	29.2	53%	
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	795 ACSR	45.2	58.2	17.4	38%	19.1	42%	19.6	43%	
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	UG Cable	31.9	31.9	17.4	55%	19.1	60%	19.6	62%	
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	Recloser	27.1	27.1	0.0	0%	0.0	0%	0.0	0%	
Methuen	2353	23	Meth Jcnctn	Golden Rock	Relay	23.9	23.9	4.0	17%	0.0	0%	0.0	0%	
Methuen	2376	23	Meth Jcnctn	Golden Rock	Relay	23.9	23.9	23.9	0%	0.0	0%	0.0	0%	
Methuen	2376	23	SPICKET RIVER TAP	SPICKET RIVER	OH Line	35.9	40.7	24.2	67%	25.9	72%	27.3	76%	

Table 11 Base Case 2019 Supply Line Normal Loading

Salem NH Transformer Contingency Analysis															
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum		Rating (MVA)		Projected Contingency						
			From	To	Nameplate Rating	SN	SE	2019		2022		2036			
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.70	91.60	0.0	0.0	0%	0%	0.0	0%	0.0	0%
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.40	10.90	4.2	39%	7.0	64%	7.2	66%	7.2	66%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.60	14.20	4.2	30%	7.0	49%	7.2	51%	7.2	51%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.10	10.30	4.2	41%	7.0	68%	7.2	70%	7.2	70%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.40	12.90	9.9	77%	11.3	88%	11.6	90%	11.6	90%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.40	12.90	9.9	77%	11.3	88%	11.6	90%	11.6	90%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.50	13.00	9.9	76%	11.3	87%	11.6	90%	11.6	90%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.50	13.00	9.9	76%	11.3	87%	11.6	90%	11.6	90%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.10	4.7	46%	12.0	119%	12.4	123%	12.4	123%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.20	4.7	51%	12.0	131%	12.4	135%	12.4	135%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.60	11.60	4.7	40%	12.0	104%	12.4	107%	12.4	107%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.40	14.40	12.1	84%	13.4	93%	13.8	96%	13.8	96%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.90	14.40	12.1	84%	13.4	93%	13.8	96%	13.8	96%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.90	14.40	12.1	84%	13.4	93%	13.8	96%	13.8	96%

Table 12 Base Case 2019 Transformer Contingency Loading

Salem NH Supply Line Contingency Analysis															
Study Area	Circuit	Voltage (kV)	Line Section		Rating (MVA)		2019		2022		2036				
			From	To	SN	SE	MVA	Load > SE	% SE	MVA	Load > SE	% SE	MVA	Load > SE	% SE
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	48.3	0.0	74%	59.3	0.0	91%	61.0	0.0	93%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	48.3	0.0	67%	59.3	0.0	82%	61.0	0.0	84%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley Tap	31.9	31.9	29.7	0.0	93%	32.9	1.0	103%	33.9	2.0	106%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	26.4	0.0	97%	27.1	0.0	100%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	56.9	0.0	87%	68.6	3.2	105%	70.6	5.2	108%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	56.9	0.0	98%	68.6	10.4	118%	70.6	12.4	121%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley Tap	31.9	31.9	29.7	0.0	93%	32.9	1.0	103%	33.9	2.0	106%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	26.4	0.0	97%	27.1	0.0	100%
Methuen MA	2353	23	Meth Jnctn	Golden Rock	23.9	23.9	34.9	11.0	146%	44.6	20.7	187%	47.1	23.2	197%
Methuen MA	2376	23	Meth Jnctn	Golden Rock	23.9	23.9	26.0	2.1	109%	28.4	4.5	119%	30.0	6.1	125%
Methuen MA	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	0.0	59%	25.9	0.0	64%	27.3	0.0	67%

Table 13 Base Case 2019 Supply Line Contingency Loads



Base Case - Golden Rock 115/13.2 kV in Service

Salem NH Feeder Analysis											
Study Area	Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2022			2036		
						Amps	N-1	%SN	Amps	N-1	%SN
Salem NH	BARRON AVENUE 10	13.2	10L1	387	462	0	462	0%	0	462	0%
Salem NH	BARRON AVENUE 10	13.2	10L2	526	578	0	578	0%	0	578	0%
Salem NH	BARRON AVENUE 10	13.2	10L4	339	339	0	339	0%	0	339	0%
Salem NH	OLDE TROLLEY 18	13.2	18L1	503	565	196	369	39%	202	363	40%
Salem NH	OLDE TROLLEY 18	13.2	18L2	503	515	336	179	67%	346	169	69%
Salem NH	OLDE TROLLEY 18	13.2	18L3	515	515	433	82	84%	446	69	87%
Salem NH	OLDE TROLLEY 18	13.2	18L4	516	612	480	132	93%	494	118	96%
Salem NH	PELHAM 14	13.2	14L4	530	589	292	297	55%	301	288	57%
Salem NH	SALEM DEPOT 9	13.2	9L1	322	371	320	51	99%	329	42	102%
Salem NH	SALEM DEPOT 9	13.2	9L2	322	371	242	129	75%	249	122	77%
Salem NH	SALEM DEPOT 9	13.2	9L3	507	507	386	121	76%	397	110	78%
Salem NH	SPICKET RIVER 13	13.2	13L1	515	515	470	45	91%	484	31	94%
Salem NH	SPICKET RIVER 13	13.2	13L2	515	515	352	163	68%	362	153	70%
Salem NH	SPICKET RIVER 13	13.2	13L3	522	522	344	178	66%	354	168	68%
Salem NH	GOLDEN ROCK 19	13.2	19L4	530	589	76	513	14%	78	511	15%
Salem NH	GOLDEN ROCK 19	13.2	19L6	530	589	233	356	44%	240	349	45%
Salem NH	GOLDEN ROCK 19	13.2	19L8	530	589	212	377	40%	218	371	41%

Table 14 Base Case (w/ Golden Rock 13.2 kV) Feeder Normal Loading

Salem NH Transformer Analysis														
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)			Projected Load 2022			Projected Load 2036		
			From	To		SN	SE	MVA	N-1	% SN	MVA	N-1	% SN	
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.4	10.9	0.0	10.9	0%	0.0	10.9	0%	
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.6	14.2	0.0	14.2	0%	0.0	14.2	0%	
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.1	10.3	0.0	10.3	0%	0.0	10.3	0%	
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.4	12.9	4.5	8.4	36%	4.6	8.3	37%	
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.4	12.9	7.7	5.2	62%	7.9	5.0	64%	
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.5	13	9.9	3.1	79%	10.2	2.8	82%	
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.5	13	11.0	2.0	88%	11.3	1.7	90%	
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.1	7.3	2.8	99%	7.5	2.6	102%	
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.2	5.5	3.7	75%	5.7	3.5	77%	
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.6	11.6	8.8	2.8	76%	9.1	2.5	78%	
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.4	14.4	10.7	3.7	75%	11.1	3.3	77%	
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	8.0	6.4	58%	8.3	6.1	60%	
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	7.9	6.5	57%	8.1	6.3	58%	
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	83.9	94.4	11.9	82.5	14%	12.3	82.1	15%	

Table 15 Base Case (w/ Golden Rock 13.2 kV) Transformer Normal Loads

Salem NH Supply Line Analysis										
Study Area	Circuit	Voltage	Line Section				Rating (MVA)		Projected Load	
			From	To	SN	SE	2022 MVA	2022 %SN	2036 MVA	2036 %SN
Salem NH	2352	23 Golden Rock	Barron Ave. Tap		54.7	67.4	33.8	62%	34.8	64%
Salem NH	2352	23 Barron Ave. Tap	Olde Trolley Tap		72.5	72.5	33.8	47%	34.8	48%
Salem NH	2352	23 Olde Trolley Tap	Olde Trolley		31.9	31.9	12.2	38%	12.5	39%
Salem NH	2352	23 Olde Trolley Tap	Salem Depot #9		27.1	27.1	21.7	80%	22.3	82%
Salem NH	2393	23 Golden Rock	Barron Ave. Tap		54.7	67.4	20.9	38%	21.5	39%
Salem NH	2393	23 Barron Ave. Tap	Olde Trolley Tap		45.2	58.2	20.9	46%	21.5	48%
Salem NH	2393	23 Olde Trolley Tap	Olde Trolley		31.9	31.9	20.9	65%	21.5	67%
Salem NH	2393	23 Olde Trolley Tap	Salem Depot #9		27.1	27.1	0.0	0%	0.0	0%
Methuen	2353	23 Meth Jcnctn	Golden Rock		23.9	23.9	0.0	0%	0.0	0%
Methuen	2376	23 Meth Jcnctn	Golden Rock		23.9	23.9				
Methuen	2376	23 SPICKET RIVER TAP	SPICKET RIVER		35.9	40.7	26.7	74%	28.1	78%

Table 16 Base Case (w/ Golden Rock 13.2 kV) Supply Line Normal Loading

Salem NH Transformer Contingency Analysis											
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Contingency			
			From	To		SN	SE	2022 MVA	2022 %SE	2036 MVA	2036 %SE
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.40	10.90	0.0	0%	0.0	0%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.60	14.20	0.0	0%	0.0	0%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.10	10.30	0.0	0%	0.0	0%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.40	12.90	12.6	98%	13.0	101%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.40	12.90	12.6	98%	13.0	101%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.50	13.00	12.6	97%	13.0	100%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.50	13.00	12.6	97%	13.0	100%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.10	12.0	119%	12.4	123%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.20	12.0	131%	12.4	135%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.60	11.60	12.0	104%	12.4	107%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.40	14.40	10.7	75%	11.1	77%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.90	14.40	10.7	75%	11.1	77%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.90	14.40	10.7	75%	11.1	77%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	83.90	94.40	35.2	37%	36.2	38%

Table 17 Base Case (w/ Golden Rock 13.2 kV) Transformer Contingency Loading

Salem NH Supply Line Contingency Analysis												
Study Area	Circuit	Voltage (kV)	Line Section		Rating (MVA)		Projected Contingency					
			From	To	SN	SE	2022			2036		
							MVA	Load > SE	% SE	MVA	Load > SE	% SE
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.7	67.4	66.6	0.0	99%	68.6	1.2	102%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	72.5	72.5	66.6	0.0	92%	68.6	0.0	95%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	33.0	1.1	104%	34.0	2.1	107%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	21.7	0.0	80%	22.3	0.0	82%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.7	67.4	66.6	0.0	99%	68.6	1.2	102%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	66.6	8.5	115%	68.6	10.4	118%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	33.0	1.1	104%	34.0	2.1	107%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	21.7	0.0	80%	22.3	0.0	82%
Methuen MA	2353	23	Meth Jcnctn	Golden Rock	23.9	23.9	33.8	9.9	142%	35.7	11.8	149%
Methuen MA	2376	23	Meth Jcnctn	Golden Rock	23.9	23.9	20.9	0.0	87%	22.0	0.0	92%
Methuen MA	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	26.7	0.0	65%	28.1	0.0	69%

Table 18 Base Case (w/ Golden Rock 13.2 kV) Supply Line Contingency Loading



Alternative Plan #1 Loading

Salem NH Feeder Analysis														
Study Area	Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2019			2022			2036		
						Amps	N-1	%SN	Amps	N-1	%SN	Amps	N-1	%SN
						Salem NH	BARRON AVENUE 10	13.2 10L1		387	462	107	355	28%
Salem NH	BARRON AVENUE 10	13.2 10L2		526	578	268	310	51%	320	258	61%	330	248	63%
Salem NH	BARRON AVENUE 10	13.2 10L4		339	339	176	163	52%	260	79	77%	268	71	79%
Salem NH	OLDE TROLLEY 18	13.2 18L1		503	565	133	432	27%	196	369	39%	201	364	40%
Salem NH	OLDE TROLLEY 18	13.2 18L2		503	515	404	111	80%	6	509	1%	6	509	1%
Salem NH	OLDE TROLLEY 18	13.2 18L3		515	515	375	140	73%	349	166	68%	359	156	70%
Salem NH	OLDE TROLLEY 18	13.2 18L4		516	612	387	225	75%	204	408	40%	210	402	41%
Salem NH	PELHAM 14	13.2 14L4		530	589	44	545	8%	317	272	60%	326	263	62%
Salem NH	SALEM DEPOT 9	13.2 9L1		322	371	271	100	84%	302	69	94%	311	60	97%
Salem NH	SALEM DEPOT 9	13.2 9L2		322	371	224	147	70%	240	131	75%	247	124	77%
Salem NH	SALEM DEPOT 9	13.2 9L3		507	507	319	188	63%	391	116	77%	402	105	79%
Salem NH	SPICKET RIVER 13	13.2 13L1		515	515	326	189	63%	358	157	70%	369	146	72%
Salem NH	SPICKET RIVER 13	13.2 13L2		515	515	290	225	56%	225	290	44%	232	283	45%
Salem NH	SPICKET RIVER 13	13.2 13L3		522	522	442	80	85%	483	39	93%	497	25	95%
Salem NH	GOLDEN ROCK 19	13.2 19L4		530	589		589	0%	77	512	14%	79	510	15%
Salem NH	GOLDEN ROCK 19	13.2 19L6		530	589		589	0%	246	343	46%	252	337	48%
Salem NH	GOLDEN ROCK 19	13.2 19L8		530	589		589	0%	359	230	68%	369	220	70%

Table 19 Alt #1 Feeder Normal Loading

Salem NH Transformer Analysis																
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)				Projected Load						
			From	To		SN	SE	2019		2022		2036				
								MVA	% SN	MVA	% SN	MVA	% SN			
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.4	10.9	2.4	8.5	28%	10.6	0.3	113%	10.9	0.0	116%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.6	14.2	6.1	8.1	45%	7.3	6.9	54%	7.5	6.7	55%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.1	10.3	4.0	6.3	44%	5.9	4.4	65%	6.1	4.2	67%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.4	12.9	3.0	9.9	25%	4.5	8.4	36%	4.6	8.3	37%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.4	12.9	9.2	3.7	75%	0.1	12.8	1%	0.1	12.8	1%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.5	13	8.6	4.4	69%	8.0	5.0	64%	8.2	4.8	66%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.5	13	8.8	4.2	71%	4.7	8.3	37%	4.8	8.2	38%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.1	6.2	3.9	84%	6.9	3.2	94%	7.1	3.0	97%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.2	5.1	4.1	70%	5.5	3.7	75%	5.6	3.6	77%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.6	11.6	7.3	4.3	63%	8.9	2.7	77%	9.2	2.4	79%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.4	14.4	7.5	6.9	52%	8.2	6.2	57%	8.4	6.0	59%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	6.6	7.8	48%	5.1	9.3	37%	5.3	9.1	38%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	10.1	4.3	73%	11.0	3.4	79%	11.4	3.0	82%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.7	91.6	0.0	91.6	0%	15.6	76.0	20%	16.0	75.6	20%

Table 20 Alt #1 Transformer Normal Loading

Salem NH Supply Line Analysis													
Study Area	Circuit	Voltage	Line Section		Rating (MVA)				Projected Load				
			From	To	SN	SE	2019		2022		2036		
							MVA	%SN	MVA	%SN	MVA	%SN	
Salem NH	2352	23 Golden Rock	Barron Ave. Tap	54.8	65.4	30.9	56%	25.9	47%	26.7	49%		
Salem NH	2352	23 Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	30.9	55%	25.9	46%	26.7	47%		
Salem NH	2352	23 Olde Trolley Tap	Olde Trolley	31.9	31.9	12.3	39%	4.6	14%	4.7	15%		
Salem NH	2352	23 Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	69%	21.3	79%	22.0	81%		
Salem NH	2393	23 Golden Rock	Barron Ave. Tap	54.8	65.4	26.0	47%	30.6	56%	31.5	57%		
Salem NH	2393	23 Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	17.4	38%	12.6	28%	13.0	29%		
Salem NH	2393	23 Olde Trolley Tap	Olde Trolley	31.9	31.9	17.4	55%	12.6	40%	13.0	41%		
Salem NH	2393	23 Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0%	0.0	0%	0.0	0%		
Methuen	2353	23 Meth Jnctn	Golden Rock	23.9	23.9	4.0	17%	0.0	0%	0.0	0%		
Methuen	2376	23 Meth Jnctn	Golden Rock	23.9	23.9	0%	0%	0%	0%	0%	0%		
Methuen	2376	23 SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	67%	24.4	68%	25.7	72%		

Table 21 Alt #1 Supply Line Normal Loading

Salem NH Transformer Contingency Analysis													
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Contingency					
			From	To		SN	SE	2019		2022		2036	
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.40	10.90	6.3	58%	8.8	80%	9.0	83%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.60	14.20	6.3	44%	8.8	62%	9.0	63%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.10	10.30	6.3	61%	8.8	85%	9.0	87%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.40	12.90	9.9	77%	11.5	89%	11.8	92%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.40	12.90	9.9	77%	11.5	89%	11.8	92%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.50	13.00	9.9	76%	11.5	88%	11.8	91%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.50	13.00	9.9	76%	11.5	88%	11.8	91%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.10	9.3	92%	9.3	92%	9.6	95%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.20	9.3	101%	9.3	101%	9.6	104%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.60	11.60	9.3	80%	9.3	80%	9.6	82%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.40	14.40	12.1	84%	8.4	58%	8.7	60%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.90	14.40	12.1	84%	8.4	58%	8.7	60%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.90	14.40	12.1	84%	8.4	58%	8.7	60%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.70	91.60	8.4	9%	17.0	19%	17.5	19%

Table 22 Alt #1 Transformer Contingency Loading

Salem NH Supply Line Contingency Analysis															
Study Area	Circuit	Voltage (kV)	Line Section		Rating (MVA)		2019		2022		2036				
			From	To	SN	SE	MVA	Load > SE	% SE	MVA	Load > SE	% SE			
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	48.3	0.0	74%	38.6	0.0	59%	39.7	0.0	61%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	48.3	0.0	67%	38.6	0.0	53%	39.7	0.0	55%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	17.2	0.0	54%	17.8	0.0	56%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	21.3	0.0	79%	22.0	0.0	81%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	56.9	0.0	87%	56.5	0.0	86%	58.2	0.0	89%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	56.9	0.0	98%	56.5	0.0	97%	58.2	0.0	100%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	17.2	0.0	54%	17.8	0.0	56%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	21.3	0.0	79%	22.0	0.0	81%
Methuen MA	2353	23	Meth Jnctn	Golden Rock	23.9	23.9	34.9	11.0	146%	31.9	8.0	133%	33.7	9.7	141%
Methuen MA	2376	23	Meth Jnctn	Golden Rock	23.9	23.9	26.0	2.1	109%	30.6	6.7	128%	32.2	8.3	135%
Methuen MA	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	0.0	59%	24.4	0.0	60%	25.7	0.0	63%

Table 23 Alt #1 Supply Line Contingency Loading

Alternative #2 Loading

Salem NH Feeder Analysis														
Study Area	Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2019			2022			2036		
						Amps	N-1	%SN	Amps	N-1	%SN	Amps	N-1	%SN
						Salem NH	BARRON AVENUE 10	13.2	10L1	387	462	107	355	28%
Salem NH	BARRON AVENUE 10	13.2	10L2	526	578	268	310	51%	259	319	49%	266	312	51%
Salem NH	BARRON AVENUE 10	13.2	10L4	339	339	176	163	52%	181	397	34%	186	392	35%
Salem NH	OLDE TROLLEY 18	13.2	18L1	503	565	133	432	27%	217	348	43%	223	342	44%
Salem NH	OLDE TROLLEY 18	13.2	18L2	503	515	404	111	80%	44	471	9%	45	470	9%
Salem NH	OLDE TROLLEY 18	13.2	18L3	515	515	375	140	73%	349	166	68%	359	156	70%
Salem NH	OLDE TROLLEY 18	13.2	18L4	516	612	387	225	75%	205	407	40%	211	401	41%
Salem NH	PELHAM 14	13.2	14L4	530	589	44	545	8%	317	272	60%	326	263	62%
Salem NH	SALEM DEPOT 9	13.2	9L1	322	371	271	100	84%	303	275	58%	312	266	59%
Salem NH	SALEM DEPOT 9	13.2	9L2	322	371	224	147	70%	288	290	55%	297	281	57%
Salem NH	SALEM DEPOT 9	13.2	9L3	507	507	319	188	63%	391	187	74%	402	176	77%
Salem NH	SPICKET RIVER 13	13.2	13L1	515	515	326	189	63%	347	168	67%	357	158	69%
Salem NH	SPICKET RIVER 13	13.2	13L2	515	515	290	225	56%	312	203	61%	321	194	62%
Salem NH	SPICKET RIVER 13	13.2	13L3	522	522	442	80	85%	386	136	74%	397	125	76%
Salem NH	GOLDEN ROCK 19	13.2	19L4	530	589		589	0%	84	528	16%	87	525	17%
Salem NH	GOLDEN ROCK 19	13.2	19L6	530	589		589	0%	313	299	60%	322	290	61%
Salem NH	GOLDEN ROCK 19	13.2	19L8	530	589		589	0%	413	199	79%	425	187	81%

Table 24 Alt #2 Feeder Normal Loading



Salem NH Transformer Analysis																
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)			Projected Load							
			From	To		SN	SE	2019		2022		2036				
								MVA	% SN	MVA	% SN	MVA	% SN			
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.7	91.6	56.9	34.7	72%	56.7	34.9	72%	58.4	33.2	74%
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.4	10.9	2.4	8.5	28%	9.8	1.1	78%	10.0	3.0	80%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.6	14.2	6.1	8.1	45%	5.9	8.3	43%	6.1	8.1	45%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.1	10.3	4.0	6.3	44%	4.1	6.2	33%	4.3	8.7	34%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.4	12.9	3.0	9.9	25%	5.0	7.9	40%	5.1	7.8	41%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.4	12.9	9.2	3.7	75%	1.0	11.9	8%	1.0	11.9	8%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.5	13	8.6	4.4	69%	8.0	5.0	64%	8.2	4.8	66%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.5	13	8.8	4.2	71%	4.7	8.3	37%	4.8	8.2	39%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.1	6.2	3.9	84%	6.9	3.2	55%	7.1	5.9	57%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.2	5.1	4.1	70%	6.6	2.6	53%	6.8	6.2	54%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.6	11.6	7.3	4.3	63%	8.9	2.7	77%	9.2	2.4	79%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.4	14.4	7.5	6.9	52%	7.9	6.5	55%	8.2	6.2	57%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	6.6	7.8	48%	7.1	7.3	51%	7.3	7.1	53%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	10.1	4.3	73%	8.8	5.6	63%	9.1	5.3	65%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.7	91.6	0.0	91.6	0%	18.5	73.1	24%	19.1	72.5	24%

Table 25 Alt #2 Transformer Normal Loading

Salem NH Supply Line Analysis													
Study Area	Circuit	Voltage	Line Section		Rating (MVA)			Projected Load					
			From	To	SN	SE	2019		2022		2036		
							MVA	%SN	MVA	%SN	MVA	%SN	
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	30.9	56%	28.4	52%	29.2	53%	
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	30.9	55%	28.4	50%	29.2	52%	
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	12.3	39%	6.0	19%	6.1	19%	
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	69%	22.4	83%	23.1	85%	
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	26.0	47%	28.3	52%	29.2	53%	
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	17.4	38%	12.7	28%	13.0	29%	
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	17.4	55%	12.7	40%	13.0	41%	
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0%	0.0	0%	0.0	0%	
Methuen	2353	23	Meth Jcnctn	Golden Rock	23.9	23.9	4.0	17%	0.0	0%	0.0	0%	
Methuen	2376	23	Meth Jcnctn	Golden Rock	23.9	23.9	0.0	0%	0.0	0%	0.0	0%	
Methuen	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	67%	23.9	67%	25.2	70%	

Table 26 Alt #2 Supply Line Normal Loading

Salem NH Transformer Contingency Analysis													
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Rating		Projected Contingency						
			From	To	SN	SE	2019		2022		2036		
							MVA	% SE	MVA	% SE	MVA	% SE	
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.40	10.90	6.3	58%	11.3	87%	11.6	89%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.60	14.20	6.3	44%	11.3	79%	11.6	82%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.10	10.30	6.3	61%	11.3	87%	11.6	89%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.40	12.90	9.9	77%	11.5	89%	11.8	92%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.40	12.90	9.9	77%	11.5	89%	11.8	92%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.50	13.00	9.9	76%	11.5	88%	11.8	91%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.50	13.00	9.9	76%	11.5	88%	11.8	91%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.10	9.3	92%	11.8	91%	12.1	93%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.20	9.3	101%	11.8	91%	12.1	93%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.60	11.60	9.3	80%	11.8	102%	12.1	105%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.40	14.40	12.1	84%	13.4	93%	13.8	96%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.90	14.40	12.1	84%	13.4	93%	13.8	96%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.90	14.40	12.1	84%	13.4	93%	13.8	96%
Salem NH	PELHAM 14	T1	115	13.2	40	50.30	56.00	8.4	15%	17.0	30%	17.5	31%
Salem NH	PELHAM 14	T2	115	13.2	40	50.30	56.00	8.4	15%	17.0	30%	17.5	31%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.70	91.60		0%		0%		0%

Table 27 Alt #2 Transformer Contingency Loading

Salem NH Supply Line Contingency Analysis															
Study Area	Circuit	Voltage (kV)	Line Section		Rating (MVA)		Projected Contingency								
			From	To	SN	SE	2019		2022		2036				
							MVA	Load > SE	MVA	Load > SE	MVA	Load > SE			
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	48.3	0.0	74%	41.1	0.0	63%	42.3	0.0	65%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	48.3	0.0	67%	41.1	0.0	57%	42.3	0.0	58%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	18.6	0.0	58%	19.2	0.0	60%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	22.4	0.0	83%	23.1	0.0	85%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	56.9	0.0	87%	56.7	0.0	87%	58.4	0.0	89%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	56.9	0.0	98%	56.7	0.0	98%	58.4	0.2	100%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	18.6	0.0	58%	19.2	0.0	60%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	22.4	0.0	83%	23.1	0.0	85%
Methuen MA	2353	23	Meth Jnctn	Golden Rock	23.9	23.9	34.9	11.0	145%	32.5	8.6	136%	34.3	10.4	144%
Methuen MA	2376	23	Meth Jnctn	Golden Rock	23.9	23.9	26.0	2.1	109%	28.3	4.4	119%	29.9	6.0	125%
Methuen MA	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	0.0	59%	23.9	0.0	59%	25.2	0.0	62%

Table 28 Alt #2 Supply Line Contingency Loading

Alternative #3 Loading

Salem NH Feeder Analysis														
Study Area	Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2019			2022			2036		
						Amps	N-1	%SN	Amps	N-1	%SN	Amps	N-1	%SN
Salem NH	BARRON AVENUE 10	13.2	10L1	387	462	107	355	28%	460	118	88%	473	105	90%
Salem NH	BARRON AVENUE 10	13.2	10L2	526	578	268	310	51%	276	302	52%	284	294	54%
Salem NH	BARRON AVENUE 10	13.2	10L4	339	339	176	163	52%	181	397	34%	186	392	35%
Salem NH	OLDE TROLLEY 18	13.2	18L1	503	565	133	432	27%	217	348	43%	224	341	44%
Salem NH	OLDE TROLLEY 18	13.2	18L2	503	515	404	111	80%	44	471	9%	45	470	9%
Salem NH	OLDE TROLLEY 18	13.2	18L3	515	515	375	140	73%	341	174	66%	351	164	68%
Salem NH	OLDE TROLLEY 18	13.2	18L4	516	612	387	225	75%	204	408	40%	210	402	41%
Salem NH	PELHAM 14	13.2	14L4	530	589	44	545	8%	317	272	60%	326	263	62%
Salem NH	SALEM DEPOT 9	13.2	9L1	322	371	271	100	84%	219	359	42%	226	352	43%
Salem NH	SALEM DEPOT 9	13.2	9L2	322	371	224	147	70%	288	290	55%	297	281	56%
Salem NH	SALEM DEPOT 9	13.2	9L3	507	507	319	188	63%	391	187	74%	402	176	77%
Salem NH	SPICKET RIVER 13	13.2	13L1	515	515	326	189	63%	168	347	33%	173	342	34%
Salem NH	SPICKET RIVER 13	13.2	13L2	515	515	290	225	56%	146	369	28%	150	365	29%
Salem NH	SPICKET RIVER 13	13.2	13L3	522	522	442	80	85%	102	420	19%	105	417	20%
Salem NH	GOLDEN ROCK 19	13.2	19L4	530	589		589	0%	84	528	16%	86	526	16%
Salem NH	GOLDEN ROCK 19	13.2	19L6	530	589		589	0%	542	70	103%	558	54	106%
Salem NH	GOLDEN ROCK 19	13.2	19L8	530	589		589	0%	275	337	52%	283	329	54%
Salem NH	BARRON AVENUE 10	13.2	10L5	516	589		589	0%	121	468	23%	125	464	24%
Salem NH	SALEM DEPOT 9	13.2	9L4	516	589		589	0%	8	581	2%	8	581	2%
Salem NH	SALEM DEPOT 9	13.2	9L5	516	589		589	0%	466	123	90%	480	109	93%

Table 29 Alt #3 Feeder Normal Loading

Salem NH Transformer Analysis																
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)										
			From	To		SN	SE	MVA	N-1	%SN	MVA	N-1	%SN	MVA	N-1	%SN
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.4	10.9	2.4	8.5	26%	10.5	0.4	84%	10.8	2.2	87%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.6	14.2	6.1	8.1	45%	6.3	7.9	46%	6.5	7.7	48%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.1	10.3	4.0	6.3	44%	4.1	6.2	33%	4.3	8.7	34%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.4	12.9	3.0	9.9	25%	5.0	7.9	40%	5.1	7.8	41%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.4	12.9	9.2	3.7	75%	1.0	11.9	8%	1.0	11.9	8%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.5	13	8.6	4.4	69%	7.8	5.2	62%	8.0	5.0	64%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.5	13	8.8	4.2	71%	4.7	8.3	37%	4.8	8.2	38%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.1	6.2	3.9	84%	5.0	5.1	40%	5.2	7.8	41%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.2	5.1	4.1	70%	6.6	2.6	53%	6.8	6.2	54%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.6	11.6	7.3	4.3	63%	8.9	2.7	77%	9.2	2.4	79%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.4	14.4	7.5	6.9	52%	3.9	10.5	27%	4.0	10.4	28%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	6.6	7.8	48%	3.3	11.1	24%	3.4	11.0	25%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	10.1	4.3	73%	2.3	12.1	17%	2.4	12.0	17%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.7	91.6	0.0	91.6	0%	20.6	71.0	26%	21.2	70.4	27%
Salem NH	BARRON AVENUE 10	L5	23	13.2	9.375	14.4	14.4	0.0	14.4	0%	2.8	11.6	19%	2.8	11.4	21%
Salem NH	SALEM DEPOT 9	L4	23	13.2	9.375	14.4	14.4	0.0	14.4	0%	0.2	14.2	1%	0.2	14.0	1%
Salem NH	SALEM DEPOT 9	L5	23	13.2	9.375	14.4	14.4	0.0	14.4	0%	10.7	3.7	74%	11.0	3.2	81%

Table 30 Alt #3 Transformer Normal Loading

Salem NH Supply Line Analysis													
Study Area	Circuit	Voltage	Line Section		Rating (MVA)			Projected Load					
			From	To	SN	SE	MVA	2019 MVA	2019 %SN	2022 MVA	2022 %SN	2036 MVA	2036 %SN
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	30.9	56%	37.3	68%	38.4	70%	
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	30.9	55%	37.3	66%	38.4	68%	
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	12.3	39%	6.0	19%	6.1	19%	
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	69%	31.4	116%	32.3	119%	
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	26.0	47%	29.3	53%	30.1	55%	
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	17.4	38%	12.5	28%	12.8	28%	
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	17.4	55%	12.5	39%	12.8	40%	
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0%	0.0	0%	0.0	0%	
Methuen	2353	23	Meth Jcnctn	Golden Rock	23.9	23.9	4.0	17%	6.9	29%	7.3	30%	
Methuen	2376	23	Meth Jcnctn	Golden Rock	23.9	23.9	0%	0%	0%	0%	0.0	0%	
Methuen	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	67%	9.5	26%	10.0	28%	

Table 31 Alt #3 Supply Line Normal Loading



Salem NH Transformer Contingency Analysis															
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Contingency							
			From	To		SN	SE	2019		2022		2036			
								MVA	% SE	MVA	% SE	MVA	% SE	MVA	% SE
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.40	10.90	4.2	39%	7.9	61%	8.1	63%		
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.60	14.20	4.2	30%	7.9	56%	8.1	57%		
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.10	10.30	4.2	41%	7.9	61%	8.1	63%		
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.40	12.90	9.9	77%	6.1	48%	6.3	49%		
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.40	12.90	9.9	77%	6.1	48%	6.3	49%		
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.50	13.00	9.9	76%	6.1	47%	6.3	49%		
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.50	13.00	9.9	76%	6.1	47%	6.3	49%		
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.10	4.7	46%	7.8	60%	8.1	62%		
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.20	4.7	51%	7.8	60%	8.1	62%		
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.60	11.60	4.7	40%	7.8	68%	8.1	70%		
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.40	14.40	12.1	84%	4.8	33%	4.9	34%		
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.90	14.40	12.1	84%	4.8	33%	4.9	34%		
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.90	14.40	12.1	84%	4.8	33%	4.9	34%		
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.70	91.60	0.0	0%	0%	0%	0%	0%		
Salem NH	BARRON AVENUE 10	L5	23	13.2	9.375	14.40	14.40	0%	0%	7.9	56%	8.1	57%		
Salem NH	SALEM DEPOT 9	L4	23	13.2	9.375	14.40	14.40	0%	0%	7.8	55%	8.1	57%		
Salem NH	SALEM DEPOT 9	L5	23	13.2	9.375	14.40	14.40	0%	0%	7.8	55%	8.1	57%		

Table 32 Alt #3 Transformer Contingency Loading

Salem NH Supply Line Contingency Analysis														
Study Area	Circuit	Voltage (kV)	Line Section		Rating (MVA)	2019		2022		2036				
			From	To		MVA	Load > SE	MVA	Load > SE	MVA	Load > SE			
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	48.3	0.0	74%	50.0	0.0	76%	51.5	0.0	79%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	48.3	0.0	67%	50.0	0.0	69%	51.5	0.0	71%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	29.7	0.0	93%	18.4	0.0	58%	19.0	0.0	60%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	18.6	0.0	69%	31.4	4.3	116%	32.3	5.2	119%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	56.9	0.0	87%	66.4	1.0	102%	68.4	3.0	105%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	56.9	0.0	98%	66.4	8.3	114%	68.4	10.2	118%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	29.7	0.0	93%	18.4	0.0	58%	19.0	0.0	60%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	18.6	0.0	69%	31.4	4.3	116%	32.3	5.2	119%
Methuen MA	2353	23	Meth Jnctn	Golden Rock	23.9	34.9	11.0	145%	41.5	17.6	174%	43.8	19.9	183%
Methuen MA	2376	23	Meth Jnctn	Golden Rock	23.9	26.0	2.1	109%	29.3	5.4	123%	30.9	7.0	129%
Methuen MA	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	24.2	0.0	59%	9.5	0.0	23%	10.0	0.0	25%

Table 33 Alt #3 Supply Line Contingency Loading

Alternative #4 Loading

Salem NH Feeder Analysis														
Study Area	Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2019			2022			2036		
						Amps	N-1	%SN	Amps	N-1	%SN	Amps	N-1	%SN
						Salem NH	BARRON AVENUE 10	13.2	10L1	387	462	107	355	28%
Salem NH	BARRON AVENUE 10	13.2	10L2	526	578	268	310	51%	479	99	91%	493	85	94%
Salem NH	BARRON AVENUE 10	13.2	10L4	339	339	176	163	52%	192	386	36%	197	381	38%
Salem NH	OLDE TROLLEY 18	13.2	18L1	503	565	133	432	27%	217	348	43%	224	341	44%
Salem NH	OLDE TROLLEY 18	13.2	18L2	503	515	404	111	80%	411	104	82%	423	92	84%
Salem NH	OLDE TROLLEY 18	13.2	18L3	515	515	375	140	73%	341	174	66%	351	164	68%
Salem NH	OLDE TROLLEY 18	13.2	18L4	516	612	387	225	75%	133	479	26%	137	475	26%
Salem NH	PELHAM 14	13.2	14L4	530	589	44	545	8%	382	207	72%	393	196	74%
Salem NH	SALEM DEPOT 9	13.2	9L1	322	371	271	100	84%	201	377	38%	207	371	39%
Salem NH	SALEM DEPOT 9	13.2	9L2	322	371	224	147	70%	288	290	55%	297	281	57%
Salem NH	SALEM DEPOT 9	13.2	9L3	507	507	319	188	63%	391	187	74%	402	176	77%
Salem NH	SPICKET RIVER 13	13.2	13L1	515	515	326	189	63%	168	347	33%	173	342	34%
Salem NH	SPICKET RIVER 13	13.2	13L2	515	515	290	225	56%	146	369	28%	150	365	29%
Salem NH	SPICKET RIVER 13	13.2	13L3	522	522	442	80	85%	204	318	39%	210	312	40%
Salem NH	BARRON AVENUE 10	13.2	10L5	516	589		589	0%	169	420	33%	174	415	34%
Salem NH	SALEM DEPOT 9	13.2	9L4	516	589		589	0%	500	89	97%	515	74	100%
Salem NH	SALEM DEPOT 9	13.2	9L5	516	589		589	0%	466	123	90%	480	109	93%

Table 34 Alt #4 Feeder Normal Loading

Salem NH Transformer Analysis																
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Load								
			From	To		SN	SE	2019		2022		2036				
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.7	91.6	56.9	34.7	72%	53.0	38.6	67%	60.7	30.9	77%
Salem NH	GOLDEN ROCK 19	T2	115	23	50	78.7	91.6	91.6	0%	28.0	63.6	36%	61.3	30.3	78%	
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.4	10.9	2.4	8.5	26%	2.7	8.2	29%	2.8	10.2	22%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.6	14.2	6.1	8.1	45%	11.0	3.2	81%	11.3	2.9	83%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.1	10.3	4.0	6.3	44%	4.4	5.9	48%	4.5	8.5	36%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.4	12.9	3.0	9.9	25%	5.0	7.9	40%	5.1	7.8	41%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.4	12.9	9.2	3.7	75%	9.4	3.5	76%	9.7	3.2	78%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.5	13	8.6	4.4	69%	7.8	5.2	62%	8.0	5.0	64%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.5	13	8.8	4.2	71%	3.0	10.0	24%	3.1	9.9	25%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.1	6.2	3.9	84%	4.6	5.5	62%	4.7	8.3	38%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.2	5.1	4.1	70%	6.6	2.6	90%	6.8	6.2	54%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.6	11.6	7.3	4.3	63%	8.9	2.7	77%	9.2	2.4	79%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.4	14.4	7.5	6.9	52%	3.9	10.5	27%	4.0	10.4	28%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	6.6	7.8	48%	3.3	11.1	24%	3.4	11.0	25%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	10.1	4.3	73%	4.7	9.7	34%	4.8	9.6	35%
Salem NH	BARRON AVENUE 10	L5	23	13.2	9.375	14.4	14.4	0.0	14.4	0%	3.9	10.5	27%	4.0	10.2	29%
Salem NH	SALEM DEPOT 9	L4	23	13.2	9.375	14.4	14.4	0.0	14.4	0%	11.4	3.0	79%	11.8	2.4	87%
Salem NH	SALEM DEPOT 9	L5	23	13.2	9.375	14.4	14.4	0.0	14.4	0%	10.7	3.7	74%	11.0	3.2	81%

Table 35 Alt #4 Transformer Normal Loading

Salem NH Supply Line Analysis													
Study Area	Circuit	Voltage	Line Section		Rating (MVA)			Projected Load					
			From	To	SN	SE	MVA	%SN	MVA	%SN	MVA	%SN	
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	18.6	34%	42.2	77%	43.4	79%	
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	18.6	33%	42.2	75%	43.4	77%	
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	0.0	0%	0.0	0%	0.0	0%	
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	69%	42.2	156%	43.4	160%	
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	17.4	32%	10.8	20%	11.2	20%	
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	17.4	38%	10.8	24%	11.2	25%	
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	0.0	0%	0.0	0%	0.0	0%	
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0%	0.0	0%	0.0	0%	
Methuen	2353	23	Meth Jcnctn	Golden Rock	23.9	23.9	4.0	17%	3.9	16%	4.0	17%	
Methuen	2376	23	Meth Jcnctn	Golden Rock	23.9	23.9	0.0	0%	0.0	0%	0.0	0%	
Methuen	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	67%	11.8	33%	12.2	34%	
Salem NH	Line #3	23	Golden Rock	Barron Ave. Tap	54.8	65.4	20.9	38%	28.0	51%	28.8	53%	
Salem NH	Line #3	23	Barron Ave. Tap	Rockingham Tap	56.4	72.5	0.0	0%	14.4	25%	14.8	26%	

Table 36 Alt #4 Supply Lines Normal Loading

Salem NH Transformer Contingency Analysis															
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Contingency							
			From	To		SN	SE	2019		2022		2036			
								MVA	% SE	MVA	% SE	MVA	% SE	MVA	% SE
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.70	91.60		0%	81.0	88%	83.4	91%		
Salem NH	GOLDEN ROCK 19	T2	115	23	50	78.70	91.60		0%	81.0	88%	83.4	91%		
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.40	10.90	4.2	39%	7.3	56%	7.5	58%		
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.60	14.20	4.2	30%	7.3	51%	7.5	53%		
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.10	10.30	4.2	41%	7.3	56%	7.5	58%		
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.40	12.90	9.9	77%	8.4	65%	8.6	67%		
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.40	12.90	9.9	77%	8.4	65%	8.6	67%		
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.50	13.00	9.9	76%	8.4	65%	8.6	67%		
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.50	13.00	9.9	76%	8.4	65%	8.6	67%		
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.10	4.7	46%	10.6	81%	10.9	84%		
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.20	4.7	51%	10.6	81%	10.9	84%		
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.60	11.60	4.7	40%	10.6	91%	10.9	94%		
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.40	14.40	12.1	84%	5.9	41%	6.1	42%		
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.90	14.40	12.1	84%	5.9	41%	6.1	42%		
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.90	14.40	12.1	84%	5.9	41%	6.1	42%		
Salem NH	BARRON AVENUE 10	L5	23	13.2	9.375	14.40	14.40	4.2	29%	7.3	51%	7.5	53%		
Salem NH	SALEM DEPOT 9	L4	23	13.2	9.375	14.40	14.40	4.7	32%	10.6	74%	10.9	76%		
Salem NH	SALEM DEPOT 9	L5	23	13.2	9.375	14.40	14.40	4.7	32%	10.6	74%	10.9	76%		

Table 37 Alt #4 Transformer Contingency Loading



Salem NH Supply Line Contingency Analysis															
Study Area	Circuit	Voltage (kV)	Line Section		Rating (MVA)		2019			2022			2036		
			From	To	SN	SE	MVA	Load > SE	% SE	MVA	Load > SE	% SE	MVA	Load > SE	% SE
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	36.0	0.0	55%	42.2	0.0	65%	43.4	0.0	66%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	36.0	0.0	50%	42.2	0.0	58%	43.4	0.0	60%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	0.0	0.0	0%	0.0	0.0	0%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	42.2	15.1	156%	43.4	16.4	160%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	48.3	0.0	74%	30.0	0.0	46%	30.8	0.0	47%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	48.3	0.0	83%	30.0	0.0	52%	30.8	0.0	53%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	30.0	0.0	94%	30.8	0.0	97%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	0.0	0.0	0%	0.0	0.0	0%
Methuen MA	2353	23	Meth Jnctn	Golden Rock	23.9	23.9	18.6	0.0	78%	18.0	0.0	75%	19.0	0.0	80%
Methuen MA	2376	23	Meth Jnctn	Golden Rock	23.9	23.9	17.4	0.0	73%	0.0	0.0	0%	0.0	0.0	0%
Methuen MA	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	0.0	59%	11.8	0.0	29%	12.5	0.0	31%
Salem NH	Line #3	23	Golden Rock	Barron Ave. Tap	54.8	65.4	20.9	0.0	32%	55.8	0.0	85%	58.9	0.0	90%
Salem NH	Line #3	23	Barron Ave. Tap	Rockingham Tap	56.4	72.5	0.0	0.0	0%	42.2	0.0	58%	44.5	0.0	61%
Salem NH	Line #3	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0.0	0%	42.2	15.1	156%	44.5	17.4	164%

Table 38 Alt #4 Supply Line Contingency Loading

Alternative #5 Loading

Salem NH Feeder Analysis														
Study Area	Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2019			2022			2036		
						Amps	N-1	%SN	Amps	N-1	%SN	Amps	N-1	%SN
Salem NH	BARRON AVENUE 10	13.2	10L1	387	462	107	355	28%	117	461	22%	121	457	23%
Salem NH	BARRON AVENUE 10	13.2	10L2	526	578	268	310	51%	475	103	90%	489	89	93%
Salem NH	BARRON AVENUE 10	13.2	10L4	339	339	176	163	52%	191	387	36%	197	381	38%
Salem NH	OLDE TROLLEY 18	13.2	18L1	503	565	133	432	27%	217	348	43%	224	341	44%
Salem NH	OLDE TROLLEY 18	13.2	18L2	503	515	404	111	80%	409	106	81%	421	94	84%
Salem NH	OLDE TROLLEY 18	13.2	18L3	515	515	375	140	73%	341	174	66%	351	164	68%
Salem NH	OLDE TROLLEY 18	13.2	18L4	516	612	387	225	75%	133	479	26%	137	475	26%
Salem NH	PELHAM 14	13.2	14L4	530	589	44	545	8%	382	207	72%	393	196	74%
Salem NH	SALEM DEPOT 9	13.2	9L1	322	371	271	100	84%	201	377	38%	207	371	39%
Salem NH	SALEM DEPOT 9	13.2	9L2	322	371	224	147	70%	288	290	55%	297	281	57%
Salem NH	SALEM DEPOT 9	13.2	9L3	507	507	319	188	63%	391	187	74%	402	176	77%
Salem NH	SPICKET RIVER 13	13.2	13L1	515	515	326	189	63%	168	347	33%	173	342	34%
Salem NH	SPICKET RIVER 13	13.2	13L2	515	515	290	225	56%	164	351	32%	169	346	33%
Salem NH	SPICKET RIVER 13	13.2	13L3	522	522	442	80	85%	206	316	40%	212	310	41%
Salem NH	ROCKINGHAM 21 -23kV	13.2	21L9	516	589		589	0%	460	129	89%	474	115	92%
Salem NH	ROCKINGHAM 21 -23kV	13.2	21L10	516	589		589	0%	500	89	97%	515	74	100%
Salem NH	ROCKINGHAM 21 -23kV	13.2	21L11	516	589		589	0%	170	419	33%	175	414	34%

Table 39 Alt #5 Feeder Normal Loading

Salem NH Transformer Analysis																
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Load								
			From	To		SN	SE	2019		2022		2036				
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.7	91.6	56.9	34.7	72%	31.0	60.6	39%	31.9	59.7	40%
Salem NH	GOLDEN ROCK 19	T2	115	23	50	78.7	91.6	0.0	91.6	0%	53.7	37.9	68%	55.3	36.3	70%
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.4	10.9	2.4	8.5	26%	2.7	8.2	29%	2.8	10.2	22%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.6	14.2	6.1	45%	10.9	3.3	80%	11.2	3.0	82%	
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.1	10.3	4.0	6.3	44%	4.4	5.9	48%	4.5	8.5	36%
Salem NH	OLDE TROLLEY #18	L1	23	13.2	9.375	12.4	12.9	3.0	9.9	25%	5.0	7.9	40%	5.1	7.8	41%
Salem NH	OLDE TROLLEY #18	L2	23	13.2	9.375	12.4	12.9	9.2	3.7	75%	9.4	3.5	75%	9.6	3.3	78%
Salem NH	OLDE TROLLEY #18	L3	23	13.2	9.375	12.5	13	8.6	4.4	69%	7.8	5.2	62%	8.0	5.0	64%
Salem NH	OLDE TROLLEY #18	L4	23	13.2	9.375	12.5	13	8.8	4.2	71%	3.0	10.0	24%	3.1	9.9	25%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.1	6.2	3.9	84%	4.6	5.5	62%	4.7	8.3	38%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.2	5.1	4.1	70%	6.6	2.6	90%	6.8	6.2	54%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.6	11.6	7.3	4.3	63%	8.9	2.7	77%	9.2	2.4	79%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.4	14.4	7.5	6.9	52%	3.9	10.5	27%	4.0	10.4	28%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	6.6	7.8	48%	3.8	10.6	27%	3.9	10.5	28%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	10.1	4.3	73%	4.7	9.7	34%	4.9	9.5	35%
Salem NH	ROCKINGHAM 21 -23kV	L9	23	13.2	9.375	12.5	13	0.0	13.0	0%	10.5	2.5	84%	10.8	2.2	87%
Salem NH	ROCKINGHAM 21 -23kV	L10	23	13.2	9.375	12.5	13	0.0	13.0	0%	11.4	1.6	91%	11.8	1.2	94%
Salem NH	ROCKINGHAM 21 -23kV	L11	23	13.2	9.375	12.5	13	0.0	13.0	0%	3.9	9.1	31%	4.0	9.0	32%

Table 40 Alt #5 Transformer Normal Loading

Salem NH Supply Line Analysis												
Study Area	Circuit	Voltage	Line Section		Rating (MVA)		Projected Load					
			From	To	SN	SE	2019		2022		2036	
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	30.9	56%	20.1	37%	20.7	38%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	30.9	55%	20.1	36%	20.7	37%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	12.3	39%		0%	0.0	0%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	69%	20.1	74%	20.7	76%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	26.0	47%	10.8	20%	11.2	20%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	56.2	17.4	38%	10.8	24%	11.2	25%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	17.4	55%	10.8	34%	11.2	35%
Salem NH	2353	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0%	0.0	0%	0.0	0%
Methuen	2376	23	Meth Jcn	Golden Rock	23.9	23.9	4.0	17%		0%	0.0	0%
Methuen	2376	23	Meth Jcn	Golden Rock	23.9	23.9	0.0	0%		0%	0.0	0%
Methuen	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	67%	12.3	34%	12.7	35%
Salem NH	Line #3	23	Golden Rock	Barron Ave. Tap	54.8	65.4			27.9	51%	28.7	52%
Salem NH	Line #3	23	Barron Ave. Tap	Rockingham Tap	56.4	72.5			14.3	25%	14.7	26%
Salem NH	Line #3	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1			0.0	0%	0.0	0%
Salem NH	Line #4	23	Golden Rock	Barron Ave. Tap	54.8	65.4			25.8	47%	26.6	49%
Salem NH	Line #4	23	Barron Ave. Tap	Rockingham Tap	56.4	72.5			25.8	46%	26.6	47%
Salem NH	Line #4	23	Olde Trolley Tap	Salem Depot #9	56.4	72.5			0.0	0%	0.0	0%

Table 41 Alt #5 Supply Line Normal Loading

Salem NH Transformer Contingency Analysis													
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Contingency					
			From	To		SN	SE	2019		2022		2036	
								MVA	% SE	MVA	% SE	MVA	% SE
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.70	91.60		0%	84.7	92%	87.2	95%
Salem NH	GOLDEN ROCK 19	T2	115	23	50	78.70	91.60		0%	84.7	92%	87.2	95%
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.40	10.90	6.3	58%	9.0	69%	9.2	71%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.60	14.20	6.3	44%	9.0	63%	9.2	65%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.10	10.30	6.3	61%	9.0	69%	9.2	71%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.40	12.90	9.9	77%	8.4	65%	8.6	67%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.40	12.90	9.9	77%	8.4	65%	8.6	67%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.50	13.00	9.9	76%	8.4	65%	8.6	66%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.50	13.00	9.9	76%	8.4	65%	8.6	66%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.10	9.3	92%	10.1	77%	10.4	80%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.20	9.3	101%	10.1	77%	10.4	80%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.60	11.60	9.3	80%	10.1	87%	10.4	89%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.40	14.40	12.1	84%	6.2	43%	6.3	44%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.90	14.40	12.1	84%	6.2	43%	6.3	44%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.90	14.40	12.1	84%	6.2	43%	6.3	44%
Salem NH	ROCKINGHAM 21-23kV	L9	23	13.2	9.375	12.50	13.00	0.0	0%	12.9	99%	13.3	102%
Salem NH	ROCKINGHAM 21-23kV	L10	23	13.2	9.375	12.50	13.00	0.0	0%	12.9	99%	13.3	102%
Salem NH	ROCKINGHAM 21-23kV	L11	23	13.2	9.375	12.50	13.00	0.0	0%	12.9	99%	13.3	102%

Table 42 Alt #5 Transformer Contingency Loading



Salem NH Supply Line Contingency Analysis															
Study Area	Circuit	Voltage (kV)	Line Section		Rating (MVA)		2019			2022			2036		
			From	To	SN	SE	MVA	Load > SE	% SE	MVA	Load > SE	% SE	MVA	Load > SE	% SE
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	48.3	0.0	74%	46.0	0.0	70%	47.3	0.0	72%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	48.3	0.0	67%	46.0	0.0	63%	47.3	0.0	65%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	0.0	0.0	0%	0.0	0.0	0%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	46.0	18.9	170%	47.3	20.2	175%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	56.9	0.0	87%	25.2	0.0	38%	25.9	0.0	40%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	56.9	0.0	98%	25.2	0.0	43%	25.9	0.0	45%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	25.2	0.0	79%	25.9	0.0	81%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	0.0	0.0	0%	0.0	0.0	0%
Methuen MA	2353	23	Meth Jnctn	Golden Rock	23.9	23.9	30.9	7.0	129%	20.1	0.0	84%	21.2	0.0	89%
Methuen MA	2376	23	Meth Jnctn	Golden Rock	23.9	23.9	26.0	2.1	109%	10.8	0.0	45%	11.4	0.0	48%
Methuen MA	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	0.0	59%	12.3	0.0	30%	13.0	0.0	32%
Salem NH	Line #3	23	Golden Rock	Barron Ave. Tap	54.8	65.4	0.0	0.0	0%	38.7	0.0	59%	40.8	0.0	62%
Salem NH	Line #3	23	Barron Ave. Tap	Rockingham Tap	56.4	72.5	0.0	0.0	0%	25.2	0.0	35%	26.6	0.0	37%
Salem NH	Line #3	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0.0	0%	0.0	0.0	0%	0.0	0.0	0%
Salem NH	Line #4	23	Golden Rock	Barron Ave. Tap	54.8	65.4	0.0	0.0	0%	46.0	0.0	70%	48.5	0.0	74%
Salem NH	Line #4	23	Barron Ave. Tap	Rockingham Tap	56.4	72.5	0.0	0.0	0%	46.0	0.0	63%	48.5	0.0	67%
Salem NH	Line #4	23	Olde Trolley Tap	Salem Depot #9	56.4	72.5	0.0	0.0	0%	46.0	0.0	63%	48.5	0.0	67%

Table 43 Alt #5 Supply Line Contingency Loading

Alternative #6 Loading

Salem NH Feeder Analysis														
Study Area	Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2019			2022			2036		
						Amps	N-1	%SN	Amps	N-1	%SN	Amps	N-1	%SN
						Salem NH	OLDE TROLLEY 18	13.2 18L1		503	565	107	458	21%
Salem NH	OLDE TROLLEY 18	13.2 18L2		503	515	268	247	53%	252	263	50%	260	255	52%
Salem NH	OLDE TROLLEY 18	13.2 18L3		515	515	176	339	34%	348	167	68%	358	157	70%
Salem NH	OLDE TROLLEY 18	13.2 18L4		516	612	133	479	26%	461	151	89%	474	138	92%
Salem NH	PELHAM 14	13.2 14L4		530	589	323	266	61%	46	543	9%	48	541	9%
Salem NH	SPICKET RIVER 13	13.2 13L1		515	515	271	244	53%	347	168	67%	357	158	69%
Salem NH	SPICKET RIVER 13	13.2 13L2		515	515	224	291	43%	312	203	61%	321	194	62%
Salem NH	SPICKET RIVER 13	13.2 13L3		522	522	319	203	61%	390	132	75%	402	120	77%
Salem NH	GOLDEN ROCK 19	13.2 19L4		530	589		589	0%	84	528	16%	86	526	16%
Salem NH	GOLDEN ROCK 19	13.2 19L6		530	589		589	0%	259	353	49%	267	345	51%
Salem NH	GOLDEN ROCK 19	13.2 19L8		530	589		589	0%	235	377	45%	242	370	46%
Salem NH	ROCKINGHAM 21	13.2 21L1		530	589		589	0%	455	134	86%	468	121	88%
Salem NH	ROCKINGHAM 21	13.2 21L2		515	589		589	0%	0	589	0%	0	589	0%
Salem NH	ROCKINGHAM 21	13.2 21L3		515	515		515	0%	0	515	0%	0	515	0%
Salem NH	ROCKINGHAM 21	13.2 21L4		515	515		515	0%	0	515	0%	0	515	0%
Salem NH	ROCKINGHAM 21	13.2 21L5		530	589		589	0%	281	308	53%	289	300	55%
Salem NH	ROCKINGHAM 21	13.2 21L6		530	589		589	0%	288	301	54%	296	293	56%
Salem NH	ROCKINGHAM 21	13.2 21L7		530	589		589	0%	372	217	70%	383	206	72%
Salem NH	ROCKINGHAM 21	13.2 21L8		530	589		589	0%	441	148	83%	454	135	86%

Table 44 Alt #6 Feeder Normal Loading

Salem NH Transformer Analysis																
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Load								
			From	To		SN	SE	2019		2022		2036				
								MVA	%SN	MVA	%SN	MVA	%SN			
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.7	91.6	91.6	0%	29.2	62.4	37%	30.1	61.5	38%	
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.4	12.9	2.4	10.5	20%	5.0	7.9	40%	5.1	7.8	41%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.4	12.9	6.1	6.8	49%	5.8	7.1	47%	5.9	7.0	48%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.5	13	4.0	9.0	32%	8.0	5.0	64%	8.2	4.8	65%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.5	13	3.0	10.0	24%	10.5	2.5	84%	10.8	2.2	87%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.4	14.4	6.2	8.2	43%	7.9	6.5	55%	8.2	6.2	57%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	5.1	9.3	37%	7.1	7.3	51%	7.3	7.1	53%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	7.3	7.1	52%	8.9	5.5	64%	9.2	5.2	66%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.7	91.6	0.0	91.6	0%	13.2	78.4	17%	13.6	78.0	17%
Salem NH	ROCKINGHAM 21	T1	115	13.2	50	78.7	91.6	0.0	91.6	0%	25.3	66.3	32%	26.1	65.5	33%
Salem NH	ROCKINGHAM 21	T2	115	13.2	50	78.7	91.6	0.0	91.6	0%	16.7	74.9	21%	17.2	74.4	22%

Table 45 Alt #6 Transformer Normal Loading

Salem NH Supply Line Analysis												
Study Area	Circuit	Voltage	Line Section		Rating (MVA)		Projected Load					
			From	To	SN	SE	2019		2022		2036	
							MVA	%SN	MVA	%SN	MVA	%SN
Salem NH	2352	23 Golden Rock	Barron Ave. Tap	54.8	65.4	9.6	17%	10.7	20%	11.0	20%	
Salem NH	2352	23 Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	9.6	17%	10.7	19%	11.0	20%	
Salem NH	2352	23 Olde Trolley Tap	Olde Trolley	31.9	31.9	8.6	27%	10.7	34%	11.0	35%	
Salem NH	2352	23 Olde Trolley Tap	Salem Depot #9	27.1	27.1	1.0	4%	18.5	68%	19.0	70%	
Salem NH	2393	23 Golden Rock	Barron Ave. Tap	54.8	65.4	7.1	13%	18.5	34%	19.0	35%	
Salem NH	2393	23 Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	7.1	16%	18.5	41%	19.0	42%	
Salem NH	2393	23 Olde Trolley Tap	Olde Trolley	31.9	31.9	7.1	22%	18.5	58%	19.0	60%	
Salem NH	2393	23 Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0%	0.0	0%	0.0	0%	
Methuen	2353	23 Meth Jcnctn	Golden Rock	23.9	23.9	0.0	0%	0.0	0%	0.0	0%	
Methuen	2376	23 Meth Jcnctn	Golden Rock	23.9	23.9	0.0	0%	0.0	0%	0.0	0%	
Methuen	2376	23 SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	18.6	52%	24.0	67%	25.3	71%	

Table 46 Alt #6 Supply Line Normal Loading

Salem NH Transformer Contingency Analysis															
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Contingency							
			From	To		SN	SE	2019		2022		2036			
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.70	91.60	0.0	0%	0.0	0%	0.0	0%	0.0	0%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.40	12.90	5.2	40%	9.7	75%	10.0	78%	10.0	78%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.40	12.90	5.2	40%	9.7	75%	10.0	78%	10.0	78%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.50	13.00	5.2	40%	9.7	75%	10.0	77%	10.0	77%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.50	13.00	5.2	40%	9.7	75%	10.0	77%	10.0	77%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.40	14.40	9.3	65%	12.0	83%	12.3	86%	12.3	86%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.90	14.40	9.3	65%	12.0	83%	12.3	86%	12.3	86%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.90	14.40	9.3	65%	12.0	83%	12.3	86%	12.3	86%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.70	91.60	0.0	0%	0.0	0%	0.0	0%	0.0	0%
Salem NH	ROCKINGHAM 21	T1	115	13.2	50	78.70	91.60	0.0	0%	44.8	49%	46.1	50%	46.1	50%
Salem NH	ROCKINGHAM 21	T2	115	13.2	50	78.70	91.60	0.0	0%	44.8	49%	46.1	50%	46.1	50%

Table 47 Alt #6 Transformer Contingency Loading

Salem NH Supply Line Contingency Analysis														
Study Area	Circuit	Voltage (kV)	Line Section		Rating (MVA)		Projected Contingency							
			From	To	SN	SE	2019		2022		2036			
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	16.7	0.0	25%	29.2	45%	30.1	0.0	46%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	16.7	0.0	23%	29.2	78%	30.1	0.0	80%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	15.6	0.0	49%	29.2	92%	30.1	0.0	94%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	1.0	0.0	4%	0.0	0%	0.0	0.0	0%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	16.7	0.0	25%	29.2	45%	30.1	0.0	46%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	16.7	0.0	29%	29.2	78%	30.1	0.0	80%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	15.6	0.0	49%	29.2	92%	30.1	0.0	94%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	1.0	0.0	4%	0.0	0%	0.0	0.0	0%
Methuen MA	2353	23	Meth Jnctn	Golden Rock	23.9	23.9	9.6	0.0	40%	10.7	45%	11.3	0.0	47%
Methuen MA	2376	23	Meth Jnctn	Golden Rock	23.9	23.9	7.1	0.0	30%	18.5	77%	19.5	0.0	82%
Methuen MA	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	18.6	0.0	46%	24.0	59%	25.3	0.0	62%

Table 48 Alt #6 Supply Line Contingency Loading



Alternative #7 Loading

Salem NH Feeder Analysis														
Study Area	Substation	Voltage (kV)	Feeder	SN Rating (Amps)	SE Rating (Amps)	2019			2022			2036		
						Amps	N-1	%SN	Amps	N-1	%SN	Amps	N-1	%SN
						Salem NH	BARRON AVENUE 10	13.2	10L1	387	462	107	355	28%
Salem NH	BARRON AVENUE 10	13.2	10L2	526	578	268	310	51%	287	291	55%	295	283	56%
Salem NH	BARRON AVENUE 10	13.2	10L4	339	339	176	163	52%	181	397	34%	186	392	35%
Salem NH	OLDE TROLLEY 18	13.2	18L1	503	565	133	432	27%	217	348	43%	224	341	44%
Salem NH	OLDE TROLLEY 18	13.2	18L2	503	515	404	111	80%	291	224	58%	299	216	59%
Salem NH	OLDE TROLLEY 18	13.2	18L3	515	515	375	140	73%	341	174	66%	351	164	68%
Salem NH	OLDE TROLLEY 18	13.2	18L4	516	612	387	225	75%	284	328	55%	292	320	57%
Salem NH	PELHAM 14	13.2	14L4	530	589	44	545	8%	490	99	92%	504	85	95%
Salem NH	SALEM DEPOT 9	13.2	9L1	322	371	271	100	84%	297	281	56%	305	273	58%
Salem NH	SALEM DEPOT 9	13.2	9L2	322	371	224	147	70%	288	290	55%	297	281	57%
Salem NH	SALEM DEPOT 9	13.2	9L3	507	507	319	188	63%	391	187	74%	402	176	77%
Salem NH	SPICKET RIVER 13	13.2	13L1	515	515	326	189	63%	348	167	68%	358	157	70%
Salem NH	SPICKET RIVER 13	13.2	13L2	515	515	290	225	56%	310	205	60%	319	196	62%
Salem NH	SPICKET RIVER 13	13.2	13L3	522	522	442	80	85%	385	137	74%	396	126	76%
Salem NH	GOLDEN ROCK 19	13.2	19L4	530	589		589	0%	84	528	16%	86	526	16%
Salem NH	GOLDEN ROCK 19	13.2	19L6	530	589		589	0%	113	499	22%	116	496	22%
Salem NH	PELHAM 14	13.2	14L6	528	647		647	0%	326	321	62%	336	311	64%

Table 49 Alt #7 Feeder Normal Loading

Salem NH Transformer Analysis																
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Load								
			From	To		SN	SE	2019		2022		2036				
								MVA	%SN	MVA	%SN	MVA	%SN			
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.7	91.6	56.9	34.7	72%	60.9	30.7	77%	62.7	28.9	80%
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.4	10.9	2.4	8.5	26%	6.1	4.8	65%	6.3	6.7	50%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.6	14.2	6.1	8.1	45%	6.6	7.6	48%	6.8	7.4	50%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.1	10.3	4.0	6.3	44%	4.1	6.2	45%	4.3	8.7	34%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.4	12.9	3.0	9.9	25%	5.0	7.9	40%	5.1	7.8	41%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.4	12.9	9.2	3.7	75%	6.6	6.3	54%	6.8	6.1	55%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.5	13	8.6	4.4	69%	7.8	5.2	62%	8.0	5.0	64%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.5	13	8.8	4.2	71%	6.5	6.5	52%	6.7	6.3	53%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.1	6.2	3.9	84%	6.8	3.3	92%	7.0	6.0	56%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.2	5.1	4.1	70%	6.6	2.6	90%	6.8	6.2	54%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.6	11.6	7.3	4.3	63%	8.9	2.7	77%	9.2	2.4	79%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.4	14.4	7.5	6.9	52%	8.0	6.4	55%	8.2	6.2	57%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.9	14.4	6.6	7.8	48%	7.1	7.3	51%	7.3	7.1	52%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.9	14.4	10.1	4.3	73%	8.8	5.6	63%	9.1	5.3	65%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.7	91.6	0.0	91.6	0%	4.5	87.1	6%	4.6	87.0	6%

Table 50 Alt #7 Transformer Normal Loading

Salem NH Supply Line Analysis												
Study Area	Circuit	Voltage	Line Section		Rating (MVA)		Projected Load					
			From	To	SN	SE	2019		2022		2036	
							MVA	%SN	MVA	%SN	MVA	%SN
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	30.9	56%	33.9	62%	34.9	64%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	30.9	55%	33.9	60%	34.9	62%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	12.3	39%	11.6	36%	12.0	38%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	69%	22.3	82%	23.0	85%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	26.0	47%	27.0	49%	27.8	51%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	17.4	38%	14.3	32%	14.7	33%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	17.4	55%	14.3	45%	14.7	46%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	0.0	0%	0.0	0%	0.0	0%
Methuen	2353	23	Meth Jcnctn	Golden Rock	23.9	23.9	4.0	17%	0.0	0%	0.0	0%
Methuen	2376	23	Meth Jcnctn	Golden Rock	23.9	23.9	0.0	0%	0.0	0%	0.0	0%
Methuen	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	67%	23.8	66%	25.2	70%

Table 51 Alt #7 Supply Line Normal Loading

Salem NH Transformer Contingency Analysis													
Study Area	Substation	Tranf. ID.	System Voltage (kV)		Maximum Nameplate Rating	Rating (MVA)		Projected Contingency					
			From	To		SN	SE	2019		2022		2036	
								MVA	% SE	MVA	% SE	MVA	% SE
Salem NH	GOLDEN ROCK 19	T1	115	23	50	78.70	91.60	0.0	0%	0.0	0%	0.0	0%
Salem NH	BARRON AVENUE 10	L1	23	13.2	7	9.40	10.90	6.3	58%	8.4	65%	8.7	67%
Salem NH	BARRON AVENUE 10	L2	23	13.2	7	13.60	14.20	6.3	44%	8.4	59%	8.7	61%
Salem NH	BARRON AVENUE 10	L4	23	13.2	7	9.10	10.30	6.3	61%	8.4	65%	8.7	67%
Salem NH	OLDE TROLLEY 18	L1	23	13.2	9.375	12.40	12.90	9.9	77%	9.2	71%	9.5	73%
Salem NH	OLDE TROLLEY 18	L2	23	13.2	9.375	12.40	12.90	9.9	77%	9.2	71%	9.5	73%
Salem NH	OLDE TROLLEY 18	L3	23	13.2	9.375	12.50	13.00	9.9	76%	9.2	71%	9.5	73%
Salem NH	OLDE TROLLEY 18	L4	23	13.2	9.375	12.50	13.00	9.9	76%	9.2	71%	9.5	73%
Salem NH	SALEM DEPOT 9	L1	23	13.2	7	7.36	10.10	9.3	92%	11.2	86%	11.5	88%
Salem NH	SALEM DEPOT 9	L2	23	13.2	7	7.36	9.20	9.3	101%	11.2	86%	11.5	88%
Salem NH	SALEM DEPOT 9	L3	23	13.2	9.375	11.60	11.60	9.3	80%	11.2	96%	11.5	99%
Salem NH	SPICKET RIVER 13	L1	23	13.2	9.375	14.40	14.40	12.1	84%	11.9	83%	12.3	85%
Salem NH	SPICKET RIVER 13	L2	23	13.2	9.375	13.90	14.40	12.1	84%	11.9	83%	12.3	85%
Salem NH	SPICKET RIVER 13	L3	23	13.2	9.375	13.90	14.40	12.1	84%	11.9	83%	12.3	85%
Salem NH	GOLDEN ROCK 19	T2	115	13.2	50	78.70	91.60	0.0	0%	0.0	0%	0.0	0%

Table 52 Alt #7 Transformer Contingency Loading

Salem NH Supply Line Contingency Analysis															
Study Area	Circuit	Voltage (kV)	Line Section		Rating (MVA)		Projected Contingency								
			From	To	SN	SE	2019		2022		2036				
							MVA	Load > SE	% SE	MVA	Load > SE	% SE	MVA	Load > SE	% SE
Salem NH	2352	23	Golden Rock	Barron Ave. Tap	54.8	65.4	48.3	0.0	74%	48.2	0.0	74%	49.6	0.0	76%
Salem NH	2352	23	Barron Ave. Tap	Olde Trolley Tap	56.4	72.5	48.3	0.0	67%	48.2	0.0	67%	49.6	0.0	68%
Salem NH	2352	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	25.9	0.0	81%	26.7	0.0	84%
Salem NH	2352	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	22.3	0.0	82%	23.0	0.0	85%
Salem NH	2393	23	Golden Rock	Barron Ave. Tap	54.8	65.4	56.9	0.0	87%	60.9	0.0	93%	62.7	0.0	96%
Salem NH	2393	23	Barron Ave. Tap	Olde Trolley Tap	45.2	58.2	56.9	0.0	98%	48.2	0.0	83%	49.6	0.0	85%
Salem NH	2393	23	Olde Trolley Tap	Olde Trolley	31.9	31.9	29.7	0.0	93%	25.9	0.0	81%	26.7	0.0	84%
Salem NH	2393	23	Olde Trolley Tap	Salem Depot #9	27.1	27.1	18.6	0.0	69%	22.3	0.0	82%	23.0	0.0	85%
Methuen MA	2353	23	Meth Jnctn	Golden Rock	23.9	23.9	30.9	7.0	129%	38.1	14.2	159%	40.2	16.3	188%
Methuen MA	2376	23	Meth Jnctn	Golden Rock	23.9	23.9	26.0	2.1	109%	27.0	3.1	113%	28.5	4.6	119%
Methuen MA	2376	23	SPICKET RIVER TAP	SPICKET RIVER	35.9	40.7	24.2	0.0	59%	23.8	0.0	59%	25.2	0.0	62%

Table 53 Alt #7 Supply Line Contingency Loading

### 9.4 Appendix D – MWhr Summary

Plan	2022 Predicted Contingency N-1 Problems					
	180 MWhr Transformer Criteria Violations		120 MWhr Supply Line Criteria Violations		Feeders above 16 MWhr	
	Description	MWhr	Description	MWhr	Description	MWhr
Base	Golden Rock T1 Outage	679	2393 Baron Ave Tap to Olde Trolley Tap	159	18L3	18
			G133 - 115kV Transmission Line	439	18L4	24
					9L1	24
					9L2	20
					9L3	23
					13L1	18
					13L2	20
13L3	17					
1	Golden Rock T1 Outage	254			9L2	16
2	Golden Rock T1 Outage	237			9L2	16
3	Golden Rock T1 Outage	352			9L2	16
4					9L2	16
5					21L10	19
6					9L2	16
					21L7	25
7	Golden Rock T1 Outage	345			21L8	23
					9L2	16
					14L4 / 14L6	52
					14L3 / 14L4 / 14L6	88

Table 54 2022 Predicted Contingency N-1 Problems



### 9.5 Appendix E – Spicket River Backup Analysis




Figure 55: Voltage Performance during 13L1 contingency (low voltage <0.95 per-unit shown in red)

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

## 9.6 Appendix F – 22.8 kV Voltage Analysis

<u>Plan</u>	<u>Description</u>	<u>Voltage Issues</u>	
		<u>Summer Normal</u>	<u>Contingency</u>
<b>Alternative 1</b>	Existing 23 kV system. 2.5 MW of generation available on each of the Salem Depot 9L3 and Barron Ave. 10L4 feeders during contingency conditions.	None	None
<b>Alternative 2</b>	Existing 23 kV system.	None	None
<b>Alternative 3</b>	Add 2-23/13 kV feeder positions at Salem Depot and one at Barron Ave. to the existing system.	Salem Depot 23 kV bus at .9375 per-unit. Olde Trolley 23 kV bus at .9471 per-unit.	Olde Trolley 23 kV bus at .87857 per-unit for 2352 and Golden Rock 115/23 kV transformer out-of-service.
			Salem Depot 23 kV bus at .8676 per-unit for 2352 and Golden Rock 115/23 kV transformer out-of-service.
<b>Alternative 4</b>	Add the second Golden Rock 115/23 kV transformer, one new 23 kV line, 2-23/13 kV feeder positions at Salem Depot and one at Barron Ave. to the existing system.	None	None
<b>Alternative 5</b>	Add the second Golden Rock 115/23 kV transformer, two new 23 kV lines and a new 23/13 kV Rockingham substation to the existing system.	None	Salem Depot 23 kV bus at .87524 per-unit for 2352 out-of-service. Rockingham 23 kV bus at .88188 per-unit for 2352 or second new line out-of-service.
<b>Alternative 7</b>	Existing 23 kV system. Added contingency of picking up the Pelham 14L4 and L6 feeders through ties to Olde Trolley and Barron Ave.	None	Olde Trolley 23 kV bus at .89932 per-unit for Golden Rock 115/23 kV transformer out-of-service.
			Salem Depot 23 kV bus at .89206 per-unit for Golden Rock 115/23 kV transformer out-of-service.
<b>Base</b>	Existing 23 kV system.	Olde Trolley 23 kV bus at .9411 per-unit and Salem Depot 23 kV bus at .9328 per-unit.	Olde Trolley 23 kV bus at .87171 per-unit for either 2352 or Golden Rock 115/23 kV transformer out-of-service.
			Salem Depot 23 kV bus at .86229 per-unit for either 2352 or Golden Rock 115/23 kV transformer out-of-service.

Liberty Utilities  
 System Planning  
 Salem Area Study 2020

### 9.7 Appendix G – Comparison of Plans – Cost vs Added Capacity

Alternative Plan	Total Cost (\$M)	Spent to Date Towards Plan (\$M)	MVA Capacity Provided		\$ / MVA		Criteria Ranking
			Total	Firm	Total	Firm	
Alt Plan #1	\$11.41*	\$3.5	88.7	10	\$129	\$1,141	7
Alt Plan #2	\$24.00	\$3.5	104.7	17.1	\$229	\$1,404	4
Alt Plan #3	\$35.31	\$3.5	146.9	60.3	\$240	\$586	5
Alt Plan #4	\$33.94	\$0.0	152.1	108.1	\$223	\$314	3
Alt Plan #5	\$33.15	\$1.5	152.1	93.7	\$218	\$354	2
Alt Plan #6	\$34.90	\$5.0	177.7	142.3	\$196	\$245	1
Alt Plan #7	\$25.01	\$3.5	116.68	29.1	\$214	\$859	6

\* Does not include annual operating expenses for diesel generation, estimated to be \$200,000 / year  
 Table 55 Comparison of Plans – Cost vs Added Capacity

Liberty Utilities  
System Planning  
Salem Area Study 2020

## 9.8 Appendix H – Comparable Past Studies to Salem

### A. Mt Support Substation Expansion

#### a. Project Need

The main driver for the Mt Support Substation Expansion Project was load relief of forecasted overloads under normal and contingency conditions and voltage violations. With the contingency loss of the Mt Support transformer or Transmission line, the sub transmission system would result overloaded. Other feeders and transformers in the area were projected to violate the Distribution Planning Criteria for normal and contingency loading.

#### b. Selected Solution

To address the system deficiencies in the area, rather than expand or rely on the existing sub transmission system, the preferred solution included the extension of a new 115kV transmission line, the installation of a new 115/13.2kV transformer and the installation of two new 13.2kV distribution feeders.

### B. Michael Ave Substation

#### a. Project Need

The main driver for the Michael Ave Project was to provide added capacity for the expansion of Whelen Engineering in Charlestown NH and to address the asset conditions at the Charlestown Substation. The issues experienced with the Charlestown substation were similar to those being experienced with Salem Depot and Barron Ave substations.

#### b. Selected Solution

To address the asset condition at the Charlestown Substation and provide added capacity to supply Whelen Engineering, the preferred solution included the installation of a new 115kV substation in Charlestown NH including a new 115/13kV transformer, a new 115kV transmission line and two new 13.2kV distribution feeders. The new Michael Ave substation allowed for the retirement of the Charlestown Substation and for the expansion of Whelen Engineering.

### C. Pelham Substation Expansion

#### a. Project Need

The main driver for the Pelham Substation Expansion Project was load relief of forecasted overloads under normal and contingency conditions and to address the asset condition of the existing substation transformer. With the contingency loss of the Pelham transformer or Transmission line, the system lacked the necessary capacity to resolve Planning Criteria Violations for load at risk. Other feeders in the area were projected to violate the Distribution Planning Criteria for normal and contingency loading.

#### b. Selected Solution

To address the system deficiencies in the area, the preferred solution included the complete refurbishment of the Pelham substation including the extension of a new 115kV transmission line tap, the installation of a new 115/13.2kV transformer, the replacement of the existing 115/13.2kV transformer and the installation of two new 13.2kV distribution feeders.



Liberty Utilities  
System Planning  
Salem Area Study 2020

## **10.0 Annex List**

**Annex A - National Grid Internal Strategy Document Distribution  
Substation Transformers Revised Strategy – October 2009**

**Annex B – 10L1 Testing & Maintenance Report: United Power  
Group - August 2014**

**Annex C – 10L4 Testing & Maintenance Report: United Power  
Group - September 2014**

**Annex D – 9L3 Testing & Maintenance Report: United Power  
Group - August 2014**

**Annex E – 2020 Dissolved Gas Analysis: Weidmann**  
**1. Barron Ave 10L2 - Test Report #01-7334797-618125-00**  
**2. Barron Ave 10L1 - Test Report #01-7334796-618125-00**  
**3. Salem Depot 9L3 - Test Report #01-7334792-618125-00**  
**4. Salem Depot 9L2 - Test Report #01-7334791-618125-00**

**Annex F – Liberty Utilities Electrical Substation Clearances  
Standard - Doc. # ENG-SUB006 – August 2020**

THIS PAGE INTENTIONALLY LEFT BLANK

## Distribution Substation Transformers Table of Contents

<b>Distribution Substation Transformers Strategy Statement .....</b>	<b>2</b>
<b>Distribution Substation Transformers Strategy Justification .....</b>	<b>3</b>
<b>1.0 Purpose and Scope .....</b>	<b>3</b>
<b>2.0 Background .....</b>	<b>3</b>
2.1 Substation Maintenance Standards.....	4
2.2 Data.....	4
2.3 Events.....	7
2.4 Transformer Health and Risk Scores (THaRS).....	7
<b>3.0 Benefits .....</b>	<b>13</b>
3.1 Safety & Environmental .....	13
3.2 Reliability .....	13
3.3 Regulatory .....	13
3.4 Customers.....	13
<b>4.0 Estimated Costs .....</b>	<b>13</b>
<b>5.0 Implementation .....</b>	<b>14</b>
<b>6.0 Risk Assessment .....</b>	<b>14</b>
6.1 Safety & Environmental .....	14
6.2 Reliability .....	14
6.3 Regulatory .....	15
6.4 Customer .....	15
<b>7.0 Data Requirements.....</b>	<b>15</b>
7.1 Existing/Interim: .....	15
7.2 Proposed: .....	15
<b>8.0 References.....</b>	<b>15</b>
<b>9.0 Massachusetts.....</b>	<b>16</b>
<b>10.0 New York.....</b>	<b>20</b>
<b>11.0 Rhode Island.....</b>	<b>26</b>
<b>12.0 New Hampshire and Vermont .....</b>	<b>29</b>

## Distribution Substation Transformers Strategy Statement

The strategic aims for Distribution Substation Power Transformers are to:

- minimize random transformer failures
- ensure that the transformer population is capable of performing its function
- provide replacement for those units that are identified as more likely to fail.

A list of candidates for replacement on a per state basis can be found in the state specific section of this document. It should be noted that transformers suggested for replacement are evaluated in conjunction with substation reviews. This strategy is based on transformer condition and risk, and has been developed with significant input from subject matter experts, local operations colleagues and available historic and test results.

This strategy supports both reliability and a sustainable network by establishing a list of replacement candidates by state, applying an ongoing GE Type U replacement program, and employing a tactical application of Load Tap Changer (LTC) filtration and condition monitoring.

### Amendments Record

Issue	Date	Summary of Changes / Reasons	Author(s)	Approved By (Inc. Job Title)
	10/14/09	Revision	Eileen Duarte Distribution Asset Strategy	John Pettigrew Executive Vice President, Electric Distribution Operations
1	07/30/07	Initial Issue	Tony McGrail Substations O&M	John Pettigrew Executive Vice President, Electric Distribution Operations



## **Distribution Substation Transformers Strategy Justification**

### **1.0 Purpose and Scope**

This strategy sets forth a Distribution Substation Transformer program to allow National Grid to confidently rank its substation transformers in terms of health, identify those transformers that are most critical to the system, and rank transformers in terms of risk so that the transformers are properly prioritized for asset replacement.

This strategy is consistent with the approach taken for our transmission assets and supports achieving the objective to improve reliability and meet service quality standards in all states in which National Grid operates. This strategy pertains to substation transformers described by FERC as distribution, which includes TxD, and DxD.

### **2.0 Background**

Substation transformers are a critical asset class in the successful operation of the electrical distribution system. Consequently, we must endeavor to be proactive in our determination of the following:

- Transformer health through test and assessment
- Need for maintenance and content of the maintenance
- Spares and mobiles strategies
- System requirements and transformer capability
- Identification of ‘at risk’ units
- Identification of replacement candidates

Substation transformers have a number of characteristics that require close attention and supervision, such as:

- Transformers are usually very reliable (depending on size, configuration LTC’s etc)
- Transformers have a long asset life expectancy
- Failures may cause significant interruptions
- Transformers are expensive
- Replacement is an involved procedure requiring coordination of many departments and issues
- Determining health and condition is a complex task
- Lead times for new transformers may be over a year
- Individual transformers of known manufacturer/design may be less reliable than others
- Safety and environmental concerns regarding large quantities of oil
- Replacement versus refurbish or repair decisions are complex
- Transformers have many sub-systems, including bushings, cooling, oil containment, tap changers, etc.

## 2.1 Substation Maintenance Standards

Transformer maintenance is covered under our substation maintenance standards and procedures. A list of substation maintenance documents can be found in SMS 400.00.1. There is no international standard that applies to transformer asset health. Work has been conducted to identify root cause analysis of failures at CIGRE, Doble Engineering, and HSB Insurance (1,2,3,4). These documents are referenced when transformer decisions are made at National Grid.

An oil sample is taken from our transformers on a one or two-year time-frame based on the size of the transformer as described in Substation Maintenance Standard (SMS) 402.02.1 and 402.01.1. Transformers rated 15 MVA and above are tested annually, and transformers rated between 2.5-14.9 MVA are tested on a 24 month interval (7, 8). The interval may change based on the results of the Dissolved Gas Analysis (DGA) or system incidents that indicate possible transformer health issues.

Transformers receive a bi-monthly Visual and Operational (V&O) inspection as part of the substation bi-monthly V&O. A severe trouble condition<sup>1</sup> problem is addressed immediately. Problems and discrepancies found are corrected, and problems and discrepancies not corrected are recorded on an inspection card and follow-up work is generated. This is in accordance with the SMS 400.06.1 [17].

In addition, Thermographic Inspections are performed on transformers as part of the annual substation Thermographic Inspection. A Thermographic Inspection Report is created for detected problems and follow-up work is scheduled. This is in accordance with the SMS 400.07.1 [18].

Specialized testing to ascertain transformer health in detail is performed on commissioning or after an incident (7, 8). These tests include power factor, capacitance, Sweep Frequency Response Analysis (SFRA) and other tests to gain information about the integrity of the transformer insulation and winding structure.

Transformers equipped with Load Tap Changers (LTC's) will receive a V&O inspection (six times a year), thermographic inspection (annually), and DGA sample on the LTC. Internal inspections are performed if the results of the inspections and/or the DGA sample indicates the need, or if the number of operations exceeds the ROP constant or the time interval limit has been reached. The timeframe for DGA samples and internal inspections are based on the manufacturer and type of LTC, which is listed in SMS 412.01.1[19].

Maintenance is performed on transformers as necessary based on the findings of the above mentioned inspections, oil analysis, testing and Company expert analysis and knowledge of the unit.

## 2.2 Data


The substation distribution transformer population consists of 1,471 operating units and 155 spares. This is based on an MVA rating up to 20 MVA. Of the 1,471 operating units and 155 spares listed in AIMMS, 1,078 units and 99 spares have associated age data.

The age profile for the operating distribution transformers are displayed in Figure 1. Fifty percent of the transformer population with a known age was manufactured prior to 1972, with the majority being between 35 and 60 years old. In addition, 5 % of the population is greater than 70 years old, while 10% are greater than 60

---

<sup>1</sup> Hazardous situation to system operation and/or National Grid employees or the public


years old. Twenty-seven percent of the transformer population is missing age data information. The transformer age profile on a per state basis can be found in the Appendix. After analyzing the age profile data on a per state basis, it is expected that the average age of the transformer population is actually higher than the average 29 years indicated and most likely closer to what is seen in Rhode Island, and average age of 36 years with only 7.6% of missing age data. The greater the percentage of missing age data, the younger the transformer population seems to be, indicating that the missing age data relates to older units.



**Figure 1. Distribution Transformer Age Profile**


The age profile for the spare transformers is displayed in Figure 2. The average age of the spare fleet of transformers is 22 years. Fifty percent of the transformer population was manufactured prior to 1973, with the majority being between 35 and 54 years of age. In addition, 7 % of the population is greater than 63 years of age while 16% are greater than 52 years of age. Thirty-six percent of the transformer spare population is missing age data information.

The number of spares and age data, which was extracted from AIMMS, is presently under review. An initiative to determine the number of viable spares is underway, and CASCADE will be updated in 2010 in conjunction with the development of a transformer spares strategic approach.



**Figure 2: Distribution Transformer Age Profile Spares**


The transformers MVA profile is shown in Figure 3 and indicates that 75% of the transformer population is 5 MVA or less, 91% is 7.5 MVA or less, and 98% is 20 MVA or less. DGA samples are typically taken on transformer banks rated 2.5 MVA or larger, equating to 0.833 MVA for single phase units in accordance with Substation Maintenance Standard 402.02.1 version 1.8.



**Figure 3. Distribution Transformer MVA Profile**

## 2.3 Events

Over the last ten years there have been 47 transformers system wide that have failed due to various reasons. Figure 4 displays the number of failures on a per year basis.



**Figure 4. National Grid Transformer Failures**

Based on the IDS and SIR data, over the last ten years there have been 212 events related to substation transformers. The most frequent listed failure reason extracted from this data is deteriorated equipment (79) followed by animals (32), overload (15), short circuit (14) and device failed (12). The number one cause of substation transformer failures is through faults. A healthy transformer is more likely able to withstand a thru fault than a unit that is deteriorated, aged or in poor electrical/mechanical condition.

Transformer failures are inevitable but we aim to minimize the likelihood of failures caused both by:

- Internal events – insulation failure, winding movement etc.
- External events – through faults, lightning, animal incursions etc.

Incipient internal events may be detected through Dissolved Gas Analysis (DGA), Visual & Operational Inspections (V&O), InfraRed inspections, PIW's or identified through engineering and industry knowledge. External events are addressed through application of lightning arresters, animal protection and pursuit of such activities as Feeder Hardening and Vegetation Management.

The failure rate for power transformers is approximately 0.5% per year with an average age at failure of between 30 and 35 years. Older units are not, *per se*, more likely to fail. However, they may be more susceptible due to accumulated effects of through faults and irreversible paper aging mechanisms. Transformer failures are captured by Substation O&M Services and the details distributed to key personnel in a bi-annual report. It is recommended that these failures be entered and maintained in Cascade in future.

## 2.4 Transformer Health and Risk Scores (THaRS)

In order to better manage the transformer fleet, we need to better understand the condition of all members of the fleet and their risks. This is not a simple matter and even the best managed fleet would still be prone to some



random failures. The aim is to prevent as many failures as possible, reduce the exposure, and thus reduce impact to an acceptable level (1).

Transformers tend to be reliable (3), but the reliability is a function of faults seen, maintenance and the manufacture/design of the transformer. DGA alone is not sufficient to detect incipient faults, and the industry best practice is to expect that about 25% to 50% of imminent failures may be detected using DGA. To help better manage our transformer fleet and not rely on DGA alone, a scoring system based on condition and risk has been put in place to formulate a ‘watch list’ of transformers. This list will be closely monitored, and an action plan will be developed for each transformer on ‘watch’ to assist in preventing failures.

Distribution uses the work developed for transformer dissolved gas analysis (DGA) at National Grid UK as discussed at the Doble 2002 Client Conference (5). The technical discussion presented by John Lapworth, National Grid, UK discusses a method of using a DGA scoring system based on ratios of key gasses to identify transformers that may be at risk of poor condition. Certain key gasses and combinations of key gasses are indicators of particular problems within a transformer. The basic combustible gas results are combined to give a single DGA score for each transformer for each oil sample. This DGA score is the baseline for prioritizing our fleet of transformers.

DGA analysis is performed by engineers in each region. The DGA scoring system is a newly applied tool in National Grid that assists in the ranking process. In the UK for transmission transformers, generally with conservators<sup>2</sup> since they are free-breathing and key gasses are released into the atmosphere, a score of 60 is an indication of ‘monitor’ while a score of 100 is an ‘alarm’ situation. In the early days of analysis and review, it seems that with US distribution transformers, generally sealed<sup>3</sup>, we can set the ‘monitor’ level to 100 and the ‘alarm’ level to 150. Key gasses remain contained within the transformer oil on sealed units, and therefore will have more combustible gasses present. This is, of course, a heuristic process but it can be validated by reviewing DGA results from known failed units. Failed units in the data set have an average DGA score in excess of 300, but as this was post fault, further analysis is necessary to gain the proper trend information.

Once the transformer population has received a DGA score, analysis with Subject Matter Experts (SME’s) occurs to evaluate transformers with elevated scores or scores that have increased significantly since the previous analysis. This review, which includes review of other maintenance performed (V&O Inspection, Infrared survey, known problems such as through faults, field repairs, protective component issues, capacity issues), is conducted and the DGA rating is adjusted accordingly. After this review, the DGA score is converted to a DGA rating, which becomes part of the Transformer Health and Risk Score (THaRS) method used to prioritize transformers for replacement. A rating of 10 indicates a DGA score greater than 125, a rating of 5 indicates a DGA score between 76 and 125, and a DGA score less than 75 receives a rating of 1. However, these ratings are adjusted based on favorable or unfavorable comments from the SME’s. For example, if a transformer’s DGA score is greater than 125, but the SME’s input is favorable (stable, transformer repaired, etc), then the score will be changed from a 10 to a 1.

---

<sup>2</sup> Conservator type transformers have free-breathing tanks and key gasses are released into the atmosphere.

<sup>3</sup> Sealed transformers have sealed tanks and key gasses remain within the transformer oil

In addition to the DGA rating, an MVA score is provided to each unit based on the formula  $(MVA+20)/20$ . Twenty MVA is used indicating the largest MVA for distribution class transformers. A larger unit is considered more critical than a smaller unit because typically it may carry more load, and is more costly to replace.

As displayed in Figure 1, National Grid has a large population of aging transformers. As the unit ages, the insulation condition deteriorates and therefore becomes more susceptible to failures. In addition, older units have more likely been exposed to through faults, thus further weakening the insulation integrity. Also, parts become obsolete and maintenance becomes costly. The health review includes an age score based on a life expectancy of 60 years, an age that we expect half of our transformers to reach. A transformer that is 60 years old would receive a score of 2, while a transformer that is new would receive a score of 1.

Transformers that contain 50 ppm or more of PCB are considered a hazardous waste and must be handled and disposed of in accordance with EP-1, Waste Management. Units that are known or expected to contain PCB in the insulating oil are an environmental and human health risk, and therefore are considered during this transformer health review. A transformer failure that contains 50 ppm or more of PCB in the oil is a contamination issue that requires an immediate and costly clean up. A score of 1.2 is given to those units containing PCB of 50 ppm or more, and a score of 1 to those units that are PCB free. Although PCB spills are serious, units containing PCB insulating oils can be mitigated by retro-filling with mineral oil.

Highly Utilized (HUtz) transformers are those transformers that have been identified to operate at 100% load or more during peak load periods. Although based on certain circumstances and the time of year, these transformers may or may not exceed 100% load. However, a transformer that is operated at its limit or above for long periods of time may result in a more rapid deterioration of condition than units operated below maximum load. In addition, since the capacity of these transformers has been exceeded, a future solution may be necessary in order to withstand the growth these transformers are serving. Therefore, a HUtz score has been incorporated into the health and risk review. If a transformer is operated above 100% load, the amount above 100% is added to 1.0. For example, a transformer that operates at 114% load will receive a HUtz score of 1.14.

The scores are applied to each transformer and a final transformer health and risk score (THaRS) is determined. The transformers are ranked in order of replacement priority based on the descending order of the final score. Further technical input from SME's is performed and the list is revised in light of their comments and experience. Table 1 describes the transformer health and risk scores.

THaRS is a simple but comprehensive method developed to initiate the replacement prioritization of the distribution substation transformer fleet. The scoring system is highly weighted on transformer condition with some risk incorporated into the analysis. Additionally, it should be noted that both O&M and the operations staff have provided comments and direction with regards to the history and capability of individual units, and assisted with the prioritization of the final list.

Condition Evaluation		Impact Evaluation			Risk Analysis
DGA	Age	PCB	HUtz	MVA	THaRS
$10 > 125$ $05 > 75 \leq 125$ $01 \leq 75$	$(60 + \text{Age}) / 60$	$1.2 =$ PCB $1.0 \neq$ PCB	1.0 + percent overload	$(20 + \text{MVA}) / 20$	$\text{DGA} * \text{MVA} * \text{Age} * \text{PCB} * \text{HUtz}$
Comments from SME's are included in the score	Based on the life expectancy of 60 years			Based on largest unit being 20 MVA	

**Table 1. Transformer Health and Risk Scores**

Applying transformer health and risk scores allows us to provide a basic asset ranking. Future asset ranking methods will combine the methods discussed in this document along with the following:

- Design and manufacture information
- Station situation
- Oil quality
- Transformer winding type and LTC Type
- Capability of asset to perform required function
- Past performance, maintenance and costs
- Spare availability and mobile readiness
- Available through fault and interruption data

Transformer health and risk scores are not, by themselves, an indicator of a transformer problem. There is a need for more engineering judgment. For example, DGA results in NY tend to have higher hydrogen values than those from NE and the cause is related to the lab used; consequently they have a higher DGA score. Going forward, NY and NE will be using the same laboratory, and this ambiguity will be resolved.

The transformer health and risk score (THaRS) profile for National Grid's transformer fleet is displayed in Figure 6. The results represent the latest DGA records and PCB comments listed in AIMMS for all FERC coded TxD and DxD units rated greater than 0.5 MVA. The Highly Utilized Transformer List for Summer 2009 was used to determine the HUtz score (13).

Figure 5 shows how the scores are placed in good, fair and poor health and risk categories. There is some overlap, but when the score is above 10, the transformer warrants further investigation and is most likely on the 15 year replacement list. For example, if a transformer had a score of 6.5, the unit may either be considered good or fair. If a transformer received a score of 18, then the unit could be considered either fair or poor. Further analysis would be necessary in order to determine the outcome. A transformer with a score of 37 would be considered poor and a score of 3.3 would be considered good. In any event, a transformer with a score of 10 or higher warrants further investigation, and is most likely on the replacement list.

There were a total of 887 THaRS performed on National Grid's fleet of transformers; 323 performed on NE units and 524 performed on NY units. This does not correlate with the total number of operating transformers because either a DGA sample was not performed (units less than 2.5 MVA do not require DGA samples),

or the MVA rating is 0.5 MVA or less.

The average THaRS of the National Grid fleet of operating transformers is 3.11, which indicates that the majority of the units are in good condition and pose little risk. In addition, 825 transformers have scores less than 10, of which 92.5% have scores less than 5. There is 1 transformer with a score greater than 40; 1 with a score between than 30 and 40; 10 with a score between than 20 and 30, and 62 with a score between than 10 and 20. From a population of 887 units scored, and noting that not all transformers are DGA sampled, 7% have a score greater than 10. All scores have been reviewed to ensure consistency of approach. It is recommended that those units (50) with scores in the fair-poor and poor categories have a mitigation plan in place in case of failure prior to replacement. Units with a score of 10 or higher (55 of the population) are placed on a watch list and monitored more closely; the watch list and associated action plans are in the process of being finalized and made generally available.




Figure 5 Transformer Health and Risk Scores (THaRS) Descriptors




Figure 6. National Grid Transformer Health and Risk Score Profile

**Asset Replacement:** As the transformer population ages, replacement of both the oldest units and those most likely to fail should be considered. Older units tend to have insulation deterioration due to aging paper, and units most likely to fail may be those that have seen numerous faults.

The volume of transformers which are, in theory, required to be replaced annually is determined by analysis of the population of transformers in each state: by expecting the population to have an average life expectancy of 60 years, the volume required for replacement each year can be identified. However, this statistical analysis of the population does not identify individual units which are actual candidates for replacement. For example, New York's total MVA is  $2590.63/60\text{years} = 43.18$  MVA per year is suggested to be replaced.

The process continues by identifying the 'at risk' subpopulation of power transformers based on condition, and then identifying those with high Transformer Health and Risk Scores or with known and probable failure modes. This analysis is ongoing as the status of the transformer health and risk is in a constant state of flux. As of July 2009, there is a list of 80 transformers as candidates for replacement in the next 5 years. The list of replacement transformers can be found in the appendix under the appropriate state. The replacement candidates are listed in order of priority with the five-year candidates coded in orange. The preceding ten-year replacement list is coded in yellow. Each list generates replacement candidates for the next 15 years. It must be noted that this list is dynamic and updates to the lists are constantly ongoing due to changes in condition and risk. Therefore, the list projected in this strategy represents a snapshot in time and does not reflect the absolute list. This list is maintained by Asset Strategy and is communicated to Asset Planning. Although this list changes based on condition, transformers allocated for immediate replacement will not change. In addition, units that fail unexpectedly will be addressed immediately.

**Type U Bushing Replacement:** It is industry best practice to identify and replace those bushings that are GE Type U. These bushings have a known catastrophic failure mode, and are a risk to both safety and the system. The Substation Maintenance Standard, SMS 450.20.1 (10) discusses the replacement policy in detail.

**LTC Filtration Systems:** A tactical plan to apply LTC filtration systems to units requiring high maintenance and a risk of failure is ongoing. Units equipped with arcing-in-oil design type load tap changers, and elevated numbers of LTC operations are closely evaluated and considered candidates for installation of an LTC filtration system (11). Installation of LTC filtration systems will be installed when units come out of service for LTC maintenance per EOP SMP412.01.1 Load Tap Changer (12). The failure rate of transformers is strongly linked to tap changers, and the filtration unit helps keep the LTC clean, and extends the maintenance interval and the transformer life.

**Condition Monitoring:** Condition monitoring is applied on a case by case basis using an identified cost benefit. At present, National Grid may use additional condition monitoring to supplement our DGA where appropriate. This additional condition monitoring may comprise of oil analysis and partial discharge.

**Surge Arrester Replacement:** Presently, there is a substation Surge Arrester Strategy and an arrester replacement standard, SMS 419.15.2 Transformer Surge Arrester Replacement that addresses the replacement of any non-metal oxide (MOV) type arrester. This maintenance standard is an initiative to improve system reliability and transformer protection, and to reduce the likelihood of catastrophic arrester failures by implementing new protection technology.



### 3.0 Benefits

The risk of outages and catastrophic events will be reduced. All transformers will have an asset health (condition) score based on the following inputs:

- Available DGA, field diagnostic and test information
- Operational history, including load, faults, fault level and temperature data
- Particular manufacturer & design input
- Maintenance and inspection data
- Expected lifetime curve, including EOSU<sup>4</sup> and LOSU<sup>5</sup> where available
- Reliability Centered Maintenance (RCM) analysis of available failure data and incident data

All transformers will be assessed for criticality based on the consequence of failure or unavailability using the following inputs:

- Impact on CAIDI, SAIFI, SAIDI, CMI and CI statistics
- Input from system operation and system planning
- Availability of spares, mobile units and replacement complexity

All transformers will be ranked in terms of risk (consequence of criticality and health), and will be targeted for replacement based on risk and the constraints of the business.

As a result, the risk of outages, catastrophic events, and random failures will be reduced.

#### 3.1 Safety & Environmental

Fewer transformer failures, removal of older units, and mitigation or removal of PCB contained units reduces the probability of an oil leak and oil containment issues.

#### 3.2 Reliability

Risk to reliability will lessen as a result of fewer transformer interruptions related to the replaced units.

#### 3.3 Regulatory

Potential improvements in SAIFI and SAIDI may be achieved.

#### 3.4 Customers

Customer outages may be reduced. A customer outage may be substantial if a transformer fails. Transformer failures may affect numerous feeders resulting in a larger number of customers without power.

### 4.0 Estimated Costs

The costs indicated here are estimates that represent all aspects of a straightforward transformer replacement including engineering, foundation upgrades, purchase price, installation, commissioning and basic connections,

---

<sup>4</sup> Earliest Onset of Significant Unreliability

<sup>5</sup> Longest Onset of Significant Unreliability

but does not include changes to protection or significant infrastructure upgrades. The numbers given are for indication based on recent experiences and MVA of units.

For units rated 7.4 MVA and below, the estimated replacement cost is \$900k per unit (average).  
For units rated above 7.4 MVA, the estimated replacement cost is \$1500k per unit (average).

There are 54 units on the five-year replacement list below 7.4 MVA, giving a total of \$48.6M  
There are 26 units on the five-year replacement list above 7.4 MVA, giving a total of \$39.0M

This results in an overall estimated cost of \$87.6M for 5 years, or \$17.52M per annum. However, there is a lead time associated with these costs that skews the actual annual values.

The GE Type U bushings replacement initiative will continue to be applied in accordance with SMS 450.20.1.  
The Surge Arrester replacement initiative will continue to be applied in accordance with SMS 419.15.2.

As discussed in Section 2.4, an LTC filtration system may be installed at an estimated cost of \$25k per unit as needed.

Condition or partial discharge monitoring is a possibility, but unlikely on distribution equipment. It is considered a small capital item, and would be considered on an as needed basis.

## **5.0 Implementation**

There should be an on-going state prioritized asset replacement plan based on condition and risk, and a tactical response program to install LTC filtration systems and condition or partial discharge monitoring as needed.

Continued review and revision of the replacement lists in each state will be performed in conjunction with SME's, Substations O&M staff and Operations staff so as to gather and reflect the latest data and information available for each transformer.

## **6.0 Risk Assessment**

### **6.1 Safety & Environmental**

Transformer failures may be both catastrophic and sudden. Distribution units may be smaller, but they are usually in closer proximity to residential areas. A catastrophic bushing or arrester failure has placed porcelain shards in neighboring fields, and the results of a transformer failure may cause oil contamination of the environment resulting in excessive clean-up costs.

### **6.2 Reliability**

In most cases, a transformer failure will lead to power outages for customers. A transformer failure can take time to fix as the timing depends on many factors, including availability of spare transformers, mobile transformers or sourcing a replacement externally. In these cases, a transformer failure may have substantial impact.

### 6.3 Regulatory

The loss of a transformer may impact several regulatory targets. Although the number of substation events are low, they do contribute to SAIFI and SAIDI.

### 6.4 Customer

Customer outages may be substantial if a transformer fails. A transformer failure may affect numerous feeders resulting in a larger amount of customers without power.

## 7.0 **Data Requirements**

As National Grid evolves in the ability to manage the transformer fleet, our data requirements will grow.

### 7.1 Existing/Interim:

AIMMS, PIW's IDS

### 7.2 Proposed:


Cascade, EMS, PIW's, IDS

## 8.0 **References**

1. CIGRE failure study
2. Alan Wilson "Impact of technical condition on utilization of power transformers", Doble 2002
3. William Bartley, HSB, "Risk and Transformer Assessment", Doble HSB paper, 2004
4. Marsh, Keynote address, EuroDoble 2006
5. John Lapworth "A scoring system for integrating dissolved gas analysis results into a life management process for power transformers", Doble 2002
6. SMS 430.10.3 Transformer Oil In Service - Evaluation
7. SMS 402.01.1 Transformer 15 MVA and above
8. SMS 402.02.1 Transformer 2.5 to 14.9 MVA
9. Hartford Steam Boiler Insurance Company Asset Management Newsletter, July 2006
10. SMS 450.20.1 GE Type U Bushing Replacement
11. Falla, Dan, National Grid, Installation of LTC Oil Filtration Systems, August, 2007
12. SMS 412.01.1 Load Tap Changer
13. Highly Utilized Transformer List Summer 2009, National Grid
14. SMS 419.15.2 Transformer Surge Arrester Replacement
15. Jacques Afonso, Surge Arrester Strategy, January 8, 2009
16. Technical Evaluation of Proposed Capital Expenditure Program for NGC's 2006/07 Price Control Extension, Draft Final Report, July 2005, OFGEM
17. SMS 400.06.1 Visual and Operational (V&O) Inspection
18. SMS 400.07.1 Thermographic Inspection
19. EP-1; Waste Management
20. EPA 40 CFR Chapter 1, 761.125 Requirements for PCB Spill Cleanup


## 9.0 Massachusetts

There are 483 operating transformers in Massachusetts listed in AIMMS, with 85 spares. Of the 483 units, 269 received transformer health and risk scores. The total MVA population in Massachusetts is 2,572, and it is suggested that approximately 43 MVA be replaced per year to keep up with the aging population and to lessen the risk of failures.



**Figure 7. Substation Distribution Transformer Age Profile**

Of the 483 operating transformers listed in AIMMS, 362 have age data, and therefore the average age is 29 years. This is similar to the total transformer population shown in Figure 1. The Massachusetts transformer age profile is displayed in Figure 7. Transformers without an age recorded tend to be older units.



**Figure 8. Transformer Health and Risk Scores for Massachusetts**

In reference to Figure 8, 91% of the transformer health and risk scores for Massachusetts are 5 or below. This indicates that a large majority of the units in Massachusetts are in good condition and pose very little risk based on this health and risk scoring system. However, 5.2% of the population have scores 10 or greater, and 1% greater than 20. These units are on the 15 year replacement list found in Table 2. The THARS number was excluded from the list because it is still in development, and it is our intention to improve on this prioritization tool.

The replacement candidates for Massachusetts are listed below in order of priority. The red coded unit(s) are already on the replacement list for FY10, the orange coated list is the replacement list for FY11 to FY14, and the yellow coded list is for the following 10 years. The number of units on the replacement list is based on the total population of transformer MVA divided by 60 years.



Represents those already on the list for replacement FY10  
 Represents replacement candidates for FY11-FY14 in order of priority.  
 Represent replacement candidates for FY15-FY25 in order of priority. Analysis based mostly on age then MVA for  
**MA - REPLACEMENT BASED ON 43 MVA PER YEAR**

STA LOC	EQNUM	MVA	VOLT	AGE	LAST DGA							
					ZHYD ROGE N	ZMET HANE	ZCAR BON_ MONO	ZET HAN E	ZETH YLEN E	ZAC ETY LEN	ZCOM BUST_ GAS	
Salem 2 Valley St	20757	7	23	41	36	64	300	105	28	0	533	
Tyngsboro 211	21601	6.25	23-13.2	37	855	53	344	3	701	2	1958	
West Gloucester 28	23586	12.5	34.5-22.9	23	154	62	727	24	2	0	969	
Rockport 40	23898	9.38	34.5-22.9	21	16	9	1140	2	46	0	1213	
Vine 8	20363	3.75	13.8-4.33 kV	59	542	43	509	1	58	0	1153	
Walnut Street 32	21112	10	24.6-4.16	62	32	8	158	8	6	0	212	
Walnut Street 32	21111	10	24.6-4.16	62	18	6	90	8	4	0	126	
Gloucester 24	20113	7.25	23-2.4	62	17	25	73	83	16	0	214	
Melrose 4	20152	9.38	23-4.16	47	0	2	3	17	3	0	25	
Melrose 4	20151	9.38	23-4.16	47	0	33	259	28	85	0	405	
Water Street 31	21094	9.375	23.5-4.16 kV	52								
Salem 15	22955	1.5	13.2-2.3 kV	1	79							
Salem 15	22956	1.5	13.2-2.3 kV	1	79							
Salem 15	22957	1.5	13.2-2.3 kV	1	79							
Lawrence 2	20135	7.5	13.8-2.4	85	5	3	144	2	2	0	156	
Lawrence 2	20136	7.5	13.8-2.4	85	0	1	90	1	3	0	95	
Medford 9	20149	10	23.46-4	69	14	27	1130	0	36	0	1207	
Medford 9	20150	10	23.46-4	59	27	30	1100	8	39	0	1204	
Worthen Street 13	21899	7	13.8-13.2ZZ kV	36	29	145	567	110	126	0		
Plainville 3451	21545	6.25	22.9-13.8 kV	37	49	469	1980	398	273	0		
North Lawrence 6	20653	9.38	13.8-2.4 kV	7	59	8	5	184	1	39	0	237
Revere Beach 35	20250	9.38	22.9-4.16 kV	59	0	1	3	1	0	0	5	
Bancroft Street 3	21756	6.25	13.2-2.4 kV	5	59	17	58	42	45	200	0	362
Faraday Street 11	20657	9.38	13.2-2.4 kV	7	58	6	5	23	5	1	0	40
Burrill 2	20065	3.65	13.8-4.36 kV	58	14	85	1100	34	34	0	1267	
Quebec Street 17	20238	12.5	23.5-13.8 kV	57	5	21	10	153	9	0	198	
Newburyport 36	21046	9.38	22.9-2.4 kV	7	57	185	9	151	10	3	0	358
<b>Total MVA</b>		<b>206.9</b>										
Glendal 6	20110	7.5	23-2.4	61	12	27	629	23	143	0		
Glendal 6												
Wollaston 2	20387	9.38	13.8-2.4	61	0	4	7	9	1	0	21	
Revere 7	20248	9.38	23-2.4	?	0	10	38	13	25	0	86	
Revere 7	20249	9.38	23-2.4	?	1	4	11	3	0	0	19	
Newburyport 36	21047	9.38	22.9-2.4 kV	7	57	12	18	103	26	14	0	173
Amesbury 5	21003	9.38	22.3-2.4 kV	7	57	15	9	81	17	11	0	133
Water Street 31	21408	6.25	22-2.4 kV	5/6	57	0	10	20	11	70	0	111
Hudson 7	20132	3.75	13.8-4.36 kV	57	9	7	561	3	2	0	582	
Salem 3 Boston St	20283	10	24.45-4.16	50	11	48	182	34	48	0	323	
Salem 3 Boston St	20284	10	23-2.4 kV	7.5	61	18	6	161	0	3	0	188
Lawrence 1	20774	12.5	23.5-13.8 kV	56	36	64	300	105	28	0	533	
Quebec Street 17	20237	12.5	23.5-13.8-4.16	56	7	1	29	1	2	0	40	
Topsfield 26	23591	12.5	22.9-22.9 kV	?	14	17	625	5	1	0	662	
Faraday Street 11	20658	9.38	13.2-2.4 kV	7	56	4	6	35	2	8	0	55
Dale Street 55	20581	7	22.9-13.2 kV	?	222	19	1070	3	49	0	1363	
South Billerica 18	23115	7	22.9-13.8 kV	?	6	42	396	20	21	0	485	
North Andover 7	20606	6.25	22.9-2.4 kV	5	56	14	7	168	14	15	0	218
Andover 3	20650	9.38	14.1-4.16 kV	55	63	13	169	13	9	0	267	
Methuen 5	20720	9.38	22.9-4.16 kV	55	4	21	22	70	5	0	122	
North Beverly 18	22539	9.38	22.9-4.16 kV	55	5	14	25	55	5	0	104	
Andover 2	20651	9.38	14.1-4.16 kV	55	24	7	18	22	2	0	25	

Unc

of 31

North Andover 7	20606	6.25	22.9-2.4 kV	5	56	14	7	168	14	15	0	218
Andover 3	20650	9.38	14.1-4.16 kV		55	63	13	169	13	9	0	267
Methuen 5	20720	9.38	22.9-4.16 kV		55	4	21	22	70	5	0	122
North Beverly 18	22539	9.38	22.9-4.16 kV		55	5	14	25	55	5	0	104
Andover 3	20651	9.38	14.1-4.16 kV		55	24	7	18	33	3	0	85
North Beverly 18	20183	9.38	22.9-4.16 kV		55	103	6	197	25	8	0	339
Methuen 5	20721	9.38	22.9-4.16 kV		55	0	16	24	30	3	0	73
Perry Street 3	20212	9.38	13.2-4.16 kV		55	0	2	47	1	17	0	67
Kent 13	20802	4.69	13.8-4.36 kV		55	35	65	390	104	16	0	610
Western 4	20380	3.75	13.8-4.36 kV		55	0	113	174	384	18	0	689
Perry Street 3	20213	9.38	13.2-4.16 kV		54	11	4	143	2	39	0	199
Atlantic 4	20003	6.25	13.8-4.16 kV		54	92	4	281	2	2	0	381
Lawrence 1	20134	9.38	13.8-2.3 kV	7	53	28	8	89	18	12	0	155
Humphrey 1	20133	6.25	13.8-4.36 kV		?	28	83	468	181	12	0	772
Beverly 12	20279	7	23-4.16 kV	5/	40	9	48	543	17	16	0	633
Sheffield 8	20273	7	23-13.8 kV	5/	40	68	48	325	124	13	0	578
West Methuen 63	23142	20	23-13.8 kV	1/	38	13	21	279	7	22	0	342
West Methuen 63	23263	20	23-13.8 kV	1/	38	19	30	150	29	4	0	232
North Lawrence 6	23316	20	23-13.2 kV	1/	36	20	20	326	13	21	0	400
Swampscott 22	23135	20	23-13.8 kV	1/	36	56	5	217	1	11	1	291
Risingdale 9	23580	20	23-23.8 kV	1/	35	10	11	85	4	13	0	123
Candle Street 101	24034	30	46-13.2 kV	3/	13	18	2	161	1	1	0	183
Candle Street 101	24041	30	46-13.2 kV	3/	13	2	3	47	1	1	0	54
<b>Total MVA</b>					<b>414.01</b>							


**Table 2. Massachusetts Transformer Replacement List**

In reference to Table 2, there are 27 transformers on the list for replacement over the next 5 years. One is to be replaced in FY10, which is excluded from the cost analysis. There is one single-phase bank that will be replaced with a 3-phase transformer. Therefore the cost is representative of replacing 24, 3-phase transformers. The cost of replacement is as follows:

Eight units at \$900k per unit (average), \$1.44M pa for 5 years  
 Sixteen units at \$1.5M per unit (average), \$4.8M pa for 5 years


## 10.0 New York

There are 807 operating transformers in New York listed in AIMMS, with 56 spares. Of the 807 units, 524 received transformer health and risk scores. The total MVA population in New York is 2,591, and it is suggested that approximately 43 MVA be replaced per year to keep up with the aging population and to lessen the risk of failures.



**Figure 9. Distribution Transformer Age Profile**

The available age data listed in AIMMS for New York results in an average age of 27 years, which is based on 547 units with age data. New York also has the largest amount of missing age data; this is not a significant issue as age may be inferred, if necessary, from related substation equipment and age is used as an indicator for condition rather than a driver for replacement. New York has 7 smaller units (less than 2.5 MVA) on the replacement list that may be best solved with a planning solution rather than replacement. The New York transformer age profile can be found in Figure 9.



**Figure 10. Transformer Health and Risk Scores for New York**

In reference to Figure 10, 93% of the transformer health and risk scores for New York are below 5. This indicates that a large majority of the units in New York are in good condition and pose very little risk based on this health and risk scoring system. On the other hand, 7% of the population have scores greater than 10, and 1% greater than 20. These units are on the 15 year replacement list, which is attached below in Table 3.

**NY - REPLACEMENT BASED ON 43 MVA PER YEAR**

**LAST DGA**

DIVISION	STA LOC	EQNUM	MVA	VOLT	AGE	ZHYD	ZME	ZCAR	ZETH	ZETH	ZACE	ZCOMB
						ROGE N	THA NE	BON_ MON	ANE	YLEN E	TYLE NE	UST_G AS
NYCDSU	Fayetteville Station 18	222261	6.25	34.5-2.4 kV	52	25	211	108	333	929	0	1606
NYWDSU	French Creek Station	220472	3.75	34.5-13.8 kV	36	123	17	782	11	9	32	974
NYWDSU	Station 034	219590	2.5	23-4.16 kV	79	141	7	129	6	9	0	292
NYWDSU	Station 124 - Alameda	219384	3.75	34.5-4.16 kV		15	801	327	1483	2708	0	5334
NYWDSU	Station 124 - Alameda	219390	5.25	34.5-4.16 kV		4	140	184	315	61	0	704
NYWDSU	Station 124 - Alameda	219388	4.687	34.5-4.16 kV		20	80	269	120	39	0	528
NYWDSU	Station 124 - Alameda	219382	3.75	34.5-4.16 kV	?	12	137	93	508	36	0	786
NYWDSU	Avon Station 43	220403	3.75	34.5-4.8 kV	49	34	100	131	41	6	0	312
NYEDSU	Newtonville Station 30	221606	5.6	34.5-4.16 kV		108	65	84	41	107	0	405
NYWDSU	Station 056	219732	3.13	23-4.16 kV	53	304	13	378	13	21	0	729
NYWDSU	Oak Hill Station 62	220487	2.5	34.5-4.8 kV		261	7	540	5	26	0	839
NYEDSU	Chrisler Avenue Station	221777	3	34.5-4.16 kV	?	9792	10	236	5	4	0	10047
NYWDSU	Station 038	219633	2.5	23-4.16 kV	79	13	4	110	18	8	0	153
NYCDSU	Mill Street Station 748	221188	6.25	23-4.8 kV 5/	54	16	45	270	77	6	0	414
NYEDSU	McCrea Street Station	221950	3.75	34.5-4.8 kV	59	191	5	527	4	3	0	730
NYCDSU	Mill Street Station 748	221187	6.25	23-4.8 kV 5/	54	348	123	107	258	17	0	853
NYCDSU	Mill Street Station 748	221189	6.25	23-4.8 kV 5/	54	8	72	148	95	7	0	330
NYEDSU	Chrisler Avenue Station	221776	3	34.5-4.16 kV	62	9	5	303	3	6	0	326
NYCDSU	Fisher Avenue Station	220643	6.25	34.5-13.8 kV	39	0	1	28	1	2	0	32
NYCDSU	Rock City Station 623	222363	7	46-4.16 kV	55	81	636	125	776	1805	0	3423
NYEDSU	Summit Station 347	222446	10.5	69-4.8 kV 7.	40	46	39	140	28	68	0	321
NYWDSU	Golah Station	220370	7.5	69-34.5 kV 7	71	208	30	351	30	16	0	635
NYEDSU	Chestertown Station 4	222029	10.5	34.5-13.8 kV		19	169	126	316	378	0	1008
NYWDSU	Station 037	219618	2.5	23-4.16 kV	79	96	6	189	7	10	0	308
NYEDSU	Hoag Station 221	222408	0.7	34.5-4.8 kV	61	95	6	571	4	6	0	682
NYEDSU	Hoag Station 221	222407	0.7	34.5-4.8 kV	61	92	6	576	4	5	1	684
NYEDSU	Hoag Station 221	222409	0.7	34.5-4.8 kV	61	142	10	915	5	8	0	1080
NYCDSU	Westvale Station 133	210278	7.5	34.5-4.16 kV	49	38	3	167	2	8	2	220
NYCDSU	Galeville Station 213	220674	6.25	34.5-4.16 kV	51	228	35	677	101	17	0	1058
NYCDSU	Glenwood Station 227	220701	6.25	34.5-4.16 kV	49	21	267	322	390	1174	0	2174
NYEDSU	Colvin Avenue Station	222411	6.25	34.5-4.16 kV		111	113	275	66	278	1	844
NYCDSU	Fabius Station 55	220852	0.83	34.5-4.8 kV	50	121	10	311	60	12	0	514
NYCDSU	Fabius Station 55	220851	0.83	34.5-4.8 kV	50	62	7	187	34	6	0	296
NYCDSU	Fabius Station 55	220853	0.83	34.5-4.8 kV	50	7	90	276	173	14	0	560
NYCDSU	Cuyler Station 24	222280	2	34.5-4.16 kV	80							
NYCDSU	Cuyler Station 24	222281	2	34.5-4.16 kV	80							
NYCDSU	Cuyler Station 24	222282	2	34.5-4.16 kV	80							
NYCDSU	Cuyler Station 24	222283	2	34.5-4.16 kV	80							
NYCDSU	Cuyler Station 24	222284	2	34.5-4.16 kV	80							
NYCDSU	Cuyler Station 24	222285	2	34.5-4.16 kV	80							
NYWDSU	Station 030	219562	3	23-4.16 kV	59	297	28	966	23	7	0	1321
NYWDSU	Machias Station 13	246649	3.75	34.5--4.8 kV		76	30	172	36	38	0	352
NYWDSU	Station 083 - Welch A	220250	3.5	12-4.16 kV		399	69	771	82	26	0	1347
NYWDSU	Station 057	222125	5.3	23-4.16 kV	36	94	6	452	7	4	0	563
NYWDSU	North Collins Station S	222246	2.5	34.5-4.8 kV	46	123	212	193	359	50	0	937
NYWDSU	Station 025	219527	2.5	23-4.16 kV		7	4	136	6	5	6	164
NYWDSU	Station 029	219558	2.5	23-4.16 kV		43	6	104	6	8	0	167
NYWDSU	Station 027	219544	2.5	23-4.16 kV		29	5	73	6	11	0	124



NYWDSU	Station 045	219660	2.5	23-4.16 kV 2.5		87	8	306	149	14	0	564
NYCDSU	Roosevelt Road Temp	210109	1.667	23-4.8 kV 1.66		41	27	51	84	8	0	211
NYEDSU	Glens Falls Hospital S	222024	3.2	34.5-4.16 kV 2	35	101	40	236	75	39	0	491
<b>Total MVA</b>				<b>195.094</b>								
NYCDSU	State Street Station 9	221400	3.75	23-4.8 kV 3/3.	55	44	6	420	7	22	0	499
NYCDSU	Miller Street Station 1	220549	3.1	34.5-4.8	69	6	3	79	3	2	0	93
NYCDSU	Miller Street Station 1	220550	3.1	34.5-4.9	69	29	4	114	4	2	0	153
NYCDSU	Miller Street Station 1	220551	3.1	34.5-4.10	69	4	3	78	3	1	0	89
NYWDSU	Station 048	219683	4.687	23-4.16 kV 3.7	16	0	1	80	1	38	0	120
NYWDSU	Elm Street Station	219816	22.5	23 kV 22.5 MV	42	28	9	901	4	4	1	947
NYWDSU	Elm Street Station	219812	.15	23 kV .15 MVA	42	27	2	100	2	1	0	132
NYCDSU	Fayette Street Station	222295	12/16/20	34.5-4.16 kV 1	43	25	104	157	121	158	0	565
NYCDSU	Fayette Street Station	222293	12/16/20	34.5-4.16 kV 1	43	3	1	37	1	1	0	43
NYWDSU	Station 056	219734	2.5/3.1	23-4.16 kV 2.5	109	4	80	272	133	63	0	552
NYEDSU	Tibbits Avenue Station	221591	5/6.25	34.5-4.16 kV 5	55	119	5	341	4	2	0	471
NYEDSU	Scotia Station 255	221771	5/6.25	34.5-4.16 kV 5	54	68	3	311	0	1	0	383
NYWDSU	Station 051	219697	3	23-4.16 kV 2.5	70	45	21	684	11	8	0	769
NYEDSU	Partridge Street Static	221629	14	34.5-4.16 kV 1		0	32	462	39	12	0	545
NYEDSU	Partridge Street Static	221720	14	34.5-4.16 kV 1		0	27	423	27	12	0	489
NYCDSU	Conkling Station 652	221055	6.25	43.8/4.36 kV 5	53	84	73	260	186	15	0	618
NYCDSU	Park Street Station 14	220629	6.25	34.5-4.16 kV 5	53	46	19	338	11	1	0	415
NYEDSU	Karner Station 317	221618	6.25	34.5-4.16 kV 5	75	12	69	257	264	25	0	627
NYEDSU	Shore Road Station 2	221782	6.3	34.5-4.8 kV 5/	52	104	4	392	1	2	0	503
NYEDSU	Selkirk Station 149	221523	9.4	34.5-13.8 kV 7	40	9	53	339	39	79	0	519
NYCDSU	Seventh North Street	220713	7	34.5-4.8 kV 5/	48	2	77	113	122	7	0	321
NYEDSU	Saratoga Station 142	222469	6.3	34.5-4.16 kV 5	72	21	4	243	2	6	0	276
NYEDSU	Lynn Street Station 32	221923	6.25	34.5-4.16 kV 5	50	138	128	1205	130	19	0	1620
NYEDSU	Gloversville Station 72	222460	25	69-13.8 kV 15/	16	15	6	339	3	7	0	370
NYWDSU	Sheppard Road Static	220383	4.2	34.5-13.8 kV 3	36	101	52	454	47	32	0	686
NYEDSU	Delmar Station 279	221561	11	34.5-4.8 kV 5/	49	79	74	826	87	24	1	1091
NYEDSU	Watt Street Station 38	222432	10.5	34.5-13.8 kV 7	38	60	157	648	194	32	0	1091
NYCDSU	Lenox Station 513	220983	6.25	13.2-4.16 kV 5		80	27	239	185	16	1	548
NYEDSU	Market Hill Station 32	221881	6.25	69-4.16 kV 5/6	45	35	28	613	14	7	0	697
NYEDSU	Newtonville Station 30	221605	6.25	34.5-13.8 kV 5		13	2	194	1	1	0	211
NYEDSU	Lansingburgh Station	221696	7.5	34.5-13.8 kV 7		140	104	709	126	28	0	1107
NYCDSU	State Street Station 9	221402	3.75	23-4.8 kV 3/3.	55	148	237	737	1457	138	0	2717
NYWDSU	Station 043	219667	2.5	23-4.16 kV 2.5	80	0	3	82	2	1	0	88
NYCDSU	Homer Station 129	220606	3.13	34.5 -4.8 kV 2.	56	23	8	266	15	14	0	326
NYCDSU	Homer Station 129	220607	3.13	34.5-4.8 kV 2.	56	14	5	180	5	5	0	209
NYCDSU	Homer Station 129	220605	3.13	34.5-4.8 kV 2.	59	7	4	147	3	4	0	165
NYWDSU	Station 026	219537	5.25	23-4.16 kV 3.7		18	67	214	126	22	0	447
NYWDSU	Station 026	219533	5.25	23-4.16 kV 3.7		5	63	202	126	32	0	428
NYCDSU	West Herkimer Station	221098	7	46-13.8 kV 5/6	38	25	87	320	135	18	0	585
NYWDSU	Station 157	219450	5	23-4.16 kV 5 N		72	57	247	140	18	0	534
NYWDSU	Station 023	219511	2.5	23-4.16 kV 2.5	80	10	6	118	4	27	0	165
NYWDSU	Station 041	219643	2.5	23-4.16 kV 2.5	80	11	5	163	5	10	0	194
NYEDSU	Rensselaer Station 13	221721	10	34.5-13.8 kV 1		15	23	424	16	13	0	491
NYWDSU	Station 041	219647	2.5	23-4.16 kV 2.5	80	13	2	80	2	1	0	98
NYWDSU	Station 023	219512	2.5	23-4.16 kV 2.5	80	7	4	132	5	9	0	157
NYWDSU	Station 037	219620	2.5	23-4.16 kV 2.5	79	86	5	88	12	9	0	200
NYWDSU	Station 037	219614	2.5	23-4.16 kV 2.5	79	12	5	133	6	8	0	164
NYWDSU	Station 037	219619	2.5	23-4.16 kV 2.5	79	35	5	102	6	8	0	156

NYWDSU	Station 034	219594	2.5	23-4.16 kV 2.5	79	8	6	178	5	9	0	206
NYWDSU	Station 035	219604	2.5	23-4.16 kV 2.5	79	7	5	118	4	6	0	140
NYWDSU	Station 035	219603	2.5	23-4.16 kV 2.5	79	4	3	74	2	3	0	86
NYWDSU	Station 035	219598	2.5	23-4.16 kV 2.5	79	6	4	102	3	7	0	122
NYWDSU	Station 034	219595	2.5	23-4.16 kV 2.5	79	2	4	128	3	6	0	143
NYWDSU	Station 035	219602	2.5	23-4.16 kV 2.5	79	4	5	105	4	7	0	125
NYWDSU	Station 040	219635	4.8	23-4.16 kV 3.7		413	40	335	25	25	0	838
NYWDSU	Station 023	219513	2.5	23-4.16 kV 2.5	78	7	2	21	3	2	0	35
NYEDSU	Delmar Station 279	221560	6.25	34.5-4.8 kV 5/6	58	176	5	435	3	2	0	621
NYCDSU	Ash Street Station 220	220700	9.4	34.5-4.16 kV 7	45	30	50	115	121	34	0	350
NYCDSU	Ash Street Station 220	220698	9.4	34.5-4.16 kV 7	45	30	6	168	118	16	0	338
NYCDSU	Ash Street Station 220	220699	9.4	34.5-4.16 kV 7	45	34	8	203	119	19	1	384
NYCDSU	Mine Road Station 77	221262	9.4	34.5-23 kV 7.5	45	2	3	8	0	2	5	20
NYEDSU	Mayfield Station 356	221898	10.5	69-13.8 kV 7.5	41	16	83	192	168	15	0	474
NYCDSU	Antwerp Station 801	221209	3.75	23-4.8 kV 3.75	48	0	8	461	4	154	0	627
NYWDSU	Poland Station 66	220323	2.5	34.5-4.8 kV 2.5	54	1	102	304	211	100	1	719
NYEDSU	Schuylerville Station 3	222479	6.3	34.5-4.8 kV 5/6		26	4	567	2	60	0	659
NYWDSU	Greenhurst Station 60	220533	2.5	34.5-4.8 kV 2.5	53	25	7	216	24	13	0	285
NYCDSU	Constantia Station 19	220669	3.65	34.5-4.16 kV 3	69	9	8	442	5	4	0	468
NYCDSU	Clinton Station 604	221025	10.5	46-13.8 kV 7.5	40	150	8	247	9	8	0	422
NYEDSU	Emmet Street Station	221755	6.25	34.5-4.16 kV 3	55	141	6	354	4	2	0	507
NYWDSU	Sherman Station 54	220529	2.5	34.5-4.8 kV 2.5	51	0	14	236	7	3	0	260
NYWDSU	Station 067	219769	3.75	34.5-4.16 kV 3	?	25	5	197	68	16	1	312
NYWDSU	Station 160 - Summer	219456	3.75	23-4.16 kV 3.7	?	37	60	163	164	10	0	434
NYWDSU	Station 058	219737	4.69	34.5-4.16 kV 3	41	14	31	217	20	80	1	363
NYWDSU	Station 058	219735	4.69	34.5-4.16 kV 3	41	0	71	172	92	87	2	424
NYWDSU	Station 052	219708	3	23-4.16 kV 2.5	70	42	19	514	13	11	0	599
NYWDSU	Station 052	219706	3	23-4.16 kV 2.5	70	35	17	437	13	11	0	513
NYWDSU	Station 052	219710	3	23-4.16 kV 2.5	70	32	17	406	12	10	0	477
NYWDSU	Station 051	219701	3	23-4.16 kV 2.5	70	42	20	697	11	8	0	778
NYWDSU	Station 051	219699	3	23-4.16 kV 2.5	70	39	21	708	10	10	0	788
NYEDSU	Schoharie Station 234	221848	10.5	69-13.8 kV 7.5	38	26	32	127	78	38	0	301
NYEDSU	Brunswick Station 264	221556	10.5	34.5-13.8 kV 7	38	3	70	217	153	23	0	466
NYEDSU	Commerce Avenue S	221600	8.4	34.5-13.8 kV 7		0	1	60	1	1	0	63
NYWDSU	Station 027	219539	2.5	23-4.16 kV 2.5		9	8	75	14	12	0	118
NYWDSU	Station 067	219767	3.75	34.5-4.16 kV 3	42	33	39	112	22	11	2	219
NYWDSU	Station 038	219627	2.5	23-4.16 kV 2.5	79	8	5	147	6	8	0	174
NYWDSU	Station 038	219632	2.5	23-4.16 kV 2.5	79	6	5	129	5	10	0	155
NYWDSU	Station 038	219631	2.5	23-4.16 kV 2.5	79	2	3	92	2	2	0	101
NYCDSU	Fine Station 978	221424	1	34.5-4.8 kV 1 I	57							
NYCDSU	Moira Station 859	221293	3	34.5-4.8 kV 3/4	59	13	4	120	3	4	0	144
NYCDSU	Gabriels Station 835	221268	1.28	46-4.8 kV 1.28	?	4	1	52	1	1	0	59
<b>Total MVA</b>			<b>424</b>									

NYEDSU	Commerce Avenue S	221600	8.4	34.5-13.8 kV	7	0	1	60	1	1	0	63
NYWDSU	Station 027	219539	2.5	23-4.16 kV	2.5	9	8	75	14	12	0	118
NYWDSU	Station 067	219767	3.75	34.5-4.16 kV	3 42	33	39	112	22	11	2	219
NYWDSU	Station 038	219627	2.5	23-4.16 kV	2.5 79	8	5	147	6	8	0	174
NYWDSU	Station 038	219632	2.5	23-4.16 kV	2.5 79	6	5	129	5	10	0	155
NYWDSU	Station 038	219631	2.5	23-4.16 kV	2.5 79	2	3	92	2	2	0	101
<b>Total MVA</b>						<b>431</b>						


**Table 3. New York Transformer Replacement List**

In reference to Table 3, there are 51 transformers on the list for replacement over the next 5 years in New York. There are 4 single-phase banks that will be replaced with 3-phase transformers. Therefore the cost is representative of replacing 40, 3-phase transformers. The cost of replacement is as follows:

- Thirty nine units at \$900k per unit (average), \$7.02M pa for 5 years
- Four units at \$1.5M per unit (average), \$1.2M pa for 5 years


## 11.0 Rhode Island

There are 143 operating transformers in Rhode Island listed in AIMMS, with 12 spares. Of the 143 units, 79 received transformer health and risk scores. The total MVA population in Rhode Island is 983.94, and it is suggested that approximately 16 MVA be replaced per year to keep up with the aging population and to lessen the risk of failures.



**Figure 11. Distribution Transformer Age Profile**

There are 132 units with age data in AIMMS for Rhode Island. Based on the available age data, the average RI transformer age is 36 years. Rhode Island has the oldest average age, but has the least amount of transformers with missing age data as a proportion of the population (7.69%). The Rhode Island transformer age profile can be found in Figure 11.



**Figure 12. Transformer Health and Risk Scores for Rhode Island**

In reference to Figure 12, 93.7% of the transformer health and risk scores for Rhode Island are 5.0 or below. This indicates that a large majority of the units in Rhode Island are in good condition and pose very little risk based on this health and risk scoring system. On the other hand, 2.5% of the population have scores greater than 10, and there is one unit with a score of 41. This unit is on the top of the Rhode Island replacement list. The attached list of replacement candidates for Rhode Island is listed below in Table 4.



**RI - REPLACEMENT BASED ON 16 MVA PER YEAR**

STA LOC	EQNUM	MVA	VOLT	AGE	LAST DGA							
					ZHYD ROGE N	ZME THA NE	ZCARB ON_M ONOXI	ZETH ANE	ZETH YLENE	ZACE TYLE NE	ZCOMB UST_G AS	
<b>Geneva 71</b>	21233	9.38	23-4.16 kV	7 44								
Admiral Street 9	20652	15	22-11	79	2160	6	356	1	23	0	2546	
Admiral Street 9	20659	15	22-11	79	44	6	467	3	18	0	538	
South Street	20316	10	22-11	69	672	2	51	1	10	1		
Elmwood Gnd Bank -	24448	0.5	21.45-11	79								
Elmwood Gnd Bank -	24449	0.5	21.45-11	72								
Elmwood Gnd Bank -	24450	0.5	21.45-11	79								
Hunt River 40	23170	17.92	34.5	39	6	7	167	1	2	0	183	
Hope 15	20794	6.25	21.9-7.2	?	14	2	93	0	3	0	112	
Lakewood 57	22817	10.5	22.9-4.16	45	0	0	2	0	1	1	4	
Vernon 23	24254	3.13	23-4.16	60	18	4	155	0	4	0	181	
<b>Total MVA</b>		<b>79.3</b>										
Lafayette 30	20837	6.25	33.6-12.470Y	52	5	2	84	1	16	0	108	
Toray Fan 87	23700	9.38	34.5-2.4	79	3	5	31	15	3	0	57	
Harris Avenue 12	23244	9.38	23-4.16 kV	7 ?	9	58	335	53	36	0	491	
Knightsville 66	20882	9.38	22.9-4.16 kV	54	0	1	60	0	18	0	79	
Knightsville 66	22811	9.38	22.9-4.16 kV	54	3	1	66	0	4	0	74	
Toray Lumirror 88	23701	10.5	34.5-4.16 kV	49	5	39	206	23	44	0	317	
West Greenville 45	20918	6.25	22.9-13.2 kV	49	0	9	289	0	20	0	318	
Langworthy Corner 86	20222	7	33.6-12.470Y	46	82	17	819	5	47	0	970	
Geneva 71	21232	9.38	22.9-4.16 kV	44	0	1	7	2	14	0	24	
Lakewood 57	21351	10.5	22.9-4.16 kV	43	9	15	70	13	4	0	111	
Coventry 54	20679	9.38	34.5-12.470Y	43	19	2	115	0	1	0	137	
Auburn 73	21347	10.5	21.9-4.16 kV	42	5	10	122	6	3	0	146	
Warwick 52	21036	10.5	22.9-13.2 kV	41	30	146	172	253	13	0	614	
Warwick Mall 28	20498	6.25	22.9-13.2 kV	40	30	130	449	58	341	1	1009	
<b>Total MVA</b>		<b>108.4</b>										


**Table 4. Rhode Island Transformer Replacement List**

In reference to Table 4, there are 11 transformers on the list for replacement over the next 5 years in Rhode Island. However, one is to be replaced in FY10, which is excluded from the cost analysis. There is one single-phase bank that will be replaced with a 3-phase transformer. Therefore the cost is representative of replacing 8, 3-phase transformers. The cost of replacement is as follows:

- Three units at \$900k per unit (average), \$540k pa for 5 years
- Five units at \$1.5M per unit (average), \$1.5M pa for 5 years


## 12.0 New Hampshire and Vermont

There are 44 operating transformers in New Hampshire and Vermont, with 2 spares. Of the 44 units, 15 received transformer health and risk scores. The replacement candidates in New Hampshire and Vermont were based on condition rather than total MVA due to the small quantity of units located in these states. There is one unit on the replacement list that is located in Vermont.



**Figure 13. Distribution Transformer Age Profile**

There are 37 units with age data in AIMMS for New Hampshire and Vermont. Based on the available age data, the average NH and VT transformer age is 34 years. NH and VT have the least amount of transformers with missing age data by actual count (7 units). The New Hampshire and Vermont transformer age profile is shown in Figure 13.



**Figure 14. Transformer Health and Risk Scores for New Hampshire and Vermont**

In reference to Figure 14, the majority of the transformer health and risk scores for New Hampshire and Vermont are 5.0 or below. This indicates that a most of the units in New Hampshire and Vermont are in good condition and pose very little risk based on this health and risk scoring system. There is 1 unit with a score of 15 and this unit is on the replacement list. The replacement candidates for New Hampshire and Vermont are listed below in Table 5 and Table 6.

NH - REPLACEMENT BASED ON CONDITION						LAST DGA						
DIVISION	STA LOC	EQNUM	MVA	VOLT	AGE	ZHYD ROGE N	ZMET HANE	ZCAR BON_ MON	ZET HAN E	ZET HYL ENE	ZA CE TY	ZCOM BUST GAS
NENG	Salem Depot 9	23068	7	22.9-13.2	?	565	264	1050	139	96	0	2114
NENG	Salem Depot 9	20402	7	22.9-13.2	41	104	17	1160	4	28	0	1313
NENG	Spicket River 13	23438	9.38	22.9-13.2 ZZ	?	129	71	508	40	104	0	852
NENG	Barron Avenue 10	20775	6.25	22.9-13.2	47	11	150	708	93	49	0	1011
<b>Total MVA</b>		<b>29.63</b>										
NENG	Barron Avenue 10	21649	6.25	22.9-13.2 kV	38	11	150	708	93	49	0	1011
NENG	Charlestown 32	23604	6.25	45-13.2 kV 5/	36	30	29	736	5	63	0	863
NENG	Salem Depot 9	22772	9.38	22.9-13.2 ZZ k	20	70	39	573	17	3	0	702
<b>Total MVA</b>		<b>21.88</b>										

**Table 5. New Hampshire Transformer Replacement List**

VT - REPLACEMENT BASED ON CONDITION						ZHYD ROGE N	ZMET HANE	ZCAR BON_ MONO XIDE	ZET HAN E	ZET HYL ENE	ZAC ETYL ENE	ZCOM BUST _GAS
DIVISION	STA LOC	EQNUM	MVA	VOLT	AGE							
NENG	Bridge Street 67	20062	3.75	6.9-4.8	49							

**Table 6. Vermont Transformer Replacement List**

In reference to Tables 5 and 6, there are 5 transformers on the list for replacement over the next 5 years in New Hampshire (4 units) and in Vermont (1 unit). The cost of replacement is as follows:

Four units at \$900k per unit (average), \$720k pa for 5 years

One unit at \$1.5M per unit (average), \$300k pa for 5 years

## United Power Group, Inc.

Liberty Utilities  
9 Lowell Road  
Salem, NH 03079

Date. 8/27/14  
Project No.

### **Project Location:**

Barron Ave. Substation

### **Scope:**

Perform testing & maintenance on the following equipment:

1. 10L1 Transformer
2. 10L1 Recloser and Form 3A Controller
3. 10L1 Voltage Regulators
4. Substation Perimeter Fence Grounding

### **Remarks:**

1. Transformer 10L1's bushings are showing signs of deterioration. UPG would like to see past test data for the transformer.  
The transformer is over 40 years old. UPG recommends retesting the transformer in 1 year to see if the condition worsens.
2. Recloser 10L1 and form 3A controller test results are acceptable for service.
3. Voltage regulators 10L1 test results are acceptable for service.
4. UPG was asked to inspect the ground on the perimeter fence. It was discovered that most of the fence was ungrounded;  
a 2-point test was used to find this issue. UPG recommends adding grounds to the fence posts and adding a ground wire along the chain link.

**Submitted by:** James Fazio



## United Power Group, Inc.

Customer Liberty Utilities Date 8/26/2014 Page No. \_\_\_\_\_  
 Address Salem, NH Air Temp. 25C Project No. \_\_\_\_\_  
 Owner Liberty Utilities Date Last Inspection \_\_\_\_\_ Rel. Humidity 32%  
 Address Salem, NH Last Inspection Report No. \_\_\_\_\_  
 By Others \_\_\_\_\_

Equipment Location Barron Ave. Substation  
 Owner Identification Transformer 10L1

### Nameplate Information

Manufacturer GE KVA 5000/5600/7000 Phase 3 Cycle 60  
 Serial No. F-959759 Type Power Form \_\_\_\_\_ Class QA  
 Primary Voltage 13.2kV Delta Wye X Rated Current 141 Amperes  
 Secondary Voltage 7.62kV Delta Wye X Rated Current 245 Amperes  
 Coolant Oil X Askarel \_\_\_\_\_ Air \_\_\_\_\_ Nitrogen \_\_\_\_\_ Other \_\_\_\_\_  
 Coolant Capacity - Units \_\_\_\_\_ Main Tank 690UG LTC \_\_\_\_\_ Switch \_\_\_\_\_  
 Temperature Rise \_\_\_\_\_ Date of Manufacture \_\_\_\_\_ Impedance 3.58%  
 No Load Tap Changer Voltages 24100/23500/22900/22300/21700

Gauges and Counters	Measured	Maximum	Reset	Trip	Alarm	LTC	Measured	Max.	Min.
Oil Temperature	40C	60C	X			Tap	NA		
Wdg. Temperature			X			Counter	NA		
Pressure	1+								
Oil Level	25C								

### Visual Inspection

Primary Connection	OK	Secondary Connections	OK
Tap Connections	OK	Leaks	NA
Gas Regulator	NA	Paint	OK
Infra-Red Inspection	NA	Grounds	OK

Fans and Controls	Oil Temp.	Wdg. Temp.	Manual	Auto	Lubrication Date
Stage 1	60C		X	X	
Stage 2					

### Accessory Inspection

	Alarm	Trip
Pressure Relief Device - Main Tank		
Pressure Relief Device - LTC		
Sudden Pressure Device		

### Additional Tests

---



---



---



---

Remarks (1) Cooling fan is missing.

Submitted By JF

**Transformer 10L1 – Doble Test**

<b>Company</b>	UPG		<b>Serial Number</b>	F-959759	
<b>Location</b>	Barron Ave. Substation		<b>Special ID</b>	Transformer - 10L1	
<b>Division</b>	Liberty Utilities		<b>Circuit Designation</b>		
<b>Manufacturer</b>	GE		<b>Configuration</b>	Y-Y	
<b>Year Mfg.</b>			<b>Tank Type</b>	OTHER	
<b>Mfr. Location</b>	USA		<b>Coolant</b>	OIL	
<b>Phases</b>	3		<b>Class</b>	OA/FA	
<b>Oil Volume</b>	690 UG		<b>BIL</b>	110 kV	
<b>Weight</b>	18600 LB		<b>Winding Config.</b>	Wye-Wye	
<b>kV</b>	22.9, 7.62		<b>VA Rating</b>	, 5000, 5600, 7000 kVA	
<b>Note</b>					
<b>Test Date</b>	8/26/2014	<b>Test Time</b>	7:54:38 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	23 °C	<b>Tank Temp.</b>	23°C	<b>RH.</b>	61 %
<b>Tested by</b>	JF/RB	<b>Work Order #</b>		<b>Last Test Date</b>	7/31/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	2

**Bushing Nameplate**

Dsg	Serial	Mfr	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	kV	Amps	Year
H2	1629051	GE	U	0.25	433			25	400	1967
H3	1629067	GE	U	0.31	446			25	400	1967
X1	1629055	GE	U	0.27	432			25	400	1967
X2	1629526	GE	U	0.27	439			25	400	1967
XO	1629093	GE	U	0.26	460			25	400	1967
X3	1629060	GE	U	0.27	431			25	400	1967
H1	1629061	GE	U	0.28	449			25	400	1967

**Overall Tests**

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH + CHL	8.005	28.401	1.007		1.00	7533.6		
CH	8.004	28.362	1.002	0.35	1.00	7523.1	G	

### Bushing C1

ID	Serial	NP %PF	NP Cap	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
H1	1629061	0.28	449	10.005	1.722	0.1360	0.79	1.00	456.73	D	
H2	1629051	0.25	433	10.005	1.642	0.0920	0.56	1.00	435.61	D	
H3	1629067	0.31	446	10.010	1.695	0.1050	0.62	1.00	449.49	D	
X1	1629055	0.27	432	10.006	1.630	0.0690	0.42	1.00	432.28	G	
X2	1629526	0.27	439	10.006	1.745	0.0530	0.30	1.00	462.82	D	
X3	1629060	0.27	431	10.005	1.758	0.0640	0.36	1.00	466.21	D	
XO	1629093	0.26	460	10.006	1.738	0.0540	0.31	1.00	460.91	G	

### Insulation Resistance

Mfr.				Serial #			
Connection	Volts	T1(Mohms)	T2(Mohms)	PI			
Hi / Lo to Earth	5000	9500	21000	2.2105			

### Exciting Current Tests

		Mfr.	Type	Steps	Boost %	Buck %	Position Found	Position Left	Oil Volume				
De-Energized Tap Changer													
On-Load Tap Changer													
		H1 - H0			H2 - H0			H3 - H0					
DETC	LTC	Test kV	mA	Watts	X	mA	Watts	X	mA	Watts	X	IR <sub>auto</sub>	IR <sub>man</sub>
	3	8.045	113.84	949.85	L	74.934	657.28	L	114.32	956.31	L	G	

### Turns Ratio (H-L) Tests

Mfr		Serial #		HV Winding				LV Winding			
Connections		H1 - H0		H2 - H0				H3 - H0			
		X1 - X0		X2 - X0				X3 - X0			
Tap	Np Volt	Tap	Np Volt	Cal	Ratio 1	Ratio 2	Ratio 3	Min Lim	Max Lim	IR <sub>auto</sub>	IR <sub>man</sub>
3	13220		7620	1.735	1.732	1.737	1.734	1.726	1.744	G	

## United Power Group, Inc.

### VACUUM RECLOSER TEST AND INSPECTION REPORT

Customer	<u>Liberty Utilities</u>	Date	<u>8/26/2014</u>	Page No.	_____
Address	<u>Salem, NH</u>	Air Temp.	<u>88F</u>	Project No.	_____
Owner	<u>Liberty Utilities</u>	Date Last Inspection	_____	Rel. Humidity	<u>38%</u>
Address	<u>Salem, NH</u>	Last Inspection Report No.	_____		
Equipment Location	<u>Barron Ave.</u>				
Owner Identification	<u>Recloser 10L1</u>				

**Breaker Nameplate Data:**

Manufacturer	<u>McGraw Edison</u>	Type	<u>VSA</u>
Serial No.	<u>1896</u>	Type Operating Mechanism	<u>Coil Spring</u>
Amperes	<u>800</u>	Age	_____
		Interrupt. Rating	<u>12kA</u>
			KV <u>15.5</u>

Adjustment Checks	Mfr's Rec.	As Found	As Left
Latch Wipe		X	X
Latch Clearance		X	X
Stop Clearance		X	X
Prop. Clearance		X	X
Phase Checked	A	B	C
Contact Gap	X	X	X
Contact Travel	X	X	X
Contact Wipe	X	X	X
Erosion Indicator	X	X	X

Specified Tolerances (If Applicable)	
Latch Wipe	NA
Latch Clearance	NA
Stop Clearance	NA
Prop. Clearance	NA
Contact Gap	NA
Contact Travel	NA
Contact Wipe	NA
Erosion Indicator	NA

Phase Test Data	A	B	C
5 KV Bottle Megohms			
5 KV Open CB	B1	B3	B5
Megohms To Ground	100,000+	100,000+	100,000+
<i>Bushings not under test were grounded.</i>	B2	B4	B6
	100,000+	100,000+	100,000+
5 KV Closed CB	B1 & B2	B3 & B4	B5 & B6
Megohms To Ground	100,000+	100,000+	100,000+
<i>K = Number Entered Above X 1000</i>			
Closing/Opening Speed	Visual OK		
Contact Rest. Microhms	239	237	241

Inspection and Maintenance:				
Checked Items:	Insp. Item	Found Dirty	Cleaned & Lubed	See Remarks
Vacuum Bottles	X			
Primary Stabs	X			
Ground Stab	X			
Structural Checks	X			
Mech. Conn.	X			
Charging Motor	X			
Closing Springs	X			
Opening Springs	X			
Operation Coils	X			
Auxiliary Devices	X			
Insulating Memb.	X			
Recloser Wiring	X			
Racking Device				
Heater & Lights	X			
Cubicle Wiring	X			
<i>X = Yes For This Entry</i>				
Counter Found			644	
Counter Left			670	

HIPOT Tests Microamps 1 Minute Test			
Phase tested	1	2	3
37.5 KV AC. Bottle Test	P	P	P
37.5 KV Closed CB Test	P	P	P
<i>Bottle Test is a Go No Go Test (P = Pass) (F = Fail)</i>			
<i>Closed Test Energize a Phase &amp; Grd. All Others</i>			

Remarks: Results are acceptable.

Submitted by: J Fazio Equipment Used: DLRO, Megger, HIPOT

### 10L1 - Vacuum Recloser

<b>Company</b>	UPG	<b>Serial Number</b>	1896
<b>Location</b>	Barron Ave Substation	<b>Special ID</b>	Breaker 10L1
<b>Division</b>	Liberty Utility	<b>Circuit Designation</b>	
<b>Manufacturer</b>	MC-ED	<b>Type</b>	VSA
<b>Yr. Manufactured</b>		<b>Class</b>	
<b>Mfr. Location</b>	USA	<b>Mechanism Type</b>	
<b>Interrupting Rating</b>	12.0 kA	<b>Mechanism Design</b>	COIL SPRING
<b>Weight</b>		<b>BIL</b>	110 kV
<b>Total Weight</b>	525 LB	<b>Control Volts</b>	125
<b>Counter</b>		<b>Amps</b>	800
<b>kV</b>	15.5		
<b>Note</b>			
<b>Test Date</b>	8/26/2014	<b>Test Time</b>	11:05:30 AM
<b>Air Temperature</b>	35 °C	<b>Tank Temp.</b>	°C
<b>Tested by</b>	JF	<b>Work Order #</b>	
<b>Checked by</b>		<b>Test Set Type</b>	M4K
<b>Checked Date</b>		<b>Set Top S/N</b>	
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>	
<b>Copies</b>		<b>Sheet #</b>	
		<b>Weather</b>	SUNNY
		<b>RH.</b>	34 %
		<b>Last Test Date</b>	7/31/2014
		<b>Retest Date</b>	
		<b>Reason</b>	ROUTINE
		<b>Travel Time</b>	
		<b>Duration</b>	
		<b>Crew Size</b>	

### Overall Tests

Test Mode	Ph.	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
GND	1	10.003	0.1820	0.0070	G	
GND	1	10.003	0.1750	0.0110	G	
GND	2	10.004	0.1900	0.0110	G	
GND	2	10.003	0.1840	0.0160	G	
GND	3	10.003	0.1920	0.0060	G	
GND	3	10.005	0.1760	0.0090	G	
UST	1	10.004	0.0370	0.0010	G	
UST	2	10.004	0.0390	0.0050	G	
UST	3	10.003	0.0380	0.0010	G	



**Hot Collar Tests**

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	1	GROUND	1	10.005	0.0610	0.0080	G	
	2	GROUND	1	10.007	0.0610	0.0050	G	
	3	GROUND	1	10.006	0.0660	0.0060	G	
	4	GROUND	1	10.006	0.0620	0.0060	G	
	5	GROUND	1	10.007	0.0650	0.0050	G	
	6	GROUND	1	10.007	0.0610	0.0050	G	

# United Power Group, Inc.

## PROTECTIVE RELAY TEST REPORT

Page No. \_\_\_\_\_

Customer Liberty Utilities Date 8/26/14 Proj. No. \_\_\_\_\_

Address Salem, NH Air Temp. 88F Rel. Hum. 35%

Owner Liberty Utilities Date Last Inspection By Others

Address Salem, NH Last Inspection Report No. \_\_\_\_\_

Equipment Location Barron Ave. Substation

Owner Identification 10L1 Recloser

Circuit Identification 10L1 C.T.Ratio 1000/1 P.T.Ratio \_\_\_\_\_

Visual Inspection				Routine Maintenance							
Cover Gasket		X		Glass Cleaned		X		Mfr:	Cooper		
Glass		X		Case Cleaned		X		Type Ph:	Form 3A		
Foreign Material		X		Relay Cleaned		X		Cat No:			
Moisture		X		Connections Tight		X		Tap Range Ph:			
Spiral Spring				Taps Tightened				Tap Range Grd:			
Bearing Condition				Contacts Cleaned				Inst. Range Ph:			
Bearing End-Play				Insulation Resistance		X		Inst Range Grd:			
Disc Clearance				Trip Circuit		X		Use:	51P/51G/79		
Rust		X						S/N =			

Remarks: Results are acceptable.

Relay Settings															
	Reclosing			Inst. Element Setting		Tap Setting		Curve Setting				Time Dial Setting			
	1st	2nd	3rd	50P-1	50G-1	51P	51G	50P-1	50G-1	51P	51G	51P Fast	51G Fast	51P	51G
Specified	5	15	LO			560A	200A					A	1	D	3
As Found	5	15	LO			560A	200A					A	1	D	3
As Left	5	15	LO			560A	200A					A	1	D	3

Test Operations - As Found - Time in Seconds

	Zero Set	Time Element		Current Voltage			Inst. Element		Targets		Reclosing					
		P. U.		Time			Current/Voltage									
		Tap 1	Tap 2	P. U.	Tap 1	Tap 2	Pick Up	Delay	LED	Reset	1st	2nd	3rd	4th		
A Phase		0.588		X	X2	X4	1.16	0.254			X	X				
B Phase		0.586					1.13	0.247			X	X	5	15	LO	
C Phase		0.587					1.15	0.248			X	X				
GRD		0.203					6.26	2.36			X	X				

Test Operations - As Left - Time in Seconds

	Zero Set	Time Element		Current Voltage			Inst. Element		Targets		Reclosing					
		P. U.		Time			Current/Voltage									
		Tap 1	Tap 2	P. U.	Tap 1	Tap 2	Pick Up	Delay	LED	Reset	1st	2nd	3rd	4th		
A Phase		0.588		X	X2	X4	1.16	0.254			X	X				
B Phase		0.586					1.13	0.247			X	X	5	15	LO	
C Phase		0.587					1.15	0.248			X	X				
GRD		0.203					6.26	2.36			X	X				

Submitted By JF Equipment Used Doble 2253

### 10L1 - A Phase Voltage Regulator

<b>Company</b>	UPG	<b>Serial Number</b>	M168839 PVC		
<b>Location</b>	Barron Ave. Substation	<b>Special ID</b>	10L1Regulators		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>	A Phase		
<b>Manufacturer</b>	GE	<b>Type</b>	VR-1		
<b>Yr. Manufactured</b>	2000	<b>Class</b>	OA		
<b>Mfr. Location</b>	USA				
<b>Tank Type</b>	N2 BLANKETED	<b>Coolant</b>	OIL		
<b>Phases</b>	1	<b>BIL</b>	95 kV		
<b>Weight</b>	2790 LB	<b>Oil Volume</b>	95 UG		
<b>kV</b>	7.96	<b>Amps</b>	313		
<b>Impedance</b>	%	<b>VA Rating</b>	250 kVA		
<b>Catalog #</b>		<b>LTC Counter</b>	98624		
<b>Design</b>	Step	<b>Ctrl Wire Diameter</b>			
<b>Catalog/Style</b>		<b>Crew Size</b>			
<b>Note</b>					
<b>Test Date</b>	8/27/2014	<b>Test Time</b>	7:35:00 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	24 °C	<b>Tank Temp.</b>	24°C	<b>RH.</b>	59 %
<b>Tested by</b>		<b>Work Order #</b>		<b>Last Test Date</b>	8/1/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH	8.003	15.928	3.775	2.37	1.00	4223.8	G	

### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	S	GROUND	3	10.012	0.0690	0.0240	G	
	L	GROUND	3	10.014	0.0690	0.0310	G	
	SL	GROUND	3	10.012	0.0650	0.0210	G	

### Insulation Resistance

<b>Mfr.:</b>	AVO	<b>Serial #:</b>				
<b>kV</b>	<b>Connection</b>	<b>T1(Mohms)</b>	<b>T2(Mohms)</b>	<b>PI</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
5000	Src/Load to Earth	3200	6100	1.9062	G	

### Exciting Current Tests

	<b>Mfr.</b>	<b>Type</b>	<b>Steps</b>	<b>Position Found</b>	<b>Position Left</b>					
De-Energized Tap Changer										
On-Load Tap Changer										
	<b>Connections</b>	<b>SA - SL</b>		<b>SB - SL</b>		<b>SC - SL</b>				
<b>LTC</b>	<b>Test kV</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>	
1L	2.500	504.32	792.04							
N	2.500	852.15	856.43							
1R	2.501	501.95	824.77							
2R	2.500	851.27	871.76							
3R	2.501	502.12	816.97							
4R	2.502	852.36	900.32							
5R	2.502	849.18	922.24							
6R	2.502	852.70	905.43							
7R	2.500	502.95	820.01							
8R	2.502	853.18	907.52							
9R	2.503	504.92	847.34							
10R	2.500	853.11	891.57							
11R	2.500	503.78	824.60							
12R	2.503	853.83	919.61							
13R	2.500	850.87	902.72							
14R	2.501	853.13	902.59							
15R	2.499	504.35	819.84							
16R	2.501	853.06	893.12							

### 10L1 – B Phase Voltage Regulator

<b>Company</b>	UPG	<b>Serial Number</b>	M168838 PVC		
<b>Location</b>	Barron Ave. Substation	<b>Special ID</b>	10L1Regulators		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>	B Phase		
<b>Manufacturer</b>	GE	<b>Type</b>	VR-1		
<b>Yr. Manufactured</b>	2000	<b>Class</b>	OA		
<b>Mfr. Location</b>	USA				
<b>Tank Type</b>	N2 BLANKETED	<b>Coolant</b>	OIL		
<b>Phases</b>	1	<b>BIL</b>	95 kV		
<b>Weight</b>	2790 LB	<b>Oil Volume</b>	95 UG		
<b>kV</b>	7.96	<b>Amps</b>	313		
<b>Impedance</b>	%	<b>VA Rating</b>	250 kVA		
<b>Catalog #</b>		<b>LTC Counter</b>	98624		
<b>Design</b>	Step	<b>Ctrl Wire Diameter</b>			
<b>Catalog/Style</b>		<b>Crew Size</b>			
<b>Note</b>					
<b>Test Date</b>	8/27/2014	<b>Test Time</b>	7:35:00 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	24 °C	<b>Tank Temp.</b>	24°C	<b>RH.</b>	59 %
<b>Tested by</b>	JF	<b>Work Order #</b>		<b>Last Test Date</b>	8/1/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH	8.009	15.110	2.741	1.81	1.00	4007.2	G	

### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	S	GROUND	3	10.011	0.0720	0.0260	G	
	L	GROUND	3	10.014	0.0660	0.0310	G	
	SL	GROUND	3	10.012	0.0660	0.0300	G	



**Insulation Resistance**

<b>Mfr.:</b>	AVO	<b>Serial #:</b>				
<b>kV</b>	<b>Connection</b>	<b>T1(Mohms)</b>	<b>T2(Mohms)</b>	<b>PI</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
5000	Src/Load to Earth	8600	13400	1.5581	G	

**Exciting Current Tests**

		<b>Mfr.</b>	<b>Type</b>	<b>Steps</b>	<b>Position Found</b>	<b>Position Left</b>			
De-Energized Tap Changer									
On-Load Tap Changer									
	<b>Connections</b>	<b>SA - SL</b>		<b>SB - SL</b>		<b>SC - SL</b>			
<b>LTC</b>	<b>Test kV</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
1L	2.501	513.71	784.42						
N	2.502	863.16	883.66						
1R	2.500	510.79	801.35						
2R	2.502	862.19	889.40						
3R	2.503	512.35	835.33						
4R	2.500	862.91	869.66						
5R	2.501	859.01	897.53						
6R	2.502	862.84	899.14						
7R	2.504	513.60	845.59						
8R	2.501	863.50	895.13						
9R	2.500	512.98	813.39						
10R	2.502	863.31	897.76						
11R	2.500	513.21	813.64						
12R	2.501	863.61	889.59						
13R	2.501	862.06	910.00						
14R	2.502	863.77	912.19						
15R	2.500	514.03	816.40						
16R	2.502	863.93	902.15						

### 10L1 – C Phase Voltage Regulator

<b>Company</b>	UPG	<b>Serial Number</b>	M168837 PVC		
<b>Location</b>	Barron Ave. Substation	<b>Special ID</b>	10L1Regulators		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>	C Phase		
<b>Manufacturer</b>	GE	<b>Type</b>	VR-1		
<b>Yr. Manufactured</b>	2000	<b>Class</b>	OA		
<b>Mfr. Location</b>	USA				
<b>Tank Type</b>	N2 BLANKETED	<b>Coolant</b>	OIL		
<b>Phases</b>	1	<b>BIL</b>	95 kV		
<b>Weight</b>	2790 LB	<b>Oil Volume</b>	95 UG		
<b>kV</b>	7.96	<b>Amps</b>	313		
<b>Impedance</b>	%	<b>VA Rating</b>	250 kVA		
<b>Catalog #</b>		<b>LTC Counter</b>	98624		
<b>Design</b>	Step	<b>Ctrl Wire Diameter</b>			
<b>Catalog/Style</b>		<b>Crew Size</b>			
<b>Note</b>					
<b>Test Date</b>	8/27/2014	<b>Test Time</b>	7:46:31 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	23 °C	<b>Tank Temp.</b>	23°C	<b>RH.</b>	59 %
<b>Tested by</b>		<b>Work Order #</b>		<b>Last Test Date</b>	8/27/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH	8.004	16.483	4.126	2.50	1.00	4371.0	G	

### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	S	GROUND	3	10.011	0.0730	0.0380	G	
	L	GROUND	3	10.014	0.0680	0.0280	G	
	SL	GROUND	3	10.010	0.0640	0.0360	G	

**Insulation Resistance**

<b>Mfr.:</b>	AVO	<b>Serial #:</b>				
<b>kV</b>	<b>Connection</b>	<b>T1(Mohms)</b>	<b>T2(Mohms)</b>	<b>PI</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
5000	Src/Load to Earth	4890	7220	1.4765		G

**Exciting Current Tests**

		<b>Mfr.</b>	<b>Type</b>	<b>Steps</b>	<b>Position Found</b>	<b>Position Left</b>			
De-Energized Tap Changer									
On-Load Tap Changer									
	<b>Connections</b>	<b>SA - SL</b>		<b>SB - SL</b>		<b>SC - SL</b>			
<b>LTC</b>	<b>Test kV</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
1L	2.515	531.36	845.75						
N	2.509	892.74	923.63						
1R	2.500	526.14	787.71						
2R	2.502	888.78	876.65						
3R	2.500	526.26	789.59						
4R	2.500	888.19	853.04						
5R	2.500	884.38	874.44						
6R	2.503	889.94	893.95						
7R	2.501	527.56	807.78						
8R	2.501	889.12	867.20						
9R	2.500	527.55	792.53						
10R	2.502	889.62	882.03						
11R	2.501	528.06	807.26						
12R	2.501	889.55	872.37						
13R	2.500	887.03	870.17						
14R	2.500	889.19	852.58						
15R	2.501	528.70	807.44						
16R	2.500	889.34	853.53						

## United Power Group, Inc.

Customer Liberty Utilities Date 8/27/2014 Page No. \_\_\_\_\_  
 Address Salem, NH Air Temp. 85F Proj. No. \_\_\_\_\_  
 Owner Liberty Utilities Date Last Inspection By Others Rel. Hum. 54%  
 Address Salem, NH Last Inspection Report No. \_\_\_\_\_

Equipment Location Barron Ave.  
 Owner Identification 10L1

Manuf. GE Type VR1 Test Set# TTR-JF  
 Gallons 95 Oil Levels OK KVA 250

Nameplate Voltage	7960
Line to Line Voltage	
Percent Regulation	5/8%

Ser # A M168839 PVC  
 Ser # B M168838 PVC  
 Ser # C M168837 PVC

Doble Factor	Power Results
Test KV	8
Position	N

Tap Position	Tap Voltage	TTR Ratio	TTR MEASURED VALUES:		
			S-SL A	S-SL B	S-SL C
			L-SL A	L-SL B	L-SL C
16R	8756	0.909	0.904	0.906	0.906
15R	8706	0.914	0.912	0.912	0.912
14R	8657	0.920	0.917	0.917	0.917
13R	8607	0.925	0.923	0.923	0.923
12R	8557	0.930	0.929	0.929	0.929
11R	8507	0.936	0.934	0.934	0.934
10R	8458	0.941	0.941	0.941	0.941
9R	8408	0.947	0.946	0.946	0.946
8R	8358	0.952	0.951	0.951	0.951
7R	8308	0.958	0.957	0.957	0.957
6R	8259	0.964	0.962	0.962	0.962
5R	8209	0.970	0.969	0.969	0.969
4R	8159	0.976	0.976	0.976	0.976
3R	8109	0.982	0.982	0.982	0.982
2R	8060	0.988	0.988	0.988	0.988
1R	8010	0.994	0.994	0.994	0.994
N	7960	1.000	1.000	1.000	1.000
1L	7910	1.006	1.006	1.006	1.006
2L	7861	1.013	1.013	1.013	1.013
3L	7811	1.019	1.019	1.019	1.019
4L	7761	1.026	1.025	1.025	1.025
5L	7711	1.032	1.033	1.033	1.033
6L	7662	1.039	1.041	1.041	1.041
7L	7612	1.046	1.047	1.047	1.047
8L	7562	1.053	1.054	1.054	1.054
9L	7512	1.060	1.061	1.061	1.061
10L	7463	1.067	1.068	1.068	1.068
11L	7413	1.074	1.075	1.075	1.075
12L	7363	1.081	1.082	1.082	1.082
13L	7313	1.088	1.091	1.091	1.091
14L	7264	1.096	1.099	1.099	1.099
15L	7214	1.103	1.107	1.107	1.107
16L	7164	1.111	1.115	1.115	1.115

Remarks: Regulator test results are acceptable.

Docket No. DE 21-004  
Attachment DOE 10-1.e.2  
Page 183 of 245

## United Power Group, Inc.

Liberty Utilities  
9 Lowell Road  
Salem, NH 03079

Date. 9/18/14  
Project No.

### **Project Location:**

Barron Ave. Substation

### **Scope:**

Perform testing & maintenance on the following equipment:

1. 10L4 Transformer
2. 10L4 Recloser and Form 6 Controller
3. 10L4 Voltage Regulators

### **Remarks:**

1. Transformer 10L4's X1 and X2 bushings are showing signs of deterioration. UPG would like to see past test data for the transformer. There is also signs of oil leaking around the bottom valve. A closer look will be taken when the oil sample is extracted.
2. Recloser 10L4 and form 6 controller test results are acceptable for service.
3. Voltage regulators 10L4 test results are acceptable for service.

**Submitted by:** James Fazio



**Transformer 10L4 – Doble Test**

<b>Company</b>	UPG		<b>Serial Number</b>	G-853504	
<b>Location</b>	Barron Ave. Substation		<b>Special ID</b>	Transformer - 10L4	
<b>Division</b>	Liberty Utilities		<b>Circuit Designation</b>		
<b>Manufacturer</b>	GE		<b>Configuration</b>	Y-Y	
<b>Year Mfg.</b>			<b>Tank Type</b>	OTHER	
<b>Mfr. Location</b>	USA		<b>Coolant</b>	OIL	
<b>Phases</b>	3		<b>Class</b>	OA/FA	
<b>Oil Volume</b>	1010 UG		<b>BIL</b>	110 kV	
<b>Weight</b>	35700 LB		<b>Winding Config.</b>	Wye-Wye	
<b>kV</b>	22.9, 7.97		<b>VA Rating</b>	, , 5000, 6250 kVA	
<b>Note</b>					
<b>Test Date</b>	9/17/2014	<b>Test Time</b>	9:31:01 AM	<b>Weather</b>	
<b>Air Temperature</b>	22 °C	<b>Tank Temp.</b>	°C	<b>RH.</b>	40 %
<b>Tested by</b>	JF/MH	<b>Work Order #</b>		<b>Last Test Date</b>	8/26/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	

**Bushing Nameplate**

Dsg	Serial	Mfr	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	kV	Amps	Year
H2	8T01120505	A-BB	O+C	0.36	535	0.30	431	25	400	1998
H3	8T01120509	A-BB	O+C	0.37	530	0.33	425	25	400	1998
X1	1715668	GE	U	0.30	444			16	400	1971
X2	1715669	GE	U	0.31	446			16	400	1971
XO	1715667	GE	U	0.32	447			16	400	1971
X3	1583864	GE	U	0.28	439			16	400	1965
H1	8T01120504	A-BB	O+C	0.36	533	0.42	430	25	400	1998

**Overall Tests**

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH + CHL	8.001	31.693	1.101		1.00	8406.7		
CH	8.001	31.689	1.102	0.35	1.00	8405.6	G	

**Bushing C1**

ID	Serial	NP %PF	NP Cap	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
H1	8T01120504	0.36	533	10.002	2.016	0.0790	0.39	1.00	534.65	G	
H2	8T01120505	0.36	535	10.002	1.923	0.0710	0.37	1.00	537.03	G	
H3	8T01120509	0.37	530	10.002	1.905	0.0740	0.39	1.00	531.98	G	
X1	1715668	0.30	444	8.001	1.684	0.1120	0.67	1.00	446.74	D	
X2	1715669	0.31	446	8.002	1.598	0.0950	0.59	1.00	446.09	D	
X3	1583864	0.28	439	8.001	1.577	0.0550	0.35	1.00	440.27	G	
XO	1715667	0.32	447	8.002	1.598	0.0570	0.36	1.00	446.19	G	

**Bushing C2**

ID	Serial #	NP %PF	NP Cap	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
H1	8T01120504	0.42	430	0.5000	1.568	0.0480	0.31	1.00	437.81	G	
H2	8T01120505	0.30	431	0.5000	1.566	0.0360	0.23	1.00	437.33	G	
H3	8T01120509	0.33	425	0.5000	1.553	0.0350	0.23	1.00	433.74	G	

**Insulation Resistance**

Mfr.	Serial #			
Connection	Volts	T1(Mohms)	T2(Mohms)	PI
Hi to Lo/Earth	5000	4900	11900	2.4286

**Exciting Current Tests**

		Mfr.	Type	Steps	Boost %	Buck %	Position Found	Position Left	Oil Volume				
De-Energized Tap Changer													
On-Load Tap Changer													
		H1 - H0			H2 - H0			H3 - H0					
DETC	LTC	Test kV	mA	Watts	X	mA	Watts	X	mA	Watts	X	IR <sub>auto</sub>	IR <sub>man</sub>
	3	8.024	122.55	1051.2	L	83.382	736.15	L	118.43	1032.3	L	G	

**Turns Ratio (H-L) Tests**

Mfr				Serial #		HV Winding			LV Winding		
						L-N			L-N		
Connections				H1 - H0		H2 - H0			H3 - H0		
				X1 - X0		X2 - X0			X3 - X0		
Tap	Np Volt	Tap	Np Volt	Cal	Ratio 1	Ratio 2	Ratio 3	Min Lim	Max Lim	IR <sub>auto</sub>	IR <sub>man</sub>
2	13570		7970	1.703	1.745	1.745	1.744				G

## United Power Group, Inc.

Customer <u>Liberty Utilities</u>	Date <u>9/17/2014</u>	Page No. _____
Address <u>Salem, NH</u>	Air Temp. <u>14C</u>	Project No. _____
Owner <u>Liberty Utilities</u>	Date Last Inspection _____	Rel. Humidity <u>37%</u>
Address <u>Salem, NH</u>	Last Inspection Report No. _____	By Others _____

Equipment Location Barron Ave. Substation  
 Owner Identification Transformer 10L4

### Nameplate Information

Manufacturer GE KVA 5000/6250 Phase 3 Cycle 60  
 Serial No. G-853504 Type Power Form \_\_\_\_\_ Class OA  
 Primary Voltage 13.57kV Delta Wye X Rated Current \_\_\_\_\_ 123 Amperes  
 Secondary Voltage 7.97kV Delta Wye X Rated Current \_\_\_\_\_ 209 Amperes  
 Coolant Oil X Askarel \_\_\_\_\_ Air \_\_\_\_\_ Nitrogen \_\_\_\_\_ Other \_\_\_\_\_  
 Coolant Capacity - Units \_\_\_\_\_ Main Tank 1010UG LTC \_\_\_\_\_ Switch \_\_\_\_\_  
 Temperature Rise \_\_\_\_\_ Date of Manufacture \_\_\_\_\_ Impedance 3.21%  
 No Load Tap Changer Voltages 24100/23500/22900/22300/21700

Gauges and Counters	Measured	Maximum	Reset	Trip	Alarm	LTC	Measured	Max.	Min.
Oil Temperature	25C	60C	X			Tap	NA		
Wdg. Temperature			X			Counter	NA		
Pressure	1+								
Oil Level	25C								

Visual Inspection			
Primary Connection	OK	Secondary Connections	OK
Tap Connections	OK	Leaks	Bottom Valve
Gas Regulator	NA	Paint	OK
Infra-Red Inspection	NA	Grounds	OK

Fans and Controls	Oil Temp.	Wdg. Temp.	Manual	Auto	Lubrication Date
Stage 1	60C		X	X	
Stage 2					

Accessory Inspection	Alarm	Trip
Pressure Relief Device - Main Tank		
Pressure Relief Device - LTC		
Sudden Pressure Device		

### Additional Tests

---



---



---



---

Remarks Oil leak on bottom valve.

Submitted By JF

### 10L4 - Vacuum Recloser

<b>Company</b>	UPG	<b>Serial Number</b>	CP571172094
<b>Location</b>	Barron Ave Substation	<b>Special ID</b>	Breaker 10L4
<b>Division</b>	Liberty Utility	<b>Circuit Designation</b>	
<b>Manufacturer</b>	KYLE	<b>Type</b>	OTHER
<b>Yr. Manufactured</b>		<b>Class</b>	
<b>Mfr. Location</b>	USA	<b>Mechanism Type</b>	
<b>Interrupting Rating</b>	12.0 kA	<b>Mechanism Design</b>	COIL SPRING
<b>Weight</b>		<b>BIL</b>	110 kV
<b>Total Weight</b>	525 LB	<b>Control Volts</b>	125
<b>Counter</b>		<b>Amps</b>	800
<b>kV</b>	15.5		
<b>Note</b>			
<b>Test Date</b>	9/17/2014	<b>Test Time</b>	12:36:43 PM
<b>Air Temperature</b>	26 °C	<b>Tank Temp.</b>	°C
<b>Tested by</b>		<b>Work Order #</b>	
<b>Checked by</b>		<b>Test Set Type</b>	M4K
<b>Checked Date</b>		<b>Set Top S/N</b>	
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>	
<b>Copies</b>		<b>Sheet #</b>	
		<b>Weather</b>	
		<b>RH.</b>	26 %
		<b>Last Test Date</b>	8/26/2014
		<b>Retest Date</b>	
		<b>Reason</b>	ROUTINE
		<b>Travel Time</b>	
		<b>Duration</b>	
		<b>Crew Size</b>	

### Overall Tests

Test Mode	Ph.	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
GND	1	10.002	0.2240	0.0030		G
GND	1	9.306	0.2010	0.0080		G
GND	2	10.002	0.2230	0.0030		G
GND	2	10.002	0.2060	0.0090		G
GND	3	10.002	0.2230	0.0020		G
GND	3	10.001	0.2000	0.0080		G
UST	1	10.001	0.0490	0.0000		G
UST	2	10.001	0.0490	0.0000		G
UST	3	10.002	0.0490	0.0000		G



**Hot Collar Tests**

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	1	GROUND	1	10.007	0.0730	0.0140	G	
	2	GROUND	1	10.008	0.0780	0.0150	G	
	3	GROUND	1	10.007	0.0770	0.0100	G	
	4	GROUND	1	10.008	0.0720	0.0150	G	
	5	GROUND	1	10.007	0.0640	0.0170	G	
	6	GROUND	1	10.007	0.0730	0.0130	G	

## United Power Group, Inc. VACUUM RECLOSER TEST AND INSPECTION REPORT

Docket No. DE 21-004  
 Attachment DOE 10-1.e.2  
 Project No. 190 of 245  
 Page 190 of 245

Customer Liberty Utilities Date 9/17/2014  
 Address Salem, NH Air Temp. 70F Rel. Humidity 38%  
 Owner Liberty Utilities Date Last Inspection \_\_\_\_\_  
 Address Salem, NH Last Inspection Report No. \_\_\_\_\_  
 Equipment Location Barron Ave.  
 Owner Identification Recloser 10L4

Breaker Nameplate Data:

Manufacturer Kyle Type VSA-12  
 Serial No. CP571172094 Type Operating Mechanism Coil Spring  
 Amperes 800 Ace \_\_\_\_\_ Interrupt. Rating 12kA KV 15.5

Adjustment Checks	Mfr's Rec.	As Found	As Left
Latch Wipe		X	X
Latch Clearance		X	X
Stop Clearance		X	X
Prop. Clearance		X	X
Phase Checked	A	B	C
Contact Gap	X	X	X
Contact Travel	X	X	X
Contact Wipe	X	X	X
Erosion Indicator	X	X	X

Specified Tolerances (If Applicable)	
Latch Wipe	NA
Latch Clearance	NA
Stop Clearance	NA
Prop. Clearance	NA
Contact Gap	NA
Contact Travel	NA
Contact Wipe	NA
Erosion Indicator	NA

Phase Test Data	A	B	C
5 KV Bottle Megohms			
5 KV Open CB	B1	B3	B5
Megohms To Ground	100.000+	100.000+	100.000+
<i>Bushings not under test were arounded.</i>	B2	B4	B6
5 KV Closed CB	B1 & B2	B3 & B4	B5 & B6
Megohms To Ground	100.000+	100.000+	100.000+
<i>K = Number Entered Above X 1000</i>			
Closing/Opening Speed	Visual OK		
Contact Rest. Microhms	169	166	168

Inspection and Maintenance:				
Checked Items:	Insp. Item	Found Dirty	Cleaned & Lubed	See Remarks
Vacuum Bottles	X			
Primary Stabs	X			
Ground Stab	X			
Structural Checks	X			
Mech. Conn.	X			
Charaina Motor	X			
Closing Springs	X			
Opening Springs	X			
Operation Coils	X			
Auxiliary Devices	X			
Insulating Memb.	X			
Recloser Wiring	X			
Racking Device				
Heater & Lights	X			
Cubicle Wiring	X			
<i>X = Yes For This Entry</i>				
Counter Found			58	
Counter Left			74	

HIPOT Tests Microamps 1 Minute Test			
Phase tested	1	2	3
37.5 KV AC. Bottle Test	P	P	P
37.5 KV Closed CB Test	P	P	P
<i>Bottle Test is a Go No Go Test (P = Pass) (F = Fail)</i>			
<i>Closed Test Energize a Phase &amp; Grd. All Others</i>			

Remarks: Results are acceptable.

---



---



---



---



---

Submitted by: J Fazio Equipment Used: DLRO. Meaer. HIPOT

Page No. \_\_\_\_\_

Customer Liberty Utilities Date 9/17/14 Proj. No. \_\_\_\_\_  
 Address Salem, NH Air Temp. 70F Docket No. DE 21-004  
 Owner Liberty Utilities Date Last Inspection Page 10-1.e.2  
 Address Salem, NH Last Inspection Report No. Page 10-1.f.2  
 Equipment Location Barron Ave. Substation  
 Owner Identification 10L4 Recloser

Circuit Identification 10L4 C.T.Ratio 1000/1 P.T.Ratio \_\_\_\_\_

Visual Inspection				Routine Maintenance							
Cover Gasket		X		Glass Cleaned		X		Mfr:	Cooper		
Glass		X		Case Cleaned		X		Type Ph:	Form F6		
Foreign Material		X		Relay Cleaned		X		Cat No:			
Moisture		X		Connections Tight		X		Tap Range Ph:	5-3200A		
Spiral Spring				Taps Tightened				Tap Range Grd:	2-1600A		
Bearing Condition				Contacts Cleaned				Inst. Range Ph:			
Bearing End-Play				Insulation Resistance		X		Inst Range Grd:			
Disc Clearance				Trip Circuit		X		Use:	51P/51G/79		
Rust		X						S/N =			

Remarks: Results are acceptable.

Relay Settings															
	Reclosing			Inst. Element Setting		Tap Setting		Curve Setting				Time Dial Setting			
	1st	2nd	3rd	50P-1	50G-1	51P	51G	50P-1	50G-1	51P	51G	50P-1	50G-1	51P	51G
Specified	5	5	LO			720A	280A							133	140
As Found	5	5	LO			720A	280A							133	140
As Left	5	5	LO			720A	280A							133	140

Test Operations - As Found - Time in Seconds

	Zero Set	Time Element		Current Voltage			Inst. Element		Targets		Reclosing				
		Tap 1	Tap 2	P. U.	Tap 1	Tap 2	Pick Up	Delay	LED	Reset	1st	2nd	3rd	4th	
A Phase		0.723		X	X3	X5			X	X					
B Phase		0.725			1.36	0.524			X	X	5	5	LO		
C Phase		0.726			1.35	0.529			X	X					
GRD		0.284			3.30	1.89			X	X	5	5	LO		

Test Operations - As Left - Time in Seconds

	Zero Set	Time Element		Current Voltage			Inst. Element		Targets		Reclosing				
		Tap 1	Tap 2	P. U.	Tap 1	Tap 2	Pick Up	Delay	LED	Reset	1st	2nd	3rd	4th	
A Phase		0.723		X	X3	X5			X	X					
B Phase		0.725			1.36	0.524			X	X	5	5	LO		
C Phase		0.726			1.35	0.529			X	X					
GRD		0.284			3.30	1.89			X	X	5	5	LO		

Submitted By JF Equipment Used Doble 2253

### 10L4 - A Phase Voltage Regulator

<b>Company</b>	UPG	<b>Serial Number</b>	M044407PFN		
<b>Location</b>	Barron Ave. Substation	<b>Special ID</b>	10L4 Regulators		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>	A Phase		
<b>Manufacturer</b>	GE	<b>Type</b>	ML-32		
<b>Yr. Manufactured</b>	1986	<b>Class</b>	OA		
<b>Mfr. Location</b>	USA				
<b>Tank Type</b>	N2 BLANKETED	<b>Coolant</b>	OIL		
<b>Phases</b>	1	<b>BIL</b>	95 kV		
<b>Weight</b>	2790 LB	<b>Oil Volume</b>	95 UG		
<b>kV</b>	7.96	<b>Amps</b>	313		
<b>Impedance</b>	%	<b>VA Rating</b>	250 kVA		
<b>Catalog #</b>		<b>LTC Counter</b>	258007		
<b>Design</b>	Step	<b>Ctrl Wire Diameter</b>			
<b>Catalog/Style</b>		<b>Crew Size</b>			
<b>Note</b>					
<b>Test Date</b>	9/18/2014	<b>Test Time</b>	8:33:18 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	16 °C	<b>Tank Temp.</b>	°C	<b>RH.</b>	60 %
<b>Tested by</b>	JF	<b>Work Order #</b>		<b>Last Test Date</b>	8/27/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH	8.001	11.093	1.172	1.06	1.00	2942.4	G	

### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	S	GROUND	3	10.013	0.0670	0.0130	G	
	L	GROUND	3	10.014	0.0680	0.0130	G	
	SL	GROUND	3	10.013	0.0610	0.0100	G	

**Insulation Resistance**

<b>Mfr.:</b>	AV0	<b>Serial #:</b>				
<b>kV</b>	<b>Connection</b>	<b>T1(Mohms)</b>	<b>T2(Mohms)</b>	<b>PI</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
5000	Src/Load to Earth	14500	26700	1.8414	G	

**Exciting Current Tests**

		<b>Mfr.</b>	<b>Type</b>	<b>Steps</b>	<b>Position Found</b>	<b>Position Left</b>			
De-Energized Tap Changer									
On-Load Tap Changer									
	<b>Connections</b>	<b>SA - SL</b>		<b>SB - SL</b>		<b>SC - SL</b>			
<b>LTC</b>	<b>Test kV</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
1L	2.500	402.14	1045.1						
N	2.499	1377.1	1286.8						
1R	2.500	401.39	1046.8						
2R	2.498	1376.7	1285.4						
3R	2.500	805.25	1161.8						
4R	2.499	1376.9	1286.7						
5R	2.500	401.82	1046.7						
6R	2.500	1376.4	1286.3						
7R	2.499	805.09	1162.6						
8R	2.499	1376.5	1286.8						
9R	2.500	402.09	1048.4						
10R	2.499	1376.4	1287.5						
11R	2.499	805.57	1164.9						
12R	2.499	1376.5	1288.1						
13R	2.500	402.34	1050.6						
14R	2.499	1377.4	1289.6						
15R	2.500	805.67	1169.1						
16R	2.499	1376.7	1290.4						



### 10L4 – B Phase Voltage Regulator

<b>Company</b>	UPG		<b>Serial Number</b>	M046769PCP	
<b>Location</b>	Barron Ave. Substation		<b>Special ID</b>	10L4 Regulators	
<b>Division</b>	Liberty Utilities		<b>Circuit Designation</b>	B Phase	
<b>Manufacturer</b>	GE		<b>Type</b>	MLT-32	
<b>Yr. Manufactured</b>	1986		<b>Class</b>	OA	
<b>Mfr. Location</b>	USA				
<b>Tank Type</b>	N2 BLANKETED		<b>Coolant</b>	OIL	
<b>Phases</b>	1		<b>BIL</b>	95 kV	
<b>Weight</b>	2790 LB		<b>Oil Volume</b>	95 UG	
<b>kV</b>	7.96		<b>Amps</b>	313	
<b>Impedance</b>	%		<b>VA Rating</b>	250 kVA	
<b>Catalog #</b>			<b>LTC Counter</b>	533046	
<b>Design</b>	Step		<b>Ctrl Wire Diameter</b>		
<b>Catalog/Style</b>			<b>Crew Size</b>		
<b>Note</b>					
<b>Test Date</b>	9/18/2014	<b>Test Time</b>	8:54:10 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	17 °C	<b>Tank Temp.</b>	°C	<b>RH.</b>	55 %
<b>Tested by</b>	JF	<b>Work Order #</b>		<b>Last Test Date</b>	8/27/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH	8.001	12.151	2.242	1.85	1.00	3222.6	G	

### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	S	GROUND	3	10.011	0.0680	0.0100	G	
	L	GROUND	3	10.015	0.0720	0.0100	G	
	SL	GROUND	3	10.012	0.0590	0.0150	G	

**Insulation Resistance**

<b>Mfr.:</b>	AV0	<b>Serial #:</b>				
<b>kV</b>	<b>Connection</b>	<b>T1(Mohms)</b>	<b>T2(Mohms)</b>	<b>PI</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
5000	Src/Load to Earth	6320	14500	2.2943		

**Exciting Current Tests**

		<b>Mfr.</b>	<b>Type</b>	<b>Steps</b>	<b>Position Found</b>	<b>Position Left</b>			
De-Energized Tap Changer									
On-Load Tap Changer									
	<b>Connections</b>	<b>SA - SL</b>		<b>SB - SL</b>		<b>SC - SL</b>			
<b>LTC</b>	<b>Test kV</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
1L	2.500	380.98	1048.9						
N	2.500	1287.6	1303.2						
1R	2.500	380.11	1046.7						
2R	2.500	1287.2	1303.8						
3R	2.500	754.57	1166.3						
4R	2.500	1287.6	1304.0						
5R	2.500	380.64	1045.7						
6R	2.500	1288.2	1305.0						
7R	2.500	755.29	1167.3						
8R	2.500	1287.8	1306.0						
9R	2.500	381.08	1048.7						
10R	2.500	1288.2	1307.2						
11R	2.499	755.66	1170.6						
12R	2.499	1288.2	1308.5						
13R	2.500	381.37	1051.2						
14R	2.500	1288.6	1310.5						
15R	2.499	756.11	1176.7						
16R	2.500	1288.8	1314.2						

### 10L4 – C Phase Voltage Regulator

<b>Company</b>	UPG	<b>Serial Number</b>	M044399PFN		
<b>Location</b>	Barron Ave. Substation	<b>Special ID</b>	10L4 Regulators		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>	C Phase		
<b>Manufacturer</b>	GE	<b>Type</b>	ML-32		
<b>Yr. Manufactured</b>	1986	<b>Class</b>	OA		
<b>Mfr. Location</b>	USA				
<b>Tank Type</b>	N2 BLANKETED	<b>Coolant</b>	OIL		
<b>Phases</b>	1	<b>BIL</b>	95 kV		
<b>Weight</b>	2790 LB	<b>Oil Volume</b>	95 UG		
<b>kV</b>	7.96	<b>Amps</b>	313		
<b>Impedance</b>	%	<b>VA Rating</b>	250 kVA		
<b>Catalog #</b>		<b>LTC Counter</b>	426012		
<b>Design</b>	Step	<b>Ctrl Wire Diameter</b>			
<b>Catalog/Style</b>		<b>Crew Size</b>			
<b>Note</b>					
<b>Test Date</b>	9/18/2014	<b>Test Time</b>	9:20:05 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	19 °C	<b>Tank Temp.</b>	°C	<b>RH.</b>	47 %
<b>Tested by</b>	JF	<b>Work Order #</b>		<b>Last Test Date</b>	8/27/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH	8.001	12.102	2.191	1.81	1.00	3209.6	G	

### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	S	GROUND	3	10.011	0.0650	0.0060	G	
	L	GROUND	3	10.015	0.0670	0.0080	G	
	SL	GROUND	3	10.012	0.0580	0.0050	G	

### Insulation Resistance

<b>Mfr.:</b>	AVO	<b>Serial #:</b>				
<b>kV</b>	<b>Connection</b>	<b>T1(Mohms)</b>	<b>T2(Mohms)</b>	<b>PI</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
5000	Src/Load to Earth	12700	27800	2.189		

### Exciting Current Tests

		Mfr.	Type	Steps	Position Found	Position Left			
De-Energized Tap Changer									
On-Load Tap Changer									
	Connections	SA - SL		SB - SL		SC - SL		IR <sub>auto</sub>	IR <sub>man</sub>
LTC	Test kV	mA	Watts	mA	Watts	mA	Watts		
1L	2.501	411.41	1059.7						
N	2.500	1376.3	1303.3						
1R	2.500	410.61	1059.3						
2R	2.499	1376.3	1303.8						
3R	2.500	810.33	1176.6						
4R	2.500	1376.6	1303.8						
5R	2.500	411.25	1059.1						
6R	2.500	1376.6	1303.1						
7R	2.500	810.99	1176.9						
8R	2.499	1377.0	1303.9						
9R	2.499	411.57	1060.8						
10R	2.500	1376.6	1304.1						
11R	2.500	810.99	1179.2						
12R	2.500	1376.7	1305.7						
13R	2.500	411.88	1063.7						
14R	2.500	1376.8	1307.3						
15R	2.499	811.02	1183.2						
16R	2.500	1376.6	1308.5						

## United Power Group, Inc.

Customer Liberty Utilities Date 9/18/2014 Page No. \_\_\_\_\_  
 Address Salem, NH Air Temp. 55F Proj. No. \_\_\_\_\_  
 Owner Liberty Utilities Date Last Inspection By Others Rel. Hum. 37%  
 Address Salem, NH Last Inspection Report No. \_\_\_\_\_

Equipment Location Barron Ave.  
 Owner Identification 10L4 Regulators

Manuf. GE Type VR1 Test Set# TTR-JF  
 Gallons 95 Oil Levels OK KVA 250

Nameplate Voltage	7960
Line to Line Voltage	
Percent Regulation	5/8%

Ser # A M044407PFN  
 Ser # B M046769PCP  
 Ser # C M044399PFN

Doble Factor	Power Results
Test KV	8
Position	N

Tap Position	Tap Voltage	TTR Ratio	TTR MEASURED VALUES:		
			S-SL A	S-SL B	S-SL C
			L-SL A	L-SL B	L-SL C
16R	8756	0.909	0.904	0.905	0.905
15R	8706	0.914	0.912	0.912	0.912
14R	8657	0.920	0.917	0.918	0.917
13R	8607	0.925	0.925	0.921	0.923
12R	8557	0.930	0.929	0.928	0.929
11R	8507	0.936	0.934	0.933	0.933
10R	8458	0.941	0.941	0.941	0.939
9R	8408	0.947	0.945	0.946	0.946
8R	8358	0.952	0.951	0.952	0.951
7R	8308	0.958	0.957	0.956	0.957
6R	8259	0.964	0.964	0.962	0.963
5R	8209	0.970	0.969	0.968	0.969
4R	8159	0.976	0.975	0.976	0.976
3R	8109	0.982	0.982	0.982	0.981
2R	8060	0.988	0.987	0.989	0.988
1R	8010	0.994	0.994	0.995	0.994
N	7960	1.000	1.000	1.001	1.000
1L	7910	1.006	1.007	1.007	1.006
2L	7861	1.013	1.013	1.013	1.013
3L	7811	1.019	1.02	1.019	1.019
4L	7761	1.026	1.025	1.024	1.025
5L	7711	1.032	1.032	1.034	1.033
6L	7662	1.039	1.041	1.041	1.042
7L	7612	1.046	1.047	1.047	1.048
8L	7562	1.053	1.055	1.055	1.054
9L	7512	1.060	1.061	1.061	1.062
10L	7463	1.067	1.069	1.068	1.068
11L	7413	1.074	1.076	1.076	1.075
12L	7363	1.081	1.083	1.082	1.082
13L	7313	1.088	1.092	1.092	1.093
14L	7264	1.096	1.099	1.101	1.099
15L	7214	1.103	1.109	1.107	1.107
16L	7164	1.111	1.117	1.116	1.115

Remarks: Regulator test results are acceptable.



## United Power Group, Inc.

Liberty Utilities  
9 Lowell Road  
Salem, NH 03079

Date: 8/1/14  
Project No.

### **Project Location:**

Salem Depot Substation

### **Scope:**

Perform testing & maintenance on the following equipment:

1. Transformer 9T3
2. Transformer 9L1T
3. 9L3 Recloser and Form 6 Controller
4. 9L3 Voltage Regulators

### **Remarks:**

1. Transformer 9T3's H3 bushing is showing signs of deterioration; the bushing's power factor value has doubled and needs to be replaced. The oil temperature and tank pressure gauges are in poor condition. UPG also recommends replacing both gauges.
2. Transformer 9L1T test results are acceptable for service.
3. Recloser 9L3 and form 6 controller test results are acceptable for service.
4. Voltage regulator 9L3 "A phase" stopped operating on the 15L tap. It was discovered that the limit switch located in the regulator tap indication gauge was misaligned. Adjustments were made and the regulator operated correctly. All other test results are acceptable.

**Submitted by:** James Fazio

### 9T3- Two-winding Transformer

<b>Company</b>	UPG	<b>Serial Number</b>	M 160691		
<b>Location</b>	Salem Depot Substation	<b>Special ID</b>	Transformer - 9T3		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>			
<b>Manufacturer</b>	GE	<b>Configuration</b>	D-ZZY		
<b>Year Mfg.</b>		<b>Tank Type</b>	OTHER		
<b>Mfr. Location</b>	USA	<b>Coolant</b>	OIL		
<b>Phases</b>	3	<b>Class</b>	OA/FA		
<b>Oil Volume</b>	1250 UG	<b>BIL</b>	110 kV		
<b>Weight</b>	43400 LB	<b>Winding Config.</b>	Delta-Wye		
<b>kV</b>	22.9, 7.62	<b>VA Rating</b>	, , 7500, 9375 kVA		
<b>Note</b>					
<b>Test Date</b>	7/31/2014	<b>Test Time</b>	11:27:29 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	31 °C	<b>Tank Temp.</b>	31°C	<b>RH.</b>	32 %
<b>Tested by</b>	JF/RB	<b>Work Order #</b>		<b>Last Test Date</b>	7/31/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	TROUBLE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	2

### Bushing Nameplate

Dsg	Serial	Mfr	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	kV	Amps	Year
H1	3745150989	W	0C	0.33	583			25	400	1989
H2	3745151089	W	0C	0.32	592			25	400	1989
H3	3740560189	W	0C	0.31	600			25	400	1989
X1	3745151189	W	0C	0.34	563			25	400	1989
X2	3745150289	W	0C	0.33	593			25	400	1989
X0	3745150389	W	0C	0.32	588			25	400	1989
X3	3745150189	W	0C	0.31	600			25	400	1989

**Overall Tests**

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH + CHL	10.004	45.326	1.337		1.00	12023.0		
CH	10.003	15.242	0.5490	0.36	1.00	4043.0	G	
CHL(UST)	10.003	30.074	0.7620	0.25	1.00	7977.4	G	
CHL		30.084	0.788	0.26	1.00	7980.000	G	
CL + CHL	8.003	64.041	1.742		1.00	16987.3		
CL	8.003	33.959	0.9870	0.29	1.00	9007.8	G	
CHL(UST)	8.003	30.073	0.7580	0.25	1.00	7977.0	G	
CHL		30.082	0.755	0.25	1.00	7979.500	G	
CH'		8.756	0.270	0.31	1.00	2263.540		
CL'		25.306	0.666	0.26	1.00	6684.280		

**Bushing C1**

ID	Serial	NP %PF	NP Cap	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
H1	3745150989	0.33	583	10.002	2.091	0.0730	0.35	1.00	583.83	G	
H2	3745151089	0.32	592	10.003	2.122	0.0680	0.32	1.00	592.63	G	
H3	3740560189	0.31	600	10.010	2.273	0.1380	0.61	1.00	603.00	D	
XO	3745150389	0.32	588	8.004	2.218	0.0820	0.37	1.00	588.27	G	
X1	3745151189	0.34	563	8.007	2.232	0.0850	0.38	1.00	592.17	G	
X2	3745150289	0.33	593	8.004	2.023	0.0720	0.36	1.00	564.80	G	
X3	3745150289-	0.33	593	8.004	2.180	0.0820	0.38	1.00	578.28	G	

**Insulation Resistance**

Mfr.	AVO		Serial #	
Connection	Volts	T1(Mohms)	T2(Mohms)	PI
Hi to Earth Guard Lo	5000	17800	20700	1.162
Lo to Earth Guard Hi	5000	14400	34400	2.388
Hi to Lo Guard Earth	5000	15200	45700	3.006

### Exciting Current Tests

			Mfr.	Type	Steps	Boost %	Buck %	Position Found	Position Left	Oil Volume			
De-Energized Tap Changer													
On-Load Tap Changer													
			H1 - H3			H2 - H1			H3 - H2				
DETC	LTC	Test kV	mA	Watts	X	mA	Watts	X	mA	Watts	X	IR <sub>auto</sub>	IR <sub>man</sub>
	3	8.028	55.290	421.21	L	22.841	175.63	L	60.242	448.31	L	G	

### Turns Ratio (H-L) Tests

Mfr		Serial #		HV Winding				LV Winding			
				L-L				L-N			
Connections		H1 - H0		H2 - H0				H3 - H0			
		X1 - X0		X2 - X0				X3 - X0			
Tap	Np Volt	Tap	Np Volt	Cal	Ratio 1	Ratio 2	Ratio 3	Min Lim	Max Lim	IR <sub>auto</sub>	IR <sub>man</sub>
3	22900		7620	3.005	3.001	2.999	3.002	2.990	3.020	G	

## United Power Group, Inc.

Customer Liberty Utilities Date 7/31/2014 Page No. \_\_\_\_\_  
 Address Salem, NH Air Temp. 25C Project No. \_\_\_\_\_  
 Owner Liberty Utilities Date Last Inspection \_\_\_\_\_ Rel. Humidity 32%  
 Address Salem, NH Last Inspection Report No. \_\_\_\_\_  
 By Others \_\_\_\_\_

Equipment Location Salem Depot Substation  
 Owner Identification 9T3

### Nameplate Information

Manufacturer GE KVA 7500/9375 Phase 3 Cycle 60  
 Serial No. M 160691 Type Power Form \_\_\_\_\_ Class QA/FA  
 Primary Voltage 22.9kV Delta X Wye \_\_\_\_\_ Rated Current 236 Amperes  
 Secondary Voltage 7.62kV Delta \_\_\_\_\_ Wye X Rated Current 410 Amperes  
 Coolant Oil X Askarel \_\_\_\_\_ Air \_\_\_\_\_ Nitrogen \_\_\_\_\_ Other \_\_\_\_\_  
 Coolant Capacity - Units \_\_\_\_\_ Main Tank 1250UG LTC \_\_\_\_\_ Switch \_\_\_\_\_  
 Temperature Rise \_\_\_\_\_ Date of Manufacture \_\_\_\_\_ Impedance 7.37%  
 No Load Tap Changer Voltages 24100/23500/22900/22300/21700

Gauges and Counters	Measured	Maximum	Reset	Trip	Alarm	LTC	Measured	Max.	Min.
Oil Temperature	40C	110C	X			Tap	NA		
Wdg. Temperature	30C	70C	X			Counter	NA		
Pressure	1+								
Oil Level	25C								

### Visual Inspection

Primary Connection	OK	Secondary Connections	OK
Tap Connections	OK	Leaks	NA
Gas Regulator	NA	Paint	OK
Infra-Red Inspection	NA	Grounds	OK

Fans and Controls	Oil Temp.	Wdg. Temp.	Manual	Auto	Lubrication Date
Stage 1	80C		OK	OK	
Stage 2					

Accessory Inspection	Alarm	Trip
Pressure Relief Device - Main Tank		
Pressure Relief Device - LTC		
Sudden Pressure Device		

### Additional Tests

---



---



---



---

Remarks Oil temp and tank pressure gauges needs to be replaced.

Submitted By JF



### 9L1T- Auto Transformer

<b>Company</b>	UPG	<b>Serial Number</b>	965618C		
<b>Location</b>	Salem Depot Substation	<b>Special ID</b>	Transformer - 9L1T		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>			
<b>Manufacturer</b>	GE	<b>Configuration</b>	Y-Y		
<b>Year Mfg.</b>		<b>Tank Type</b>	OTHER		
<b>Mfr. Location</b>	USA	<b>Coolant</b>	OIL		
<b>Phases</b>	3	<b>Class</b>	OA/FA		
<b>Oil Volume</b>	690 UG	<b>BIL</b>	150 kV		
<b>Weight</b>	18600 LB	<b>Winding Config.</b>	Wye-Wye		
<b>kV</b>	22.9, 13.8	<b>VA Rating</b>	5000,6250,7000 kVA		
<b>Note</b>					
<b>Test Date</b>	7/31/2014	<b>Test Time</b>	8:45:13 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	25 °C	<b>Tank Temp.</b>	30°C	<b>RH.</b>	45 %
<b>Tested by</b>	JF/RB	<b>Work Order #</b>		<b>Last Test Date</b>	
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	2

### Bushing Nameplate

Dsg	Serial	Mfr	Type	C1 %PF	C1 Cap	C2 %PF	C2 Cap	kV	Amps	Year
X1	1ZUA7CJ2679303	A-BB	O+C	0.26	489	0.15	647	25	400	2008
X2	1ZUA7CJ2679307	A-BB	O+C	0.25	491	0.19	671	25	400	2008
X3	0S23105550	A-BB	O+C	0.29	515	0.27	411	25	400	2000
X0	1ZUA7CJ2679302	A-BB	O+C	0.25	488	0.17	623	25	400	2008
H1	0S23105539	A-BB	O+C	0.25	489	0.25	423	25	400	2000
H2	1ZUA7CJ2679310	A-BB	O+C	0.25	497	0.24	875	25	400	2008
H3	1ZUA7CJ2679305	A-BB	O+C	0.25	489	0.16	725	25	400	2008

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH + CHL	8.004	28.796	0.9190		1.00	7638.3		
CH	8.003	28.791	0.9240	0.32	1.00	7637.0		G

### Bushing C1

ID	Serial	NP %PF	NP Cap	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
H1	0S23105539	0.25	489	8.002	1.838	0.0580	0.32	1.00	487.61	G	
H2	1ZUA7CJ2679310	0.25	497	8.006	1.872	0.0460	0.25	1.00	496.65	G	
H3	1ZUA7CJ2679305	0.25	489	8.004	1.838	0.0440	0.24	1.00	487.43	G	
X0	1ZUA7CJ2679302	0.25	488	8.004	1.832	0.0430	0.23	1.00	485.94	G	
X1	1ZUA7CJ2679303	0.26	489	8.004	1.840	0.0440	0.24	1.00	488.07	G	
X2	1ZUA7CJ2679307	0.25	491	8.004	1.849	0.0440	0.24	1.00	490.53	G	
X3	0S23105550	0.29	515	8.004	1.926	0.0630	0.33	1.00	510.89	G	

### Bushing C2

ID	Serial #	NP %PF	NP Cap	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
H1	0S23105539	0.25	423	0.4990	1.618	0.0190	0.12	1.00	429.10	G	
H2	1ZUA7CJ2679310	0.24	875	0.4990	3.310	0.0770	0.23	1.00	877.87	G	
H3	1ZUA7CJ2679305	0.16	725	0.4990	2.751	0.0520	0.19	1.00	729.70	G	
X1	1ZUA7CJ2679303	0.15	647	0.4990	2.452	0.0420	0.17	1.00	650.38	G	
X2	1ZUA7CJ2679307	0.19	671	0.4990	2.543	0.0420	0.17	1.00	674.46	G	
X3	0S23105550	0.27	411	0.5000	1.569	0.0400	0.25	1.00	416.25	G	
X0	1ZUA7CJ2679302	0.17	623	0.4990	2.356	0.0350	0.15	1.00	624.95	G	

### Insulation Resistance

Mfr.	AVO		Serial #	
Connection	Volts	T1(Mohms)	T2(Mohms)	PI
Hi to Earth Guard Lo		2480	3360	1.35

**Exciting Current Tests**

			Mfr.	Type	Steps	Boost %	Buck %	Position Found	Position Left	Oil Volume			
De-Energized Tap Changer													
On-Load Tap Changer													
			H1 - H0			H2 - H0			H3 - H0				
DETC	LTC	Test kV	mA	Watts	X	mA	Watts	X	mA	Watts	X	IR <sub>auto</sub>	IR <sub>man</sub>
	3	5.008	126.53	1067.1	L	92.078	770.76	L	126.49	1067.6	L	G	

**Turns Ratio (H-L) Tests**

Mfr		Serial #		HV Winding				LV Winding			
				L-N				L-N			
Connections		H1 - H0		H2 - H0				H3 - H0			
		X1 - X0		X2 - X0				X3 - X0			
Tap	Np Volt	Tap	Np Volt	Cal	Ratio 1	Ratio 2	Ratio 3	Min Lim	Max Lim	IR <sub>auto</sub>	IR <sub>man</sub>
3	13220		7620	1.735	1.7339	1.7339	1.7342	1.726	1.744	G	

## United Power Group, Inc.

Customer <u>Liberty Utilities</u>	Date <u>7/31/2014</u>	Page No. _____
Address <u>Salem, NH</u>	Air Temp. <u>25C</u>	Project No. _____
Owner <u>Liberty Utilities</u>	Date Last Inspection _____	Rel. Humidity <u>32%</u>
Address <u>Salem, NH</u>	Last Inspection Report No. _____	By Others _____

Equipment Location Salem Depot Substation  
 Owner Identification 9L1T

### Nameplate Information

Manufacturer	<u>GE</u>	KVA	<u>5000/6250/7000</u>	Phase	<u>3</u>	Cycle	<u>60</u>
Serial No.	<u>965618C</u>	Type	<u>Auto</u>	Form	_____	Class	<u>QA/FA</u>
Primary Voltage	<u>22.9kV</u>	Delta	<u>Wye X</u>	Rated Current	_____		<u>176</u> Amperes
Secondary Voltage	<u>7.62kV</u>	Delta	<u>Wye X</u>	Rated Current	_____		<u>306</u> Amperes
Coolant	Oil <u>X</u>	Askarel	_____	Air	_____	Nitrogen	_____
						Other	_____
Coolant Capacity - Units	_____	Main Tank	<u>690UG</u>	LTC	_____	Switch	_____
Temperature Rise	_____	Date of Manufacture	_____	Impedance	_____		<u>3.46%</u>
No Load Tap Changer Voltages	<u>24100/23500/22900/22300/21700</u>						

Gauges and Counters	Measured	Maximum	Reset	Trip	Alarm	LTC	Measured	Max.	Min.
Oil Temperature	30C	30C				Tap	NA		
Wdg. Temperature	30C	30C				Counter	NA		
Pressure									
Oil Level	25C								

Visual Inspection			
Primary Connection	OK	Secondary Connections	OK
Tap Connections	OK	Leaks	NA
Gas Regulator	NA	Paint	OK
Infra-Red Inspection	NA	Grounds	OK

Fans and Controls	Oil Temp.	Wdg. Temp.	Manual	Auto	Lubrication Date
Stage 1					
Stage 2					

Accessory Inspection	Alarm	Trip
Pressure Relief Device - Main Tank		
Pressure Relief Device - LTC		
Sudden Pressure Device		

**Additional Tests**

---



---



---



---

Remarks Transformer tested OK.

Submitted By JF

### 9L3 - Vacuum Recloser

<b>Company</b>	UPG		<b>Serial Number</b>	CP571029803	
<b>Location</b>	Salem Depot		<b>Special ID</b>	Recloser 9L3	
<b>Division</b>	Liberty Utility		<b>Circuit Designation</b>		
<b>Manufacturer</b>	CPS		<b>Type</b>	VSA	
<b>Yr. Manufactured</b>	2006		<b>Class</b>		
<b>Mfr. Location</b>	USA		<b>Mechanism Type</b>		
<b>Interrupting Rating</b>	12.0 kA		<b>Mechanism Design</b>	COIL SPRING	
<b>Weight</b>			<b>BIL</b>	110 kV	
<b>Total Weight</b>	525 LB		<b>Control Volts</b>	125	
<b>Counter</b>	124		<b>Amps</b>	800	
<b>kV</b>	15.5				
<b>Note</b>					
<b>Test Date</b>	7/31/2014	<b>Test Time</b>	2:06:19 PM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	31 °C	<b>Tank Temp.</b>		<b>RH.</b>	34 %
<b>Tested by</b>	JF	<b>Work Order #</b>		<b>Last Test Date</b>	
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	

### Overall Tests

Test Mode	Ph.	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
GND	1	10.007	0.2210	0.0180		G
GND	1	10.005	0.2080	0.0220		G
GND	2	10.004	0.2210	0.0270		G
GND	2	10.004	0.2120	0.0250		G
GND	3	10.004	0.2210	0.0150		G
GND	3	10.004	0.2080	0.0340		G
UST	1	10.007	0.0500	0.0010		G
UST	2	10.003	0.0480	0.0000		G
UST	3	10.004	0.0490	0.0010		G



### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	1	GROUND	1	10.004	0.0720	0.0290	G	
	2	GROUND	1	10.005	0.0740	0.0200	G	
	3	GROUND	1	10.004	0.0710	0.0130	G	
	4	GROUND	1	10.004	0.0730	0.0130	G	
	5	GROUND	1	10.004	0.0740	0.0120	G	
	6	GROUND	1	10.004	0.0810	0.0270	G	

## United Power Group, Inc.

### VACUUM RECLOSER TEST AND INSPECTION REPORT

Customer	Liberty Utilities	Date	6/10/2011	Page No.	4
Address	Salem, NH	Air Temp.	77F	Project No.	U061118
Owner	Liberty Utilities	Date Last Inspection	New	Rel. Humidity	42%
Address	Salem, NH	Last Inspection Report No.			
Equipment Location	Salem Depot				
Owner Identification	Recloser 9L3				

**Breaker Nameplate Data:**

Manufacturer	Cooper	Type	VSA12
Serial No.	CP571029803	Type Operating Mechanism	Coil Spring
Amperes	800	Age	2006
		Interrupt. Rating	12kA
		KV	15.5

Adjustment Checks	Mfr's Rec.	As Found	As Left
Latch Wipe		X	X
Latch Clearance		X	X
Stop Clearance		X	X
Prop. Clearance		X	X
Phase Checked	A	B	C
Contact Gap	X	X	X
Contact Travel	X	X	X
Contact Wipe	X	X	X
Erosion Indicator	X	X	X

Specified Tolerances (If Applicable)	
Latch Wipe	NA
Latch Clearance	NA
Stop Clearance	NA
Prop. Clearance	NA
Contact Gap	NA
Contact Travel	NA
Contact Wipe	NA
Erosion Indicator	NA

Phase Test Data	A	B	C
5 KV Bottle Megohms			
5 KV Open CB	B1	B3	B5
Megohms To Ground	100,000+	100,000+	100,000+
<i>Bushings not under test were grounded.</i>	B2	B4	B6
	100,000+	100,000+	100,000+
5 KV Closed CB	B1 & B2	B3 & B4	B5 & B6
Megohms To Ground	100,000+	100,000+	100,000+
<i>K = Number Entered Above X 1000</i>			
Closing/Opening Speed	Visual OK		
Contact Rest. Microhms	180	192	181

Inspection and Maintenance:				
Checked Items:	Insp. Item	Found Dirty	Cleaned & Lubed	See Remarks
Vacuum Bottles	X			
Primary Stabs	X			
Ground Stab	X			
Structural Checks	X			
Mech. Conn.	X			
Charging Motor	X			
Closing Springs	X			
Opening Springs	X			
Operation Coils	X			
Auxiliary Devices	X			
Insulating Memb.	X			
Recloser Wiring	X			
Racking Device				
Heater & Lights	X			
Cubicle Wiring	X			
<i>X = Yes For This Entry</i>				
Counter Found			140	
Counter Left			163	

HIPOT Tests Microamps 1 Minute Test			
Phase tested	1	2	3
37.5 KV AC. Bottle Test	P	P	P
37.5 KV Closed CB Test	P	P	P
<i>Bottle Test is a Go No Go Test (P = Pass) (F = Fail)</i>			
<i>Closed Test Energize a Phase &amp; Grd. All Others</i>			

Remarks: Results are acceptable.

Submitted by: J Fazio Equipment Used: DLRO, Megger, HIPOT

# United Power Group, Inc.

## PROTECTIVE RELAY TEST REPORT

Customer Liberty Utilities Date 8/1/14 Page No. \_\_\_\_\_  
 Address Salem, NH Air Temp. 80F Proj. No. \_\_\_\_\_  
 Owner Liberty Utilities Date Last Inspection By Others Rel. Hum. 35%  
 Address Salem, NH Last Inspection Report No. \_\_\_\_\_  
 Equipment Location Salem Depot Substation  
 Owner Identification 9L3 Recloser

Circuit Identification 9L3 C.T.Ratio 1000/1 P.T.Ratio \_\_\_\_\_

Visual Inspection				Routine Maintenance					
Cover Gasket		X		Glass Cleaned		X		Mfr:	Cooper
Glass		X		Case Cleaned		X		Type Ph:	Form F6
Foreign Material		X		Relay Cleaned		X		Cat No:	
Moisture		X		Connections Tight		X		Tap Range Ph:	5-3200A
Spiral Spring				Taps Tightened				Tap Range Grd:	2-1600A
Bearing Condition				Contacts Cleaned				Inst. Range Ph:	
Bearing End-Play				Insulation Resistance		X		Inst Range Grd:	
Disc Clearance				Trip Circuit		X		Use:	51P/51G/79
Rust		X						S/N =	

Remarks: Results are acceptable.

Relay Settings															
	Reclosing			Inst. Element Setting		Tap Setting		Curve Setting				Time Dial Setting			
	1st	2nd	3rd	50P-1	50G-1	51P	51G	50P-1	50G-1	51P	51G	50P-1	50G-1	51P	51G
Specified	5	10	LO			600A	240A							132	IEC VI
As Found	5	10	LO			600A	240A							132	IEC VI
As Left	5	10	LO			600A	240A							132	IEC VI

### Test Operations - As Found - Time in Seconds

	Zero Set	Time Element		Current Voltage			Inst. Element		Targets		Reclosing				
		P. U.		Time			Current/Voltage								
		Tap 1	Tap 2	P. U.	Tap 1	Tap 2	Pick Up	Delay	LED	Reset	1st	2nd	3rd	4th	
A Phase		0.600		X	X2	X4				X	X				
B Phase		0.600								X	X	5	10	LO	
C Phase		0.600								X	X				
GRD		0.241								X	X				

### Test Operations - As Left - Time in Seconds

	Zero Set	Time Element		Current Voltage			Inst. Element		Targets		Reclosing				
		P. U.		Time			Current/Voltage								
		Tap 1	Tap 2	P. U.	Tap 1	Tap 2	Pick Up	Delay	LED	Reset	1st	2nd	3rd	4th	
A Phase		0.600		X	X2	X4				X	X				
B Phase		0.600								X	X	5	10	LO	
C Phase		0.600								X	X				
GRD		0.241								X	X				

Submitted By JF Equipment Used Doble 2253

### 9L3 - Voltage Regulator "A Phase"

<b>Company</b>	UPG	<b>Serial Number</b>	Q557660-TSR		
<b>Location</b>	Salem Depot Substation	<b>Special ID</b>	9L3 Regulators		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>	A Phase		
<b>Manufacturer</b>	GE	<b>Type</b>	VR-1		
<b>Yr. Manufactured</b>	2000	<b>Class</b>	OA		
<b>Mfr. Location</b>	USA				
<b>Tank Type</b>	N2 BLANKETED	<b>Coolant</b>	OIL		
<b>Phases</b>	1	<b>BIL</b>	95 kV		
<b>Weight</b>	3079 LB	<b>Oil Volume</b>	112 UG		
<b>kV</b>	7.96	<b>Amps</b>	418		
<b>Impedance</b>	%	<b>VA Rating</b>	333 kVA		
<b>Catalog #</b>		<b>LTC Counter</b>	186279		
<b>Design</b>	Step	<b>Ctrl Wire Diameter</b>			
<b>Catalog/Style</b>		<b>Crew Size</b>			
<b>Note</b>					
<b>Test Date</b>	8/1/2014	<b>Test Time</b>	7:29:06 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	23 °C	<b>Tank Temp.</b>	23°C	<b>RH.</b>	62 %
<b>Tested by</b>	jf	<b>Work Order #</b>		<b>Last Test Date</b>	
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	1

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH	8.004	19.973	2.052	1.03	1.00	5297.7	G	

### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	S	GROUND	2	10.004	0.0770	0.0530	G	
	L	GROUND	2	10.006	0.0790	0.0510	G	
	SL	GROUND	2	10.004	0.0580	0.0470	G	

### Insulation Resistance

<b>Mfr.:</b>	AVO	<b>Serial #:</b>				
<b>kV</b>	<b>Connection</b>	<b>T1(Mohms)</b>	<b>T2(Mohms)</b>	<b>PI</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
5000	Src/Load to Earth	5600	26000	4.6429		G

### Exciting Current Tests

		<b>Mfr.</b>	<b>Type</b>	<b>Steps</b>	<b>Position Found</b>	<b>Position Left</b>			
De-Energized Tap Changer									
On-Load Tap Changer									
	<b>Connections</b>	<b>SA - SL</b>		<b>SB - SL</b>		<b>SC - SL</b>			
<b>LTC</b>	<b>Test kV</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
1R	2.500	1144.1	1010.4						
N	2.500	1151.7	984.34						
1L	2.500	685.37	892.26						
2L	2.501	1150.8	1011.6						
3L	2.503	684.84	912.81						
4L	2.500	1151.2	989.06						
5L	2.502	685.01	907.98						
6L	2.502	1151.5	1015.2						
7L	2.503	1148.7	1028.0						
8L	2.500	1151.3	998.78						
9L	2.503	1147.7	1046.1						
10L	2.507	1151.4	1037.8						
11L	2.501	1146.2	1017.6						
12L	2.500	1150.0	999.93						
13L	2.501	682.53	896.33						
14L	2.500	1150.4	991.85						
15L	2.501	682.36	895.51						
16L	2.502	1150.2	1012.6						



### 9L3 - Voltage Regulator “B Phase”

<b>Company</b>	UPG	<b>Serial Number</b>	Q557658-TSR		
<b>Location</b>	Salem Depot Substation	<b>Special ID</b>	9L3 Regulators		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>	B Phase		
<b>Manufacturer</b>	GE	<b>Type</b>	VR-1		
<b>Yr. Manufactured</b>	2000	<b>Class</b>	OA		
<b>Mfr. Location</b>	USA				
<b>Tank Type</b>	N2 BLANKETED	<b>Coolant</b>	OIL		
<b>Phases</b>	1	<b>BIL</b>	95 kV		
<b>Weight</b>	3079 LB	<b>Oil Volume</b>	112 UG		
<b>kV</b>	7.96	<b>Amps</b>	418		
<b>Impedance</b>	%	<b>VA Rating</b>	333 kVA		
<b>Catalog #</b>		<b>LTC Counter</b>	186279		
<b>Design</b>	Step	<b>Ctrl Wire Diameter</b>			
<b>Catalog/Style</b>		<b>Crew Size</b>			
<b>Note</b>					
<b>Test Date</b>	8/1/2014	<b>Test Time</b>	10:17:53 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	25 °C	<b>Tank Temp.</b>	25°C	<b>RH.</b>	55 %
<b>Tested by</b>	JF	<b>Work Order #</b>		<b>Last Test Date</b>	8/1/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	1

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH	8.004	20.432	1.814	0.89	1.00	5419.5	G	

### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	S	GROUND	2	10.005	0.0680	0.0310	G	
	L	GROUND	2	10.008	0.0710	0.0300	G	
	SL	GROUND	2	10.007	0.0690	0.0280	G	

### Insulation Resistance

<b>Mfr.:</b>	AVO	<b>Serial #:</b>				
<b>kV</b>	<b>Connection</b>	<b>T1(Mohms)</b>	<b>T2(Mohms)</b>	<b>PI</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
5000	Src/Load to Earth	12300	34200	2.7805		

### Exciting Current Tests

		<b>Mfr.</b>	<b>Type</b>	<b>Steps</b>	<b>Position Found</b>	<b>Position Left</b>			
De-Energized Tap Changer									
On-Load Tap Changer									
	<b>Connections</b>	<b>SA - SL</b>		<b>SB - SL</b>		<b>SC - SL</b>			
<b>LTC</b>	<b>Test kV</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
1R	2.505	1165.1	1059.9						
N	2.502	1170.9	1004.2						
1L	2.501	695.86	925.58						
2L	2.504	1171.3	1042.6						
3L	2.500	695.31	915.41						
4L	2.499	1170.3	997.49						
5L	2.502	695.67	921.06						
6L	2.501	1170.9	1017.4						
7L	2.499	1167.3	1021.4						
8L	2.505	1171.5	1035.8						
9L	2.500	1166.0	1029.8						
10L	2.499	1169.8	1005.1						
11L	2.503	1165.7	1036.7						
12L	2.502	1170.1	1013.2						
13L	2.500	692.89	903.68						
14L	2.503	1169.7	1024.3						
15L	2.501	693.18	910.64						
16L	2.503	1169.6	1022.6						

### 9L3 - Voltage Regulator "C Phase"

<b>Company</b>	UPG	<b>Serial Number</b>	Q557659-TSR		
<b>Location</b>	Salem Depot Substation	<b>Special ID</b>	9L3 Regulators		
<b>Division</b>	Liberty Utilities	<b>Circuit Designation</b>	C Phase		
<b>Manufacturer</b>	GE	<b>Type</b>	VR-1		
<b>Yr. Manufactured</b>	2000	<b>Class</b>	OA		
<b>Mfr. Location</b>	USA				
<b>Tank Type</b>	N2 BLANKETED	<b>Coolant</b>	OIL		
<b>Phases</b>	1	<b>BIL</b>	95 kV		
<b>Weight</b>	3079 LB	<b>Oil Volume</b>	112 UG		
<b>kV</b>	7.96	<b>Amps</b>	418		
<b>Impedance</b>	%	<b>VA Rating</b>	333 kVA		
<b>Catalog #</b>		<b>LTC Counter</b>	186279		
<b>Design</b>	Step	<b>Ctrl Wire Diameter</b>			
<b>Catalog/Style</b>		<b>Crew Size</b>			
<b>Note</b>					
<b>Test Date</b>	8/1/2014	<b>Test Time</b>	11:11:19 AM	<b>Weather</b>	SUNNY
<b>Air Temperature</b>	29 °C	<b>Tank Temp.</b>	29°C	<b>RH.</b>	46 %
<b>Tested by</b>	JF	<b>Work Order #</b>		<b>Last Test Date</b>	8/1/2014
<b>Checked by</b>		<b>Test Set Type</b>	M4K	<b>Retest Date</b>	
<b>Checked Date</b>		<b>Set Top S/N</b>		<b>Reason</b>	ROUTINE
<b>Last Sheet #</b>		<b>Set Bottom S/N</b>		<b>Travel Time</b>	
<b>P.O. #</b>		<b>Ins. Book #</b>		<b>Duration</b>	
<b>Copies</b>		<b>Sheet #</b>		<b>Crew Size</b>	1

### Overall Tests

Meas.	Test kV	mA	Watts	%PF corr	Corr Fctr	Cap(pF)	IR <sub>auto</sub>	IR <sub>man</sub>
CH	8.004	21.188	2.491	1.18	1.00	5619.8	G	

### Hot Collar Tests

Serial #	ID	Test Mode	Skirt #	Test kV	mA	Watts	IR <sub>auto</sub>	IR <sub>man</sub>
	S	GROUND	2	10.005	0.077	0.054	G	
	L	GROUND	2	10.008	0.068	0.051	G	
	SL	GROUND	2	10.007	0.055	0.044	G	

### Insulation Resistance

<b>Mfr.:</b>	AVO	<b>Serial #:</b>				
<b>kV</b>	<b>Connection</b>	<b>T1(Mohms)</b>	<b>T2(Mohms)</b>	<b>PI</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
5000	Src/Load to Earth	5800	9700	1.6724		

### Exciting Current Tests

		<b>Mfr.</b>	<b>Type</b>	<b>Steps</b>	<b>Position Found</b>	<b>Position Left</b>			
De-Energized Tap Changer									
On-Load Tap Changer									
	<b>Connections</b>	<b>SA - SL</b>		<b>SB - SL</b>		<b>SC - SL</b>			
<b>LTC</b>	<b>Test kV</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>mA</b>	<b>Watts</b>	<b>IR<sub>auto</sub></b>	<b>IR<sub>man</sub></b>
1R	2.504	1141.3	1008.0						
N	2.501	1149.3	987.89						
1L	2.502	683.01	894.75						
2L	2.506	1150.6	1017.4						
3L	2.501	682.80	890.91						
4L	2.499	1148.8	971.44						
5L	2.502	682.90	895.02						
6L	2.506	1150.1	1018.0						
7L	2.499	1145.5	996.83						
8L	2.500	1148.4	969.91						
9L	2.500	1144.8	1002.6						
10L	2.500	1147.8	972.31						
11L	2.503	1144.9	1016.2						
12L	2.501	1148.8	984.69						
13L	2.502	681.13	888.42						
14L	2.502	1148.5	992.23						
15L	2.501	680.04	881.51						
16L	2.503	1148.8	998.48						

## United Power Group, Inc.

Customer Liberty Utilities Date 8/1/2014 Page No. \_\_\_\_\_  
 Address Salem, NH Air Temp. 68F Proj. No. \_\_\_\_\_  
 Owner Liberty Utilities Date Last Inspection By Others Rel. Hum. 34%  
 Address Salem, NH Last Inspection Report No. \_\_\_\_\_

Equipment Location Salem Depot  
 Owner Identification 9L3 Regulator Bank

Manuf. GE Type VR1 Test Set# TTR-JF  
 Gallons 112 Oil Levels OK KVA 333

Nameplate Voltage	7960
Line to Line Voltage	
Percent Regulation	5/8%

Ser # A Q557660 - TSR  
 Ser # B Q557658 - TSR  
 Ser # C Q557659 - TSR

Doble Factor	Power Results
Test KV	8
Position	N

Tap Position	Tap Voltage	TTR Ratio	TTR MEASURED VALUES:		
			S-SL A	S-SL B	S-SL C
			L-SL A	L-SL B	L-SL C
16R	8756	0.909	0.906	0.906	0.906
15R	8706	0.914	0.911	0.911	0.911
14R	8657	0.920	0.915	0.915	0.915
13R	8607	0.925	0.921	0.921	0.921
12R	8557	0.930	0.926	0.926	0.926
11R	8507	0.936	0.932	0.932	0.932
10R	8458	0.941	0.937	0.937	0.937
9R	8408	0.947	0.944	0.944	0.944
8R	8358	0.952	0.951	0.951	0.951
7R	8308	0.958	0.957	0.957	0.957
6R	8259	0.964	0.963	0.963	0.963
5R	8209	0.970	0.969	0.969	0.969
4R	8159	0.976	0.975	0.975	0.975
3R	8109	0.982	0.981	0.981	0.981
2R	8060	0.988	0.985	0.985	0.985
1R	8010	0.994	0.995	0.995	0.995
N	7960	1.000	1.000	1.000	1.000
1L	7910	1.006	1.006	1.006	1.006
2L	7861	1.013	1.013	1.013	1.013
3L	7811	1.019	1.017	1.017	1.017
4L	7761	1.026	1.024	1.024	1.024
5L	7711	1.032	1.031	1.031	1.031
6L	7662	1.039	1.037	1.037	1.037
7L	7612	1.046	1.044	1.044	1.044
8L	7562	1.053	1.053	1.053	1.053
9L	7512	1.060	1.061	1.062	1.061
10L	7463	1.067	1.067	1.067	1.067
11L	7413	1.074	1.075	1.075	1.075
12L	7363	1.081	1.083	1.083	1.083
13L	7313	1.088	1.091	1.091	1.091
14L	7264	1.096	1.097	1.097	1.097
15L	7214	1.103	1.105	1.105	1.105
16L	7164	1.111	1.112	1.112	1.112

Remarks: Regulator test results are acceptable.



# WEIDMANN

**WEIDMANN ELECTRICAL TECHNOLOGY**  
 3430 PROGRESS DRIVE, UNIT B + BENSALEM, PA + 19020  
 215 639 8599 + 215 639 8577  
 WWW.WEIDMANN-ELECTRICAL.COM

**TEST REPORT**  
**01-7334797-618125-00**  
 Page 1 of 2

Liberty Utilities

LONDONDERRY, NH 03053 US  
 ATTN: MARIO BARONE  
 PO#: PO000016751  
 Project ID:  
 Customer ID: REF# 024304

**Serial#:** HA08863002 **Mfr:** ABB  
**Location:** BARRON AVENUE 10 **kV:** 22.9  
**Equipment:** TRANSFORMER **kVA:** 9375  
**Compartment:** MAIN(BOTTOM) **Year Mf'd:** 2002  
**Breathing:** SEAL **Syringe ID:** 55005286  
**Bank: Phase:** **Bottle ID:**  
**Fluid:** MIN USGal: 1323 **Sampled By:**

**Control#:** 7334797  
**Order#:** 618125  
**Account:** 110710  
**Received:** 04/28/2020  
**Reported:** 05/12/2020

Lab Control Number:		7334797	7044984	7035705 <sup>7</sup>
Date Sampled:		11/21/2019	06/14/2017	12/17/2014
Order Number:		618125	541715	539662
Oil Temp:			45	50
Dissolved Gas Analysis (DGA) ASTM D-3612 <sup>1</sup>	Hydrogen (H2) (µL/L):	<2	347	<2
	Methane (CH4) (µL/L):	17	17	16
	Ethane (C2H6) (µL/L):	7	6	4
	Ethylene (C2H4) (µL/L):	1	1	<1
	Acetylene (C2H2) (µL/L):	<1	<1	<1
	<b>Carbon Monoxide (CO) (µL/L):</b>	<b>474</b>	<b>531</b>	<b>431</b>
	Carbon Dioxide (CO2) (µL/L):	1425	1681	1320
	Nitrogen (N2) (µL/L):	60545	74393	98100
	Oxygen (O2) (µL/L):	2263	2549	14600
	Total Dissolved Gas (TDG) (µL/L):	64732	79525	114471
Total Dissolved Combustible Gas (TDCG) (µL/L):	499	<b>902</b>	451	
Equivalent TCG (%):	0.5603	1.2905	0.2979	
<b>DGA Diagnostics</b>	<b>DGA Keys Gas / Interpretive Method:</b>	Hydrogen within condition 1 limits (100 µL/L).		
	<b>PER IEEE C57.104-2008</b>	Methane within condition 1 limits (120 µL/L).		
	(most recent sample)	Ethane within condition 1 limits (65 µL/L).		
		Ethylene within condition 1 limits (50 µL/L).		
		Acetylene within condition 1 limits (1 µL/L).		
		Carbon Monoxide: Condition 2 Indications of overheated cellulose insulation (350 µL/L).		
		Carbon Dioxide within condition 1 limits (2500 µL/L).		
		TDCG within condition 1 limits (720 µL/L).		
	<b>DGA TDCG Rate Interpretive Method:</b>	Retest Annually.		
	<b>PER IEEE C57.104-2008</b>	1-Continue normal operation.		
	(two most recent sample)			
	<b>DGA Cellulose (Paper) Insulation:</b>	CO2/CO Ratio is only applicable when CO2 greater than 5000 and CO greater than 500.		
	<b>Weidmann DGA Condition Code:</b>	NORMAL		
	<b>Weidmann Recommended Action:</b>	Continue normal operation. Resample for testing within one year.		
<b>Comment:</b>				
<b>General Oil Quality (GOQ)</b>				
ASTM D-1533 <sup>1</sup>	Moisture in Oil (mg/kg):	5	12	5
ASTM D-971 <sup>1</sup>	Interfacial Tension (mN/m):	33.85	38.17	36.0
ASTM D-974 <sup>1</sup>	Acid Number (mg KOH/g):	0.004	0.014	0.005
ASTM D-1500 <sup>1</sup>	Color Number (ASTM):	L1.0	L1.0	1
ASTM D-1524 <sup>1</sup>	Visual Exam. (Relative):	PASS	PASS	PASS
		CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT
ASTM D-1524 <sup>1</sup>	Sediment Exam. (Relative):	LIGHT	TRACE	
ASTM D-877 <sup>1</sup>	Dielectric Breakdown (kV):	47	54	52
ASTM D-1816	Dielectric Breakdown 1 mm (kV °C):		34 (25°C)	23 (50°C)
ASTM D-924 <sup>1</sup>	Power Factor @ 25°C (Routine) (%):	0.057	0.099	0.056
ASTM D-924	Power Factor @ 100°C (Routine) (%):			1.052
ASTM D-1298	Density @15°C (g/mL):			0.891

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.02 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results; accreditation status does not apply to these results. 8. Imported Equipment 10. mg/kg, µg/g, µg/mL, µL/L = ppm, µg/L = ppb, mN/m = dynes/cm, mm<sup>3</sup>/s = cSt

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.

# WEIDMANN

**WEIDMANN ELECTRICAL TECHNOLOGY**  
 3430 PROGRESS DRIVE, UNIT B + BENSELEM, PA + 19020  
 215 639 8599 + 215 639 8577  
 WWW.WEIDMANN-ELECTRICAL.COM

**TEST REPORT**  
**01-7334797-618125-00**  
 Page 2 of 2

Liberty Utilities

Serial#: HA08863002

Mfr: ABB

Control#: 7334797

Location: BARRON AVENUE 10

kV: 22.9

Order#: 618125

Equipment: TRANSFORMER

kVA: 9375

Account: 110710

LONDONDERRY, NH 03053 US

Compartment: MAIN(BOTTOM)

Year Mfd: 2002

Received: 04/28/2020

ATTN: MARIO BARONE

Breathing: SEAL

Syringe ID: 55005286

Reported: 05/12/2020

PO#: PO000016751

Bank: Phase:

Bottle ID:

Project ID:

Fluid: MIN USGal: 1323

Sampled By:

Customer ID: REF# 024304

	<b>Lab Control Number:</b>	7334797	7044984	7035705 <sup>7</sup>
	<b>Date Sampled:</b>	11/21/2019	06/14/2017	12/17/2014
	<b>Order Number:</b>	618125	541715	539662
	<b>Oil Temp:</b>		45	50
<b>ASTM D-4052</b>	<b>Density @15°C</b>			0.891
<b>ASTM D-445</b>	<b>Viscosity @40°C</b>			8.93
<b>ASTM D-2668<sup>5,6</sup></b>	<b>Oxidation Inhibitor</b>		0.187	0.183
				0.251
<b>GOQ Diagnostics</b>	<b>Moisture in Oil:</b>	Acceptable for in-service oil (35 mg/kg max).		
<b>PER IEEE C57.106-2015</b>	<b>Interfacial Tension:</b>	Acceptable for in-service oil (25 mN/m min).		
(most recent sample)	<b>Acid Number:</b>	Acceptable for in-service oil (0.2 mg KOH/g max).		
	<b>Color Number and Visual:</b>	Diagnostic not applicable. Diagnostic not applicable.		
	<b>Dielectric Breakdown ASTM D-877:</b>	Diagnostic not applicable.		
	<b>Power Factor @ 25°C (Routine):</b>	Acceptable for in-service oil (0.5% max).		
	<b>Oxidation Inhibitor:</b>	Exceeds limit for in-service oil Type I (0.0% min and 0.08% max). Acceptable for in-service oil type II (0.08% min and 0.3% max).		
<b>Comment:</b>				
<b>Furanic Compound</b>	<b>2-Furaldehyde (µg/L):</b>	< 10	< 10	
<b>ASTM D-5837<sup>5</sup></b>	<b>5-Hydroxy-methyl-furaldehyde (µg/L):</b>	< 10	< 10	
	<b>2-Acetylfuran (µg/L):</b>	< 10	< 10	
	<b>5-Methyl-2-furaldehyde (µg/L):</b>	< 10	< 10	
	<b>2-Furyl alcohol (µg/L):</b>	< 10	< 10	
<b>Furanic Compound Diagnostics (most recent sample):</b>				
New insulation with a high degree of mechanical strength will typically have a Degree of Polymerization (DP) of 1000-1300. "Middle Aged" paper is approximately 500 and paper with less than 250 is in its "Old Age." Severely degraded insulation with a DP of 150 or less will have very little mechanical strength and may result in a transformer failure. The above estimations are based on a study by Chendong of GSU transformers filled with mineral oil.				
<b>Estimated Average Degree of Polymerization (DP): &gt;1003</b>				
<b>Estimated Operating Age of the Equipment: &lt;1.0</b>				
<b>Notations:</b>				
<b>Comment:</b>				
<b>PCB</b>	<b>Concentration (mg/kg):</b>	< 1.0 mg/kg	< 1.0 mg/kg	
<b>mod EPA Method 8082a<sup>5,6</sup></b>	<b>PCB Type (Arocolor):</b>	ND	ND	
	<b>Reporting Limit:</b>	1	1	
<b>Comment:</b>				

## End of Test Report

Authorized By:



ERIC MCANANY  
 CHEMIST

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.02 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results; accreditation status does not apply to these results. 8. Imported Equipment 10. mg/kg, µg/g, µg/mL, µL/L = ppm, µg/L = ppb, mN/m = dynes/cm, mm<sup>2</sup>/s = cSt

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.

**WEIDMANN**

**WEIDMANN ELECTRICAL TECHNOLOGY**  
 3430 PROGRESS DRIVE, UNIT B + BENSALEM, PA + 19020  
 215 639 8599 + 215 639 8577  
 WWW.WEIDMANN-ELECTRICAL.COM

**TEST REPORT**  
**01-7334796-618125-00**  
 Page 1 of 2

Liberty Utilities **Serial#:** F959759 **Mfr:** GENERAL ELECTRIC **Control#:** 7334796  
**Location:** BARRON AVENUE 10 **kV:** 22.9 **Order#:** 618125  
**Equipment:** TRANSFORMER **kVA:** 7000 **Account:** 110710  
 LONDONDERRY, NH 03053 US **Compartment:** MAIN(BOTTOM) **Year Mfd:** 1970 **Received:** 04/28/2020  
 ATTN: MARIO BARONE **Breathing:** SEAL **Syringe ID:** 53004958 **Reported:** 05/12/2020  
 PO#: PO000016751 **Bank:** Phase: **Bottle ID:**  
**Project ID:** **Fluid:** MIN USGal: 739 **Sampled By:**  
**Customer ID:** REF# 023486

	Lab Control Number:	7334796	7044991	7035681 <sup>7</sup>	7035704 <sup>7</sup>	7035682 <sup>7</sup>
	Date Sampled:	11/21/2019	06/14/2017	01/11/2016	01/17/2014	01/17/2014
	Order Number:	618125	541715	539638	539661	539639
	Oil Temp:		65	60	60	60
Dissolved Gas Analysis (DGA) ASTM D-3612 <sup>1</sup>	Hydrogen (H2) (µL/L):	31	37	36	53	53
	Methane (CH4) (µL/L):	8	8	10	11	11
	Ethane (C2H6) (µL/L):	3	3	2	2	2
	Ethylene (C2H4) (µL/L):	1	1	1	1	1
	Acetylene (C2H2) (µL/L):	<1	<1	<1	<1	<1
	Carbon Monoxide (CO) (µL/L):	390	435	439	585	585
	Carbon Dioxide (CO2) (µL/L):	3476	3966	4600	5220	5220
	Nitrogen (N2) (µL/L):	54119	64457	68900	77200	77200
	Oxygen (O2) (µL/L):	15897	21425	22700	20900	20900
	Total Dissolved Gas (TDG) (µL/L):	73925	90332	96688	103972	103972
Total Dissolved Combustible Gas (TDCG) (µL/L):	433	484	488	652	652	
	Equivalent TCG (%):	0.5356	0.4982	0.4686	0.5812	0.5812

DGA Diagnostics	<b>DGA Keys Gas / Interpretive Method:</b>	Hydrogen within condition 1 limits (100 µL/L).
	<b>PER IEEE C57.104-2008</b> (most recent sample)	Methane within condition 1 limits (120 µL/L). Ethane within condition 1 limits (65 µL/L). Ethylene within condition 1 limits (50 µL/L). Acetylene within condition 1 limits (1 µL/L). Carbon Monoxide: Condition 2 Indications of overheated cellulose insulation (350 µL/L). Carbon Dioxide: Condition 2 Indications of overheated cellulose insulation (2500 µL/L). TDCG within condition 1 limits (720 µL/L).
	<b>DGA TDCG Rate Interpretive Method:</b> <b>PER IEEE C57.104-2008</b> (two most recent sample)	Retest Annually. 1-Continue normal operation.
	<b>DGA Cellulose (Paper) Insulation:</b>	CO2/CO Ratio is only applicable when CO2 greater than 5000 and CO greater than 500.
	<b>Weidmann DGA Condition Code:</b>	NORMAL
	<b>Weidmann Recommended Action:</b>	Continue normal operation. Resample for testing within one year.

Comment:						
<b>General Oil Quality (GOQ)</b>						
ASTM D-1533 <sup>1</sup>	Moisture in Oil (mg/kg):	9	16	10	9	9
ASTM D-971 <sup>1</sup>	Interfacial Tension (mN/m):	40.15	37.72	41.0	42.0	42.0
ASTM D-974 <sup>1</sup>	Acid Number (mg KOH/g):	0.007	0.022	0.005	0.005	0.005
ASTM D-1500 <sup>1</sup>	Color Number (ASTM):	L1.5	L1.0	1.5	1.5	1.5
ASTM D-1524 <sup>1</sup>	Visual Exam. (Relative):	PASS	PASS	PASS	PASS	PASS
		CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT
ASTM D-1524 <sup>1</sup>	Sediment Exam. (Relative):	TRACE	TRACE			
ASTM D-877 <sup>1</sup>	Dielectric Breakdown (kV):	51	47	62	59	59
ASTM D-1816	Dielectric Breakdown 1 mm (kV °C):		30 (27°C)	37 (60°C)	36 (60°C)	36 (60°C)
ASTM D-924 <sup>1</sup>	Power Factor @ 25°C (Routine) (%):	0.006	0.016	0.002	0.002	0.002
ASTM D-924	Power Factor @ 100°C (Routine) (%):			0.014	0.412	0.412

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.02 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results; accreditation status does not apply to these results. 8. Imported Equipment 10. mg/kg, µg/g, µg/mL, µL/L = ppm, µg/L = ppb, mN/m = dynes/cm, mm<sup>2</sup>/s = cSt

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.

# WEIDMANN

**WEIDMANN ELECTRICAL TECHNOLOGY**  
 3430 PROGRESS DRIVE, UNIT B + BENSALEM, PA + 19020  
 215 639 8599 + 215 639 8577  
 WWW.WEIDMANN-ELECTRICAL.COM

**TEST REPORT**  
**01-7334796-618125-00**  
 Page 2 of 2

Liberty Utilities	Serial#: F959759	Mfr: GENERAL ELECTRIC	Control#: 7334796
	Location: BARRON AVENUE 10	kV: 22.9	Order#: 618125
	Equipment: TRANSFORMER	kVA: 7000	Account: 110710
LONDONDERRY, NH 03053 US	Compartment: MAIN(BOTTOM)	Year Mf'd: 1970	Received: 04/28/2020
ATTN: MARIO BARONE	Breathing: SEAL	Syringe ID: 53004958	Reported: 05/12/2020
PO#: PO000016751	Bank: Phase:	Bottle ID:	
Project ID:	Fluid: MIN USGal: 739	Sampled By:	
Customer ID: REF# 023486			

	Lab Control Number:	7334796	7044991	7035681 <sup>7</sup>	7035704 <sup>7</sup>	7035682 <sup>7</sup>
	Date Sampled:	11/21/2019	06/14/2017	01/11/2016	01/17/2014	01/17/2014
	Order Number:	618125	541715	539638	539661	539639
	Oil Temp:		65	60	60	60
ASTM D-1298	Density @15°C (g/mL):			0.896	0.896	0.896
ASTM D-4052	Density @15°C (g/mL):			0.896	0.896	0.896
ASTM D-445	Viscosity @40°C (mm <sup>2</sup> /s):			10.05	10.02	10.02
ASTM D-2668 <sup>5,6</sup>	Oxidation Inhibitor (wt. %)	0.173	0.179	0.235	0.237	0.237
GOQ Diagnostics	Moisture in Oil:	Acceptable for in-service oil (35 mg/kg max).				
PER IEEE C57.106-2015	Interfacial Tension:	Acceptable for in-service oil (25 mN/m min).				
(most recent sample)	Acid Number:	Acceptable for in-service oil (0.2 mg KOH/g max).				
	Color Number and Visual:	Diagnostic not applicable. Diagnostic not applicable.				
	Dielectric Breakdown ASTM D-877:	Diagnostic not applicable.				
	Power Factor @ 25°C (Routine):	Acceptable for in-service oil (0.5% max).				
	Oxidation Inhibitor:	Exceeds limit for in-service oil Type I (0.0% min and 0.08% max). Acceptable for in-service oil type II (0.08% min and 0.3% max).				
<b>Comment:</b>						
Furanic Compound	2-Furaldehyde (µg/L):	59	69			
ASTM D-5837 <sup>5</sup>	5-Hydroxy-methyl-furaldehyde (µg/L):	< 10	< 10			
	2-Acetylfuran (µg/L):	< 10	< 10			
	5-Methyl-2-furaldehyde (µg/L):	13	< 10			
	2-Furyl alcohol (µg/L):	< 10	< 10			
<b>Furanic Compound Diagnostics (most recent sample):</b>						
New insulation with a high degree of mechanical strength will typically have a Degree of Polymerization (DP) of 1000-1300. "Middle Aged" paper is approximately 500 and paper with less than 250 is in its "Old Age." Severely degraded insulation with a DP of 150 or less will have very little mechanical strength and may result in a transformer failure. The above estimations are based on a study by Chendong of GSU transformers filled with mineral oil.						
Estimated Average Degree of Polymerization (DP): 784						
Estimated Operating Age of the Equipment: 10.3						
<b>Notations:</b>						
<b>Comment:</b>						
PCB	Concentration (mg/kg):	6.79 mg/kg	4.23 mg/kg			
mod EPA Method 8082a <sup>5,6</sup>	PCB Type (Arocolor):	1242	1242			
	Reporting Limit:	1	1			
<b>Comment:</b>						

## End of Test Report

Authorized By:   
 ERIC MCANANY  
 CHEMIST

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.02 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results; accreditation status does not apply to these results. 8. Imported Equipment 10. mg/kg, µg/g, µg/mL, µL/L = ppm, µg/L = ppb, mN/m = dynes/cm, mm<sup>2</sup>/s = cSt

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.

**WEIDMANN**

**WEIDMANN ELECTRICAL TECHNOLOGY**  
 3430 PROGRESS DRIVE, UNIT B + BENSALEM, PA + 19020  
 215 639 8599 + 215 639 8577  
 WWW.WEIDMANN-ELECTRICAL.COM

**TEST REPORT****01-7334792-618125-00**

Page 1 of 2

Liberty Utilities

Serial#: M160691

Mfr: GENERAL  
ELECTRIC

Control#: 7334792

Location: SALEM DEPOT #9

kV: 23

Order#: 618125

Equipment: TRANSFORMER

kVA: 9300

Account: 110710

LONDONDERRY, NH 03053 US

Compartment: MAIN(BOTTOM)

Year Mfd: 1989

Received: 04/28/2020

ATTN: MARIO BARONE

Breathing: SEAL

Syringe ID: 3001645

Reported: 05/12/2020

PO#: PO000016751

Bank: Phase:

Bottle ID:

Project ID:

Fluid: MIN USGal: 1250

Sampled By:

Customer ID: REF# 022772

Lab Control Number:		7334792	7044980	7035699 <sup>7</sup>	7035709 <sup>7</sup>	7035700 <sup>7</sup>
Date Sampled:		11/21/2019	06/14/2017	09/01/2016	12/16/2014	12/16/2014
Order Number:		618125	541715	539656	539666	539657
Oil Temp:			55	90	80	80
Dissolved Gas Analysis (DGA) ASTM D-3612 <sup>1</sup>	Hydrogen (H2) (µL/L):	40	51	50	50	50
	Methane (CH4) (µL/L):	55	56	54	51	51
	Ethane (C2H6) (µL/L):	56	44	48	39	39
	Ethylene (C2H4) (µL/L):	4	4	4	4	4
	Acetylene (C2H2) (µL/L):	<1	<1	<1	<1	<1
	Carbon Monoxide (CO) (µL/L):	459	495	477	447	447
	Carbon Dioxide (CO2) (µL/L):	13496	14360	14800	14200	14200
	Nitrogen (N2) (µL/L):	64658	80509	89000	83300	83300
	Oxygen (O2) (µL/L):	<500	1194	4950	6500	6500
	Total Dissolved Gas (TDG) (µL/L):	79090	96713	109383	104591	104591
Total Dissolved Combustible Gas (TDCG) (µL/L):	614	650	633	591	591	
Equivalent TCG (%):	0.6293	0.5587	0.4794	0.4804	0.4804	
<b>DGA</b>	<b>DGA Keys Gas / Interpretive Method:</b>	Hydrogen within condition 1 limits (100 µL/L).				
<b>Diagnostics</b>	<b>PER IEEE C57.104-2008</b> (most recent sample)	Methane within condition 1 limits (120 µL/L). Ethane within condition 1 limits (65 µL/L). Ethylene within condition 1 limits (50 µL/L). Acetylene within condition 1 limits (1 µL/L). Carbon Monoxide: Condition 2 Indications of overheated cellulose insulation (350 µL/L). Carbon Dioxide: Condition 4 Severe Indications of overheated cellulose insulation (10000 µL/L). TDCG within condition 1 limits (720 µL/L).				
	<b>DGA TDCG Rate Interpretive Method:</b> <b>PER IEEE C57.104-2008</b> (two most recent sample)	Retest Annually. 1-Continue normal operation.				
	<b>DGA Cellulose (Paper) Insulation:</b>	CO2/CO Ratio is only applicable when CO2 greater than 5000 and CO greater than 500.				
	<b>Weidmann DGA Condition Code:</b>	CAUTION				
	<b>Weidmann Recommended Action:</b>	Resample within 6 months for testing.				
<b>Comment:</b>						
<b>General Oil Quality (GOQ)</b>						
ASTM D-1533 <sup>1</sup>	Moisture in Oil (mg/kg):	10	23	58	6	6
ASTM D-971 <sup>1</sup>	Interfacial Tension (mN/m):	37.99	37.82	35.0	38.0	38.0
ASTM D-974 <sup>1</sup>	Acid Number (mg KOH/g):	0.007	0.016	0.005	0.005	0.005
ASTM D-1500 <sup>1</sup>	Color Number (ASTM):	L0.5	L0.5	0.5	0.5	0.5
ASTM D-1524 <sup>1</sup>	Visual Exam. (Relative):	PASS	PASS	PASS	PASS	PASS
		CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT
ASTM D-1524 <sup>1</sup>	Sediment Exam. (Relative):	TRACE	TRACE			
ASTM D-877 <sup>1</sup>	Dielectric Breakdown (kV):	47	51	55	63	63
ASTM D-1816	Dielectric Breakdown 1 mm (kV °C):		25 (24°C)	42 (90°C)	39 (80°C)	39 (80°C)
ASTM D-924 <sup>1</sup>	Power Factor @ 25°C (Routine) (%):	0.006	0.018	0.008	0.005	0.005

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.02 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results; accreditation status does not apply to these results. 8. Imported Equipment 10. mg/kg, µg/g, µg/mL, µL/L = ppm, µg/L = ppb, mN/m = dynes/cm, mm<sup>2</sup>/s = cSt

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.



# WEIDMANN

**WEIDMANN ELECTRICAL TECHNOLOGY**  
 3430 PROGRESS DRIVE, UNIT B + BENSALEM, PA + 19020  
 215 639 8599 + 215 639 8577  
 WWW.WEIDMANN-ELECTRICAL.COM

**TEST REPORT**  
**01-7334792-618125-00**  
 Page 2 of 2

Liberty Utilities

Serial#: M160691

Mfr: GENERAL  
ELECTRIC

Control#: 7334792

Location: SALEM DEPOT #9

kV: 23

Order#: 618125

Equipment: TRANSFORMER

kVA: 9300

Account: 110710

LONDONDERRY, NH 03053 US

Compartment: MAIN(BOTTOM)

Year Mf'd: 1989

Received: 04/28/2020

ATTN: MARIO BARONE

Breathing: SEAL

Syringe ID: 3001645

Reported: 05/12/2020

PO#: PO000016751

Bank: Phase:

Bottle ID:

Project ID:

Fluid: MIN USGal: 1250

Sampled By:

Customer ID: REF# 022772

	Lab Control Number:	7334792	7044980	7035699 <sup>7</sup>	7035709 <sup>7</sup>	7035700 <sup>7</sup>
	Date Sampled:	11/21/2019	06/14/2017	09/01/2016	12/16/2014	12/16/2014
	Order Number:	618125	541715	539656	539666	539657
	Oil Temp:		55	90	80	80
ASTM D-924	Power Factor @ 100°C (Routine) (%)			0.340	0.324	0.324
ASTM D-1298	Density @15°C (g/mL)			0.874	0.873	0.873
ASTM D-4052	Density @15°C (g/mL)			0.874	0.873	0.873
ASTM D-445	Viscosity @40°C (mm <sup>2</sup> /s)			8.52	8.46	8.46
ASTM D-2668 <sup>5,6</sup>	Oxidation Inhibitor (wt. %)	0.045	0.033	0.059	0.069	0.069
GOQ Diagnostics	Moisture in Oil:	Acceptable for in-service oil (35 mg/kg max).				
PER IEEE C57.106-2015	Interfacial Tension:	Acceptable for in-service oil (25 mN/m min).				
(most recent sample)	Acid Number:	Acceptable for in-service oil (0.2 mg KOH/g max).				
	Color Number and Visual:	Diagnostic not applicable. Diagnostic not applicable.				
	Dielectric Breakdown ASTM D-877:	Diagnostic not applicable.				
	Power Factor @ 25°C (Routine):	Acceptable for in-service oil (0.5% max).				
	Oxidation Inhibitor:	Acceptable for in-service oil Type I (0.0% min and 0.08% max). Exceeds limit for in-service oil type II (0.08% min and 0.3% max).				
<b>Comment:</b>						
Furanic Compound	2-Furaldehyde (µg/L):	10	< 10			
ASTM D-5837 <sup>5</sup>	5-Hydroxy-methyl-furaldehyde (µg/L):	< 10	< 10			
	2-Acetylfuran (µg/L):	< 10	< 10			
	5-Methyl-2-furaldehyde (µg/L):	< 10	< 10			
	2-Furyl alcohol (µg/L):	< 10	< 10			
<b>Furanic Compound Diagnostics (most recent sample):</b>						
New insulation with a high degree of mechanical strength will typically have a Degree of Polymerization (DP) of 1000-1300. "Middle Aged" paper is approximately 500 and paper with less than 250 is in its "Old Age." Severely degraded insulation with a DP of 150 or less will have very little mechanical strength and may result in a transformer failure. The above estimations are based on a study by Chendong of GSU transformers filled with mineral oil.						
Estimated Average Degree of Polymerization (DP): 1001						
Estimated Operating Age of the Equipment: <1.0						
<b>Notations:</b>						
<b>Comment:</b>						
PCB	Concentration (mg/kg):	< 1.0 mg/kg	< 1.0 mg/kg			
mod EPA Method 8082a <sup>5,6</sup>	PCB Type (Arocolor):	ND	ND			
	Reporting Limit:	1	1			
<b>Comment:</b>						

## End of Test Report

Authorized By:



ERIC MCANANY  
 CHEMIST

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.02 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results; accreditation status does not apply to these results. 8. Imported Equipment 10. mg/kg, µg/g, µg/mL, µL/L = ppm, µg/L = ppb, mN/m = dynes/cm, mm<sup>2</sup>/s = cSt

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.

# WEIDMANN

**WEIDMANN ELECTRICAL TECHNOLOGY**  
 3430 PROGRESS DRIVE, UNIT B + BENSLEM, PA + 19020  
 215 639 8599 + 215 639 8577  
 WWW.WEIDMANN-ELECTRICAL.COM

**TEST REPORT**  
**01-7334791-618125-00**  
 Page 1 of 2

Liberty Utilities

Serial#: G859810A

Mfr: GENERAL ELECTRIC

Control#: 7334791

Location: SALEM DEPOT 9

kV: 22.9

Order#: 618125

Equipment: TRANSFORMER

kVA: 7000

Account: 110710

LONDONDERRY, NH 03053 US

Compartment: MAIN(BOTTOM)

Year Mf'd:

Received: 04/28/2020

ATTN: MARIO BARONE

Breathing: SEAL

Syringe ID: 53005817

Reported: 05/12/2020

PO#: PO000016751

Bank: Phase:

Bottle ID:

Project ID:

Fluid: MIN USGal: 1010

Sampled By:

Customer ID: REF# 023068

	Lab Control Number:	7334791	7044979	7035697 <sup>7</sup>	7035708 <sup>7</sup>	7035698 <sup>7</sup>
	Date Sampled:	11/21/2019	06/14/2017	09/01/2016	12/16/2014	12/16/2014
	Order Number:	618125	541715	539654	539665	539655
	Oil Temp:		56	60	60	60
Dissolved Gas Analysis (DGA) ASTM D-3612 <sup>1</sup>	Hydrogen (H2) (µL/L):	469	488	226	649	649
	Methane (CH4) (µL/L):	307	355	299	373	373
	Ethane (C2H6) (µL/L):	194	175	194	183	183
	Ethylene (C2H4) (µL/L):	111	121	122	136	136
	Acetylene (C2H2) (µL/L):	<1	<1	<1	<1	<1
	Carbon Monoxide (CO) (µL/L):	1164	1293	773	1320	1320
	Carbon Dioxide (CO2) (µL/L):	18354	19237	19400	17200	17200
	Nitrogen (N2) (µL/L):	61883	78625	76300	72700	72700
	Oxygen (O2) (µL/L):	585	1295	14100	3950	3950
	Total Dissolved Gas (TDG) (µL/L):	83067	101589	111414	96511	96511
Total Dissolved Combustible Gas (TDCG) (µL/L):	2245	2432	1614	2661	2661	
	Equivalent TCG (%):	2.6607	2.2693	1.195	2.783	2.783

DGA Diagnostics	DGA Keys Gas / Interpretive Method:	Hydrogen: Condition 2 Indications of partial discharge activity (100 µL/L).
	PER IEEE C57.104-2008	Methane: Condition 2 Indications of overheated (>150°C) oil (120 µL/L).
	(most recent sample)	Ethane: Condition 4 Indications of severely overheated (>250°C) oil (150 µL/L).
		Ethylene: Condition 3 Indications of significantly overheated (>350°C) oil (100 µL/L).
		Acetylene within condition 1 limits (1 µL/L).
		Carbon Monoxide: Condition 3 Indications of significantly overheated cellulose insulation (570 µL/L).
		Carbon Dioxide: Condition 4 Severe Indications of overheated cellulose insulation (10000 µL/L).
		TDCG: Condition 3 Levels indicate a high level of decomposition. Faults are probably present (1920 µL/L).
	DGA TDCG Rate Interpretive Method:	Retest Monthly.
	PER IEEE C57.104-2008	Exercise extreme caution. Analyze for individual gases. Plan outage. Advise manufacturer.
	(two most recent sample)	
	DGA Cellulose (Paper) Insulation:	CO2/CO >= 10: Indication of thermal decomposition of cellulose insulation.
	Weidmann DGA Condition Code:	CAUTION
	Weidmann Recommended Action:	Resample within 6 months for testing.

## Comment:

## General Oil Quality (GOQ)

ASTM D-1533 <sup>1</sup>	Moisture in Oil	(mg/kg):	19	91	<2	4	4
ASTM D-971 <sup>1</sup>	Interfacial Tension	(mN/m):	38.6	37.21	37.0	39.0	39.0
ASTM D-974 <sup>1</sup>	Acid Number	(mg KOH/g):	0.009	0.021	0.005	0.005	0.005
ASTM D-1500 <sup>1</sup>	Color Number	(ASTM):	L1.5	L1.0	1.5	1.5	1.5
ASTM D-1524 <sup>1</sup>	Visual Exam.	(Relative):	PASS	PASS	PASS	PASS	PASS
			CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT	CLR&BRIGHT
ASTM D-1524 <sup>1</sup>	Sediment Exam.	(Relative):	ND	ND			
ASTM D-877 <sup>1</sup>	Dielectric Breakdown	(kV):	48	48	65	61	61

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.02 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. 8. Imported Equipment 10. mg/kg, µg/g, µg/mL, µL/L = ppm, µg/L = ppb, mN/m = dynes/cm, mm<sup>2</sup>/s = cSt

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.

# WEIDMANN

WEIDMANN ELECTRICAL TECHNOLOGY  
 3430 PROGRESS DRIVE, UNIT B + BENSALEM, PA + 19020  
 215 639 8599 + 215 639 8577  
 WWW.WEIDMANN-ELECTRICAL.COM

TEST REPORT  
 01-7334791-618125-00  
 Page 2 of 2

Liberty Utilities

Serial#: G859810A

Mfr: GENERAL  
ELECTRIC

Control#: 7334791

Location: SALEM DEPOT 9

kV: 22.9

Order#: 618125

Equipment: TRANSFORMER

kVA: 7000

Account: 110710

LONDONDERRY, NH 03053 US

Compartment: MAIN(BOTTOM)

Year Mfd:

Received: 04/28/2020

ATTN: MARIO BARONE

Breathing: SEAL

Syringe ID: 53005817

Reported: 05/12/2020

PO#: PO000016751

Bank: Phase:

Bottle ID:

Project ID:

Fluid: MIN USGal: 1010

Sampled By:

Customer ID: REF# 023068

Lab Control Number:		7334791	7044979	7035697 <sup>7</sup>	7035708 <sup>7</sup>	7035698 <sup>7</sup>
Date Sampled:		11/21/2019	06/14/2017	09/01/2016	12/16/2014	12/16/2014
Order Number:		618125	541715	539654	539665	539655
Oil Temp:			56	60	60	60
ASTM D-1816	Dielectric Breakdown 1 mm (kV °C):		27 (25°C)	40 (60°C)	42 (60°C)	42 (60°C)
ASTM D-924 <sup>1</sup>	Power Factor @ 25°C (Routine) (%):	0.007	0.021	0.006	0.004	0.004
ASTM D-924	Power Factor @ 100°C (Routine) (%):			0.195	0.238	0.238
ASTM D-1298	Density @15°C (g/mL):			0.887	0.887	0.887
ASTM D-4052	Density @15°C (g/mL):			0.887	0.887	0.887
ASTM D-445	Viscosity @40°C (mm <sup>2</sup> /s):			9.34	9.31	9.31
ASTM D-2668 <sup>5,6</sup>	Oxidation Inhibitor (wt. %)	0.068	0.066	0.095	0.098	0.098
GOQ Diagnostics		Moisture in Oil: Acceptable for in-service oil (35 mg/kg max).				
PER IEEE C57.106-2015		Interfacial Tension: Acceptable for in-service oil (25 mN/m min).				
(most recent sample)		Acid Number: Acceptable for in-service oil (0.2 mg KOH/g max).				
		Color Number and Visual: Diagnostic not applicable. Diagnostic not applicable.				
		Dielectric Breakdown ASTM D-877: Diagnostic not applicable.				
		Power Factor @ 25°C (Routine): Acceptable for in-service oil (0.5% max).				
		Oxidation Inhibitor: Acceptable for in-service oil Type I (0.0% min and 0.08% max). Exceeds limit for in-service oil type II (0.08% min and 0.3% max).				
<b>Comment:</b>						
Furanic Compound	2-Furaldehyde (µg/L):	41	38			
ASTM D-5837 <sup>5</sup>	5-Hydroxy-methyl-furaldehyde (µg/L):	< 10	< 10			
	2-Acetyl furan (µg/L):	< 10	< 10			
	5-Methyl-2-furaldehyde (µg/L):	38	28			
	2-Furyl alcohol (µg/L):	< 10	< 10			
<b>Furanic Compound Diagnostics (most recent sample):</b>						
New insulation with a high degree of mechanical strength will typically have a Degree of Polymerization (DP) of 1000-1300. "Middle Aged" paper is approximately 500 and paper with less than 250 is in its "Old Age." Severely degraded insulation with a DP of 150 or less will have very little mechanical strength and may result in a transformer failure. The above estimations are based on a study by Chendong of GSU transformers filled with mineral oil.						
Estimated Average Degree of Polymerization (DP): 828						
Estimated Operating Age of the Equipment: 7.6						
<b>Notations:</b>						
<b>Comment:</b>						
PCB	Concentration (mg/kg):	268.13 mg/kg	265.02 mg/kg			
mod EPA Method 8082a <sup>5,6</sup>	PCB Type (Arocolor):	1260/54/42	1260/54/42			
	Reporting Limit:	1	1			
<b>Comment:</b>						

## End of Test Report


Authorized By:



ERIC MCANANY  
 CHEMIST

Notations: 1. Analysis is ISO/IEC 17025:2017 accredited, ANAB Accredited Certificate Number L2303.02 2. This test is conducted by a subcontracted laboratory. 3. Subcontracted laboratory has received ISO Standard 17025 accreditation for this test. 5. This test is conducted by Weidmann Laboratory other than Primary Lab. 6. Weidmann Laboratory has received ISO Standard 17025 accreditation for this test. 7. Imported Sample: WEIDMANN Electrical Technology accepts no responsibility for these results; accreditation status does not apply to these results. 8. Imported Equipment 10. mg/kg, µg/g, µg/mL, µL/L = ppm, µg/L = ppb, mN/m = dynes/cm, mm<sup>2</sup>/s = cSt

Accreditation applies to current analysis only. The analyses, opinions or interpretations contained in this report are based upon material and information supplied by the client. WEIDMANN Electrical Technology does not imply that the contents of the sample received by this laboratory are the same as all such material in the environment from which the sample was taken. Our test results relate only to the sample or samples tested. Any interpretations or opinions expressed represent the best judgment of WEIDMANN Electrical Technology. WEIDMANN Electrical Technology assumes no responsibility and makes no warranty or representation, expressed or implied as to the condition, productivity or proper operation of any equipment or other property for which this report may be used or relied upon for any reason whatsoever. This test report shall not be reproduced except in full, without written approval of the laboratory.

	<b>ENGINEERING DOCUMENT</b>	Doc. # <b>ENG-SUB006</b>
	General Standard	Page 1 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

**INTRODUCTION**

An initial step in the engineering and design of any electric station is the selection of suitable electrical clearances. Design clearances and spacing of energized and grounded parts are established for two purposes, to assure the proper operation of the substation and to assure the safety of the public and personnel working in and around the substation bus and equipment.

**PURPOSE**

The purpose of this standard is to provide the design requirements for electrical clearances and spacing for outdoor substations.

**ACCOUNTABILITY**

Not Applicable

**COORDINATION**

Not Applicable

**REFERENCES**

IEEE Paper T-72-131-6 “Minimum Line-To-Ground Electrical Clearances for EHV Substations Based on Switching Surge Requirements” by IEEE Working Group 59.1, IEEE Transactions on Power Apparatus and Systems, Volume 91, 1972, pages 1924-1930.

IEEE Paper 31-TP-66-16, “Minimum Phase to Phase Electrical Clearances for Substations Based on Switching Surges and Lightning Surges”, T. Udo, IEEE Power Transactions on Power Apparatus and Systems, Volume 85, 1966, pages 838-845

IEEE Paper 31 TP 66-106 “Series Gaps in Air Break Switches”, P. Mayo, IEEE Transactions on Power Apparatus and Systems, Volume PAS-66, No. 4, April 1967, pages 428-438.

LU-ENG-SUB005 Animal Deterrents in Electric Substations


**DEFINITIONS**

See Section 3.0

**TRAINING**

Not Applicable

<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.          FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Author: 227 Robert J Johnson

	<b>ENGINEERING DOCUMENT</b>	Doc. # <b>ENG-SUB006</b>
	<b>General Standard</b>	Page 2 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20


**DOCUMENT CONTENTS**

Table of Contents

1.0	OPERATING REQUIREMENTS .....	3
2.0	CODES & STANDARDS .....	3
3.0	EXPLANATION OF TERMS .....	4
4.0	ELECTRICAL CLEARANCES AND SPACING FOR OUTDOOR STATIONS .....	5
5.0	SAFETY CLEARANCES .....	6
6.0	ELECTRICAL CLEARANCES AND SPACING FOR INDOOR FACILITIES .....	7
7.0	LIBERTY PREFERRED CLEARANCE AND SPACING .....	8
8.0	TABLES AND FIGURES .....	8
9.0	REVISION HISTORY .....	19

<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.                  FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Author: 228 Robert J Johnson



	<b>ENGINEERING DOCUMENT</b> <b>General Standard</b>	Doc. # <b>ENG-SUB006</b>
	<b>Electrical Substation Clearances</b>	Page 3 of 19 Version 1.0 – 08/01/20


## **1.0 OPERATING REQUIREMENTS**

- 1.1** The proper operation of the substation is addressed by establishing clearances and spacing that coordinate with the design insulation level of the substation. Minimum electrical clearances in air-insulated substations have a direct correlation with the insulation levels.
- 1.1.1 For voltages up to 115kV, clearances are generally selected based on BIL.
  - 1.1.2 At 230 kV, clearances are generally dictated by BIL, but could also be dictated by switching surge.
  - 1.1.3 For EHV (345kV and above), clearances are generally dictated by switching surge withstand requirements. Table 8.3 provides typical insulation levels for substation equipment.
- 1.2** The potential for hazards and personal injury is greatly increased as the proximity of personnel to electrical equipment decreases. Consequently, safety clearances are established to minimize the possibility of accidental human contact with live parts. Guards shall be provided around all live parts operating above 300V phase-to-phase without adequate insulating covering, unless the location of the live parts gives a sufficient safety clearance zone.
- 1.3** Working clearances around electrical equipment are designed to provide safe access to personnel working in the substation. The safe distances required for normal operation and maintenance work are specified in:
- 1.3.1 Table 2A-D Minimum Approach Distances of this standard
  - 1.3.2 Section 5 Substations of Liberty’s Employee Safety & Health Handbook.

## **2.0 CODES & STANDARDS**

- 2.1** This standard is based on the following:
- 2.1.1 ANSI C2-2007, National Electrical Safety Code (NESC)
  - 2.1.2 ANSI C37.06-2000, “AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis-Preferred Ratings and Related Required Capabilities”
  - 2.1.3 ANSI C37.32-2002, “American National Standard for Switchgear - High Voltage Air Switches, Bus Supports, and Switch Accessories - Schedules of Preferred Ratings, Manufacturing Specifications, and Application Guide”
  - 2.1.4 ANSI C84.1-2006, “Electrical Power Systems and Equipment - Voltage Ratings (60 Hz)”
  - 2.1.5 IEEE C57.12.00-2006, IEEE Standard General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers,

<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.          FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Author: 229 Robert J Johnson

	<b>ENGINEERING DOCUMENT</b>	Doc. # <b>ENG-SUB006</b>
	<b>General Standard</b>	Page 4 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

- 2.1.6 IEEE C62.22-1996, “Guide for the Application of Metal-Oxide Surge Arresters for Alternating-Current Systems”.
- 2.1.7 IEEE Std. 1313.1-1996, “IEEE Standard for Insulation Coordination - Definitions, Principles, and Rules”
- 2.1.8 IEEE Std. 1313.2-1999, “IEEE Guide for the Application of Insulation Coordination”
- 2.1.9 IEEE Std. 1427-2006, “IEEE Guide for Recommended Electrical Clearances and Insulation Levels in Air-Insulated Electrical Power Substations”
- 2.1.10 Liberty Employee Health & Safety Handbook
- 2.1.11 NEMA Standards Publication No. SG-6-2000, “Power Switching Equipment”
- 2.1.12 NESC 2017 – “National Electric Safety Code”
- 2.1.13 OSHA Standard 29CFR1910.269, “Working on Exposed Energized Parts”

### **3.0 EXPLANATION OF TERMS**

- 3.1 Air Switch: A switching device designed to close and open one or more electric circuits by means of guided separable contacts that separate in air.
- 3.2 BIL: Commonly referred to as “Basic Impulse Level” or “Basic Insulation Level.” The BIL value is a reference insulation value expressed in terms of the crest value of a standard lightning impulse.
- 3.3 BSL: The reference insulation level expressed in terms of the crest value of a standard switching impulse.
- 3.4 Centerline-to-Centerline Spacing of Buses: A distance that is measured from the centerline of one bus/conductor to the centerline of another bus/conductor
- 3.5 Clearance between Live Parts: A distance that is measured from surface to surface of two electrically connected parts having voltages different from that of the ground.
- 3.6 Clearances: The clear distance measured between two objects measured surface to surface.
- 3.7 Double-Break Switch: A switch that opens a conductor of a circuit at two points.
- 3.8 Equipment Internal & External BIL/BSL: The internal insulation level of equipment such as transformers vs. the external insulation level of the substation
- 3.9 Horn-Gap Switches: A switch provided with arcing horns.
- 3.10 Insulation Coordination: The process of bringing the insulation strengths of electrical equipment and buses into the proper relationship with expected overvoltages and with the characteristics of the insulating media and surge protective devices, to obtain an acceptable risk of failure.
- 3.11 Maintenance Clearances: Clearance values designed to provide adequate distances during the maintenance of electrical equipment

<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Author: 230 Robert J Johnson


	<b>ENGINEERING DOCUMENT</b>	Doc. # <b>ENG-SUB006</b>
	<b>General Standard</b>	Page 5 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

- 3.12 Maximum System Voltage: The highest voltage at which a system is designed to operate.
- 3.13 Minimum clearances: The shortest distance measured between any energized parts.
- 3.14 Nominal System Voltage: The nominal value assigned to a system for the purpose of conveniently designating its voltage class. The actual operating voltage of a system may vary above and below the nominal value.
- 3.15 Phase to Grade: The shortest distance between any energized part and finished grade, that is the surface beneath a person’s feet or beneath a vehicle’s tires.
- 3.16 Phase to Ground: The shortest distance between any energized part(s) and the adjacent grounded part(s).
- 3.17 Phase to Phase: The shortest distance between any energized parts where the parts are different phases, including phases of different voltages.
- 3.18 Recommended Clearance: The clearance value in accordance with all applicable codes that have been obtained through years of successful experience.
- 3.19 Safe Working Clearances: Clearance values designed to ensure the safety of personnel working about electrical equipment.
- 3.20 Side Break Switch: A switch in which the travel of the blade is in a plane parallel to the base of the switch.
- 3.21 Spacing: The clear distance measured between two objects measured center to center.
- 3.22 Surge Arrester: Electrical device designed to protect electrical systems and equipment from overvoltages and from transient overvoltages that appear on the system.
- 3.23 Vertical Break Switch: A switch in which the travel of the blade is in a plane perpendicular to the plane of the mounting base. The blade in the closed position is parallel to the mounting base.

**4.0 ELECTRICAL CLEARANCES AND SPACING FOR OUTDOOR STATIONS**

- 4.1 Table 8.1 provides Liberty’s design requirements for electrical clearances and spacing for outdoor substations. These values are based on a combination of code requirements and Liberty’s operating experience and preferred practices. It lists the phase-to-ground and phase-to-phase clearance values as well as phase-to-phase spacing. Figure 8.1 provides a visual aid of various electrical clearance values that may be used in a substation. Liberty Preferred Clearances and Spacing are presented in Section 7.0.
- 4.2 When Preferred and Minimum values are listed for the same attribute in Table 8.1, the preferred value should be used for design. The Minimum values listed are based on the minimum requirements of ANSI C37.32. The minimum values are to be used only in evaluating existing stations, or in the design of new stations where space is very limited and the more generous preferred value cannot be accommodated.
- 4.3 The phase-to-ground and phase-to-phase clearances listed in ANSI C37.32 are generally more conservative than those of IEEE 1427. Historically ANSI C37.32 has been used as the governing code for electrical clearances and is reflected in Liberty current

<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Author: 231 Robert J Johnson

	<b>ENGINEERING DOCUMENT</b>	Doc. # <b>ENG-SUB006</b>
	<b>General Standard</b>	Page 6 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

practices. For that reason the more conservative values of Liberty Preferred Practices, ANSI C37.32 and IEEE 1427 are used in Table 8.1 except as noted.

- 4.4** Liberty tries to design the appearance of its substations to be pleasing to the eye. As such one goal is to keep the station bus spacing as uniform as possible. The phase spacing for a voltage level should be as uniform as possible. The phase spacing for a voltage level should be used through-out the entire station. Based solely on the phase spacing tables in this document you could have three different phase spacings for one voltage level given by dimensions A, B and F in Clearance Figure 8.1. When determining the phase spacing pick the largest dimension necessary for the type of switches to be used and use that dimension for all of the bus spacing at that voltage level.

## **5.0 SAFETY CLEARANCES**

### **5.1** NESC Rules

5.1.1 These clearances are for personnel safety and are based on NESC requirements and Liberty’s preferred practices. The following NESC rules are used for the basis of this Section:

- a. Rule 110 “General Requirements”
- b. Rule 124 “Guarding Live Parts”
- c. Rule 232 “Vertical Clearances of Wires, Conductors, Cables, and Equipment Above Ground, Roadway, Rail or Water Surfaces”
- d. Rule 234 “Clearances of Wires, Conductors, Cables and Equipment from Buildings, Bridges, Rail Cars, Swimming Pools and other Installations”
- e. Rule 441 “Energized Conductors or Parts”

### **5.2** Design Factors


5.2.1 Factors that are considered in establishing substation safety clearance requirements include the following:

- a. Clearances from earth, taking into account a number of factors such as voltage class, height of a person, depth of snow where applicable, height of footings, etc.
- b. Clearances to vehicles, taking into account the height of typical maintenance vehicles, and the height of floats and trucks that are used for the transportation of major equipment.
- c. Clearances to fences.

### **5.3** Design Safety Clearances

5.3.1 Table 8.1 also provides Liberty design “Safety Clearances” from energized parts to personnel, roadways, control house roofs, railroads, vehicles, and fences within the substation and to buildings on the property line. Figures 8.1, 8.2, 8.3, 8.4 and 8.5 assist in interpreting the values presented in Table 8.1. Personnel clearance values presented in Table 8.1 are also applicable to personnel working

<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Author: 232 Robert J Johnson

	<b>ENGINEERING DOCUMENT</b>	Doc. # <b>ENG-SUB006</b>
	<b>General Standard</b>	Page 7 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

in indoor areas of the substation. Liberty Preferred Clearances and Spacing are presented in Section 7.0.

5.3.2 The derivation/source of these clearances is as follows:

- a. NESC Part 2, Rule 232C1a - For the minimum clearance from energized conductor to roadways/other land traverse by vehicles. Clearance values for cables (lines/strain bus) are derived from Rule 232B1 (H) and for Rigid Bus from Rule 232B2 (J).
- b. NESC Part 1, Rule 110A2 - For the minimum safety clearance to station fence (S). This table presents the minimum values required by code.
- c. NESC Part 1, Rule 124A1 - For the minimum horizontal clearance from unguarded live parts (E) and minimum vertical clearance from unguarded live parts to grade (D).
- d. NESC Part 1 Rule 124C3 - For the minimum horizontal clearance from guard to live parts.
- e. NESC Part 2, Rule 234C1 - For the minimum clearance from conductors to the roof of the substation control house (K) or the side wall of buildings(M).
- f. NESC Part 4, Rule 441A1 - For the minimum approach distance to energized conductors. These distances are more conservative than those shown in Table R-6 of OSHA 29CFR1910.269, "Working on Exposed Energized Parts".
- g. NESC Part 2, Rules 232B1 and 232C1a - For the minimum clearance from overhead conductors to railroad tracks within the substation site (L).

**5.4** Working Clearances Around Equipment

5.4.1 Working clearances around electrical equipment are designed to provide safe access to personnel working in the substation. The safe distances required for normal operation and maintenance work are specified in:

- a. Table 2A - D Minimum Approach Distances of this standard
- b. Section 5 Substations of Liberty's Employee Health & Safety Handbook.


**6.0** **ELECTRICAL CLEARANCES AND SPACING FOR INDOOR FACILITIES**

**6.1** Table 8.2 provides electrical clearance for bare conductors for indoor substation facilities. It lists the phase-to-ground and phase-to-phase minimum and recommended clearance values. When both values are shown, the clearance used should be as near the recommended as practical. Figure 8.1 provides a visual aid of various electrical clearance values that may be used in a substation.

**6.2** This section present the values based on the codes cited in Table 8.2. Liberty Preferred Clearances and Spacing are presented in Section 7.0.

<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Author: 233 Robert J Johnson



	<b>ENGINEERING DOCUMENT</b> <b>General Standard</b>	Doc. # <b>ENG-SUB006</b> Page 8 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

## **7.0 LIBERTY PREFERRED CLEARANCE AND SPACING**

**7.1** Sections 4.0, 5.0 and 6.0 present spacing and clearances based primarily on code minimum requirements. Liberty, through years of design and operational experience has established preferred values of design clearances and spacing. These preferred values are discussed below.

### **7.1.1 Clearances to Fences**

- a. Figure 8.3 provides the Liberty preferred clearances to substation fences and should be used for new designs for conductors leaving the station.
- b. Figure 8.4 provide the Liberty preferred clearance to substation fences and should be used for new designs for conductors not leaving the station.

### **7.1.2 Preferred Spacing, Bus Heights and Clearances**


- a. Table 8.1 provides the Liberty preferred spacing, bus height and clearances and should be used for new designs.

## **8.0 TABLES AND FIGURES**

### **8.1** Safety Clearances to Fences, Property Lines and Buildings

- 8.1.1 The permitted or intended use of the property immediately outside the fence or property line may not be known at the time of original design. Therefore proper safety clearances should be incorporated in the design to allow for the most liberal potential use of adjacent area.
- 8.1.2 Figure 8.3 illustrates the safety clearance to substation fences for conductors leaving the station.
  - a. Dimension H is the Minimum Vertical Clearance to Unguarded Live Parts for Vehicular Traffic from Table 8.1.
  - b. Dimension D is the Minimum Vertical Clearance to Unguarded Live Parts for Personnel on Foot, from Table 8.1.
  - c. Dimension S is the Minimum Clearance of Live Parts to Substation Fences from Table 8.1
- 8.1.3 The Safety Clearance boundary is located by constructing an arc with Radius S from a point on the substation fence a height of H-S above grade, such that the arc is tangent to the horizontal line defined by Dimension H and intersects the horizontal line defined by Dimension D. All live parts are to be located beyond this Safety Clearance boundary as shown in Figure 8.3. If the center of the arc is above the horizontal line defined by D, (i.e.,  $H-S > D$ ), then after a 90 degree sweep of the arc a vertical line is drawn tangent to the arc and intersecting the horizontal line defined by D


<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.</b> <b>FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Author: 234 Robert J Johnson

	<b>ENGINEERING DOCUMENT</b>	Doc. # <b>ENG-SUB006</b>
	<b>General Standard</b>	Page 9 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

- 8.1.4 Figure 8.4 illustrates the safety clearance to substation fences for conductors not leaving the station. The minimum safety clearance zone for substation fences is located by constructing an arc with radius S from a point on the fence 5'-0" above grade, such that the arc intersects the horizontal line defined by Dimension D.
- 8.1.5 Fences or walls when installed as barriers for unauthorized personnel shall be located such that exposed live parts are outside the safety zone. However, when a fence, partition, or wall with no openings through which sticks or other objects can be inserted is utilized, live parts may be installed within the safety clearance zone, if they are below the horizontal line projected from the top of the fence or wall.
- 8.1.6 Figure 8.5 illustrates the minimum clearance per NESC 234c1 of conductor in a substation to a building on the property line or that may be built on the property line.

<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.                  FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Author: 235 Robert J Johnson

Figure 8.1 - Application Guideline



This Applications Diagram's Sole Purpose is to illustrate the Application of the Various Electrical Clearances for Outdoor Structures.

It Does Not Necessarily Represent Standard Structures or Electrical Arrangements

Whenever a Foundation is Large enough for a Workman to Stand on Without Conscious Effort, the Minimum and Recommended Clearances Shall Be from the Top of the Foundation and Not Finished Grade.

- A Recommended Centerline to Centerline Spacing of Bus
- B Clearance between Live Parts.
- C Clearance from Live Parts to Ground
- D Minimum Vertical Clearance to Unguarded Live Parts Accessible Only to Personnel on Foot
- E Minimum Horizontal Clearance to Unguarded Live Parts from Any Permanent Supporting Structure for Workmen
- F Phase-to-Phase Spacing for Switches-
- G Phase-to-Ground Spacing for Horn Gap Switches
- H Minimum Vertical Clearance to Unguarded Wire and Conductor Live Parts Accessible to Vehicular Traffic.
- J Minimum Vertical Clearance to Unguarded Rigid Bus Live Parts for Vehicular Traffic
- K Minimum Vertical Clearance of Overhead Conductors to Control Enclosure Roofs
- L Minimum Vertical Clearance of Overhead Conductors to Railroad Tracks

Docket No. DE 21-004  
Attachment DOE 10-1.e.2  
Page 236 of 245

**Table 8.1 - Outdoor Phase Spacing Bus Heights and Clearances**


Nominal System Voltage (kV)	2.4	12	23	34.5	46	69	115	138	230				
	4.26	13.2							750	900	1050		
	4.8	13.8											
	7.2												
95	110	150	200	250	350	550	650	750	900	1050	11'		
8.25	15.5	25.8	38.0	48.3	72.5	121	145	242					
Clearance	<b>Bus, Vertical Break Switches, Double Side Break Switches</b>	2' - 0"	3' - 0"		4' - 0"	5' - 0"	8' - 0"		9' - 0"	11' - 0"	13' - 4"		
	<b>Side Break Switches</b>	2' - 6"	2' - 6"	3' - 0"	4' - 0"	4' - 0"	6' - 0"	9' - 0"	11' - 0"	13' - 0"	16' - 0"	18' - 0"	
Minimum Clearance	<b>Minimum per ANSI C37.32</b>	0' - 7"	1' - 0"	1' - 3"	1' - 6"	1' - 9"	2' - 7"	4' - 5"	5' - 3"	6' - 0"	7' - 5"	8' - 9"	
	<b>Preferred</b>	1' - 0"	1' - 6"	2' - 0"	2' - 6"	3' - 0"	4' - 0"	6' - 0"	7' - 0"	8' - 0"	10' - 0"	11' - 0"	
	<b>Minimum for Animal Deterrent <sup>(4)</sup></b>	See LU-ENG-SUB005 Animal Deterrents in Electric Substations											
1 Live Part to Ground (C)	<b>Minimum per ANSI C37.32</b>	0' - 6"	0' - 8" <sup>(1)</sup>	0' - 11" <sup>(1)</sup>	1' - 3" <sup>(1)</sup>	1' - 7" <sup>(1)</sup>	2' - 1'	3' - 6"	4' - 2"	4' - 10"	5' - 11"	6' - 11"	7' - 0"
	<b>Preferred</b>	0' - 8"	0' - 10"	1' - 0"	1' - 3"	1' - 7"	2' - 5"	3' - 11"	4' - 5"	5' - 2"	6' - 4"	7' - 7"	8' - 0"
	<b>Minimum for Animal Deterrent <sup>(4)</sup></b>	See LU-ENG-SUB005 Animal Deterrents in Electric Substations											
Phase-to-Phase Parts	<b>(D) Vertical <sup>(3)</sup></b>	9' - 0"		10' - 0"			11' - 0"	12' - 0"	13' - 0"	14' - 0"	15' - 0"	16' - 0"	17' - 0"
	<b>(E) Horizontal</b>	3' - 4"	3' - 6"	3' - 9"	4' - 0"	4' - 4"	4' - 11"	6' - 1"	6' - 8"	7' - 4"	9' - 4"	10' - 4"	11' - 0"
Minimum Gap at Arc Devices <sup>(5)</sup>	<b>(F) Phase-to-Phase</b>	3' - 0"		4' - 0"	5' - 0"	6' - 0"	7' - 0"	10' - 0"	12' - 0"	14' - 0"	16' - 0"	18' - 0"	19' - 0"
	<b>(G) Phase-to-Ground</b>	2' - 0"		2' - 6"	3' - 0"	3' - 9"	4' - 3"	6' - 0"	7' - 6"	9' - 0"	10' - 0"	11' - 0"	

(Continued)

Nominal System Voltage (kV)		2.4 4.26 4.8 7.2	12 13.2 13.8	23	34.5	46	69	115	138	230	
Clearances from Roads/Land Vehicles	(H) Line/Strain Bus	22' - 0"		25' - 0"			30' - 0"			34' - 0"	
	(J) Rigid Bus	20' - 0"					20' - 6"	21' - 6"		23' - 6"	
Clearances Overhead Conductors to Control		12' - 6"			12' - 9"	13' - 2"	14' - 2"	14' - 7"		16' - 6"	
Clearances Overhead Conductors to Railroad		26' - 6"			26' - 9"	27' - 2"	28' - 1"	28' - 7"		30' - 6"	
Clearance of Conductor to Buildings (M)		7' - 6"			7' - 8"	8' - 2"	9' - 0"	9' - 6"		11' - 3"	
Clearance <sup>(6)</sup> (S)		11' - 0"			12' - 0"		14' - 0"		16' - 5"		
Clearance to Energized Conductors (and) - Qualified Employee		2' - 2"	3' - 0"	3' - 0"	4' - 0"		5' - 0"	6' - 0"		7' - 0"	
Clearance to Energized Conductors (and) - Non-Qualified Employee(OSHA)		10' - 0"				10' - 8"		12' - 4"	13' - 0"		16' - 0"


.1  
 is to attributes in Figures 8.1, 8.2, 8.3, 8.4 and 8.5  
 Clearances values based on ANSI C37.32 and IEEE 1427 and Liberty Preferred Practices  
 Clearances based on NESC 2017 and Liberty Preferred Practices  
 Clearances values not yet established in either C37.32 or IEEE 1427  
 Clearances based on IEEE 1427 that exceed the requirements of ANSI C37.32  
 based on IEEE 1427 for 2.5 per unit switching surge factor (BSL 760 kV) to qualify Liberty practices that are less than ANSI C37.32  
 of 8' - 6" shall be maintained to the bottom of porcelain or other parts of indeterminate potential  
 of 34.5 kV and less, if the phase to phase spacing and/or clearance to ground is less than that required for animal deterrents then animal guards should be installed on the  
 clearance may be reduced as long as the minimum clearance between live parts is maintained.  
 Clearances of S in the table meet or exceed the Minimum Clearances to Fences in accordance with NESC Table 110-1




	<b>ENGINEERING DOCUMENT</b>	Doc.# <b>ENG-SUB006</b>
	<b>General Standard</b>	Page 13 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

**Figure 8.2 - Clearance From Live Parts**


Figure 8.2 should be used in conjunction with Table 8.1 to obtain the indicated horizontal and vertical clearances.




PRINTED COPIES ARE NOT DOCUMENT CONTROLLED. FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Sponsor: Robert J Johnson <sup>239</sup>


	<b>ENGINEERING DOCUMENT</b>	Doc.# <b>ENG-SUB006</b>
	General Standard	Page 14 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

**Figure 8.3 - Safety Clearance to Substation Fences for Conductors Leaving the Station**




	<b>ENGINEERING DOCUMENT</b>	Doc.# <b>ENG-SUB006</b>
	<b>General Standard</b>	Page 15 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20


**Figure 8.4 - Safety Clearance to Substation Fences for Conductors Not Leaving the Station**




<b>PRINTED COPIES ARE NOT DOCUMENT CONTROLLED.          FOR THE LATEST AUTHORIZED VERSION PLEASE REFER TO THE APPROPRIATE DEPARTMENT WEBSITE.</b>		
ENG-SUB006 Electrical Substation Clearance	Originating Department: Substation Engineering and Design	Sponsor: 241 Robert J Johnson

	<b>ENGINEERING DOCUMENT</b> General Standard	Doc.# <b>ENG-SUB006</b> Page 16 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

**Figure 8.5 - Safety Clearance to Building on Property Line for Conductors Not Leaving Station**



	<b>ENGINEERING DOCUMENT</b>	Doc.# <b>ENG-SUB006</b>
	General Standard	Page 17 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20


**Table 8.2 - Indoor Phase Spacing and Clearances for Bare Conductors**

kV Class		7.5	15	23	34.5
BIL (kV Crest) <sup>1</sup>		60	110	125	150
Rated Maximum Voltage		2400 V 4160 V 4800 V	8320 V 12 kV 13.2 kV 13.8 kV	23 kV	34.5 kV 38 kV
Spacing of Buses	Rec. <sup>5</sup>	12"	18"	20"	24"
	Min. <sup>5</sup>	9"	12"	14"	18"
Clearance Between Live Parts	Rec. <sup>5</sup>	8"	14"	16"	20"
	Min. <sup>2</sup>	4 ½"	9"	13"	18"
Clearance From Live Parts to Ground	Rec. <sup>5</sup>	6"	10"	18"	24"
	Min. <sup>3</sup>	4 ½"	8"	11"	15"
Minimum Clearance to Unguarded Live Parts	Vert. <sup>4</sup>	8' - 10"	9' - 0"	9' - 1"	9' - 3"
	Horz. <sup>4</sup>	3' - 4"	3' - 6"	3' - 7"	3' - 9"

**Notes** for Table 8.1


1. Based on ANSI C37.32 Table 12
2. Based on ANSI C37.32 Table 14
3. Based on IEEE 1427 Table 3
4. Based on NESC Table 124-1
5. Based on Liberty Preferred Practices
6. Any reduction in clearances or spacing of conductors allowed by covering them is determined by a number of factors (material used, conductor shape, installation geometry, thickness of the covering, etc.) and can only be established by test for specific cases. Covered conductors shall be treated as bare conductors for clearance and spacing purposes unless otherwise established by vendor's guideline or testing specific to the covering used.



	<b>ENGINEERING DOCUMENT</b>	Doc.# <b>ENG-SUB006</b>
	<b>General Standard</b>	Page 18 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

**Table 8.3 - Electrical Power Equipment BIL Ratings (kV)**

Max. System Voltage (kV)	High Voltage Circuit Breakers (ANSI C37.06)			Air Switches (ANSI C37.32)		Transformers (IEEE C57.12.00)	
	Indoor Oil	Indoor Oil-less	Outdoor Table 4	Indoor Table 12	Outdoor Table 6	Power Table 3	Distribution Table 3
4.76	60	60		60		60/75	60
8.25	75	95		75	95	75/95	75
15	95	95	110	95/110	110	95/110	95
25.8	125		150	125	150	150	125
38	150	150	200	150	200	200	150
48.3			250		250	200/250	200/250
72.5			350		350	250/350	250/350
121			550		550	350/450/550	
145			650		650	450/550/650	
242			900		900/1050	650/750/825/900	
372			1300		1050/1300	900/1050/1175	

	<b>ENGINEERING DOCUMENT</b> <b>General Standard</b>	Doc.# <b>ENG-SUB006</b> Page 19 of 19
	<b>Electrical Substation Clearances</b>	Version 1.0 – 08/01/20

**9.0 REVISION HISTORY**

Date	Rev #	Description	Lead/Author
08/01/2020	1.0	Initial Version of Liberty Utilities document. Updated from National Grid document to be NH Specific.	Robert J Johnson

Attachment DOE 10-1.a

Substation	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 23</b>	115-23	11155	55.0	83.9	94.4	47.8
<b>Pulliam 14</b>	115-13.2	12140	80.0	100.6	112.0	56.0
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
Salem Depot 9	23-13.2	119.375	23.4	26.3	30.9	19.3
Olde Troley 18	23-13.2	449.375	37.5	49.8	51.8	38.8
Specker River 13	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Total</b>			<b>245.0</b>	<b>334.9</b>	<b>367.7</b>	<b>211.0</b>

Substation	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 23</b>	115-23	11155	55.0	83.9	94.4	47.8
<b>Golden Rock 19</b>	115-13.2	11155	55.0	83.9	94.4	0.0
<b>Pulliam 14</b>	115-13.2	12140	80.0	100.6	112.0	56.0
<b>Rockingham 21</b>	115-13.2	12155	110.0	157.8	188.8	94.4
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
<b>Baron Ave 10 + Gen</b>	23-13.2	1817	21.0	34.1	36.4	23.2
<b>Baron Ave 10 R</b>	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Baron Ave 10 +</b>	23-13.2	449.375	37.5	56.3	57.6	43.2
		1217				
<b>Salem Depot 9 + Gen</b>	23-13.2	119.375	23.4	26.3	30.9	19.3
		1217				
<b>Salem Depot 9 + Gen</b>	23-13.2	119.375	25.4	28.3	32.9	19.3
<b>Salem Depot 9 R</b>	23-13.2	119.375	28.5	42.2	43.2	28.8
<b>Salem Depot 9 +</b>	23-13.2	449.375	46.0	76.3	77.6	57.6
<b>Olde Troley 18</b>	23-13.2	449.375	37.5	49.8	51.8	38.8
<b>Specker River 13</b>	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Specker River 13 + Gen</b>	23-13.2	119.375	32.1	46.2	47.2	30.8
<b>Tuscan Village</b>	23-13.2	119.375	28.1	42.2	43.2	28.8

**ALTERNATE PLAN CAPACITY**

Alternate Plan 1	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 23</b>	115-23	11155	55.0	83.9	94.4	47.8
<b>Pulliam 14</b>	115-13.2	12140	80.0	100.6	112.0	56.0
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
Salem Depot 9	23-13.2	119.375	23.4	26.3	30.9	19.3
Olde Troley 18	23-13.2	449.375	37.5	49.8	51.8	38.8
Specker River 13	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Total</b>			<b>245.0</b>	<b>334.9</b>	<b>367.7</b>	<b>211.0</b>
Plan 1 Additions kVA			66.8	101.7	111.7	30.0
Plan 1 Additions \$/kVA			\$12,251	\$188,477	\$138,117	\$120,581
						\$1,225,100

Alternate Plan 2	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 23</b>	115-23	11155	55.0	83.9	94.4	47.8
<b>Pulliam 14</b>	115-13.2	12140	80.0	100.6	112.0	56.0
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
Salem Depot 9	23-13.2	119.375	23.4	26.3	30.9	19.3
Olde Troley 18	23-13.2	449.375	37.5	49.8	51.8	38.8
Specker River 13	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Total</b>			<b>245.0</b>	<b>334.9</b>	<b>367.7</b>	<b>211.0</b>
Plan 2 Additions kVA			66.8	101.7	111.7	30.0
Plan 2 Additions \$/kVA			\$12,263	\$183,193	\$117,033	\$109,678
						\$716,433

Alternate Plan 3	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 23</b>	115-23	11155	55.0	83.9	94.4	47.8
<b>Pulliam 14</b>	115-13.2	12140	80.0	100.6	112.0	56.0
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
Salem Depot 9	23-13.2	119.375	23.4	26.3	30.9	19.3
Olde Troley 18	23-13.2	449.375	37.5	49.8	51.8	38.8
Specker River 13	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Total</b>			<b>245.0</b>	<b>334.9</b>	<b>367.7</b>	<b>211.0</b>
Plan 3 Additions kVA			95.0	146.9	154.9	60.3
Plan 3 Additions \$/kVA			\$13,527	\$128,958	\$83,408	\$79,096
						\$203,167

Alternate Plan 4	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 23</b>	115-23	11155	55.0	83.9	94.4	47.8
<b>Pulliam 14</b>	115-13.2	12140	80.0	100.6	112.0	56.0
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
Salem Depot 9	23-13.2	119.375	23.4	26.3	30.9	19.3
Olde Troley 18	23-13.2	449.375	37.5	49.8	51.8	38.8
Specker River 13	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Total</b>			<b>245.0</b>	<b>334.9</b>	<b>367.7</b>	<b>211.0</b>
Plan 4 Additions kVA			95.0	152.1	157.7	108.1
Plan 4 Additions \$/kVA			\$13,485	\$128,958	\$80,456	\$77,689
						\$113,837

Alternate Plan 5	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 23</b>	115-23	11155	55.0	83.9	94.4	47.8
<b>Pulliam 14</b>	115-13.2	12140	80.0	100.6	112.0	56.0
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
Salem Depot 9	23-13.2	119.375	23.4	26.3	30.9	19.3
Olde Troley 18	23-13.2	449.375	37.5	49.8	51.8	38.8
Specker River 13	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Total</b>			<b>245.0</b>	<b>334.9</b>	<b>367.7</b>	<b>211.0</b>
Plan 5 Additions kVA			95.0	152.1	157.7	93.2
Plan 5 Additions \$/kVA			\$13,275	\$128,958	\$80,456	\$77,689
						\$126,747

Alternate Plan 6	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 23</b>	115-23	11155	55.0	83.9	94.4	47.8
<b>Pulliam 14</b>	115-13.2	12140	80.0	100.6	112.0	56.0
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
Salem Depot 9	23-13.2	119.375	23.4	26.3	30.9	19.3
Olde Troley 18	23-13.2	449.375	37.5	49.8	51.8	38.8
Specker River 13	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Total</b>			<b>245.0</b>	<b>334.9</b>	<b>367.7</b>	<b>211.0</b>
Plan 6 Additions kVA			105.0	173.1	172.4	132.9
Plan 6 Additions \$/kVA			\$11,689	\$104,563	\$68,950	\$48,871
						\$86,093

Alternate Plan 6	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 23</b>	115-23	11155	55.0	83.9	94.4	47.8
<b>Pulliam 14</b>	115-13.2	12140	80.0	100.6	112.0	56.0
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
Salem Depot 9	23-13.2	119.375	23.4	26.3	30.9	19.3
Olde Troley 18	23-13.2	449.375	37.5	49.8	51.8	38.8
Specker River 13	23-13.2	119.375	28.1	42.2	43.2	28.8
<b>Total</b>			<b>245.0</b>	<b>334.9</b>	<b>367.7</b>	<b>211.0</b>
Plan 7 Additions kVA			105.0	173.1	172.4	132.9
Plan 7 Additions \$/kVA			\$11,689	\$79,248	\$51,881	\$44,461
						\$67,859

Plan #1 Additions	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 19</b>	115-13.2	11155	55.0	78.7	91.4	0.0
<b>Baron Ave 10 + Gen</b>	23-13.2	1817	21.0	21.0	21.0	21.0
Salem Depot 9 R	23-13.2	119.375	23.4	23.4	23.4	19.3
<b>Specker River 13 + Gen</b>	23-13.2	119.375	28.1	28.1	28.1	0.0
<b>Total Added Capacity</b>			<b>65.0</b>	<b>86.7</b>	<b>108.4</b>	<b>100.0</b>

Plan #2 Additions	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 19</b>	115-13.2	11155	55.0	78.7	91.4	0.0
<b>Baron Ave 10 R</b>	23-13.2	119.375	28.1	28.1	28.1	23.2
<b>Salem Depot 9 +</b>	23-13.2	119.375	23.4	23.4	23.4	19.3
<b>Total Added Capacity</b>			<b>66.9</b>	<b>106.7</b>	<b>111.7</b>	<b>173.3</b>

Plan #3 Additions	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 19</b>	115-13.2	11155	55.0	78.7	91.4	0.0
<b>Baron Ave 10 +</b>	23-13.2	449.375	37.5	44.0	44.0	41.1
<b>Salem Depot 9 +</b>	23-13.2	119.375	23.4	23.4	23.4	19.3
<b>Total Added Capacity</b>			<b>95.0</b>	<b>146.0</b>	<b>154.8</b>	<b>60.3</b>

Plan #4 Additions	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 19</b>	115-13.2	11155	55.0	83.9	94.4	47.8
<b>Baron Ave 10 +</b>	23-13.2	449.375	37.5	44.0	44.0	41.1
<b>Salem Depot 9 +</b>	23-13.2	119.375	23.4	23.4	23.4	19.3
<b>Total Added Capacity</b>			<b>95.0</b>	<b>152.1</b>	<b>157.7</b>	<b>108.1</b>

Plan #5 Additions	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 19</b>	115-13.2	11155	55.0	83.9	94.4	47.8
<b>Baron Ave 10 R</b>	23-13.2	119.375	28.1	28.1	28.1	23.2
<b>Salem Depot 9 +</b>	23-13.2	119.375	23.4	23.4	23.4	19.3
<b>Total Added Capacity</b>			<b>95.0</b>	<b>152.1</b>	<b>157.7</b>	<b>93.7</b>

Original Calculations on page 40 of Attachment DOE 10-1.a						
Plan #6 Additions No relocations	Voltage (KV)	Qty/Rating (MVA)	Total Nameplate Capacity (MVA)	Total Summer Normal Capacity (MVA)	Total Summer Emergency Capacity (MVA)	Total Firm Capacity (MVA)
<b>Golden Rock 19</b>	115-13.2	11155	55.0	78.7	91.4	0.0
<b>Rockingham 21</b>	115-13.2	12155	110.0	157.8	188.8	94.4
<b>Baron Ave 10</b>	23-13.2	1817	21.0	32.1	35.4	21.2
Salem Depot 9	23-13.2	119.375	23.4	26.3	30.9	19.3
<b>Total Added Capacity</b>			<b>120.4</b>	<b>177.7</b>	<b>208.1</b>	<b>142.3</b>
Revised Calculations						

Attachment DOE 10-1.b

Phase	Anticipated kW Demand	Year Complete	Tuscan	Current Status
1	96	2020	North	Complete
1	667	2020	North	Complete
1	87	2020	North	Complete
1	80	2020	North	Complete
1	1216	2021	North	Complete
1	53	2021	North	Complete
1A	1661	2021	South	Complete
1A	315	2021	South	Complete
1A	10	2021	South	Complete
1A	16	2021	South	Complete
1A	74	2021	South	Complete
1B	1233	2021	South	Complete
1C	135	2021	South	Complete
1C	44	2021	South	Complete, plus level 2 EV charger
1C	386	2021	South	Complete
1C	80	2021	South	Complete
1C	73	2021	South	Complete
1C	28	2021	South	Complete
1C	107	2021	South	Complete
1	340	2022	North	Complete
1	30	2022	North	3 Tenants, 1 storefront left with no tenant
1C	245	2022	South	3 of 4 tenants moved in
1	71	2023	North	under construction now - retail store coming 2023
1	56	2023	North	Complete, no tenant due to COVID
1A	172	2023	South	In progress, 2023
1C	317	2023	South	3 of 4 tenants moved in - 4th retail store coming 2023
1C	109	2023	South	Retail store opening 1/23
1C	188	2023	South	6 of 7 tenants moved in- 7th signed eatery 2023
2 B	1800	2023	South	In progress, 2023 Customer waiting for arrival of internal switch gear
2 B	937	2023	South	In progress, 2023 waiting for transformers
1	87	2024	North	2023/2024 redevelopment ongoing
1	127	2024	North	2023/2024 redevelopment ongoing
2A	75	2024	South	Bldng 1400 will be restaurant in 2023/2024, temp service there now
2A	2008	2024	South	Retail, resi and Garage with 420 kW Solar In progress 2023/24
2B	2900	2024	South	Was part of "Central Village Blding 1000-1500 & 4000" in DOE 5-1, reduced by 181 kW
2B	1350	2024	South	Was part of "Central Village Blding 1000-1500 & 4000" in DOE 5-1
N/A	378	2025	North	redevelopment ongoing
N/A	1547	2025	North	redevelopment ongoing
2C	3500	2025	South	Redesign 1,187,140 sq feet mixed use - not drug manuf. 2024/2025, reduced by 500 kW

Total

<b>Total North</b>	<b>5,687</b>
<b>Total South</b>	<b>16,911</b>
<b>Total Tuscan Village</b>	<b>22,598</b>
	<b>7,271</b>
	<b>4,166</b>
	<b>11,161</b>
	<b>22,598</b>

a. Market Basket load as provided in Attachment Staff 1-3 did not include 5 kW of lighting that Liberty received CIAC for. The 5 kW is added here along with the CIAC.

Attachment DOE 10-1.b

Table 2 - Refer to Bates 128<sup>1</sup> Forecast Peaks Normal Weather

Year	Summer				Winter				PC & EV						
	Month	Peak (MW)	PV & EV Peak Adj	Peak MW	Growth	Month	Peak (MW)	Peak Adj	Peak (MW)	Growth	Month	Peak (MW)	Peak Adj	Peak (MW)	Growth
2021	7	192.548	-0.089	192.459	2.11%	1	148.685	0.385	149.070	6.25%					
2022	7	192.934	0.242	193.176	0.37%	1	148.738	0.692	149.430	0.24%					
2023	7	193.387	0.557	193.944	0.40%	1	148.894	0.923	149.817	0.26%					
2024	7	193.871	0.796	194.667	0.37%	1	149.087	1.154	150.241	0.28%					
2025	7	194.365	0.955	195.320	0.34%	1	149.302	1.461	150.763	0.35%					
2026	7	194.851	1.194	196.045	0.37%	1	149.517	1.769	151.286	0.35%					
2027	7	195.326	1.353	196.679	0.32%	1	149.718	1.999	151.717	0.28%					
2028	7	195.787	1.592	197.379	0.36%	1	149.908	2.23	152.138	0.28%					
2029	7	196.237	1.672	197.909	0.27%	1	150.084	2.384	152.468	0.22%					
2030	7	196.679	1.831	198.510	0.30%	1	150.252	2.615	152.867	0.26%					
2031	7	197.11	1.99	199.100	0.30%	1	150.41	2.922	153.332	0.30%					
2032	7	197.526	2.229	199.755	0.33%	1	150.556	3.153	153.709	0.25%					
2033	7	197.929	2.388	200.317	0.28%	1	150.685	3.384	154.069	0.23%					
2034	7	198.317	2.547	200.864	0.27%	1	150.805	3.614	154.419	0.23%					
2035	7	198.695	2.786	201.481	0.31%	1	150.906	3.922	154.828	0.26%					
2036	7	199.071	2.945	202.016	0.27%	1	151.004	4.153	155.157	0.21%					
2037	7	199.435	3.184	202.619	0.30%	1	151.099	4.383	155.482	0.21%					

<sup>1</sup>PV & EV adjustments are hidden to match Table 4  
<sup>2</sup>Spot loads include Tuscan Village and single manufacturer

Table 2 - Revised

Year	Summer				Winter				Total						
	Month	Peak MW	Spot Load Adj <sup>2</sup>	Adj Load	Growth	Month	Peak (MW)	Spot Load Adj <sup>2</sup>	Adj Load	Growth	Month	Peak (MW)	Spot Load Adj <sup>2</sup>	Adj Load	Growth
2021	7	192.459	6.361	198.820		1	149.07	6.361	155.431						
2022	7	193.176	0.615	200.152	0.67%	1	149.43	0.615	156.406	0.63%					
2023	7	193.944	3.650	204.570	2.21%	1	149.817	3.650	160.443	2.58%					
2024	7	194.667	26.547	231.840	13.33%	1	150.241	26.547	187.414	16.81%					
2025	7	195.320	5.425	237.918	2.62%	1	150.763	5.425	193.361	3.17%					
2026	7	196.045	0.000	238.643	0.30%	1	151.286	0.000	193.884	0.27%					
2027	7	196.679	0.000	239.277	0.27%	1	151.717	0.000	194.315	0.22%					
2028	7	197.379	0.000	239.977	0.29%	1	152.138	0.000	194.736	0.22%					
2029	7	197.909	0.000	240.507	0.22%	1	152.468	0.000	195.066	0.17%					
2030	7	198.510	0.000	241.108	0.25%	1	152.867	0.000	195.465	0.20%					
2031	7	199.100	0.000	241.698	0.24%	1	153.332	0.000	195.930	0.24%					
2032	7	199.755	0.000	242.353	0.27%	1	153.709	0.000	196.307	0.19%					
2033	7	200.317	0.000	242.915	0.23%	1	154.069	0.000	196.667	0.18%					
2034	7	200.864	0.000	243.462	0.23%	1	154.419	0.000	197.017	0.18%					
2035	7	201.481	0.000	244.079	0.25%	1	154.828	0.000	197.426	0.21%					
2036	7	202.016	0.000	244.614	0.22%	1	155.157	0.000	197.755	0.17%					
2037	7	202.619	0.000	245.217	0.25%	1	155.482	0.000	198.080	0.16%					
Total Spot Load Adjustments:				42.598		Total Spot Load Adjustments:				42.598					



Attachment DOE 10-1.b

Table 3 - Refer to Bates 129<sup>1</sup> Forecast Peaks Extreme Weather

Year	Summer Month	Model Peak (MW)	PV & EV			Winter Month	Model Peak (MW)	PC & EV		
			Peak Adj	Peak MW	Growth			Peak Adj	Peak (MW)	Growth
2021	7	207.083	-0.089	206.994	9.82%	1	151.821	0.385	152.206	6.25%
2022	7	207.481	0.242	207.723	0.35%	1	151.874	0.692	152.566	0.24%
2023	7	207.946	0.557	208.503	0.38%	1	152.029	0.923	152.952	0.25%
2024	7	208.441	0.796	209.237	0.35%	1	152.222	1.154	153.376	0.28%
2025	7	208.947	0.955	209.902	0.32%	1	152.437	1.461	153.898	0.34%
2026	7	209.445	1.194	210.639	0.35%	1	152.653	1.769	154.422	0.34%
2027	7	209.931	1.353	211.284	0.31%	1	152.853	1.999	154.852	0.28%
2028	7	210.404	1.592	211.996	0.34%	1	153.044	2.23	155.274	0.27%
2029	7	210.865	1.672	212.537	0.26%	1	153.22	2.384	155.604	0.21%
2030	7	211.318	1.831	213.149	0.29%	1	153.387	2.615	156.002	0.26%
2031	7	211.760	1.990	213.750	0.28%	1	153.545	2.922	156.467	0.30%
2032	7	212.188	2.229	214.417	0.31%	1	153.691	3.153	156.844	0.24%
2033	7	212.603	2.388	214.991	0.27%	1	153.821	3.384	157.205	0.23%
2034	7	213.003	2.547	215.550	0.26%	1	153.94	3.614	157.554	0.22%
2035	7	213.393	2.786	216.179	0.29%	1	154.041	3.922	157.963	0.26%
2036	7	213.780	2.945	216.725	0.25%	1	154.14	4.153	158.293	0.21%
2037	7	214.156	3.184	217.340	0.28%	1	154.234	4.383	158.617	0.20%

<sup>1</sup>PV & EV adjustments are hidden to match Table 4  
<sup>2</sup>Spot loads include Tuscan Village and single manufacturer

Table 3 - Revised

Year	Summer Month	Peak MW	Spot Load Adj <sup>2</sup>	Total Adj Load	Growth	Winter Month	Peak (MW)	Spot Load Adj <sup>2</sup>	Total Adj Load	Growth	
											2021
2022	7	207.723	0.615	214.699	0.63%	1	152.566	0.615	159.542	0.61%	
2023	7	208.503	3.650	219.129	2.06%	1	152.952	3.650	163.578	2.53%	
2024	7	209.237	26.547	246.410	12.45%	1	153.376	26.547	190.549	16.49%	
2025	7	209.902	5.425	252.500	2.47%	1	153.898	5.425	196.496	3.12%	
2026	7	210.639	0.000	253.237	0.29%	1	154.422	0.000	197.020	0.27%	
2027	7	211.284	0.000	253.882	0.25%	1	154.852	0.000	197.450	0.22%	
2028	7	211.996	0.000	254.594	0.28%	1	155.274	0.000	197.872	0.21%	
2029	7	212.537	0.000	255.135	0.21%	1	155.604	0.000	198.202	0.17%	
2030	7	213.149	0.000	255.747	0.24%	1	156.002	0.000	198.600	0.20%	
2031	7	213.750	0.000	256.348	0.23%	1	156.467	0.000	199.065	0.23%	
2032	7	214.417	0.000	257.015	0.26%	1	156.844	0.000	199.442	0.19%	
2033	7	214.991	0.000	257.589	0.22%	1	157.205	0.000	199.803	0.18%	
2034	7	215.550	0.000	258.148	0.22%	1	157.554	0.000	200.152	0.17%	
2035	7	216.179	0.000	258.777	0.24%	1	157.963	0.000	200.561	0.20%	
2036	7	216.725	0.000	259.323	0.21%	1	158.293	0.000	200.891	0.16%	
2037	7	217.340	0.000	259.938	0.24%	1	158.617	0.000	201.215	0.16%	
Total Spot Load Adjustments:			42.598	Total Spot Load Adjustments:			42.598				

Attachment DOE 10-1.b

Table 4 - Refer to Bates 131 Eastern PSA Normal Weather

Year	Summer			Winter		
	Month	Peak (MW)	Growth	Month	Peak (MW)	Growth
2021	7	97.962	0.00%	1	70.659	6.25%
2022	7	98.327	0.37%	1	70.830	0.24%
2023	7	98.718	0.40%	1	71.013	0.26%
2024	7	99.086	0.37%	1	71.214	0.28%
2025	7	99.418	0.34%	1	71.462	0.35%
2026	7	99.787	0.37%	1	71.709	0.35%
2027	7	100.110	0.32%	1	71.914	0.29%
2028	7	100.466	0.36%	1	72.114	0.28%
2029	7	100.735	0.27%	1	72.270	0.22%
2030	7	101.041	0.30%	1	72.459	0.26%
2031	7	101.342	0.30%	1	72.679	0.30%
2032	7	101.675	0.33%	1	72.859	0.25%
2033	7	101.961	0.28%	1	73.029	0.23%
2034	7	102.240	0.27%	1	73.195	0.23%
2035	7	102.554	0.31%	1	73.388	0.26%
2036	7	102.826	0.27%	1	73.544	0.21%
2037	7	103.133	0.30%	1	73.699	0.21%

Table 4 - Revised

Year	Summer			Spot	Total	Growth	Winter			Spot	Total	Growth
	Month	Peak MW	Load Adj <sup>2</sup>	Load Adj <sup>2</sup>	Adj Load		Month	Peak (MW)	Load Adj <sup>2</sup>	Adj Load		
2021	7	97.962	6.361	104.323			1	70.659	6.361	77.020		
2022	7	98.327	0.615	105.303	0.94%		1	70.830	0.615	77.806	1.02%	
2023	7	98.718	3.650	109.344	3.84%		1	71.013	3.650	81.639	4.93%	
2024	7	99.086	26.547	136.259	24.61%		1	71.214	26.547	108.387	32.76%	
2025	7	99.418	5.425	142.016	4.23%		1	71.462	5.425	114.060	5.23%	
2026	7	99.787	0.000	142.385	0.26%		1	71.709	0.000	114.307	0.22%	
2027	7	100.110	0.000	142.708	0.23%		1	71.914	0.000	114.512	0.18%	
2028	7	100.466	0.000	143.064	0.25%		1	72.114	0.000	114.712	0.17%	
2029	7	100.735	0.000	143.333	0.19%		1	72.270	0.000	114.868	0.14%	
2030	7	101.041	0.000	143.639	0.21%		1	72.459	0.000	115.057	0.16%	
2031	7	101.342	0.000	143.940	0.21%		1	72.679	0.000	115.277	0.19%	
2032	7	101.675	0.000	144.273	0.23%		1	72.859	0.000	115.457	0.16%	
2033	7	101.961	0.000	144.559	0.20%		1	73.029	0.000	115.627	0.15%	
2034	7	102.240	0.000	144.838	0.19%		1	73.195	0.000	115.793	0.14%	
2035	7	102.554	0.000	145.152	0.22%		1	73.388	0.000	115.986	0.17%	
2036	7	102.826	0.000	145.424	0.19%		1	73.544	0.000	116.142	0.13%	
2037	7	103.133	0.000	145.731	0.21%		1	73.699	0.000	116.297	0.13%	
Total Spot Load Adjustments:				42.598	Total Spot Load Adjustments:			42.598				

<sup>2</sup>Spot loads include Tuscan Village and single manufacturer

Attachment DOE 10-1.b

Table 6 - Refer to Bates 133 Eastern PSA Extreme Weather

Year	Summer			Winter		
	Month	Peak (MW)	Growth	Month	Peak (MW)	Growth
2021	7	105.3599	0.00%	1	72.1455	6.25%
2022	7	105.7312	0.35%	1	72.3163	0.24%
2023	7	106.1280	0.38%	1	72.4991	0.25%
2024	7	106.5017	0.35%	1	72.6999	0.28%
2025	7	106.8403	0.32%	1	72.9477	0.34%
2026	7	107.2153	0.35%	1	73.1958	0.34%
2027	7	107.5437	0.31%	1	73.4000	0.28%
2028	7	107.9060	0.34%	1	73.5998	0.27%
2029	7	108.1812	0.26%	1	73.7563	0.21%
2030	7	108.4927	0.29%	1	73.9448	0.26%
2031	7	108.7992	0.28%	1	74.1655	0.30%
2032	7	109.1382	0.31%	1	74.3440	0.24%
2033	7	109.4303	0.27%	1	74.5150	0.23%
2034	7	109.7151	0.26%	1	74.6807	0.22%
2035	7	110.0352	0.29%	1	74.8745	0.26%
2036	7	110.3130	0.25%	1	75.0307	0.21%
2037	7	110.6260	0.28%	1	75.1847	0.21%

Table 6 - Revised

Year	Summer			Spot	Total	Winter			Spot	Total	
	Month	Peak MW	Load Adj <sup>2</sup>	Load Adj <sup>2</sup>	Adj Load	Growth	Month	Peak (MW)	Load Adj <sup>2</sup>	Adj Load	Growth
2021	7	105.360	6.361	111.721			1	72.146	6.361	78.507	
2022	7	105.731	0.615	112.707	0.88%		1	72.316	0.615	79.292	1.00%
2023	7	106.128	3.650	116.754	3.59%		1	72.499	3.650	83.125	4.83%
2024	7	106.502	26.547	143.675	23.06%		1	72.700	26.547	109.873	32.18%
2025	7	106.840	5.425	149.438	4.01%		1	72.948	5.425	115.546	5.16%
2026	7	107.215	0.000	149.813	0.25%		1	73.196	0.000	115.794	0.21%
2027	7	107.544	0.000	150.142	0.22%		1	73.400	0.000	115.998	0.18%
2028	7	107.906	0.000	150.504	0.24%		1	73.600	0.000	116.198	0.17%
2029	7	108.181	0.000	150.779	0.18%		1	73.756	0.000	116.354	0.13%
2030	7	108.493	0.000	151.091	0.21%		1	73.945	0.000	116.543	0.16%
2031	7	108.799	0.000	151.397	0.20%		1	74.166	0.000	116.764	0.19%
2032	7	109.138	0.000	151.736	0.22%		1	74.344	0.000	116.942	0.15%
2033	7	109.430	0.000	152.028	0.19%		1	74.515	0.000	117.113	0.15%
2034	7	109.715	0.000	152.313	0.19%		1	74.681	0.000	117.279	0.14%
2035	7	110.035	0.000	152.633	0.21%		1	74.875	0.000	117.473	0.17%
2036	7	110.313	0.000	152.911	0.18%		1	75.031	0.000	117.629	0.13%
2037	7	110.626	0.000	153.224	0.20%		1	75.185	0.000	117.783	0.13%
Total Spot Load Adjustments:				42.598	Total Spot Load Adjustments:			42.598			

<sup>2</sup>Spot loads include Tuscan Village and single manufacturer

Project Description	Priority	FY2022	FY2023	FY2024	FY2025	FY2026	2022 - 2026 Filter
GSE-Dist-Water Heater Blanket	2. Mandated	\$ -	\$ 82,400	\$ 82,400	\$ 82,400	\$ 82,400	\$ 329,600
GSE-Dist-Land/Land Rights Blanket	2. Mandated	\$ 2,000	\$ 2,060	\$ 2,060	\$ 2,122	\$ 2,122	\$ 10,364
GSE-Dist-Telecomm Blanket	2. Mandated	\$ 2,500	\$ 2,575	\$ 2,575	\$ 2,652	\$ 2,652	\$ 12,955
Dist-Transf/Capac Install Blanket	2. Mandated	\$ 5,000	\$ 5,150	\$ 5,150	\$ 5,305	\$ 5,305	\$ 25,909
GSE-Dist-Meter Blanket	2. Mandated	\$ 5,000	\$ 5,150	\$ 5,150	\$ 5,305	\$ 5,305	\$ 25,909
Distribution Feeder Power Factor Correction	2. Mandated	\$ 25,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 225,000
Security Conversion GSE	2. Mandated	\$ 25,000	\$ 25,000		\$ 25,000	\$ 25,000	\$ 100,000
Dist-Damage&Failure Blanket	2. Mandated	\$ 1,000,000	\$ 1,000,000	\$ 1,000,000	\$ 1,125,509	\$ 1,159,274	\$ 5,284,783
01737 GSE-Dist-Subs Blanket	2. Mandated	\$ 25,750	\$ 26,523	\$ 26,523	\$ 27,318	\$ 27,318	\$ 133,431
Lebanon Area Low Voltage Mitigation	2. Mandated	\$ 175,000	\$ 100,000	\$ 150,000	\$ 100,000	\$ 100,000	\$ 625,000
NN D-Line Work Found by Insp.	2. Mandated	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 250,000
GSE Distributed Generation Blanket	2. Mandated	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 250,000
01659 Granite St Meter Purchases	2. Mandated	\$ 257,500	\$ 265,225	\$ 265,225	\$ 273,182	\$ 281,377	\$ 1,342,509
GSE-Dist-Load Relief Blanket	2. Mandated	\$ 100,000	\$ 103,000	\$ 103,000	\$ 106,090	\$ 109,273	\$ 521,363
LED Street Light Conversion	2. Mandated	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
GSE-Dist-3rd Party Attach Blanket	2. Mandated	\$ 128,750	\$ 132,613	\$ 132,613	\$ 136,591	\$ 140,689	\$ 671,254
GSE-Dist-St Light Blanket	2. Mandated	\$ 125,000	\$ 125,000	\$ 125,000	\$ 128,750	\$ 132,613	\$ 636,363
01663 GS Storm Program Proj	2. Mandated	\$ 300,000	\$ 300,000	\$ 300,000	\$ 309,000	\$ 318,270	\$ 1,527,270
GSE-Dist-Reliability Blanket	2. Mandated	\$ 655,636	\$ 675,305	\$ 675,305	\$ 695,564	\$ 716,431	\$ 3,418,243
Main St Salem - Overhead Line Relocation	2. Mandated						\$ -
01660 Granite St Transformer Purchases	2. Mandated	\$ 432,600	\$ 445,578	\$ 445,578	\$ 458,945	\$ 472,714	\$ 2,255,415
GSE-Dist-Asset Replace Blanket	2. Mandated	\$ 412,000	\$ 424,360	\$ 424,360	\$ 437,091	\$ 450,204	\$ 2,148,014
GSE-Dist-Public Require Blanket	2. Mandated	\$ 535,600	\$ 551,668	\$ 551,668	\$ 568,218	\$ 585,265	\$ 2,792,419
Londonderry Reconfiguration	5. Discretionary						\$ -
Animal Guarding	5. Discretionary		\$ 150,000	\$ 150,000	\$ 150,000	\$ 250,000	\$ 700,000
Substation Security	5. Discretionary		\$ 100,000	\$ 100,000	\$ 100,000	\$ 250,000	\$ 550,000
Aging Equipment	5. Discretionary		\$ 250,000	\$ 150,000	\$ 150,000	\$ 1,000,000	\$ 1,550,000
Bare Conductor Replacement Program	5. Discretionary	\$ 750,000	\$ 1,215,000	\$ 1,130,000	\$ 1,021,023	\$ 1,000,000	\$ 5,116,023
Grid Modernization Program	5. Discretionary	\$ 287,523	\$ 1,569,851	\$ 2,619,851	\$ 2,619,851	\$ 1,041,928	\$ 8,139,004
Transportation Fleet & Equip. Blanket	5. Discretionary	\$ 100,000	\$ 550,000		\$ -	\$ -	\$ 650,000
AMI Placeholder - GSE	5. Discretionary		\$ 3,175,286	\$ 3,167,603	\$ 3,167,603	\$ -	\$ 9,510,493
SCADA and Distribution Automation	5. Discretionary	\$ 360,000	\$ 320,000	\$ 220,000	\$ 200,000	\$ 200,000	\$ 1,300,000
IE-NN URD Cable Replacement	5. Discretionary	\$ 1,200,000	\$ 1,350,000	\$ 1,500,000	\$ 550,000	\$ 1,500,000	\$ 6,100,000
16L1 - 6L3 Goodfellow Rd	5. Discretionary		\$ 1,200,000				\$ 1,200,000
Enhanced Bare Conductor Replacement	5. Discretionary	\$ 750,000	\$ 590,000	\$ 790,000	\$ 375,000	\$ 375,000	\$ 2,880,000
Rockingham 21L4 Feeder	5. Discretionary				\$ 550,000	\$ -	\$ 550,000
Walk in Center Relocation Londonderry	5. Discretionary				\$ -	\$ -	\$ -
SAP-Ariba GSE Portion Procure to Pay Software	5. Discretionary				\$ -	\$ -	\$ -
Pelham-New 14L5 Fdr Breaker Position	5. Discretionary	\$ -	\$ -	\$ 75,000	\$ 700,000	\$ -	\$ 775,000
Pelham-New 14L5 Fdr Distribution Line	5. Discretionary	\$ -	\$ -	\$ 25,000	\$ 700,000	\$ -	\$ 725,000
Finance Unalloc Burden	5. Discretionary						\$ -
AFUDC	5. Discretionary						\$ -
Lebanon Pole Pile	5. Discretionary						\$ -
EV Charging Business Case for Tuscan	5. Discretionary						\$ -
GSE Facilities Capital Improvements	5. Discretionary	\$ 130,000	\$ 178,714			\$ 130,000	\$ 438,714
RIVER Park UCD	5. Discretionary						\$ -
Material Bar Coding	5. Discretionary						\$ -
Quadra Upgrades	5. Discretionary						\$ -
SAP Placeholder - GSE	5. Discretionary	\$ 15,476,633					\$ 15,476,633
Reserve for Reliability Unidentified Specifics	5. Discretionary	\$ -	\$ 103,000	\$ 103,000	\$ 103,000	\$ 103,000	\$ 412,000
Reserve for Public Requirements Unidentified Specifics	5. Discretionary	\$ -	\$ 106,090	\$ 106,090	\$ 106,090	\$ 106,090	\$ 424,360
Reserve for Substation Load Relief Specifics	5. Discretionary	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
Reserve for Load Relief Unidentified Specifics	5. Discretionary	\$ -	\$ 106,090	\$ 106,090	\$ 106,090	\$ 106,090	\$ 424,360
Reserve for Damage/Failure Unidentified Specifics &	5. Discretionary	\$ 103,000	\$ 106,090	\$ 106,090	\$ 106,090	\$ 106,090	\$ 527,360
Install Lebanon 1L2-1L3 Feeder Tie	5. Discretionary	\$ -	\$ 200,000	\$ -	\$ -	\$ -	\$ 200,000
Reserve for Sub Asset Repl Specifics	5. Discretionary	\$ -	\$ 51,500	\$ 51,500	\$ 51,500	\$ 51,500	\$ 206,000
Underperforming Feeder Program	5. Discretionary	\$ 103,000	\$ 225,000	\$ 250,000	\$ 195,000	\$ 195,000	\$ 968,000
Londonderry Snow Canopy	5. Discretionary	\$ -	\$ -				\$ -
Supplemental AC for Londonderry (Dispatch/Training Rms)	5. Discretionary	\$ -	\$ -				\$ -
Spaulding Hill Line Extension	5. Discretionary				\$ -	\$ -	\$ -
Install 9L2/9L3 Tie Canobie Lake	5. Discretionary				\$ -	\$ -	\$ -
Feeder Getaway Cable Replacement	5. Discretionary		\$ 250,000	\$ 375,000	\$ 250,000	\$ 250,000	\$ 1,125,000
Air Break Switch Upgrade Program	5. Discretionary	\$ 150,000	\$ 150,000	\$ 150,000	\$ 150,000	\$ 150,000	\$ 750,000
NHE Mobiletech Roll Out (Lineworks)	5. Discretionary	\$ -	\$ -				\$ -
IT Systems & Equipment Blanket	5. Discretionary	\$ 125,000	\$ 125,000	\$ 125,000	\$ 128,750	\$ 132,613	\$ 636,363
GIS - One Graphic Card	5. Discretionary	\$ -	\$ -				\$ -
01757 NN ARP Breakers & Reclosers	5. Discretionary	\$ 100,000	\$ 375,000	\$ 375,000	\$ 375,000	\$ 375,000	\$ 1,600,000
SCADA Data center upgrades	5. Discretionary	\$ 100,000	\$ 100,000	\$ 100,000	\$ -	\$ -	\$ 300,000
GIS & OMS Electric Upgrade	5. Discretionary	\$ 1,278,804	\$ -				\$ 1,278,804
Amerductor replacement program	5. Discretionary	\$ 100,000	\$ 100,000	\$ 100,000	\$ 100,000	\$ 100,000	\$ 500,000
EAM Foundation Year	5. Discretionary	\$ -	\$ -				\$ -
Remove 1303 Line - Wilder Junction to Sachem Jct.	5. Discretionary	\$ -	\$ -	\$ 100,000	\$ -	\$ -	\$ 100,000
ERP Foundation Year	5. Discretionary	\$ -	\$ -				\$ -
Rebuild Lockhaven Rd Enfield	5. Discretionary	\$ -	\$ -	\$ 1,400,000			\$ 1,400,000
GSE-Dist-Genl Equip Blanket	5. Discretionary	\$ 50,000	\$ 51,500	\$ 51,500	\$ 53,045	\$ 54,636	\$ 260,681
Reserve for Unidentified Discretionary Projects	5. Discretionary	\$ 50,000	\$ 100,000	\$ 100,000	\$ 100,000	\$ 100,000	\$ 450,000
NN ERR/Pockets of Poor Perf	5. Discretionary	\$ 225,000	\$ 550,000	\$ -	\$ -	\$ -	\$ 775,000
Rebuild Lockhaven Rd Enfield Phase 1	5. Discretionary	\$ -	\$ -				\$ -
NH ARP Relay & related	5. Discretionary	\$ 20,000	\$ 20,000	\$ 20,000	\$ 20,000	\$ 20,000	\$ 100,000
IT Systems Allocations - Corporate	5. Discretionary	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 250,000
IE-NN UG Structures and Equipment	5. Discretionary	\$ 50,000	\$ 50,000	\$ 150,000	\$ 150,000	\$ 150,000	\$ 550,000
Install Vilas Bridge 12L1-12L2 Feeder Tie	5. Discretionary	\$ -	\$ -	\$ -			\$ -

Technical Statement of Jay E. Dudley,  
 Ronald D. Willoughby & Joseph J. DeVirgilio  
 Attachment TS-JED/RDW/JJD-2 5-Year Capital Investments  
 Page 2 of 2

Install Lebanon 1L2 Feeder Tie - Plainfield	5. Discretionary	\$ -	\$ -	\$ 10,000	\$ 1,400,000	\$ -	\$ 1,410,000
Regulator Repl- NE North NH	5. Discretionary			\$ 150,000	\$ 150,000	\$ 150,000	\$ 450,000
23kV Cable Inspection and Replacement Program	5. Discretionary	\$ -	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 200,000
Add on to Garage in Salem	5. Discretionary	\$ -	\$ -				\$ -
IE-NN Dist Transformer upgrades	5. Discretionary	\$ 76,500	\$ 76,500	\$ 76,500	\$ 76,500	\$ 76,500	\$ 382,500
Install Solar Panels - GSE Buildings	5. Discretionary	\$ -	\$ -				\$ -
Repave Parking Lot - 9 Lowell Rd Salem	5. Discretionary	\$ -	\$ -				\$ -
Purchase and Renovate New Building - Walpole	5. Discretionary	\$ 500,000	\$ 515,000				\$ 1,015,000
Barron Ave#10 Retirement	5. Discretionary	\$ 50,000	\$ 50,000				\$ 100,000
Salem Depot#9 Retirement	5. Discretionary	\$ -	\$ 100,000				\$ 100,000
NEN-NH Electric Fence FY10	5. Discretionary		\$ 50,000				\$ 50,000
PS&I Activity - New Hampshire	5. Discretionary	\$ 100,000	\$ 100,000	\$ 100,000	\$ 100,000	\$ 100,000	\$ 500,000
NH ARP Batts/Chargers Repl Prog	5. Discretionary	\$ 25,750	\$ 26,523	\$ 50,000	\$ 50,000	\$ 50,000	\$ 202,273
Placeholder for Electric Training & Development	5. Discretionary						\$ -
Walk in Center Relocation Lebanon	5. Discretionary						\$ -
Walk in Center Relocation Salem	5. Discretionary						\$ -
Balancing Placeholder	5. Discretionary	\$ -	\$ -				\$ -
Install Mt. Support 16L2-16L5 Feeder Tie	5. Discretionary						\$ -
23kV 2393 and 2352 PTR Upgrade Olde Trolley Supply	5. Discretionary						\$ -
Electric SCADA - Pi	5. Discretionary						\$ -
Vegetation Management Equipment & Software Development Upgrade	5. Discretionary						\$ -
Reserve for New Business Commercial Unident specific & SC	3. Growth	\$ -	\$ 159,135	\$ 159,135	\$ 159,135	\$ 159,135	\$ 636,540
GSE-Dist-New Bus-Resid Blanket	3. Growth	\$ 1,969,640	\$ 2,028,730	\$ 2,028,730	\$ 2,089,592	\$ 2,152,279	\$ 10,268,970
Reserve for New Business Residential	3. Growth	\$ -	\$ 159,135	\$ 159,135	\$ 159,135	\$ 159,135	\$ 636,540
GSE-Dist-New Bus-Comm Blanket	3. Growth	\$ 1,575,712	\$ 1,622,984	\$ 1,622,984	\$ 1,671,673	\$ 1,721,823	\$ 8,215,176
Sky View URD - Salem, NH	3. Growth	\$ -	\$ -				\$ -
Golden Rock 23kV Relocation	3. Growth						\$ -
Golden Rock Distribution Feeder 19L2	3. Growth						\$ -
Install 13L2-9L3 Feeder Tie	3. Growth	\$ -	\$ -				\$ -
Golden Rock Distribution Feeder 19L6-Completed	3. Growth	\$ -					\$ -
IE - NN Recloser Installations	3. Growth	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 50,000	\$ 250,000
Install Service to Tuscan Village South Line	3. Growth	\$ -			\$ -	\$ -	\$ -
MT Support- 16L7 Distribution Feeder	3. Growth				\$ -	\$ -	\$ -
Install 39L4 Distribution Slayton Hill	3. Growth			\$ 25,000	\$ 290,000	\$ -	\$ 315,000
MT Support- 16L7 Distribution Feeder (Substation)	3. Growth				\$ -	\$ -	\$ -
Install 39L4 Feeder Position Slayton Hill	3. Growth			\$ 75,000	\$ 450,000	\$ -	\$ 525,000
Rockingham Distribution Feeders	3. Growth	\$ 800,000					\$ 800,000
Rockingham Substation Transmission Supply	3. Growth	\$ 6,000,000					\$ 6,000,000
Golden Rock Substation	3. Growth	\$ -	\$ -	\$ -	\$ 50,000	\$ -	\$ 50,000
Rockingham Substation	3. Growth	\$ 600,000	\$ -				\$ 600,000
		\$ 37,618,899	\$ 22,677,732	\$ 22,949,814	\$ 23,713,118	\$ 17,232,029	\$ 124,191,592



Liberty Utilities (Granite State Electric) Corp. d/b/a Liberty

DE 21-004

2021 Least Cost Integrated Resource Plan  
December 12, 2022, Supplemental LCIRP Report

Department of Energy Data Requests - Set 9

Date Request Received: 12/21/22  
Request No. DOE 9-13

Date of Response: 1/6/23  
Respondent: Michael Cooper  
Heather Green  
Heather Tebbetts

---

**REQUEST:**

**Tree Trimming Program and Schedule**

Please provide an example of the cost-benefit analysis used to determine that reconductoring with spacer cable vs enhanced tree trimming was the best solution for the tree-related interruptions on the two Bellows Falls circuits.

**RESPONSE:**

The Company did not conduct a cost-benefit analysis to compare a tree trimming solution to a reconductoring with spacer cable solution because the Company does not see these as competing solutions to be compared against each other. Replacement of bare wire with covered conductor and spacer cable protects against vegetation contact between trim cycles. Tree trimming is intended to reduce the number of trees that could potentially come in contact with the conductor but does not replace the need to replace the bare conductor with covered conductor. Liberty does not have an enhanced tree trimming program. The June 1, 2022, *Report on Wires and Non-Wire Solutions to Address Reliability in the Bellows Falls Area* describes that the contributing factors of the long duration outages in the Bellows Falls area are the radial nature of the circuits, the bare conductor design of the circuits, and the heavily treed surrounding area. The frequency of outages is impacted by trees contacting the bare wire, which leads to pockets of poor reliability performance. Without reconductoring, the frequency of outages will remain even with tree trimming. The long duration of outages will persist due to the radial circuit design and the inability to perform isolation and restoration switching. A new circuit tie would be needed to combat the duration issue. Tree trimming alone will not address the reliability issues in the Bellows Falls area. All reconductoring projects include tree trimming, tree removal, and expanding the corridor to meet Puc 307.10 guidelines.

Liberty has provided the total cost for reconductoring, but a full assessment of the 12L1 and 12L2 would need to be done to determine how many risk trees would need to be removed and the cost of those removals, plus the cost of widening the corridor from 6 feet to 8 feet if

Docket No. DE 21-004 Request No. DOE 9-13

reconductoring is not undertaken. The marking for the removal of trees on the 12L1 and 12L2 for the most recent trim cycle was minimal due to the limited funding of the vegetation management program.