

STATE OF NEW HAMPSHIRE

Inter-Department Communication

DATE: May 26, 2021

AT (OFFICE): NHPUC

FROM: Kenneth Walsh *KGW*
Utility Analyst IV – Safety Division

SUBJECT: Docket No. DE 21-081 Public Service New Hampshire d/b/a
Eversource Energy
Petition for Amended License to Construct and Maintain Electric Lines
Over and Across State Owned Land in Greenville, New Hampshire
Staff Recommendation Revision

TO: Debra Howland, Executive Director
Thomas Frantz, Director, Electric Division
Richard Chagnon, Assistant Director, Electric Division
Lynn Fabrizio, Staff Attorney
Randall Knepper, Director, Safety Division
Paul Kasper, Assistant Director, Safety Division

The Safety Division's review of the above Staff Recommendation dated May 20, 2021 identified the following revision requirement:

- 1) Reference in the first paragraph, page 2 of Section 1 Petition contents and history noting "This crossing was previously licensed in Docket DE 20-066 pursuant to PUC Order 26,417, which licensed the replacement of the additional structures within this petition". Please add after this sentence "Although Staff Recommendation on Page 6 in Docket DE 20-066 incorrectly noted Structure # 254 to be constructed with 2-85 ft. (OAL) Type A, Class H3 steel poles, Structure #254 was to remain as a 2-85 ft. (OAL) Type EA-2, Class 2 wood poles".

Executive.Director@puc.nh.gov

amanda.noonan@puc.nh.gov

Erik.newman@eversource.com

Kenneth.Walsh@puc.nh.gov

lynn.fabrizio@puc.nh.gov

ocalitigation@oca.nh.gov

Paul.Kasper@puc.nh.gov

randy.knepper@puc.nh.gov

richard.chagnon@puc.nh.gov

susan.gagne@puc.nh.gov

tom.frantz@puc.nh.gov